

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9906290229      DOC.DATE: 99/06/21      NOTARIZED: NO      DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287

*Revised 8/10/99  
 J.V. 2nd by  
 made*

AUTH.NAME      AUTHOR AFFILIATION  
 MCCOLLUM, W.R.      Duke Power Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                                  Records Management Branch (Document Control Desk)

SUBJECT: Forwards revised "Oconee Selected Licensee Commitments Manual (SLC)." SLC Manual is Chapter 16.0 of Oconee UFSAR.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1      ENCL 1      SIZE: 2 + 10  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	LPD2-1 LA		1	1	LPD2-1 PD		1	1
	LABARGE, D		1	1				
INTERNAL:	ACRS		1	1	<u>FILE CENTER 01</u>		1	1
	NRR/DE/EEIB		1	1	NRR/DE/EMCB		1	1
	NRR/DE/EMEB		1	1	NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1	NRR/SPSB JUNG, I		1	1
	NUDOCS-ABSTRACT		1	1	OGC/RP		1	0
EXTERNAL:	NOAC		1	1	NRC PDR		1	1

**MICROFILMED**

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 15      ENCL 14

C  
A  
T  
E  
G  
O  
R  
Y  
1  
D  
O  
C  
U  
M  
E  
N  
T



**Duke Power**

Oconee Nuclear Site  
7800 Rochester Highway  
Seneca, SC 29672

(864) 885-3107 OFFICE  
(864) 885-3564 FAX

W. R. McCollum, Jr.  
Vice President

June 21, 1999


U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Oconee Nuclear Station  
Docket 50-269, -270, -287  
Selected Licensee Commitments Manual (SLC)

Gentlemen:

Pursuant to 10CFR 50.4 and 50.71, please find attached 7 copies of the latest revisions to the Oconee Selected Licensee Commitments Manual (SLC). The SLC Manual is Chapter 16.0 of the Oconee Updated Final Safety Analysis Report (UFSAR). This manual is intended to contain commitments and other station issues that warrant higher control, but are not appropriate for inclusion into the Technical Specifications (TS). Instead of being updated with the annual UFSAR Update, the SLC Manual will be updated as necessary throughout the year.

Very truly yours,



W. R. McCollum, Jr.  
Vice President  
Oconee Nuclear Station

CMB/cmb  
Attachment

xc: Luis A. Reyes  
Regional Administrator, Region II

D. E. LaBarge, ONRR

Mike Scott, Oconee  
Senior Resident Inspector

ADD 1%

9906290229 990621  
PDR ADOCK 05000269  
P PDR

June 21, 1999

To: Manual Holders

Subject: Oconee Selected Licensee Commitments Manual (SLC) Revision

On June 16, Station Management approved revisions to SLC 16.9.11 to be implemented on June 16, 1999. This revision adds a Note to Required Action A.1 of SLC 16.9.11, Turbine Building Flood Protection Measures, indicating that it is permissible to enter Condition A when the TB Flood Protection Measures are inoperable due to planned activities, provided they are performed in a prompt manner without delay. The revision also provides an additional option for the CCW pump discharge valves. Specifically, it is acceptable to close a CCW pump discharge valve, lock its handwheel and open the associated breaker in lieu of having the capability to remotely close the CCW pumps discharge valve.

Please revise your SLC manual according to instructions below.

Remove these pages

LOEP 1 ✓  
LOEP 6 ✓  
LOEP 7 ✓  
SLC Page 16.9.11-1 ✓  
SLC Page 16.9.11-2 ✓  
SLC Page 16.9.11-3 ✓  
SLC Page 16.9.11-4 ✓  
SLC Page 16.9.11-5 ✓  
SLC Page 16.9.11-6 ✓  
-----

Insert these pages

LOEP 1 ✓  
LOEP 6 ✓  
LOEP 7 ✓  
SLC Page 16.9.11-1 ✓  
SLC Page 16.9.11-2 ✓  
SLC Page 16.9.11-3 ✓  
SLC Page 16.9.11-4 ✓  
SLC Page 16.9.11-5 ✓  
SLC Page 16.9.11-6 ✓  
SLC Page 16.9.11-7 ✓

Any questions concerning this revision may be directed to Boyd Shingleton at 864-885-3428.

Regulatory Compliance  
By: Conice Breazeale  
Regulatory Compliance