

Attachment # 1

Revised Technical Specification Bases

9801140078 980105
PDR ADDCK 05000269
P PDR

Bases

The Main Feedwater System and the Turbine Bypass System are normally used for decay heat removal and cooldown above 250°F. Feedwater makeup is supplied by operation of a hotwell pump, condensate booster pump, and a main feedwater pump.

Operability of the Emergency Feedwater System (EFW) assures the capability to remove decay heat and cool down the Reactor Coolant System to the operating conditions for switch over to decay heat removal by the Decay Heat Removal System, in the event that the Main Feedwater System is inoperable. The EFW system consists of a turbine driven pump (880 gpm), two motor driven pumps (450 gpm each), and associated flow paths to the steam generators.

The limiting transient requiring maximum EFW flow is the loss of main feedwater with offsite power available. For this transient, a minimum EFW flow rate equivalent to 400 gpm at 1050 psia and no more than 130°F is adequate. Each of the three EFW pumps is capable of delivering this flow.

A 100% flowpath is defined as: The flowpath to either steam generator including associated valves and piping capable of being supplied by either the turbine driven pump or the associated motor driven pump.

One flow indicator (total EFW header flow) and steam generator level indicator (extended startup) per steam generator is required to provide indication of emergency feedwater flow to the steam generators and to confirm emergency feedwater system operation. In the event that at least one flow and steam generator level indicator per steam generator is not available, then the flowpath to this steam generator is considered to be inoperable.

The EFW System is designed to start automatically in the event of loss of both main feedwater pumps as sensed by low hydraulic oil pressure. This specific automatic initiation logic is placed in service prior to criticality and may be bypassed when shutdown to prevent inadvertent actuation during startup and shutdown. All automatic initiation logic and control functions are independent from the Integrated Control System (ICS).

Normally, decay heat is removed by steam relief through the Turbine Bypass System to the condenser. Decay heat also can be removed from the steam generators by steam relief through the main steam safety relief valves. The total relief capacity of the 16 main steam safety relief valves is 13,105,000 lbs./hr. In this case the minimum amount of water in the upper surge tank, condensate storage tank, and hotwell is sufficient to remove decay heat for at least 4 hours at hot shutdown conditions. This provides adequate time to establish normal flow through the condenser by restarting a Condenser Cooling Water (CCW) pump in a loss of station power events. The turbine bypass valves can then be utilized to relieve steam to the condenser and commence a cooldown of the RCS.

A 6 foot level in the upper surge tank will ensure that 30,000 gallons of water are available to the EFW pumps from that source. The 6 foot level setpoint includes an allowance for instrument error and for the depletion of inventory while switching to an alternate suction source.

Attachment # 2

Markup of Existing Technical Specification Bases

Bases

The Main Feedwater System and the Turbine Bypass System are normally used for decay heat removal and cooldown above 250°F. Feedwater makeup is supplied by operation of a hotwell pump, condensate booster pump, and a main feedwater pump.

Operability of the Emergency Feedwater System (EFW) assures the capability to remove decay heat and cool down the Reactor Coolant System to the operating conditions for switch over to decay heat removal by the Decay Heat Removal System, in the event that the Main Feedwater System is inoperable. The EFW system consists of a turbine driven pump (880 gpm), two motor driven pumps (450 gpm each), and associated flow paths to the steam generators.

The limiting transient requiring maximum EFW flow is the loss of main feedwater with offsite power available. For this transient, a minimum EFW flow rate equivalent to 400 gpm at 1050 psia and no more than 130°F is adequate. Each of the three EFW pumps is capable of delivering this flow.

A 100% flowpath is defined as: The flowpath to either steam generator including associated valves and piping capable of being supplied by either the turbine driven pump or the associated motor driven pump.

One flow indicator ^(total EFW header flow) ~~of~~ ^(extended startup) steam generator level indicator ^{required} per steam generator is ~~sufficient~~ to provide indication of emergency feedwater flow to the steam generators and to confirm emergency feedwater system operation. In the event that at least one indicator per steam generator is not available, then the flowpath to this steam generator is considered to be inoperable.

The EFW System is designed to start automatically in the event of loss of both main feedwater pumps as sensed by low hydraulic oil pressure. This specific automatic initiation logic is placed in service prior to criticality and may be bypassed when shutdown to prevent inadvertent actuation during startup and shutdown. All automatic initiation logic and control functions are independent from the Integrated Control System (ICS).

Normally, decay heat is removed by steam relief through the Turbine Bypass System to the condenser. Decay heat also can be also removed from the steam generators by steam relief through the main steam safety relief valves. The total relief capacity of the 16 main steam safety relief valves is 13,105,000 lbs./hr. In this case the minimum amount of water in the upper surge tank, condensate storage tank, and hotwell is sufficient to remove decay heat for at least 4 hours at hot shutdown conditions. This provides adequate time to establish normal flow through the condenser by restarting a Condenser Cooling Water (CCW) pump in a loss of station power events. The turbine bypass valves can then be utilized to relieve steam to the condenser and commence a cooldown of the RCS.

A 6 foot level in the upper surge tank will ensure that 30,000 gallons of water are available to the EFW pumps from that source. The 6 foot level setpoint includes an allowance for instrument error and for the depletion of inventory while switching to an alternate suction source.