

IPRenewal NPEmails

From: Green, Kimberly
Sent: Thursday, April 23, 2015 6:46 AM
To: Walpole, Robert W
Cc: IPRenewal NPEmails
Subject: Additional Comments

Hi Bob,

Last evening, we received additional information to help us prepare for our presentation today. I'm passing along the following to you, as I believe you may be asked about these issues:

- What were the results for Commitment 33 (this was supposed to be completed)?
- What were the results for IP2 for Commitment 43?
- For small-bore piping (socket welds), how are the inspections/locations, which are focused on the most susceptible and risk significant, determined? With regard to this particular question on socket welds, mention is made that Commitment 46 addresses socket welds, and that IPEC will perform 25 volumetric weld inspections of socket welds during each 10-year ISI interval (in the PEO) as specified by IWB-2412.

Kim

Hearing Identifier: IndianPointUnits2and3NonPublic_EX
Email Number: 5098

Mail Envelope Properties (F5A4366DF596BF458646C9D433EA37D7022D8C960B7E)

Subject: Additional Comments
Sent Date: 4/23/2015 6:46:28 AM
Received Date: 4/23/2015 6:46:30 AM
From: Green, Kimberly

Created By: Kimberly.Green@nrc.gov

Recipients:
"IPRenewal NPEmails" <IPRenewal.NPEmails@nrc.gov>
Tracking Status: None
"Walpole, Robert W" <rwalpol@entergy.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 824 | 4/23/2015 6:46:30 AM |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: