

DUKE POWER COMPANY
NUCLEAR GENERATION DEPARTMENT

ISI PLAN
ADDENDUM SHEET

Serial No. ONS3-050 Sheet 1 of 1
Current Plan Revision 3
Station: Oconee Unit 3 Volume NA
Section: 1 Page: NA

Detailed Description of Proposed Change: Delete the following item numbers from outage 7 of the Unit 3 ISI Plan: G02.001.001, G02.001.001A, G02.001.002, G02.001.002A, G02.001.003 and G02.001.004. These items will be inspected with new item numbers.

Add the following item numbers to the Unit 3 ISI Plan:

G02.001.005A	G02.001.006A	G02.001.007A	G02.001.008A	G02.001.009B
G02.001.005B	G02.001.006B	G02.001.007B	G02.001.008B	G02.001.010A
G02.001.005C	G02.001.006C	G02.001.007C	G02.001.008C	G02.001.010B
G02.001.005D	G02.001.006D	G02.001.007D	G02.001.008D	G02.001.010C

G02.001.010D G02.001.011B G02.001.011D
G02.001.011A G02.001.011C

See Update Report dated 7-21-97 for details on all of the items that are being added to the Unit 3 ISI Plan.

These items are being added to the ISI Plan to meet the requirements of NRC Bulletin 85-20. See PIP 0-097-1507.

Originated By: Rarry C Keith Date: 7-21-97

Reviewed By: RC Rouse Date: 7/21/97

Data Updated By: Rarry C Keith Date: 7-21-97

Data Verified By: RC Rouse Date: 7/21/97

9708110281 970806
PDR ADDOCK 05000269
G PDR

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
UPDATE REPORT
Oconee 3 Inservice Inspection**

Addendum Serial Number ONS3-050

Update Report

Page 1

07/21/97

Changes from 07/21/97 to 07/21/97

Plant: Oconee 3

Report order: Isometric/ID Number

Interval 3

ITEM NUMBER	ID NUMBER	DRAWING NUMBERS	INSP REQ	PROCEDURES	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS	OUT SCH INT		
									2	3	4
G02.001.001	3PDA1-47	ISI-OCN3-011 OFD-100A-3.2	UT	NDE-600	SS	3.500 0.750		A1 Discharge Make Up Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1. Reference Request for Relief 95-GO-03 for calibration block.		2,	
Revised By: LCK8302 07/21/97											
G02.001.001A	3PDA1-47	ISI-OCN3-011 OFD-100A-3.2	RT	NDE-12	SS	3.500 0.750		A1 Discharge Make Up Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1.		2,	
Revised By: LCK8302 07/21/97											
G02.001.002	3PDA2-47	ISI-OCN3-012 OFD-100A-3.2	UT	NDE-600	SS	3.500 0.750		A2 Discharge Make Up Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1. Reference Request for Relief 95-GO-03 for calibration block.		2,	
Revised By: LCK8302 07/21/97											
G02.001.002A	3PDA2-47	ISI-OCN3-012 OFD-100A-3.2	RT	NDE-12	SS	3.500 0.750		A2 Discharge Make Up Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1.		2,	
Revised By: LCK8302 07/21/97											
G02.001.003	3PDB1-47	ISI-OCN3-013 OFD-100A-3.2	RT	NDE-12	SS	3.500 0.750		B1 Discharge HPI Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1.		2,	
Revised By: LCK8302 07/21/97											
G02.001.004	3PDB2-47	ISI-OCN3-014 OFD-100A-3.2	RT	NDE-12	SS	3.500 0.750		B2 Discharge HPI Nozzle Safe End PC.47. Reference Section 7 Paragraph 7.1.2 of the ISI Plan - Volume 1.		2,	
Revised By: LCK8302 07/21/97											
G02.001.005A	3-PDA1-46	ISI-OCN3-011 OFD-100A-3.1 OM-201-597	UT	NDE-690	CS	3.500 0.750	HPI Noz Cal. Block	Reference Section 7 of the ISI Plan, Volume 1. 3A1 Make-Up Nozzle PC 46. Perform UT on the nozzle inside radius (knuckle area). Perform UT examination during outages 17, 19 & 21 for the third interval. This schedule cannot be changed. Check with Engineering prior to scheduling the fourth		3,5,7	
Revised By: LCK8302 07/21/97											

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 UPDATE REPORT
 Oconee 3 Inservice Inspection

Addendum Serial Number ONS3-050

Update Report

Page 8

07/21/97

Changes from 07/21/97 to 07/21/97

Plant: Oconee 3

Report order: Isometric/ID Number

Interval 3

ITEM NUMBER	ID NUMBER	DRAWING NUMBERS	INSP REQ	PROCEDURES	MAT/SCH	DIATHK CAL BLOCKS	COMMENTS	OUT SCH INT		
								2	3	4
G02.001.011C	3B1-THERM SLEEVE ISI OCN3-013	OFD-100A-3.1	RT	NDE-105	SS	3.500 0.750	area as described in procedure NDE-105. Perform RT examination during outages 17, 19 & 21 for the third interval. This schedule cannot be changed. Check with Engineering prior to scheduling the fourth interval.		3,5,7	
Revised By: LCK8302	07/21/97	OM-201-597					Reference Section 7 of the ISI Plan, Volume 1. HPI Nozzle 3B1. Perform RT between the nozzle to safe end and safe end to pipe weld in the thermal sleeve expansion area as described in procedure NDE-105. Perform RT examination during outages 17, 19 & 21 for the third interval. This schedule cannot be changed. Check with Engineering prior to scheduling the fourth interval.			
G02.001.011D	3B2-THERM SLEEVE ISI OCN3-014	OFD-100A-3.1	RT	NDE-105	SS	3.500 0.750	Reference Section 7 of the ISI Plan, Volume 1. HPI Nozzle 3B2. Perform RT between the nozzle to safe end and safe end to pipe weld in the thermal sleeve expansion area as described in procedure NDE-105. Perform RT examination during outages 17, 19 & 21 for the third interval. This schedule cannot be changed. Check with Engineering prior to scheduling the fourth interval.		3,5,7	
Revised By: LCK8302	07/21/97	OM-201-597					Reference Section 7 of the ISI Plan, Volume 1. HPI Nozzle 3B2. Perform RT between the nozzle to safe end and safe end to pipe weld in the thermal sleeve expansion area as described in procedure NDE-105. Perform RT examination during outages 17, 19 & 21 for the third interval. This schedule cannot be changed. Check with Engineering prior to scheduling the fourth interval.			