

Severe Accident Analysis Report

Title : Precursor Evaluation for the Keowee Failures of
6/20/97 and 6/23/97

SAAG File No.: 472

Project : Oconee Plant Support

QA Condition: N/A

Prepared By : M J Barrett

Date : 6/28/97

Checked By : BL C...l

Date : 7/2/97

Approved By : P.m. Abraham

Date : 7/3/97

9802230247 980212
PDR ADOCK 05000269
P PDR

Table of Contents

1.0 Statement of the Problem.....	1
2.0 Objectives.....	1
3.0 QA Condition	1
4.0 Applicable Procedures, Codes and Standards.....	1
5.0 Other Design Criteria.....	1
6.0 FSAR Criteria.....	2
7.0 Methodology	2
8.0 Assumptions	3
9.0 Data	4
10.0 Analysis	4
10.1 Fault Tree	4
10.2 Cut Set Recovery.....	5
10.3 Data Changes in the Cut Sets	6
11.0 Results.....	6
11.1 Calculated CDF With Keowee Unit1 Inoperable.....	6
11.2 Change In CDF for Precursor Evaluation	6
12.0 Conclusions	10
13.0 LER Discussion	12
14.0 References	12

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

1.0 Statement of the Problem

Keowee Unit 1 experienced two different failures during the time period of 6/20/97 to 6/23/97. These failures could have been pre-existing and Keowee Unit 1 may have been inoperable for some time prior to 6/20/97.

The field flashing breaker has been cycling during emergency starts and this condition has apparently contributed to an age related failure of the fuse in the control circuit.

The y-timer relay on ACB-7 drifted from the calibrated setpoint. This caused the breaker to not fully close when demanded and ultimately generated a lock-out on switchgear 1X. This fails the auxiliary ac power system for the unit. The unit will run for some time however on the batteries and this failure can be recovered.

2.0 Objectives

This calculation is intended to address the importance of this condition from a core damage standpoint. The impact on CDF is assessed and a precursor evaluation is performed. This evaluation identifies the increase (delta) in the core damage frequency conditional on the existence of the Keowee failures.

3.0 QA Condition

N/A

4.0 Applicable Procedures, Codes and Standards

- XSAA-104, Work Place Procedure for the Evaluation of Operating Experience Events, Rev. 3, 3/21/96
- XSAA-109, Work Place Procedure for the Quality Assurance of PSAs, Rev. 1, 12/12/95

5.0 Other Design Criteria

None

6.0 FSAR Criteria

None

7.0 Methodology

The Oconee PRA model (revision 2) is used in this assessment. The Keowee failures represent a decrease in the redundancy of the emergency ac power system. Since Keowee is only required during LOOP events, only the T5 initiators need to be considered in the evaluation.

Keowee Unit 1 was aligned to both the underground path and the overhead path during various periods while it was inoperable. This situation is considered in the evaluation by doing two solves. In the first solve the unit is assumed to be aligned to the UG path and the event PK1UNITHYS is set to 1.0 for the solve. In the second case the unit is assumed aligned to the OH path and event PK2UNITHYS is set to 1.0 for the solve. This provides the appropriated CDF for each alignment on an annual basis.

In calculating the overall CDF, the fraction of the time spent in each alignment is applied to the appropriate annual CDF and the number of days in the inoperable condition is used to reduce the CDF from the annual number.

During the 39 day period from 5/11 to 6/20 there were two potential failure mechanisms for Keowee 1. The field flashing breaker failure is more severe in that it is not recoverable. Therefore the CDF contribution from the ACB-7 failure is not considered for that 39 day period in order to avoid double counting on those days.

From 6/9 to 6/11 both Keowee units were in maintenance simultaneously for 39.7 hours (1.6 days). This time is subtracted from the exposure to the field flashing breaker failure since a unit already in maintenance can not fail.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

For 39 hours (1.62 days) in March Keowee Unit 1 was in maintenance. This time is subtracted from the failure exposure time for the ACB-7 failure.

8.0 Assumptions

- The SSF D/G maintenance value is left at the Oconee PRA nominal values. It has been verified that the SSF monthly PM was performed during the period of Keowee inoperability. The unavailability was found to be generally consistent with the assumed value in the PRA.
- The SSF D/G support system maintenance event is set to 0.0 for the analysis as the SSF D/G unavailability would have been too high compared to the available information.
- The calibration drift in the ACB-7 timer begins following the calibration on 11/20/96 and is discovered on 6/23/97. The point of failure is assumed to be the midpoint of this period. Keowee Unit 1 was successfully tested while aligned to the underground path on 1/5/97. This indicates the timer setting was still adequate at this time.
- The ACB-7 problem is assumed to ultimately fail Keowee Unit 1 even when the unit is initially aligned to the overhead path. Since the LOOP CDF is dominated by the T5WEATH, the unit must be transferred to the underground alignment to provide power to Oconee. The unit is assumed to fail at this time.
- If Keowee Unit 1 is generating to the grid, the field flashing breaker problem would not represent a failure mode. Normally the fraction of the time spent generating to the grid is fairly small and has little influence on the results. This is assumed to be true here.
- The ACB-7 failure is a control problem with the breaker. The breaker is physically able to be closed if done correctly. This is similar to the situation from the Keowee PRA where credit was taken for recovering from control failures of the auxiliary power ACBs. A non-recovery probability of 0.5 is applied to the CDF results for the contribution from the ACB-7 problem.
- The Keowee Unit 1 failure as a result of the field flashing breaker failure is assumed to be non-recoverable.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

- Any critical hours on the units in the month of May are assumed to occur after 5/11, that is, the units were critical while the field flashing breaker was inoperable.

9.0 Data

The Keowee Unit 1 fails to start event (PK1UNITHYS) and the Keowee Unit 2 fails to start event (PK2UNITHYS) are set to 1.0 for the respective solves.

The critical hour data used in the analysis is given in the following table.

<u>Oconee Unit</u>	<u>March</u>	<u>April</u>	<u>May</u>	<u>June</u>
1	663.6	472.6	744	312
2	744	518	191	480
3	582.8	719	60.7	480

These values are converted to days for use in the calculation.

Keowee Unit 2 was in maintenance 1.48 hours during the 40 days that the field flashing breaker was inoperable. The unavailability for unit 2 was generally less than this value for the remainder of the time period of interest, but this period is used as a reasonable estimate for the calculation and, therefore, the KU2 maintenance event KK2UNITHYM is set to 1.54E-03.

The T5WEATH initiator frequency for this evaluation is taken from SAAG file #19 to be 5.3E-03/yr

10.0 Analysis

With these assumptions in mind, the precursor evaluation calculates the conditional core damage frequency for the LOOP initiators with Keowee Unit 1 assumed to be inoperable.

10.1 Fault Tree

The Oconee PRA fault tree model (or2plt24.caf) is modified for this analysis.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

First, all initiators except for the T5FEEDF, T5SUBF, and the T5WEATH are set to false in the tree. The tree is then compressed to eliminate all of the extra logic. The resulting tree is saved as keofuse.caf and a data base with the same name is created.

Second, a change is made to the logic for the swap of the overhead unit (Unit 2 in the model) to the underground path. The event PK2SWAPDHE is a recovery that includes the human action to swap as well as the hardware failures of the Keowee unit. The hardware failures will be explicitly included by modifying the logic under gate PKU2REC and the human error rate will be set to the value of 9E-03 (ABPOPRCDHE) from the KPRA. Gate PKU2REC of the tree contained only the human error event to swap unit 2 to the underground path and the unit 2 maintenance event. Gate PKEOWEE is modified by removing the main transformer failure event (PACKEOMTHF) and moving it to gate PKEOVHD. Gate PKEOWEE is then added to PKU2REC to capture the other failure modes of the overhead unit.

The solve with the KU1 start failure set to 1 is in cut set file keofuse1.cut. The solve with the KU2 start failure set to 1 is in cut set file keofuse2.cut.

10.2 *Cut Set Recovery*

The cut sets from the solve were processed in the following steps. First, the unit 1 start failure event is set to TRUE and the cut sets are subsumed. This eliminates any other failure modes in the cut sets for unit 1. Second, the cut sets are recovered using the or2all.rul file. Third, the cut set file is then DEL TERMED against or2rec24.cut in order to isolate the new cut sets.

Finally, additional recoveries were applied to the keofuse1.cut file cut sets manually until it appeared that adding further recoveries would only cause cut sets to be truncated. The top 40 cut sets were all recovered and most cut sets below this still needed recovery but would likely have been truncated following recovery. Therefore, the CDF from the top 40 cut sets is used as the basis for the annualized CDF for this case. The cut sets in the

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

keofuse2.cut file were smaller than those in the keofuse1.cut file and nearly all were unrecovered. Since most of the recoveries to be applied were 0.1 or less, the CDF contribution when Keowee Unit 1 is on the overhead is estimated as 10% of the keofuse2.cut file probability for this analysis.

The following cut sets were found to be inappropriately recovered and the recoveries seen below were applied.

FEFTDFPTPR	NSF0ASWDHE	PK1UNITHYS	PK2SWAPDHE	T5WEATH	TACWFFSRHE
FEFTDFPTPR	NSFPU02APS	PK1UNITHYS	PK2SWAPDHE	T5WEATH	TACWFFSRHE
FEFTDFPTPR	KK2UNITHYM	NSF0ASWDHE	PK1UNITHYS	T5WEATH	TACWFFSRHE
FEFTDFPTPR	KK2UNITHYM	NSFPU02APS	PK1UNITHYS	T5WEATH	TACWFFSRHE

10.3 Data Changes in the Cut Sets

Within the cut sets the following data changes are made.

NACSUPPTRM is set equal to 0.0.

11.0 Results

11.1 Calculated CDF With Keowee Unit1 Inoperable

The annualized CDF for the case when Keowee Unit 1 is on the UG is estimated to be 5.0E-06, from keofuse1.cut. For the case when it is on the OH the value of 1.3E-06 is assumed.

11.2 Change In CDF for Precursor Evaluation

The change in CDF is calculated by considering the time that Keowee 1 is on the underground and the time that the Oconee units are critical while the inoperable conditions existed. The following spreadsheets contain the calculations for all three Oconee units.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

Unit 1

Assessment of the impact of the Keowee Unit 1 inoperable condition on Oconee Units 1, 2 & 3 power operation

FF Breaker Contribution		ACB-7 Contribution	
Annualized increase in CDF as a result of the condition when KU1 is on the UG path	5.00E-06	Period of time from 11/20/96 to 6/23/97 in days	225
Annualized increase in CDF as a result of the condition when KU1 is on the OH path	1.30E-06	Failure exposure time	112.5
Fraction of time in 1997 that KU1 was aligned to the underground path	0.368	Time period for contribution from ACB-7 unavailability	70.88
# of days that Oconee Unit 1 is at power with the FF breaker inoperable	31.4	Number of days during period that Unit 1 was not operating	14
Increase in CDF as a result of the condition	2.29E-07	Increase in CDF as a result of the condition	4.15E-07
		Failure of the auxiliary power ACBs is a recoverable failure as assumed in the KPRA (failure to recover = 0.5)	2.07E-07
The total increase in the CDF for Oconee Unit 1 for the time period of Keowee Unit 1 inoperability	4.4E-07		

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

Unit 2

Assessment of the impact of the Keowee Unit 1 inoperable condition on Oconee Units 1, 2 & 3 power operation

FF Breaker Contribution		ACB-7 Contribution	
Annualized increase in CDF as a result of the condition when KU1 is on the UG path	5.00E-06	Period of time from 11/20/96 to 6/23/97 in days	225
Annualized increase in CDF as a result of the condition when KU1 is on the OH path	1.30E-06	Failure exposure time	112.5
Fraction of time in 1997 that KU1 was aligned to the underground path	0.368	Time period for contribution from ACB-7 unavailability	70.88
# of days that Oconee Unit 2 is at power with the FF breaker inoperable	26	Number of days during period that Unit 2 was not operating	19.5
Increase in CDF as a result of the condition	1.92E-07	Annualized increase in CDF as a result of the condition	3.75E-07
		Failure of the auxiliary power ACBs is a recoverable failure as assumed in the KPRA (failure to recover = 0.5)	1.87E-07
The total increase in the CDF for the time period of Keowee Unit 1 inoperability	3.8E-07		

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

Unit 3

**Assessment of the impact of the Keowee Unit 1 inoperable condition on
Oconee Units 1, 2 & 3 power operation**

FF Breaker Contribution		ACB-7 Contribution	
Annualized increase in CDF as a result of the condition when KU1 is on the UG path	5.00E-06	Period of time from 11/20/96 to 6/23/97 in days	225
Annualized increase in CDF as a result of the condition when KU1 is on the OH path	1.30E-06	Failure exposure time	112.5
Fraction of time in 1997 that KU1 was aligned to the underground path	0.368	Time period for contribution from ACB-7 unavailability	70.88
# of days that the FF breaker is assumed to be inoperable	21	Number of days during period that Unit 3 was not operating	17
Increase in CDF as a result of the condition	1.52E-07	Annualized increase in CDF as a result of the condition	3.93E-07
		Failure of the auxiliary power ACBs is a recoverable failure as assumed in the KPRA (failure to recover = 0.5)	1.96E-07
The total increase in the CDF for the time period of Keowee Unit 1 inoperability	3.5E-07		

12.0 Conclusions

The following information summarizes the results and conclusions of the analysis. This information was included in the AIT briefing paper.

Impact of the June 20 and 23, 1997 Events on Oconee Units 2 & 3

The impact of the loss of power on the standby bus on Oconee units 2 & 3 is minor. Both units were generating and supplying power to the unit related loads. Offsite power was available throughout the event. Keowee Unit 2 started and was running in standby and capable of supplying power if needed. The 100 kV grid could have been readily connected to CT5 by manipulating the breakers in the Central Switchyard. A Lee combustion turbine could have been reconnected to the dedicated line following the event at Lee.

The unavailability of Keowee Unit 1 would have impacted the design basis accidents in the following manner.

- The Keowee Unit 1 unavailability represents a loss of redundancy to deal with a loss of offsite power at the Oconee Station. This situation did represent a potential for an increase in the calculated risk from LOOP events for the time period of the unavailability. The risk calculation is summarized in the following pages.
- For a loss of coolant accident (and other accidents not involving a loss of offsite power) no impact on the accident mitigation capability existed. All ECCS equipment is functional.
- For the LOCA-LOOP scenario, the unavailability of Keowee unit 1 represented a loss of redundancy in the ability to provide emergency power. The low probability of these two accident occurring together is sufficiently low that the risk implications are insignificant. With a single Keowee unit in operation, all ECCS trains would still have been functional.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

Impact of Potential Past Inoperability of Keowee Unit 1 on Oconee Units 1, 2 & 3

The following information is pertinent to the assessment of the risk impact of the Keowee Unit 1 inoperable condition and has been used in the assessment.

- Keowee Unit 1 was successfully emergency start tested on 5/11/97. This represents the starting point for assuming that the field flashing breaker was in the failed condition.
- The y-timer in ACB-7 was calibrated on November 20, of 1996. Keowee Unit 1 was successfully emergency start tested, while connected to the underground, on 1/5/97. The timer is assumed to have become out of tolerance at the midpoint between the calibration and the failure on 6/23/97. The condition certainly existed no earlier than 1/5/97.
- Keowee Unit 2 unavailability was low during the period from March through June, <0.2%.
- The 1997 critical hours for each of the Oconee units has been used in this calculation.

The core damage risk increase is evaluated for LOOP events. Only these are impacted by the inoperable condition of Keowee Unit 1.

The core damage risk increase, for all Oconee units, associated with the inoperable condition is estimated to be less than 1E-06

The nominal CDF for LOOP events as reported in the Oconee PRA Revision 2 summary report is 6.2E-07/year.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

13.0 LER Discussion

The following is provided for input into the LER associated with these events.

The event caused a monetary interruption of AC power to Oconee Unit 1. At the time of the event, the unit was in cold shutdown. The RCS was at approximately 100 °F with approximately 39 psig (nitrogen bubble). The unit had been shutdown for 7 days prior to the event. The decay heat level was in the range of 7 to 8 MW. Offsite power was always available as was Keowee Unit 2 and sources to CT5. This along with the multiple sources of EFW and LPSW resulted in a minimal impact on plant risk. The estimated core damage probability for the event is in the range of 3E-07.

The issue of potential past inoperability has been addressed through a precursor evaluation. This evaluation considered the impact on the LOOP initiated CDF to estimate the increase that resulted from the Keowee inoperability. This includes the impacts of both the field flashing breaker failure as well as the failure experienced on ACB-7. The maximum change in CDF was calculated to occur on Oconee Unit 1. Oconee Unit 1 experienced a change in CDF estimated at less than 5E-07 during the period of interest.

14.0 References

1. Fault Tree or2plt24.caf and the or2 database
2. Phone conversations with Ed Burchfield and Reed Severance of Oconee on 6/28/97 and 6/29/97
3. SAAG file #406.

Precursor Evaluation for the Keowee Failures of 6/20/97 and 6/23/97
SAAG File # 472

ATTACHMENTS

Cutset Report

COREMELT = 4.63E-06 (Probability)

TOP 39

Probability	%	Class	Inputs
9.78E-07	21.1%		NSFORCMDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
4.76E-07	31.4%		NACSFDDGDR PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF3RHE
4.19E-07	40.4%		NACSFDDGDM PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.84E-07	46.5%		NSFCON2CMS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.46E-07	51.8%		NSFORCMDHE PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
1.67E-07	55.4%		KK2UNITHYM NSF0RCMDHE PK1UNITHYS T5WEATH TACWFF2RHE
1.60E-07	58.9%		NSF0RCMDHE PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
1.30E-07	61.7%		NACSFDDGDR PK1UNITHYS PK2UNITHYR T5WEATH TACWFF4RHE
1.30E-07	64.5%		NSF3F01FLF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
1.30E-07	67.3%		NSF3FL2FLF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
1.20E-07	69.9%		NACSFDDGDR PK1UNITHYS PK2UNITHYS T5WEATH TACWFF3RHE
1.05E-07	72.1%		NACSFDDGDM PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
8.14E-08	73.9%		KK2UNITHYM NACSFDDGDR PK1UNITHYS T5WEATH TACWFF3RHE
7.69E-08	75.5%		NSF3PU1DPS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
7.62E-08	77.2%		NSF3PU1DPM PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
7.39E-08	78.8%		FEFSWAPDHE NSF0ASWDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF1RHE
7.16E-08	80.3%		KK2UNITHYM NACSFDDGDM PK1UNITHYS T5WEATH TACWFF2RHE
7.12E-08	81.9%		NSFCON2CMS PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
6.93E-08	83.4%		FEFTDFPTPR NSF0ASWDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF5RHE
6.84E-08	84.8%		NACSFDDGDM PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
5.87E-08	86.1%		NSFTIMEDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
4.85E-08	87.2%		KK2UNITHYM NSFCON2CMS PK1UNITHYS T5WEATH TACWFF2RHE
4.77E-08	88.2%		FEFSWAPDHE PK1UNITHYS PK2SWAPDHE RRC0004DEX T5WEATH TRCSRVLDEX TACWFF1RHE
4.64E-08	89.2%		NSFCON2CMS PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
4.47E-08	90.1%		FEFTDFPTPR PK1UNITHYS PK2SWAPDHE RRC0004DEX T5WEATH TRCSRVLDEX TACWFF5RHE
4.29E-08	91.1%		FEFSWAPDHE PK1UNITHYS PK2SWAPDHE RRC0066PRC T5WEATH TACWFF1RHE
4.02E-08	91.9%		FEFTDFPTPR PK1UNITHYS PK2SWAPDHE RRC0066PRC T5WEATH TACWFF5RHE
3.70E-08	92.7%		NACSFDDGDS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	93.5%		NHP3398MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	94.2%		NSF3082MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	95.0%		NSF3097MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.25E-08	95.7%		NSF3F01FLF PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
3.25E-08	96.4%		NSF3FL2FLF PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
3.13E-08	97.0%		NDCDCSFBYF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.03E-08	97.7%		NACDJPUGPS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.93E-08	98.3%		NACSFDDLHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.93E-08	99.0%		NSFRMULHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.51E-08	99.5%		FEFSWAPDHE NCW0125VVT PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF1RHE
2.35E-08	100.0%		FEFTDFPTPR NCW0125VVT PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF5RHE
0.00E+00	100.0%		DDC1DCBBDM DDCUN31DIM NSF0RCMDHE T5SUBF TACSFF2RHE
0.00E+00	100.0%		DDC1DCBBDM DDCUN31DIM NSF0RCMDHE T5WEATH TACWFF2RHE
0.00E+00	100.0%		DDC1DCBBYF DDCUN31DIM NSF0RCMDHE PACLOOPDEX T5SUBF TACSFF2RHE

Probability	%	Class	Inputs						
0.00E+00	100.0%		DDC3DCABYF	DDCUN31DIM	NSF0RCMDHE	T5SUBF	TACSFF2RHE		
0.00E+00	100.0%		DDCBATADEX	DDCBATBDEX	FEFTDFPTPR	KK1BOTHHYM	T5WEATH	TRCSRVLDEX	TACWFF5RHE
			PAC0T5WDEX						
0.00E+00	100.0%		DDCBATADEX	DDCBATBDEX	FEFTDFPTPR	PACXCT4THF	T5WEATH	TRCSRVLDEX	TACWFF5RHE
0.00E+00	100.0%		DDCBATADEX	DDCBATBDEX	FEFTDFPTPR	PK0KEORCOM	T5WEATH	TRCSRVLDEX	TACWFF6RHE
0.00E+00	100.0%		FEFTDFPTPR	KK1BOTHHYM	NCW0125VVT	T5WEATH	TACWFF1RHE	PAC0T5WDEX	
0.00E+00	100.0%		FEFTDFPTPR	KK1BOTHHYM	NSF0ASWDHE	T5WEATH	TACWFF1RHE	PAC0T5WDEX	
0.00E+00	100.0%		FEFTDFPTPR	NCW0125VVT	PACXCT4THF	T5WEATH	TACWFF1RHE		
0.00E+00	100.0%		FEFTDFPTPR	NSF0ASWDHE	PACXCT4THF	T5WEATH	TACWFF1RHE		
0.00E+00	100.0%		KK1BOTHHYM	NACSFDDGDM	T5WEATH	TACWFF2RHE	PAC0T5WDEX		
0.00E+00	100.0%		KK1BOTHHYM	NACSFDDGDR	T5WEATH	TACWFF3RHE	PAC0T5WDEX		
0.00E+00	100.0%		KK1BOTHHYM	NSF0RCMDHE	PACLEESCTR	T5SUBF	TACSFF3RHE		
0.00E+00	100.0%		KK1BOTHHYM	NSF0RCMDHE	T5WEATH	TACWFF2RHE	PAC0T5WDEX		
0.00E+00	100.0%		KK1BOTHHYM	NSFCON2CMS	T5WEATH	TACWFF2RHE	PAC0T5WDEX		
0.00E+00	100.0%		NACSFDDGDM	PACXCT4THF	T5WEATH	TACWFF2RHE			
0.00E+00	100.0%		NACSFDDGDM	PK0KEORCOM	T5WEATH	TACWFF3RHE			
0.00E+00	100.0%		NACSFDDGDR	PACXCT4THF	T5WEATH	TACWFF3RHE			
0.00E+00	100.0%		NACSFDDGDR	PK0KEORCOM	T5WEATH	TACWFF4RHE			
0.00E+00	100.0%		NSF0RCMDHE	PACXCT4THF	T5WEATH	TACWFF2RHE			
0.00E+00	100.0%		NSF0RCMDHE	PK0KEORCOM	T5WEATH	TACWFF3RHE			
0.00E+00	100.0%		NSF0RCMDHE	PK0KEOSCOM	T5WEATH	TACWFF2RHE			
0.00E+00	100.0%		NSF3F01FLF	PACXCT4THF	T5WEATH	TACWFF2RHE			
0.00E+00	100.0%		NSF3FL2FLF	PACXCT4THF	T5WEATH	TACWFF2RHE			
0.00E+00	100.0%		NSFCON2CMS	PACXCT4THF	T5WEATH	TACWFF2RHE			

Report Summary:

Filename: C:\DATA\OR2\CUT_SETS\KEOFUSE1.CUT
 Print date: 7/2/97 3:06 PM
 Not sorted

Cutset Report

COREMELT = 5.72E-06 (Probability)

TO 1E-8

Probability	%	Class	Inputs
9.78E-07	17.1%		NSFORCMDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
4.76E-07	25.4%		NACSFDDGDR PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF3RHE
4.19E-07	32.8%		NACSFDDGDM PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.84E-07	37.7%		NSFCON2CMS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.46E-07	42.0%		NSFORCMDHE PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
1.67E-07	44.9%		KK2UNITHYM NSF0RCMDHE PK1UNITHYS T5WEATH TACWFF2RHE
1.60E-07	47.7%		NSFORCMDHE PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
1.30E-07	50.0%		NACSFDDGDR PK1UNITHYS PK2UNITHYR T5WEATH TACWFF4RHE
1.30E-07	52.3%		NSF3F01FLF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
1.30E-07	54.6%		NSF3FL2FLF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
1.20E-07	56.6%		NACSFDDGDR PK1UNITHYS PK2UNITHYS T5WEATH TACWFF3RHE
1.05E-07	58.5%		NACSFDDGDM PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
8.14E-08	59.9%		KK2UNITHYM NACSFDDGDR PK1UNITHYS T5WEATH TACWFF3RHE
7.69E-08	61.3%		NSF3PU1DPS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
7.62E-08	62.6%		NSF3PU1DPM PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
7.39E-08	63.9%		FEFSWAPDHE NSF0ASWDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF1RHE
7.16E-08	65.1%		KK2UNITHYM NACSFDDGDM PK1UNITHYS T5WEATH TACWFF2RHE
7.12E-08	66.4%		NSFCON2CMS PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
6.93E-08	67.6%		FEFTDFPTPR NSF0ASWDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF5RHE
6.84E-08	68.8%		NACSFDDGDM PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
5.87E-08	69.8%		NSFTIMEDHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
4.85E-08	70.7%		KK2UNITHYM NSFCON2CMS PK1UNITHYS T5WEATH TACWFF2RHE
4.77E-08	71.5%		FEFSWAPDHE PK1UNITHYS PK2SWAPDHE RRC0004DEX T5WEATH TRCSRVLDEX TACWFF1RHE
4.64E-08	72.3%		NSFCON2CMS PK1UNITHYS PK2UNITHYR T5WEATH TACWFF3RHE
4.47E-08	73.1%		FEFTDFPTPR PK1UNITHYS PK2SWAPDHE RRC0004DEX T5WEATH TRCSRVLDEX TACWFF5RHE
4.29E-08	73.8%		FEFSWAPDHE PK1UNITHYS PK2SWAPDHE RRC0066PRC T5WEATH TACWFF1RHE
4.02E-08	74.5%		FEFTDFPTPR PK1UNITHYS PK2SWAPDHE RRC0066PRC T5WEATH TACWFF5RHE
3.70E-08	75.2%		NACSFDDGDS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	75.8%		NHP3398MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	76.4%		NSF3082MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.42E-08	77.0%		NSF3097MVO PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.25E-08	77.6%		NSF3F01FLF PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
3.25E-08	78.1%		NSF3FL2FLF PK1UNITHYS PK2UNITHYS T5WEATH TACWFF2RHE
3.13E-08	78.7%		NDCDCSFBYF PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
3.03E-08	79.2%		NACDJPUGPS PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.93E-08	79.7%		NACSFDDGLHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.93E-08	80.2%		NSFRCMULHE PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF2RHE
2.51E-08	80.7%		FEFSWAPDHE NCW0125VVT PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF1RHE
2.35E-08	81.1%		FEFTDFPTPR NCW0125VVT PK1UNITHYS PK2SWAPDHE T5WEATH TACWFF5RHE
2.33E-08	81.5%		-T5SUBF -KK1BOTHYIM NSF0RCMDHE PACLEE2DHE PK1UNITHYS PK2UNITHYS T5FEEDF
2.33E-08	81.9%		NACDJ01HXF PK1UNITHYS PK2UNITHYR T5WEATH
2.33E-08	82.3%		NACDJ02HXF PK1UNITHYS PK2UNITHYR T5WEATH

Probability	%	Class	Inputs							
2.22E-08	83.1%		KK2UNITHYM	NSF3F01FLF	PK1UNITHYS	T5WEATH	TACWFF2RHE			
2.22E-08	83.5%		KK2UNITHYM	NSF3FL2FLF	PK1UNITHYS	T5WEATH	TACWFF2RHE			
2.15E-08	83.8%		-T5SUBF	-KK1BOTHHYM	NSF0RCMDHE	PACLEESCTR	PK1UNITHYS	PK2UNITHYS	T5FEEDF	
2.14E-08	84.2%		NAC3X12CLC	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	84.6%		NAC3X2ACLC	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	85.0%		NAC3X2CCLC	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	85.3%		NAC3X3ACLC	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	85.7%		NAC3X4CCLC	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	86.1%		NAC3X5ACLO	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.14E-08	86.5%		NACOTS4C4C	PK1UNITHYS	PK2UNITHYR	T5WEATH				
2.12E-08	86.8%		NSF3F01FLF	PK1UNITHYS	PK2UNITHYR	T5WEATH	TACWFF3RHE			
2.12E-08	87.2%		NSF3FL2FLF	PK1UNITHYS	PK2UNITHYR	T5WEATH	TACWFF3RHE			
2.06E-08	87.6%		FEFTDFPTPR	NSFPU02APS	PK1UNITHYS	PK2UNITHYS	T5WEATH			
2.05E-08	87.9%		FEFTDFPTPR	NSFASWZLHE	PK1UNITHYS	PK2UNITHYR	T5WEATH			
1.92E-08	88.3%		FEFTDFPTPR	NSFPU02APM	PK1UNITHYS	PK2UNITHYS	T5WEATH			
1.89E-08	88.6%		FEFTDFPTPR	NSF0ASWDHE	PK1UNITHYS	PK2UNITHYR	T5WEATH	TACWFF6RHE		
1.86E-08	88.9%		FEFSWAPDHE	NSF0ASWDHE	PK1UNITHYS	PK2UNITHYS	T5WEATH			
1.78E-08	89.2%		FEFSWAPDHE	PK1UNITHYS	PK2UNITHYR	RRC0004DEX	T5WEATH	TRCSRVLDEX		
1.74E-08	89.5%		FEFTDFPTPR	NSF0ASWDHE	PK1UNITHYS	PK2UNITHYS	T5WEATH	TACWFF5RHE		
1.67E-08	89.8%		FEFTDFPTPR	PK1UNITHYS	PK2UNITHYR	RRC0004DEX	T5WEATH	TRCSRVLDEX	TACWFF5RHE	
1.61E-08	90.1%		FEFTDFPTPR	NCW0268MVO	PK1UNITHYS	PK2UNITHYS	T5WEATH			
1.61E-08	90.4%		FEFTDFPTPR	NCW0287MVO	PK1UNITHYS	PK2UNITHYS	T5WEATH			
1.60E-08	90.7%		FEFSWAPDHE	PK1UNITHYS	PK2UNITHYR	RRC0066PRC	T5WEATH			
1.60E-08	90.9%		NDC0CSFBCF	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.56E-08	91.2%		NACDJ01HXF	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.56E-08	91.5%		NACDJ02HXF	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.54E-08	91.8%		NSFCON1CMR	PK1UNITHYS	PK2SWAPDHE	T5WEATH	TACWFF3RHE			
1.54E-08	92.0%		NSFCON2CMR	PK1UNITHYS	PK2SWAPDHE	T5WEATH	TACWFF3RHE			
1.50E-08	92.3%		FEFTDFPTPR	PK1UNITHYS	PK2UNITHYR	RRC0066PRC	T5WEATH	TACWFF5RHE		
1.48E-08	92.6%		-T5SUBF	-KK1BOTHHYM	NACSFDDGDM	PACLEED2DHE	PK1UNITHYS	PK2UNITHYR	T5FEEDF	
1.47E-08	92.8%		NSFTIMEDHE	PK1UNITHYS	PK2UNITHYS	T5WEATH	TACWFF2RHE			
1.44E-08	93.1%		NAC3X12CLC	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	93.3%		NAC3X2ACLC	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	93.6%		NAC3X2CCLC	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	93.8%		NAC3X3ACLC	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	94.1%		NAC3X4CCLC	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	94.3%		NAC3X5ACLO	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.44E-08	94.6%		NACOTS4C4C	PK1UNITHYS	PK2UNITHYS	T5WEATH				
1.43E-08	94.8%		FEFTDFPTPR	NAC01BLCLT	PK1UNITHYS	PK2UNITHYR	T5WEATH			
1.43E-08	95.1%		FEFTDFPTPR	NAC01BRCLT	PK1UNITHYS	PK2UNITHYR	T5WEATH			
1.38E-08	95.3%		FEFTDFPTPR	NSFASWZLHE	PK1UNITHYS	PK2UNITHYS	T5WEATH			
1.32E-08	95.5%		KK2UNITHYM	NSF3PU1DPS	PK1UNITHYS	T5WEATH	TACWFF2RHE			
1.30E-08	95.8%		KK2UNITHYM	NSF3PU1DPM	PK1UNITHYS	T5WEATH	TACWFF2RHE			
1.30E-08	96.0%		NDCSF4BCDT	PK1UNITHYS	PK2UNITHYR	T5WEATH				
1.27E-08	96.2%		FEFSWAPDHE	KK2UNITHYM	NSF0ASWDHE	PK1UNITHYS	T5WEATH	TACWFF1RHE		
1.26E-08	96.4%		NSF3PU1DPS	PK1UNITHYS	PK2UNITHYR	T5WEATH	TACWFF3RHE			
1.25E-08	96.7%		NSF3PU1DPM	PK1UNITHYS	PK2UNITHYR	T5WEATH	TACWFF3RHE			
1.20E-08	96.9%		FEFSWAPDHE	PK1UNITHYS	PK2UNITHYS	RRC0004DEX	T5WEATH	TRCSRVLDEX		
1.19E-08	97.1%		FEFTDFPTPR	KK2UNITHYM	NSF0ASWDHE	PK1UNITHYS	T5WEATH	TACWFF5RHE		
1.17E-08	97.3%		NAC3X12CLC	PK1UNITHYS	PK2SWAPDHE	T5WEATH	TACWFF2RHE			

Cutset Report

COREMELT = 1.19E-05 (Probability)

Probability	%	Class	Inputs
1.68E-06	14.2%		NSFORCMDHE PK1UNITHYR PK2UNITHYS T5WEATH
1.26E-06	24.7%		NACSFDDGDR PK1UNITHYS PK2UNITHYS T5WEATH
1.13E-06	34.2%		NSFORCMDHE PK1UNITHYS PK2UNITHYS T5WEATH
7.19E-07	40.3%		NACSFDDGDM PK1UNITHYR PK2UNITHYS T5WEATH
4.87E-07	44.4%		NSFCON2CMS PK1UNITHYR PK2UNITHYS T5WEATH
4.84E-07	48.5%		NACSFDDGDM PK1UNITHYS PK2UNITHYS T5WEATH
3.28E-07	51.2%		NSFCON2CMS PK1UNITHYS PK2UNITHYS T5WEATH
2.23E-07	53.1%		NSF3F01FLF PK1UNITHYR PK2UNITHYS T5WEATH
2.23E-07	55.0%		NSF3FL2FLF PK1UNITHYR PK2UNITHYS T5WEATH
2.00E-07	56.7%		FEFTDFPTPR NSF0ASWDHE PK1UNITHYR PK2UNITHYS T5WEATH
1.56E-07	58.0%		-KK2UNITHYM KK1BOTHDEX NACSFDDGDR PK13CLSDEX PK2UNITHYS T5WEATH
1.50E-07	59.3%		NSF3F01FLF PK1UNITHYS PK2UNITHYS T5WEATH
1.50E-07	60.5%		NSF3FL2FLF PK1UNITHYS PK2UNITHYS T5WEATH
1.40E-07	61.7%		-KK2UNITHYM KK1BOTHDEX NSF0RCMDHE PK13CLSDEX PK2UNITHYS T5WEATH
1.35E-07	62.8%		FEFTDFPTPR NSF0ASWDHE PK1UNITHYR PK2UNITHYS T5WEATH
1.32E-07	63.9%		NSF3PU1DPS PK1UNITHYR PK2UNITHYS T5WEATH
1.31E-07	65.0%		NSF3PU1DPM PK1UNITHYR PK2UNITHYS T5WEATH
1.23E-07	66.1%		NACSFDDGDR PK1UNITHYR PK2UNITHYS T5WEATH TACWFF4RHE
1.10E-07	67.0%		KK1RUNSDEX NACSFDDGDR PK13CLSDEX PK2UNITHYS T5WEATH
1.01E-07	67.9%		NSFTIMEDHE PK1UNITHYR PK2UNITHYS T5WEATH
9.91E-08	68.7%		KK1RUNSDEX NSF0RCMDHE PK13CLSDEX PK2UNITHYS T5WEATH
8.88E-08	69.4%		NSF3PU1DPS PK1UNITHYS PK2UNITHYS T5WEATH
8.80E-08	70.2%		NSF3PU1DPM PK1UNITHYS PK2UNITHYS T5WEATH
8.40E-08	70.9%		DDCBATADEX DDCBATBDEX FEFSWAPDHE PK1UNITHYR PK2UNITHYS T5WEATH TRCSRVLDEX
8.27E-08	71.6%		NSF0RCMDHE PACXCT4THF T5WEATH TACWFF2RHE
7.81E-08	72.2%		FEFTDFPTPR PK1UNITHYS PK2UNITHYS RRC0066PRC T5WEATH
6.78E-08	72.8%		FEFTDFPTPR NCW0125VVT PK1UNITHYR PK2UNITHYS T5WEATH
6.78E-08	73.4%		NSFTIMEDHE PK1UNITHYS PK2UNITHYS T5WEATH
6.35E-08	73.9%		NACSFDDGDS PK1UNITHYR PK2UNITHYS T5WEATH
6.00E-08	74.4%		-KK2UNITHYM KK1BOTHDEX NACSFDDGDM PK13CLSDEX PK2UNITHYS T5WEATH
5.88E-08	74.9%		NHP3398MVO PK1UNITHYR PK2UNITHYS T5WEATH
5.88E-08	75.4%		NSF3082MVO PK1UNITHYR PK2UNITHYS T5WEATH
5.88E-08	75.9%		NSF3097MVO PK1UNITHYR PK2UNITHYS T5WEATH
5.75E-08	76.4%		DDCBATADEX DDCBATBDEX FEFTDFPTPR PK1UNITHYR PK2UNITHYS T5WEATH TRCSRVLDEX
5.65E-08	76.9%		TACWFF6RHE
5.65E-08	76.9%		DDCBATADEX DDCBATBDEX FEFSWAPDHE PK1UNITHYS PK2UNITHYS T5WEATH TRCSRVLDEX
5.38E-08	77.3%		-KK2UNITHYM DDCBATADEX DDCBATBDEX FEFTDFPTPR KK1BOTHDEX PK13CLSDEX PK2UNITHYS
5.38E-08	77.8%		T5WEATH TRCSRVLDEX
5.38E-08	77.8%		NDCDCSFBYF PK1UNITHYR PK2UNITHYS T5WEATH
5.36E-08	78.2%		KK1BOTHYM NSF0RCMDHE T5WEATH TACWFF2RHE PAC0T5WDEX
5.30E-08	78.7%		DDC1DCBDM DDCUN31DIM NSF0RCMDHE PK2UNITHYS T5FEEDF

Probability	%	Class	Inputs
5.29E-08	79.6%		DDCBATADEX DDCBATBDEX FEFTDFPTPR PK1UNITHYS PK2UNITHYS T5WEATH TRCSRVLDEX
5.21E-08	80.0%		TACWFF5RHE
5.04E-08	80.4%		NACDJPUGPS PK1UNITHYR PK2UNITHYS T5WEATH
5.04E-08	80.9%		NACSFDDLHE PK1UNITHYR PK2UNITHYS T5WEATH
4.80E-08	81.3%		NSFRMULHE PK1UNITHYR PK2UNITHYS T5WEATH
4.56E-08	81.6%		FEFTDFPTPR NSF0ASWDHE PACXCT4THF T5WEATH TACWFF1RHE
4.27E-08	82.0%		FEFTDFPTPR NCW0125VVT PK1UNITHYS PK2UNITHYS T5WEATH
4.24E-08	82.4%		NACSFDDGGS PK1UNITHYS PK2UNITHYS T5WEATH
4.07E-08	82.7%		KK1RUNSDEX NACSFDDGDM PK13CLSDEX PK2UNITHYS T5WEATH
4.07E-08	82.7%		NSFCON1CMR PK1UNITHYS PK2UNITHYS T5WEATH
4.07E-08	83.0%		NSFCON2CMR PK1UNITHYS PK2UNITHYS T5WEATH
4.07E-08	83.4%		-KK2UNITHYM KK1BOTHDEX NSFCON2CMS PK13CLSDEX PK2UNITHYS T5WEATH
4.02E-08	83.7%		NACSFDDGDR PACXCT4THF T5WEATH TACWFF3RHE
3.95E-08	84.1%		NHP3398MVO PK1UNITHYS PK2UNITHYS T5WEATH
3.95E-08	84.4%		NSF3082MVO PK1UNITHYS PK2UNITHYS T5WEATH
3.95E-08	84.7%		NSF3097MVO PK1UNITHYS PK2UNITHYS T5WEATH
3.81E-08	85.0%		DDCBATADEX DDCBATBDEX FEFTDFPTPR KK1RUNSDEX PK13CLSDEX PK2UNITHYS T5WEATH
3.62E-08	85.4%		TRCSRVLDEX
3.54E-08	85.7%		NDCDCSFBYF PK1UNITHYS PK2UNITHYS T5WEATH
3.50E-08	85.9%		NACSFDDGDM PACXCT4THF T5WEATH TACWFF2RHE
3.47E-08	86.2%		NACDJPUGPS PK1UNITHYS PK2UNITHYS T5WEATH
3.39E-08	86.5%		-T5SUBF -KK1BOTHYHM NSF0RCMDHE PACLEE2DHE PK1UNITHYR PK2UNITHYS T5FEEDF
3.39E-08	86.8%		DDC1DCBBYF DDCUN31DIM NSF0RCMDHE PACLOOPDEX PK2UNITHYS T5FEEDF
3.39E-08	86.8%		NACSFDDLHE PK1UNITHYS PK2UNITHYS T5WEATH
3.39E-08	87.1%		NSFRMULHE PK1UNITHYS PK2UNITHYS T5WEATH
3.25E-08	87.4%		NSF0RCMDHE PK0KEORCOM T5WEATH TACWFF3RHE
3.11E-08	87.6%		FEFTDFPTPR KK1BOTHYHM NSF0ASWDHE T5WEATH TACWFF1RHE PAC0T5WDEX
2.88E-08	87.9%		FEFTDFPTPR NSFPU02APS PK1UNITHYR PK2UNITHYS T5WEATH
2.87E-08	88.1%		KK1RUNSDEX NSFCON2CMS PK13CLSDEX PK2UNITHYS T5WEATH
2.69E-08	88.3%		FEFTDFPTPR NSFPU02APM PK1UNITHYR PK2UNITHYS T5WEATH
2.64E-08	88.6%		NACSFDDGDR PK0KEORCOM T5WEATH TACWFF4RHE
2.61E-08	88.8%		KK1BOTHYHM NACSFDDGDR T5WEATH TACWFF3RHE PAC0T5WDEX
2.60E-08	89.0%		FEFSWAPDHE NSF0ASWDHE PK1UNITHYR PK2UNITHYS T5WEATH
2.40E-08	89.2%		NSFCON2CMS PACXCT4THF T5WEATH TACWFF2RHE
2.33E-08	89.4%		-T5SUBF -KK1BOTHYHM NSF0RCMDHE PACLEE2DHE PK1UNITHYS PK2UNITHYS T5FEEDF
2.29E-08	89.6%		KK1BOTHYHM NACSFDDGDM T5WEATH TACWFF2RHE PAC0T5WDEX
2.27E-08	89.8%		DDC1DCBBDM DDCUN31DIM NACSFDDGDM PK2UNITHYS T5FEEDF
2.26E-08	90.0%		FEFTDFPTPR NCW0268MVO PK1UNITHYR PK2UNITHYS T5WEATH
2.26E-08	90.2%		FEFTDFPTPR NCW0287MVO PK1UNITHYR PK2UNITHYS T5WEATH
2.23E-08	90.4%		NSF0RCMDHE PACS226SWT PACS22TSWT PK2UNITHYS T5FEEDF
2.19E-08	90.5%		NACDJ01HXF PK1UNITHYR PK2UNITHYS T5WEATH
2.19E-08	90.7%		NACDJ02HXF PK1UNITHYR PK2UNITHYS T5WEATH
2.15E-08	90.9%		-T5SUBF -KK1BOTHYHM NSF0RCMDHE PACLEESCTR PK1UNITHYS PK2UNITHYS T5FEEDF
2.02E-08	91.1%		NAC3X12CLC PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	91.2%		NAC3X2ACLC PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	91.4%		NAC3X2CCLC PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	91.6%		NAC3X3ACLC PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	91.8%		NAC3X4CCLC PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	91.9%		NAC3X5ACLO PK1UNITHYR PK2UNITHYS T5WEATH
2.02E-08	92.1%		NACOTS4C4C PK1UNITHYR PK2UNITHYS T5WEATH