

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9811160078 DOC. DATE: 98/11/05 NOTARIZED: YES DOCKET #
FACIL: 50-269 Ocone Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Ocone Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Ocone Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
MCCOLLUM, W.R. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Records Management Branch (Document Control Desk)

SUBJECT: Informs that util proposes to perform testing at monthly frequency after completion of mods in response to 981104 request. Util finds license condition acceptable to reflect commitment to implement mods that would add test circuitry.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4+4
TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD2-2 LA LABARGE, D | 1 1 1 1 | PD2-2 PD | 1 1 |
| INTERNAL: | ACRS | 1 1 | <u>FILE CENTER 01</u> | 1 1 |
| | NRR/DE/ECGB/A | 1 1 | NRR/DE/EMCB | 1 1 |
| | NRR/DRCH/HICB | 1 1 | NRR/DSSA/SPLB | 1 1 |
| | NRR/DSSA/SRXB | 1 1 | NUDOCS-ABSTRACT | 1 1 |
| | OGC/HDS2 | 1 0 | | |
| EXTERNAL: | NOAC | 1 1 | NRC PDR | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 13

AA

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



Duke Energy Corporation

Oconee Nuclear Station

P.O. Box 1439

Seneca, SC 29679

(864) 885-3107 OFFICE

(864) 885-3564 FAX

W. R. McCollum, Jr.
Vice President

November 5, 1998

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

Subject: Oconee Nuclear Station, Units 1, 2, and 3
Docket Numbers 50-269, - 270, and - 287
Proposed Revision to Technical Specifications
Technical Specification Change # 95-03

In letters dated July 15, 1997; March 3, 1998; April 13, 1998; June 16, 1998; July 1, 1998 and October 26, 1998, Duke submitted a proposed amendment to the Oconee Nuclear Station (ONS) Technical Specifications to address the newly installed main steam line break (MSLB) detection circuitry.

The October 26, 1998 correspondence proposed a quarterly frequency for the test of the Main Steam Header Pressure and MSLB detection analog channels after implementation of the modifications which are necessary to provide on-line testing capability. (Testing will be performed on an 18 month frequency until implementation of the modifications.) In a phone conversation on November 4, 1998, the staff requested a revision to the quarterly testing frequency. In response to this request, Duke proposes to perform the testing at a monthly frequency after completion of the modifications. The proposed monthly testing frequency is consistent with operating experience, with regard to channel OPERABILITY and drift, which demonstrates that failure of more than one channel of a given function in a monthly interval is a rare event. Additionally, this frequency is consistent with the requirement for testing instrumentation with comparable functions in NUREG-1430, Revision 1 (3.3.11, "Emergency Feedwater Initiation and Control (EFIC) System Instrumentation.") as well as similar instrumentation in the ONS current technical specifications (CTS) for similar

11
ADD

9811160078 981105
PDR ADOCK 05000269
P PDR

U. S. Nuclear Regulatory Commission

November 5, 1998

Page 2

instrumentation (e.g., Engineered Safeguard Protective System (ESPS) analog instrumentation).

Attachment 1 provides a revised retyped Technical Specification Page. Attachment 2 provides a revised Technical Specification Markup page. These revised pages replace the associated pages in previous submittals. The changes represented in the attached supplemental Technical Specification pages do not impact the original No Significant Hazards Consideration or the Environmental Impact Analysis. These changes will be appropriately incorporated into an Improved Technical Specification (ITS) supplement package.

Dukes finds a License Condition acceptable to reflect Duke's commitment to implement modifications that would add test circuitry to the MSLB protection circuitry. These modifications provide for testing at power for Unit 1 during 1EOC19, Unit 2 during 2EOC17 and Unit 3 during 3EOC18.

If there are any additional questions, please call Renee' Gambrell at (864) 885-3364.

Very truly yours,



W. R. McCollum, Jr., Vice President
Oconee Nuclear Site

Attachments

U. S. Nuclear Regulatory Commission

November 5, 1998

Page 3

cc: Mr. D. E. LaBarge, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-14 H25
Washington, D.C. 20555

Mr. L. A Reyes, Regional Administrator
U. S. Nuclear Regulatory Commission Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

M. A. Scott
Senior Resident Inspector
Oconee Nuclear Station


Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health & Environmental Control
2600 Bull Street
Columbia, SC 29201

U. S. Nuclear Regulatory Commission

November 5, 1998

Page 4

W. R. McCollum, Jr., being duly sworn, states that he is vice president, Oconee Nuclear Station, Duke Energy Corporation, that he is authorized on the part of said Company to sign and file with the U. S. Nuclear Regulatory Commission this revision to the Facility Operating License Nos. DPR-38, DPR-47, DPR-55; and that all statements and matters set forth herein are true and correct to the best of his knowledge.



W. R. McCollum, Jr., Vice President
Oconee Nuclear Site

Subscribed and sworn to before me this 5th day of
November, 1998



Notary Public

My Commission Expires:

2-12-2013