

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9712120389 DOC. DATE: 97/12/03 NOTARIZED: NO
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
AUTH. NAME: AUTHOR AFFILIATION
MCCOLLUM, W.R. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

DOCKET #
05000269

SUBJECT: Provides rept of end of Cycle 17 refueling outage SG ISI rept.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-2 LA		1	1		PD2-2 PD	1	1	
	LABARGE, D		1	1					
INTERNAL:	ACRS		1	1		AEOD/SPD/RAB	1	1	
	<u>FILE CENTER 01</u>		1	1		NRR/DE/EMEB	1	1	
	NUDOCS-ABSTRACT		1	1		OGC/HDS2	1	0	
	RES/DET/EIB		1	1		RES/DET/EMEB	1	1	
EXTERNAL:	LITCO ANDERSON		1	1		NOAC	1	1	
	NRC PDR		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 2

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T



Duke Power Company

A Duke Energy Company

Oconee Nuclear Site

P.O. Box 1439

Seneca, SC 29679

W. R. McCollum, Jr.
Vice President

(864) 885-3107 OFFICE

(864) 885-3564 FAX

December 3, 1997

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Unit 1
Docket No. 50-269
Steam Generator Inservice Inspection
Steam Generator Tube Plugging and Repair 30 Day Report

As required by Technical Specification 4.17.6 (a), the number of tubes plugged or repaired during the Steam Generator Tube Inservice Inspection for the Unit 1 End of Cycle 17 refueling outage is submitted for review.

The tables below identify the quantity of tubes removed from service by plugging. There were no tubes repaired by sleeving in either steam generator. There were some tubes repaired by rerolling in the upper tubesheet. Additionally, there were samples of five tubes removed from each steam generator. In steam generator A, the samples were removed from the lower tubesheet. In steam generator B, the samples were removed from the upper tubesheet.

<u>Steam Generator</u>	<u>Number of Tubes Plugged</u>
A	52
B	128

<u>Steam Generator</u>	<u>Number of Tubes Rerolled</u>
A	39
B	1956*

A047
~~A032~~ 1/10

* 1929 of these tubes remained in service, 27 were plugged.

00055
9712120389 971203
PDR ADDCK 05000269
G PDR




NRC Document Control

December 3, 1997

Page 2

If there are any questions you may contact D. A. Nix at (864)
885-3634.

Very truly yours,

A handwritten signature in cursive script that reads "W. R. McCollum, Jr." followed by a flourish.

W. R. McCollum, Jr
Site Vice-President

NRC Document Control

Déccember 3, 1997

Page 3

xc : Mr. L. A. Reyes
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. M. A. Scott
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Max Batavia
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St. Columbia, SC 29201

Mr. D. E. LaBarge, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555