

NOTE TO ALL "RIDS" RECIPIENTS: PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 13

U

М

Ε

N

Т



W. R. McCollum, Jr. Vice President

Duke Power Company A Duke Energy Company

Oconee Nuclear Site P.O. Box 1439 Seneca, SC 29679

(864) 885-3107 OFFICE (864) 885-3564 FAX

December 30, 1997

971230

ADOCK 05000269

9801070071

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

Oconee Nuclear Station Subject:

> Docket Nos. 50-269, -270, -287 Oconee Integrated Emergency Power and Engineered Safeguards Functional Test

In a letter dated October 31, 1996, Duke Power committed to review the possibility of performing a one-time integrated emergency power and engineered safeguards functional test during the outage of all three Oconee units that was in progress at the time. In a follow-up letter dated November 21, 1996, Duke committed to the performance of a one-time integrated emergency power and ES functional test during the three unit Oconee outage.

The one-time integrated emergency power and ES functional test was performed on January 2-5, 1997. In a letter dated January 30, 1997, Duke provided the schedule for the submittal of the test report and CYME computer simulation for the one-time integrated emergency power and ES functional test. A copy of the test report was submitted to the NRC by a letter which was dated April 30, 1997. The CYME computer simulation has been completed and a report containing the results of the CYME computer simulation is attached to this letter.

The one-time integrated emergency power and ES functional test which was performed on January 2-5, 1997 demonstrated that the Oconee emergency power system was capable of performing its intended safety functions. In addition, the CYME model simulations of the one-time integrated emergency power and ES functional test correlate well with the actual test results. The attached report concludes that the CYME model conservatively models the emergency power system response during design basis accidents. Therefore, the CYME model is an acceptable method for predicting the response of ADDI'I the Oconee emergency power system.



Please address any questions to Michael Bailey at (864) 885-4390.

Very Truly Yours,

W. R. McCollum, Jr. Site Vice President Oconee Nuclear Station

Attachment

cc: L. A. Reyes, Regional Administrator Region II

> M. A. Scott, Senior Resident Inspector Oconee Nuclear Site

D. E. LaBarge, Project Manager NRR