

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

November 1993

1. Personnel Exposure -

For the month of November, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

9301210021 930115
PDR ADOCK 05000269
R PDR

MONTHLY REFUELING INFORMATION REQUEST

Revision 1

1. Facility name: Oconee, Unit 3
2. Scheduled next refueling shutdown: January 1994
3. Scheduled restart following refueling: February 1994

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
(b) in the spent fuel pool: 516
(c) in the ISFSI: See Unit 1****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present licensed capacity: July 2014***

DUKE POWER COMPANY

DATE: December 15, 1992

Name of Contact: R. A. Williams

Phone: 704-382-5346

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 20 modules (480 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1