

OPERATING DATA REPORT

DOCKET NO 50-269

DATE November 15, 1996

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 1
2. Reporting Period: October 1, 1996-October 31, 1996
3. Licensed Thermal Power (MWT): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	745.0	7320.0	204217.0
12. Number Of Hours Reactor Was Critical	206.9	6745.3	160433.9
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	72.6	6606.6	157489.2
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	223104	16897032	388366054
17. Gross Electrical Energy Generated (MWH)	61501	5832657	134251076
18. Net Electrical Energy Generated (MWH)	49323	5566967	127620041
19. Unit Service Factor	9.7	90.3	77.1
20. Unit Availability Factor	9.7	90.3	77.1
21. Unit Capacity Factor (Using MDC Net)	7.8	89.9	73.0
22. Unit Capacity Factor (Using DER Net)	7.5	85.8	70.5
23. Unit Forced Outage Rate	0.0	0.6	9.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): None			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: January 10, 1997

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

9611200222 961115
PDR ADOCK 05000269
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October 1996

DOCKET NO. 50-269
 UNIT NAME OCONEE 1
 DATE 11/15/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	96-10- 4	S	672.43	B	1		HJ	PIPEXX	EVALUATE, INSPECT & MODIFY MOISTURE SEPARATOR REHEATER DRAIN LINE & ASSOCIATED PIPING

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

OPERATING DATA REPORT

DOCKET NO 50-269
 UNIT Oconee 1
 DATE November 15, 1996
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH October, 1996

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>834</u>
2	<u>835</u>
3	<u>772</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 2
2. Scheduled next refueling shutdown: December 1997
3. Scheduled restart following refueling: January 1998

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 974*
(c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: October 2013***

DUKE POWER COMPANY

DATE: November 15, 1996

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 40 modules (960 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

DOCKET: 50 - 287

UNIT: Oconee 3

Date: 11/15/96

NARRATIVE SUMMARY

MONTH: October, 1996

Oconee Unit 3 began the month of October operating at 100% full power. The unit operated at or near 100% full power until 10/04/96 at 0800 when the unit began decreasing power to evaluate, inspect and modify moisture separator reheater drain line and associated piping. The unit held at 20% power from 10/04/96 at 1300 to 1325 to allow transmission to obtain phase voltage readings. The unit continued decreasing power to begin end-of-cycle 16 refueling outage, the unit was taken off-line on 10/04/96 at 1334. The unit remained in the outage the remainder of the month.

Prepared by: R. A Williams
Telephone: (704) - 382-5346

OPERATING DATA REPORT

DOCKET NO 50-287

DATE November 15, 1996

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 3
2. Reporting Period: October 1, 1996-October 31, 1996
3. Licensed Thermal Power (MWT): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	745.0	7320.0	191784.0
12. Number Of Hours Reactor Was Critical	87.2	6434.2	150111.1
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	85.6	6429.7	148292.7
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	213864	16341744	369366633
17. Gross Electrical Energy Generated (MWH)	73555	5706438	127544077
18. Net Electrical Energy Generated (MWH)	65443	5454032	121668210
19. Unit Service Factor	11.5	87.8	77.3
20. Unit Availability Factor	11.5	87.8	77.3
21. Unit Capacity Factor (Using MDC Net)	10.4	88.1	74.2
22. Unit Capacity Factor (Using DER Net)	9.9	84.1	71.6
23. Unit Forced Outage Rate	0.0	3.5	9.6

24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Currently Refueling

25. If Shut Down At End Of Report Period. Estimated Date of Startup: January 31, 1997

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-287
 UNIT Oconee 3
 DATE November 15, 1996
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH October, 1996

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>848</u>	17	<u>0</u>
2	<u>849</u>	18	<u>0</u>
3	<u>849</u>	19	<u>0</u>
4	<u>367</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>0</u>
16	<u>0</u>		

OPERATING DATA REPORT

DOCKET NO 50-270
UNIT Oconee 2
DATE November 15, 1996
COMPLETED BY R.A. Williams
TELEPHONE 704-382-5346

MONTH October, 1996

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

OPERATING DATA REPORT

DOCKET NO 50-270

DATE November 15, 1996

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 2
2. Reporting Period: October 1, 1996-October 31, 1996
3. Licensed Thermal Power (MWT): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	745.0	7320.0	194137.0
12. Number Of Hours Reactor Was Critical	0.0	5349.7	155009.9
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	0.0	5305.1	153001.0
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	0	13352568	374505158
17. Gross Electrical Energy Generated (MWH)	0	4648496	128269789
18. Net Electrical Energy Generated (MWH)	-5696	4422866	122164376
19. Unit Service Factor	0.0	72.5	78.8
20. Unit Availability Factor	0.0	72.5	78.8
21. Unit Capacity Factor (Using MDC Net)	0.0	71.4	73.6
22. Unit Capacity Factor (Using DER Net)	0.0	68.2	71.0
23. Unit Forced Outage Rate	100.0	16.9	8.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): None			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: December 24, 1996
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-287
 UNIT NAME OCONEE 3
 DATE 11/15/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

REPORT MONTH October 1996

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
7-P	96-10- 4	F	--	H	--		ED	TRANSF	HOLD AT 20% POWER TO ALLOW TRANSMISSION TO OBTAIN PHASE VOLTAGE READINGS
2	96-10- 4	S	659.43	C	1		RC	FUELXX	END-OF-CYCLE 16 REFUELING OUTAGE

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-270
 UNIT NAME OCONEE 2
 DATE 11/15/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

REPORT MONTH October 1996

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
6	96-10- 1	F	745.00	A	--		HJ	PIPEXX	SECOND STAGE REHEATER DRAIN LINE RUPTURE

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

DOCKET: 50 - 270

UNIT: Oconee 2

Date: 11/15/96

NARRATIVE SUMMARY

MONTH: October, 1996

Oconee Unit 2 began the month of October in an outage due to second stage reheater drain line rupture. The unit remained in the outage the entire month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346