

OPERATING DATA REPORT

DOCKET NO 50-269

DATE December 13, 1996

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 1
2. Reporting Period: November 1, 1996-November 30, 1996
3. Licensed Thermal Power (MWh): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	8040.0	204937.0
12. Number Of Hours Reactor Was Critical	0.0	6745.3	160433.9
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	0.0	6606.6	157489.2
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	0	16897032	388366054
17. Gross Electrical Energy Generated (MWH)	0	5832657	134251076
18. Net Electrical Energy Generated (MWH)	-4760	5562207	127615281
19. Unit Service Factor	0.0	82.2	76.8
20. Unit Availability Factor	0.0	82.2	76.8
21. Unit Capacity Factor (Using MDC Net)	0.0	81.8	72.8
22. Unit Capacity Factor (Using DER Net)	0.0	78.1	70.2
23. Unit Forced Outage Rate	0.0	0.6	9.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): None			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: January 16, 1997
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY _____

INITIAL ELECTRICITY _____

COMMERCIAL OPERATION _____

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

9612180106 961213
PDR ADOCK 05000269
R PDR

OPERATING DATA REPORT

DOCKET NO 50-269
 UNIT Oconee 1
 DATE December 13, 1976
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH November, 1976

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>		
16	<u>0</u>		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269
 UNIT NAME OCONEE 1
 DATE 12/13/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

REPORT MONTH November 1996

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	96-11- 1	S	720.00	B	--		HJ	PIPEXX	EVALUATE, INSPECT & MODIFY MOISTURE SEPARATOR REHEATER DRAIN LINE & ASSOCIATED PIPING

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 1
2. Scheduled next refueling shutdown: July 1997
3. Scheduled restart following refueling: August 1997

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 974*
(c) in the ISFSI: 960****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: February 2013***

DUKE POWER COMPANY

DATE: December 13, 1996

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On January 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** This date is based on 88 Dry Storage Modules. We currently have 40 modules (960 spaces). Additional modules will be built on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

DOCKET: 50 - 269

UNIT: Oconee 1

DATE: 12/13/96

NARRATIVE SUMMARY

MONTH: November, 1996

Oconee Unit 1 began the month of November in an outage to evaluate, inspect and modify moisture separator reheater drain line and associated piping. The unit remained in the outage the entire month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346

OPERATING DATA REPORT

DOCKET NO 50-270
 DATE December 13, 1996
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 2
2. Reporting Period: November 1, 1996-November 30, 1996
3. Licensed Thermal Power (MWT): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

This Month Yr.-to-Date Cumulative

11. Hours In Reporting Period	720.0	8040.0	194857.0
12. Number Of Hours Reactor Was Critical	0.0	5349.7	155009.9
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	0.0	5305.1	153001.0
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	0	13352568	374505158
17. Gross Electrical Energy Generated (MWH)	0	4648496	128269789
18. Net Electrical Energy Generated (MWH)	-5276	4417590	122159100
19. Unit Service Factor	0.0	66.0	78.5
20. Unit Availability Factor	0.0	66.0	78.5
21. Unit Capacity Factor (Using MDC Net)	0.0	65.0	73.3
22. Unit Capacity Factor (Using DER Net)	0.0	62.0	70.7
23. Unit Forced Outage Rate	100.0	25.3	9.2
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): None			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: January 06, 1997
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-270
 UNIT Oconee 2
 DATE December 13, 1996
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH November, 1996

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>		
16	<u>0</u>		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-270
 UNIT NAME OCONEE 2
 DATE 12/13/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

REPORT MONTH November 1996

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
6	96-11- 1	F	720.00	A	--		HJ	PIPEXX	SECOND STAGE REHEATER DRAIN LINE RUPTURE

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee, Unit 2
2. Scheduled next refueling shutdown: January 1998
3. Scheduled restart following refueling: February 1998

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
 (b) in the spent fuel pool: 974*
 (c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present license capacity: October 2013***

DUKE POWER COMPANY

DATE: December 13, 1996

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** This date is based on 88 Dry Storage Modules. We currently have 40 modules (960 spaces). Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

DOCKET: 50 - 270

UNIT: Oconee 2

Date: 12/13/96

NARRATIVE SUMMARY

MONTH: November, 1996

Oconee Unit 2 began the month of November in an outage due to second stage reheater drain line rupture. The unit remained in the outage the entire month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346

OPERATING DATA REPORT

DOCKET NO 50-287

DATE December 13, 1996

COMPLETED BY R.A. Williams

TELEPHONE 704-382-5346

OPERATING STATUS

1. Unit Name: Oconee 3
2. Reporting Period: November 1, 1996-November 30, 1996
3. Licensed Thermal Power (Mwt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 986
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes Year-to date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	8040.0	192504.0
12. Number Of Hours Reactor Was Critical	0.0	6434.2	150111.1
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	0.0	6429.7	148292.7
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	0	16341744	369366633
17. Gross Electrical Energy Generated (MWH)	0	5706438	127544077
18. Net Electrical Energy Generated (MWH)	-1737	5452295	121666473
19. Unit Service Factor	0.0	80.0	77.0
20. Unit Availability Factor	0.0	80.0	77.0
21. Unit Capacity Factor (Using MDC Net)	0.0	80.2	73.9
22. Unit Capacity Factor (Using DER Net)	0.0	76.5	71.3
23. Unit Forced Outage Rate	0.0	3.5	9.6
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>Currently Refueling</u>			

25. If Shut Down At End Of Report Period. Estimated Date of Startup: January 31, 1997
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

OPERATING DATA REPORT

DOCKET NO 50-287
 UNIT Oconee 3
 DATE December 13, 1996
 COMPLETED BY R.A. Williams
 TELEPHONE 704-382-5346

MONTH November, 1996

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL (MWe-Net)</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November 1996

DOCKET NO. 50-287
 UNIT NAME OCONEE 3
 DATE 12/13/96
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	96-11- 1	S	396.57	C	--		RC	FUELXX	END-OF-CYCLE 16 REFUELING OUTAGE
3	96-11-17	S	323.43	B	--		HJ	PIPEXX	EVALUATE, INSPECT & MODIFY MOISTURE SEPARATOR REHEATER DRAIN LINE & ASSOCIATED PIPING

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

DOCKET: 50 - 287

UNIT: Oconee 3

Date: 12/13/96

NARRATIVE SUMMARY

MONTH: November, 1996

Oconee Unit 3 began the month of November in an outage due to end-of-cycle 16 refueling outage. On 11/17/96 at 1234 the critical path outage event changed; to evaluate, inspect and modify moisture separator reheater drain line and associated piping. The unit remained in the outage the remainder of the month.

Prepared by: R. A Williams
Telephone: (704) - 382-5346