

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

January 1998

1. Personnel Exposure -

The total station liquid release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for January has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9803180110 980313
PDR ADOCK 05000269
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269
 UNIT NAME OCONEE 1
 DATE 02/13/98
 COMPLETED BY R. A. Williams
 TELEPHONE (704)-382-5346

REPORT MONTH January 1998

REVISION 1

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	98- 1- 1	F	624.78	A	--		CH	HTEXCH	STEAM GENERATOR "1A" TUBE LEAK
2	98- 1-27	F	119.22	A	--		CB	PIPEXX	PRESSURIZER DRAIN LINE LEAK

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

DOCKET: 50 - 269

UNIT: Oconee 1

DATE: 02/13/98

NARRATIVE SUMMARY

REVISION 1

MONTH: January, 1998

Oconee Unit 1 began the month of January in an outage due to steam generator "1A" tube leak. The unit was in the outage until 01/27/98 at 0047. On 01/27/98 at 0047 during heat-up a weld leak occurred on the pressurizer drain line. The unit was in the outage the remainder of the month.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346