

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

July 1998

1. Personnel Exposure -

The total station liquid release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9809230079 980915
PDR ADOCK 05000269
R PDR