

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

August 1998

1. Personnel Exposure -

The total station liquid release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9810200012 981015
PDR ADDCK 05000269
R PDR

Revision 1

DOCKET: 50 - 287

UNIT: Oconee 3

Date: 09/15/98

NARRATIVE SUMMARY

MONTH: August, 1998

Oconee Unit 3 began the month of August operating at 100% full power. The unit began core coastdown to end-of-cycle 17 refueling outage on 08/23/98 at 1446. The unit ended the month holding at 93% power due to core coastdown.

**Prepared by: R. A Williams
Telephone: (704) - 382-5346**