

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JULY 1999

1. Personnel Exposure -

The total station liquid release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9909200116 990914
PDR ADOCK 05000269
R PDR