



ND-2015-0006
April 15, 2015

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: **PSEG Early Site Permit Application**
Docket No. 52-043
Supplemental Response to Request for Additional Information, RAI
No. 67, Probable Maximum Surge and Seiche Flooding

- References:
- 1) PSEG Power, LLC Letter No. ND-2014-0010 to USNRC, Submittal of Revision 3 of the Early Site Permit Application for the PSEG Site, dated March 31, 2014
 - 2) RAI No. 67, SRP Section: 02.04.05 – Probable Maximum Surge and Seiche Flooding, dated October 29, 2012 (eRAI 6615)
 - 3) PSEG Power, LLC Letter No. ND-2011-0066 to USNRC, Supplemental Response to Request for Additional Information, RAI No. 39, Probable Maximum Surge and Seiche Flooding, dated December 9, 2011
 - 4) PSEG Power, LLC Letter No. ND-2013-0039 to USNRC, Response to Request for Additional Information, RAI No. 67, Probable Maximum Surge and Seiche Flooding, dated November 27, 2013
 - 5) PSEG Power, LLC Letter No. ND-2014-0020 to USNRC, Response to Request for Additional Information, RAI No. 67, Probable Maximum Surge and Seiche Flooding, dated August 21, 2014

D079
NRD

The purpose of this letter is to provide a supplemental response to the request for additional information (RAI) provided in Reference 2 above. This RAI addresses the Probable Maximum Surge and Seiche Flooding, as described in Subsection 2.4.5 of the Site Safety Analysis Report (SSAR), as submitted in Part 2 of the PSEG Site Early Site Permit Application, Revision 3.

In light of issues arising from the language describing the proposed use of engineered flood protection measures, PSEG reassessed the approach to establishing the Design Basis Flood. In Reference 5, the design basis Water Surface Elevation (WSEL) was established using a one-dimensional model. These results are considered unrealistically conservative. PSEG also performed a deterministic analysis using a two dimensional, high-resolution storm surge model, which provides a conservative, yet more realistic, design basis WSEL. This supplemental response revises the SSAR to credit the results from the high-resolution storm surge model to establish the design basis flood level for the PSEG Site. No changes to the RAI response text for Question No. 02.04.05-12 in Reference 5 are proposed.

Enclosure 1 provides markups to the Early Site Permit Application that supersede the markups provided in Reference 5. Also included is a redline copy of SSAR Subsection 2.4.5, Probable Maximum Surge and Seiche Flooding, that highlights the changes between the version of SSAR Subsection 2.4.5 provided in Reference 5 and the final version submitted herein. Enclosure 2 includes the new regulatory commitments established in this submittal.

If any additional information is needed, please contact David Robillard, PSEG Nuclear Development Licensing Engineer, at (856) 339-7914.

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 15th day of April, 2015.

Sincerely,



James Mallon
Early Site Permit Manager
Nuclear Development
PSEG Power, LLC

Enclosure 1: Optical Media containing the following:

- Proposed Revisions Part 2 – Site Safety Analysis Report, Subsection 2.4.5 - Probable Maximum Surge and Seiche Flooding
- Proposed Revisions Part 2 – Site Safety Analysis Report, Chapter 2 – Site Characteristics
- Proposed Revisions Part 3 – Environmental Report, Subsection 2.3.1 – Hydrology

Enclosure 2: Summary of Regulatory Commitments

cc: USNRC Project Manager, Division of New Reactor Licensing, PSEG Site
(w/enclosures)
USNRC Environmental Project Manager, Division of New Reactor Licensing
(w/enclosures)
USNRC Region I, Regional Administrator (w/enclosures)


PSEG Letter ND-2015-0006, dated April 15, 2015

ENCLOSURE 1

Optical Media containing the following:

- **Proposed Revisions Part 2 – Site Safety Analysis Report, Subsection 2.4.5 - Probable Maximum Surge and Seiche Flooding**
 - **Proposed Revisions Part 2 – Site Safety Analysis Report, Chapter 2 – Site Characteristics**
 - **Proposed Revisions Part 3 – Environmental Report, Subsection 2.3.1 – Hydrology**

**PSEG Site
Early Site Permit Application
RAI No. 67 Supplemental Response
Enclosure 1**



PSEG
Power LLC

Sargent & Lundy LLC



PSEG Letter ND-2015-0006, dated April 15, 2015

ENCLOSURE 2

Summary of Regulatory Commitments

ENCLOSURE 2

SUMMARY OF REGULATORY COMMITMENTS

The following table identifies commitments made in this document. (Any other actions discussed in the submittal represent intended or planned actions. They are described to the NRC for the NRC's information and are not regulatory commitments.)

COMMITMENT	COMMITTED DATE	COMMITMENT TYPE	
		ONE-TIME ACTION (Yes/No)	Programmatic (Yes/No)
PSEG will revise the SSAR and ER to incorporate the changes in Enclosure 2 in response to NRC RAI No. 67, Questions 02.04.05-12 and 02.04.05-15.	This revision will be included in a future update of the PSEG ESP application.	Yes	No