



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 14, 1994

Docket Nos. 50-269, 50-270, 50-287,
50-289, 50-302, 50-313
and 50-346

GROUP: BABCOCK & WILCOX OWNERS' GROUP

SUBJECT: SUMMARY OF MEETING HELD ON MAY 27, 1994, TO DISCUSS ULTRASONIC TESTING IN LIEU OF SURFACE EXAMINATION OF REACTOR VESSEL NOZZLE WELDS

- REFERENCES:
1. Inspection Report 50-302/89-21 issued by the NRC on August 25, 1989
 2. Letter to U.S. NRC from Duke Power Company dated November 18, 1993
 3. Letter from U.S. NRC to Duke Power Company dated March 1, 1994
 4. Letter to U.S. NRC from The B&W Owners' Group dated April 13, 1994

On May 27, 1994, NRC staff members met at Rockville, Maryland, with members of the Babcock & Wilcox Owners' Group (B&WOG) at a public meeting to discuss an alternative to surface examination of reactor vessel nozzle welds. A list of people attending the meeting is provided in Enclosure 1.

The B&WOG made presentations on the demonstration history, demonstration objectives, analysis and calculations to support flaw size used in the demonstration. Slides presented at the meeting, except for those designated as proprietary, are included in Enclosure 2. The slides designated as proprietary were previously submitted under affidavit on October 13, 1993.

During the late 1980's and early 1990's, relief requests were conditionally approved in safety evaluation reports (SERs) with the provision that the licensee's demonstrate the ultrasonic examination techniques and procedures applied on the inside diameter surface to detect surface connected defects on the outside diameter in the circumferential orientation in a laboratory test block. The defects were supposed to be cracks and not machine notches. A demonstration conducted in 1989 on a core flood nozzle with machined notches

9406200190 940614
PDR ADDCK 05000269
P PDR

150036

NRC FILE CENTER COPY

DF01
111
memo

did not detect flaws in Inconel material. In 1991, other B&W plants requested that B&WOG conduct a demonstration that could be used for all B&W plants (a generic relief request). A second demonstration conducted in 1993 on core flood nozzle and reactor coolant nozzle mockups was capable of detecting cracks larger than the maximum acceptable for the surface examination method.

In a telephone conversation on November 10, 1993, the NRC stated that the demonstration was inadequate to satisfy the condition stipulated in the SERs. A licensee submittal (Reference 2) described the reasons for believing the 1993 demonstration fulfilled the conditions stipulated by the SERs and requested the NRC reconsider its position on the 1993 demonstration. The NRC reaffirmed its position and described its concerns in additional questions to the licensee, (Reference 3). The response to these additional questions was submitted (Reference 4). The subject meeting was requested to clarify what questions or concerns remained.

B&WOG stated that for the 1993 demonstration, one official set of data collected by one individual, qualified per ASME Code, was used to identify all the flaws. The procedure that was used addressed the essential variables. The procedures that would be used for plant specific examinations would contain these same essential variables, but may have administrative changes.

Although B&WOG did not have a precise minimum detection surface flaw length, they estimated that the indexing used in the 1993 demonstration would pick-up a 1/2-inch long flaw in at least 4 scans. This would be the same for both the reactor coolant and core flood systems.

In reviewing the fracture mechanics calculation for the core flood nozzle submitted in Reference 4, B&WOG identified at least one other plant with a 40 percent higher stress value.

In summary, the NRC is amenable to granting relief from performing surface examinations of reactor vessel nozzles to reduce radiation exposure to non-destructive examination personnel. The NRC understands that the demonstration held in 1993 was not to demonstrate an equivalency to a surface examination. The demonstration was a capability demonstration to show that flaws located in the test block could be detected and was not intended to be a reliability demonstration. The presentation clarified that a fracture mechanics analysis (based on minimum detectable flaw size and maximum propagation rates) plus a reliability safety factor, combined with ultrasonic testing may prove to be an acceptable alternative and meet the intent in the SER. However, the NRC would need a detailed submittal on the fracture mechanics analysis including the loadings, basis for any assumptions, and the inclusion of margins and uncertainties. The additional information needs to specify which nozzles (size, location/identification, plant) are included and state if the analyses are bounding for all plants.

At the conclusion of the meeting, the B&WOG stated they would submit additional information in four to six weeks. The NRC said this should allow sufficient time to support the first unit affected that needs the exemption by

February 1995. The NRC encouraged B&WOG to work with ASME Code Committees to allow this alternative.

Original signed by

Linda L. Gundrum, Acting Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Presentation Slides (nonproprietary)

cc w/enclosures:
See next page

DISTRIBUTION

See attached page

OFFICE	LA:PDIII-3	APM:PDIII-3	BC:EMCB	PD:PDIII-3
NAME	MRushbrook	LGundrum	JStrosnider	JHannan
DATE	6/9/94	6/9/94	6/10/94	6/13/94

OFFICIAL RECORD COPY

FILENAME: G:\B&WOG.MIN

cc with Enclosures:
(Meeting Attendees)

Mr. Gene Navratil
GPU Nuclear
Route 441 South
P.O. Box 480
Middletown, Pa 17057

Rooney Sheffield
Duke Power Company
McGuire Nuclear Station
Hagors Ferry Road
Huntersville, NC 28078

Kevin Hacker
BWNT
3315 Old Forest Road
Lynchburg, VA 24506

David Nix
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Frank Walters
BWNT
3315 Old Forest Road
Lynchburg, VA 24506

Kenneth K. Yoon
BWNT
3315 Old Forest Road
Lynchburg, VA 24506

J. H. Taylor
BWNT
3315 Old Forest Road
Lynchburg, VA 24506

DISTRIBUTION - Meeting Minutes

Docket Files
NRC PDR
PD III-3 Reading File
JHannon
JHopkins
LGundrum
MRushbrook
B. Grimes
A. Chaffee, OEAB
OGC
E. Jordan
JStrosnider (7-D-4)
ESullivan (7-D-4)
DNaujock (7-D-4)
LWiens (14-H-25)
LRaghavan (14-H-15)
GWest (13-E-14)
GKalman (13-H-3)
RHernan (14-C-12)
PRush, Region II
KBattige (7-D-4)
ACRS (10)
OPA
NRR Mailroom, PMAS, 12/G/18
S. Black, RPEB (10-A-19)
W. Dean, EDO, Region I Plants, MS 17-G-21
A. Howell, EDO, Region II Plants, MS 17-G-21
B. McCabe, EDO, Region III Plants, MS 17-G-21
J. Mitchell, EDO, Region IV Plants, MS 17-G-21
R. Cooper, Region I, DRP
E. Merschhoff, Region II, DRP
E. Greenman, Region III, DRP
A. Beach, Region IV, DRP

ATTENDANCE LIST

<u>NAME</u>	<u>AFFILIATION</u>	<u>PHONE</u>
Gene Navratil	GPU Nuclear	717-948-8716
Rodney Sleffield	Duke Power Co.	704-874-4467
Kevin Hacker	BWNT	804-385-3539
David Nix	Duke Power Co.	803-885-3634
Frank Walters	BWNT	804-385-2208
Kenneth Yoon	BWNT	804-385-3280
James Taylor	BWNT	804-385-2817
Ken Battige	NRC/NRR	301-504-2730
Linda Gundrum	NRC/NRR	301-504-1380
Garmon West, Jr.	NRC/NRR	301-504-3063
Ted Sullivan	NRC/NRR	301-504-3266
Phillip Rush	NRC/NRR	301-504-3743
Donald Naujock	NRC/NRR	301-504-2767
Jack Strosnider	NRC/NRR	301-504-1495
Len Wiens	NRC/NRR	301-504-1495
Boyd Brown	INEL	208-526-6048
Al Porter	INEL	208-526-6048

DEMONSTRATION HISTORY

1989 Demonstration

- Proved shear wave technique was inadequate for exams performed in 1985 for OD surface connected reflectors.
- Proved longitudinal wave technique is capable of detecting OD surface connected reflectors.

1993 Demonstration

- Proved the longitudinal wave technique is capable of detecting OD surface connected thermal fatigue flaws.
- Proved the technique used provided accurate flaw sizing information.

RELIEF REQUESTS

Individual B&WOG utilities have submitted relief requests to the NRC and have received SERs with the following compliance requirements:

OCONEE AND TMI-1

1. Examine entire volume of weld and heat affected zone.
2. Demonstrate capability to detect circumferential OD surface connected cracks, not machined notches.

CRYSTAL RIVER UNIT 3

Perform a demonstration to show the capability of the ultrasonic examination to detect and size surface flaws.

ARKANSAS NUCLEAR ONE

Demonstrate the ability to detect OD surface flaws from the ID.

ISI INTERVAL END DATES FOR RELIEF REQUESTS

Arkansas Nuclear One Unit 1	February 1995
Crystal River Unit 3	March 1997
Oconee Unit 1	July 1994 ^{1, 3}
Oconee Unit 2	December 1994 ^{1, 3}
Oconee Unit 3	December 1994 ^{1, 3}
TMI - 1	April 2001 ²

¹ Examination already completed

² Two of ten examinations completed

³ Relief granted to extend subject inspection
(Unit 1--10/95, Unit 2--1/96, Unit 3--5/95)

B&WOG MEETING OBJECTIVES

- Obtain NRC concurrence that we have successfully demonstrated compliance with NRC requests as stated in the individual utilities SERs.


B&WOG Conclusion & Summary

Mockup Demonstrations verify that OD flaws of interest can be detected and sized by using the demonstrated UT techniques.


FM evaluations support the conclusion that required safety margins are maintained between minimum detectable defects and maximum expected allowable flaw size for the design conditions.

Core Flood Nozzle Safend Welds


**Carbon Steel
Nozzle**




**Inconel
Butter** **Inconel
Weld**




**SS
Safend**



**SS
Weld**



**SS
Piping**



of Flaws 1

0

2

2

2

1

Flaw # 1

2,3

4,7


8,9


10


HORIZONTAL SECTION VIEW


Ø 36.00


VERTICAL SECTION VIEW












0007 0007 0007



UB SUPERIEURE OVEN 88.C

NP SUPERIEURE ↑ OBEI ꞤꞤꞤ ↑



↓ NP SUPERIEURE ↓ OBEI ꞤꞤꞤ ↓

DEMONSTRATION OBJECTIVES

1989

DEMONSTRATE THE FLAW DETECTION CAPABILITIES OF THE ULTRASONIC (UT) EXAMINATION TECHNIQUES FOR INSPECTION of PLANAR REFLECTORS OPPOSITE SURFACE FLAWS.

1993

DEMONSTRATE THE FLAW DETECTION and SIZING CAPABILITIES OF THE ULTRASONIC (UT) EXAMINATION TECHNIQUES FOR INSPECTION of REAL OPPOSITE SURFACE FLAWS.

B&WOG UT MOCKUPS

CORE FLOOD NOZZLE PIPING WELDS

1989 MOCKUP

CORE FLOOD SAFE-END TO NOZZLE WELD
SIMILAR (MATERIAL AND GEOMETRY) TO
ALL OPERATING B&W DESIGNED PLANTS

CONTAINS FOUR SETS OF PLANAR
REFLECTORS (EDM NOTCHES)
DISTRIBUTED THROUGHOUT THE VARIOUS
MATERIALS OF THE WELD JOINT (NOZZLE
BASE MATERIAL, INCONEL BUTTERING,
INCONEL WELD AND STAINLESS STEEL
SAFE-END)

NOTCH SETS CONSISTED OF FOUR
THROUGH-WALL SIZES: 2.3%, 5.6%, 11.3%
AND 16.9%

1993 MOCKUP

CONSISTS OF A CORE FLOOD PIPE TO
SAFE-END AND SAFE-END TO NOZZLE
WELDS SIMILAR (MATERIAL AND
GEOMETRY) TO ALL OPERATING B&W
DESIGNED PLANTS

B&WOG UT MOCKUPS continued

CORE FLOOD PIPE TO SAFE-END WELD

CONTAINED FOUR O.D. SURFACE, THERMAL FATIGUE CRACKS DISTRIBUTED THROUGHOUT THE WELD AND BASE MATERIAL

CRACK SIZES RANGE FROM 11% TO 71.8% THROUGH-WALL

CORE FLOOD SAFE-END TO NOZZLE WELD

CONTAINED FOUR O.D. SURFACE, THERMAL FATIGUE CRACKS DISTRIBUTED THROUGHOUT THE VARIOUS MATERIALS OF THE WELD JOINT

CRACK SIZES RANGE FROM 12.6% TO 62.9% THROUGH-WALL

B&WOG UT MOCKUPS continued

REACTOR COOLANT NOZZLE TO PIPE WELD

1993 MOCKUP

CONSISTS OF A CLAD FERRITIC DESIGN
SIMILAR TO ALL OPERATING B&W OPERATING
PLANTS

CONTAINS FIVE THERMAL FATIGUE CRACKS
RANGING FROM 7.6% TO 78.7% THROUGH-WALL

FLAWS DISTRIBUTED IN BOTH THE WELD AND
BASE MATERIALS

DEMONSTRATION RESULTS

1989

SUCCESSFUL IN DEMONSTRATING THE DETECTABILITY OF THE UT EXAMINATION TECHNIQUE FOR SMALL (LENGTH AND THROUGH-WALL) PLANAR REFLECTORS (EDM NOTCHES) LOCATED IN THE VARIOUS MATERIALS OF THE MOCKUP


DETECTED REFLECTORS AS SMALL AS 2.3% THROUGH-WALL IN ALL THE MATERIALS OF THE WELD JOINT (NOZZLE BASE MATERIAL, INCONEL BUTTERING, INCONEL WELD AND STAINLESS STEEL SAFE-END)

1993

SUCCESSFULLY DEMONSTRATED the 100% DETECTION OF ALL THERMAL FATIGUE FLAWS IMPLANTED IN BOTH MOCKUPS (CORE FLOOD AND REACTOR COOLANT)

ACCURATELY DEPTH SIZED ALL THERMAL FATIGUE FLAWS WITHIN A RMS ERROR OF 0.076 INCHES

INSERVICE INSPECTION



FLAW EVALUATION

- o **FLAW TYPE -- EXTERNAL CIRC. FLAW ON A CYLINDER**

- o **LOAD/STRESSES**
 - **DESIGN BASIS LOADS FROM STRESS REPORT**
HEATUP AND COOLDOWN STRESSES

 - **INSPECTION INTERVAL 10 YEARS**
90 CYCLES/ 10 YEARS

- o **MATERIAL - STAINLESS STEEL**
da/dN from Appendix C of Section XI

2.1 Weld Geometry

The geometry of the two weld locations is given in Reference 5. The weld geometries are cylindrical. The pertinent dimensions for each of the weld locations are given below.

- a) For the Nozzle to Safe-end Weld
 - Outside radius of weld, $R_o = 7.8125$ inches
 - Inside radius of weld, $R_i = 6.125$ inches
 - Thickness of weld, $t = 1.6875$ inches

- b) For the Safe-end to Pipe Weld
 - Outside radius of weld, $R_o = 7.125$ inches
 - Inside radius of weld, $R_i = 5.75$ inches
 - Thickness of weld, $t = 1.375$ inches






Figure 1. Full Circumference Part-throughwall Flaw subjected to Axial Loading





**FLAW EVALUATION
OF
CORE FLOOD NOZZLE WELDS**

I. NOZZLE TO SAFE-END WELD


MAX. ALLOWABLE FLAW $a/t = 0.45$

2. SAFE-END TO PIPE WELD

MAX. ALLOWABLE FLAW $a/t = 0.56$

Core Flood Nozzle to Safe-End				
Flaw No.	a/l	a/t†	IWB-3514 Max. a/t†	t (inches)
1	.22	12.6	10.9	1.80
2	.25	25.2	11.0	1.80
3	.28	39.5	11.1	1.80
4	.45	62.9	11.8	1.80
Core Flood Safe-End to Pipe				
7	.17	22.0	11.1	1.10
8	.25	38.6	11.5	1.10
9	.29	71.8	11.6	1.10
10	.16	11.0	11.1	1.10
Reactor Coolant Outlet Nozzle to Pipe				
1	.25	7.6	11.7	3.0
2	.50	78.7	13.2	3.0
3	.27	16.3	12.3	3.0
4	.45	37.1	13.2	3.0
5	.28	10.9	12.6	3.0

ALLOWABLE FLAW SIZE



Toledo Edison Company

Davis-Besse Nuclear Power Station
Unit No. 1

cc:

Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Mr. William T. O'Connor, Jr.
Manager - Regulatory Affairs
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, Ohio 43449

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Regulations
P. O. Box 825
Columbus, Ohio 43216

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Ohio Environmental Protection Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P. O. Box 1049
Columbus, Ohio 43266-0149

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Mr. James R. Williams
State Liaison to the NRC
Adjutant General's Department
Office of Emergency Management
Agency
2825 West Granville Road
Columbus, Ohio 43235-2712

Resident Inspector
U. S. Nuclear Regulatory Commission
5503 N. State Route 2
Oak Harbor, Ohio 43449

Mr. Donald C. Shelton
Vice President, Nuclear-Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
300 Madison Avenue
Toledo, Ohio 43652

Mr. John K. Wood, Plant Manager
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, Ohio 43449

Robert E. Owen, Chief
Bureau of Radiological Health
Services
Ohio Department of Health
Post Office Box 118
Columbus, Ohio 43266-0118

Entergy Operations, Inc.

Arkansas Nuclear One, Unit 1

cc:

Mr. Harry W. Keiser, Executive Vice
President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39286

Mr. Nicholas S. Reynolds
Winston & Strawn
1400 L Street, N.W.
Washington, D.C. 20005-3502

Admiral Kinnaird R. McKee, USN (Ret)
214 South Morris Street
Oxford, Maryland 21654

Mr. Robert B. Borsum
Licensing Representative
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, Arkansas 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Honorable C. Doug Lunningham
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Radiation Control
and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72205-3867

Duke Power Company

Oconee Nuclear Station

cc:

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Mr. Steve Benesole
Compliance
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Mr. Marvin Sinkule, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Mr. J. W. Hampton
Vice President, Oconee Site
Duke Power Company
P. O. Box 1439
Seneca, South Carolina 29679

Dayne H. Brown, Director
Division of Radiation Protection
North Carolina Department of
Environmental Health and
Natural Resources
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Florida Power Corporation

cc:

Mr. Gerald A. Williams
Corporate Counsel
Florida Power Corporation
MAC-A5A
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Bruce J. Hickie, Director
Nuclear Plant Operations (NA2C)
Florida Power Corporation
Crystal River Energy Complex
15760 W. Power Line Street
Crystal River, Florida 34428-6708

Mr. Robert B. Borsum
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Bill Passetti
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. Percy M. Beard, Jr.
Sr. Vice President
Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing (NA2I)
Crystal River Energy Complex
15760 W Power Line Street
Crystal River, Florida 34428-6708

Crystal River Unit No.3
Generating Plant

Mr. Joe Myers, Director
Div. of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

Chairman
Board of County Commissioners
Citrus County
110 North Apopka Avenue
Inverness, Florida 32650

Mr. Rolf C. Widell, Director
Nuclear Operations Site Support (NA2I)
Florida Power Corporation
Crystal River Energy Complex
15760 W Power Line Street
Crystal River, Florida 34428-6708

Senior Resident Inspector
Crystal River Unit 3
U.S. Nuclear Regulatory
Commission
6745 N. Tallahassee Road
Crystal River, Florida 34428

Mr. Gary Boldt
Vice President - Nuclear
Production (SA2C)
Florida Power Corporation
Crystal River Energy Complex
15760 W Power Line Street
Crystal River, Florida 34428-6708

Three Mile Island Nuclear Station,
Unit No. 1

cc:

Michael Ross
O&M Director, TMI-1
GPU Nuclear Corporation
Post Office Box 480
Middletown, Pennsylvania 17057

John C. Fornicola
Director, Licensing and
Regulatory Affairs
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Jack S. Wetmore
TMI Licensing Manager
GPU Nuclear Corporation
Post Office Box 480
Middletown, Pennsylvania 17057

Ernest L. Blake, Jr., Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, Pennsylvania 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, Pennsylvania 17057

Michele G. Evans
Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
Post Office Box 311
Middletown, Pennsylvania 17057

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Robert B. Borsum
B&W Nuclear Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

William Dornsife, Acting Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Mr. T. Gary Broughton, Vice President
and Director - TMI-1
GPU Nuclear Corporation
Post Office Box 480
Middletown, Pennsylvania 17057