

50-269/270/
287



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 14, 1994

Licensee: Duke Power Company

Facility: Oconee Nuclear Station, Units 1, 2, and 3

SUBJECT: SUMMARY OF OCTOBER 12, 1994, MEETING WITH DUKE POWER COMPANY ON
KEOWEE PROBABILISTIC RISK ASSESSMENT PROJECT

On October 12, 1994, NRC staff members met with representatives of Duke Power Company (DPC) to discuss the status of the Probabilistic Risk Assessment (PRA) being performed for the Keowee hydrostation. A list of meeting attendees is included as Enclosure 1. Copies of licensee handouts are included as Enclosure 2.

The licensee's presentation opened with an overview of the project, including the purpose and objective of the analysis, a description of the project scope and level of detail, the project team organization, and the project schedule. In response to a staff question, the licensee explained that the analysis did not include external events, and that the external events would be covered under the IPE for External Events. The presentation also covered a brief description of the PRA process and the identification of data for the analysis. As a follow-up to a question from the previous meeting on the status of this project, the licensee stated that the decision had been made to integrate the results of this PRA study into the IPE. A number of other questions concerning clarification of the PRA process being used by DPC were also discussed. The licensee presented the preliminary results of the Keowee reliability study. The licensee then presented preliminary results for AC power reliability and the effect on core melt frequency from integrating the preliminary PRA results into the IPE. The Keowee reliability results were analyzed for the delivery of power to the startup transformer for the overhead path or transformer CT-4 for the underground path. The licensee's preliminary results indicated that the probability of core damage resulting from a loss of off-site power was comparable to the IPE results for this event.

170021

9411170291 941114
PDR ADOCK 05000269
P PDR

NRC FILE CENTER COPY

memo 4

DF01

November 14, 1994

At the conclusion of the meeting, the NRC staff requested that the licensee provide the most recent fault tree base case models for both the systems and the integrated model. In addition, cut sets were requested to show results of the base case and sensitivity studies. The licensee was requested to perform an analysis and provide the cut sets for one Keowee unit in maintenance and the other unit paralleled to the electrical off-site grid. The licensee agreed to each of these requests.

/s/
Leonard A. Wiens, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

Docket Nos. 50-269, 50-270,
and 50-287

Enclosures:

1. List of Meeting Attendees
2. Licensee Handouts

cc w/enclosures:
See next page

DISTRIBUTION

Docket File

PUBLIC

PDII-3 R/F

W. Russell/F. Miraglia, 0-12 G18

R. Zimmerman, 0-12 G18

S. Varga

J. Zwolinski

D. Nguyen, 0-7 E4

F. Burrows, 0-7 E4

M. Virgilio, 0-8 E2

J. Shackelford, RII

OGC, 0-15 B18

E. Jordan, T-4 D18

ACRS (4), TWF

G. Tracy, EDO, 0-17 G21

B. Boger, RII

M. Sinkule, RII

A. Thadani, 0-12 G18

V. Beaston, 0-7 E4

W. Swenson, 0-10 E4

S. Rosenberg, 0-10 E4

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD23:DRPE	E	PM:PD23:DRPE	E	D:PD23:DRPE	3			
NAME	CNorsworthy <i>en</i>		LWiens <i>en</i>		HBerkow <i>en</i>				
DATE	11/10/94		11/14/94		11/14/94			1	/94

DOCUMENT NAME: G:\OCONEE\PRAMTGSU.OCT

November 14, 1994

At the conclusion of the meeting, the NRC staff requested that the licensee provide the most recent fault tree base case models for both the systems and the integrated model. In addition, cut sets were requested to show results of the base case and sensitivity studies. The licensee was requested to perform an analysis and provide the cut sets for one Keowee unit in maintenance and the other unit paralleled to the electrical off-site grid. The licensee agreed to each of these requests.



Leonard A. Wiens, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

Docket Nos. 50-269, 50-270,
and 50-287

Enclosures:

1. List of Meeting Attendees
2. Licensee Handouts

cc w/enclosures:

See next page

Duke Power Company

cc:

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Oconee Nuclear Station

Mr. Ed Burchfield
Compliance
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Dayne H. Brown, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health and
Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. J. W. Hampton
Vice President, Oconee Site
Duke Power Company
P. O. Box 1439
Seneca, South Carolina 29679

MEETING ATTENDEES

KEOWEE PROBABILISTIC SAFETY ASSESSMENT STATUS MEETING

October 12, 1994

NAME	ORGANIZATION
Len Wiens	NRC/NRR/PDII-3
Duncan Brewer	Duke Power/PRA
Mike Barrett	Duke Power/PRA
P. M. Abraham	Duke Power/PRA
Duc Nguyen	EELB/NRR
Homayoon Dezfulz	SCIENTECH INC
V. Beaston	NRR/DE/EELB
Ken Canady	Duke Power/Nuclear Eng.
Fred Burrows	EELB/NRR
Ed Burchfield	Duke/ONS/Regulatory Compliance
Clay A. Little	Duke/ONS/Elec. Eng.
Warren Swenson	NRR/SPSB
Marty Virgilio	NRC/DSSA
Stacey Rosenberg	NRR/DSSA/SPSB
Frank Quinn	SCIENTECH Inc.
Herb Berkow	NRC/NRR/PDII-3
Jeff Shackelford	NRC/RII/DRS/OPS
Reed Severance	Duke Power/ONS/Mech. Sys. Eng.
Jeff Rowell	Duke Power/ONS/Elect. Power Sys.
Michael Bailey	Duke Power/ONS/Regulatory Compliance

Keowee PRA

NRC-Duke Meeting

October 12, 1994

Agenda

- 8:30 Introduction (P. M. Abraham)**
- 8:45 Overview of KPRA (Duncan Brewer)**
- 9:15 KPRA Analysis And Results
(Mike Barrett)**
- 10:30 Break**
- 10:50 AC Power Reliability Results
(Duncan Brewer)**
- 11:20 AC Power Core Melt Frequency
Results (Duncan Brewer)**
- 12:00 Break**
- 1:00 Questions and Answers**

Keowee PRA

Overview of Keowee PRA Process

By Duncan Brewer

Outline

- **Purpose and Objects of the Study**
- **Project Plan**
- **Project Team**
- **Identification of Data**
 - **Component Failure Data**
 - **Common Cause Data**
 - **Human Reliability Data**

Objectives of the Study

- . To Develop An Analytical Model Of The Keowee Hydro Station
- . *To Integrate the Keowee Model into the Oconee PRA Models for AC Power and Core Damage Frequency*
- . To Obtain An Estimate Of The Reliability Of Keowee As An Emergency Power Source,
- . *To Determine Keowee's Importance to AC Power Reliability,*
- . *To Determine Keowee's Importance to Core Damage Frequency*

Objectives of the Study

- To Compare the Estimated Reliability to the Observed Reliability During Normal Operation, Emergency Tests and Functional Tests
- The Insights Gained From This Analysis Will Be Used To Complement Efforts Which Are Currently Underway To Address Keowee Reliability Concerns

Project Scope

- Utilized PRA Methods Such As Fault Trees, Reliability Data, Success Criteria, And Modeling Of Appropriate Human Actions.
- The Required Mission Of The Keowee Hydro Station was To Start And Run To Provide Emergency Power To Oconee For All Probabilistically Significant Scenarios Resulting From Internal Initiating Events.

Project Scope



- The Model Includes All Important Components At A Level Appropriate For Gathering Statistically Significant Data.
- Support Systems Important To The Operation Of Keowee Were Also Modeled.

Project Team Organization

- Team Included System Analysts, Data Analysts, a Human Reliability Analyst, a Common Cause Analyst, and Plant Support Personnel
- 10 Members from Duke, One Outside Consultant Used for Independent Review

Task List and Schedule

- Plant Familiarization 2/94
- Develop System Models 6/94
- Develop Reliability Data 6/94
- Solve the Fault Tree Models 7/94
- Analysis of Results 9/94
- Documentation 12/94
- Peer Review (Throughout Project)
- Actions 6/95



SAAS Keowee PRA Project

Drw. KPRA (10/03/94) Rev. 6

Identification of Data

Component Failure Data


- Plant Specific Data was Collected for all Components in the Model
- Failure Data Was Collected by Review of Operator Logs and Keowee Work Requests
- Demands and Run Hours for the Period of Record Were Estimated by the System Analysts
- Generic Data was Developed from Multiple Sources of Generic Data


Identification of Data

Component Failure Data

- The Data Base Used For the Solution and Sensitivity Studies was a Bayesian Updated Combination of the Generic and Plant Specific Data
- We Retained the Ability to Calculate the Results with Generic Data, Plant Specific Data, or the Combined Data

Keowee PRA Plant Specific Data Collection Process





Keowee Reliability Assessment Type Code Development Flow Chart

Identification of Data

Common Cause Data

- Objective - Qualitatively And Quantitatively Evaluate Potential Common Cause Failure Modes Of Keowee
- Reviewed Operating Experience and System Models to Determine Appropriate Events
- Events Included at Both the System and Component Level
- Used EPRI CCDAT Software

Keowee KRA CCF Assessment Process




Figure X-1

Identification of Data

Human Reliability Data


- Reviewed Operating Experience
- Reviewed System Models
- Determined Appropriate Human Error Events
- Modeled Pre-initiator Errors , Post Initiator Errors and Recovery Errors
- Also, Performed a Qualitative Review for Errors of Commission

Identification of Data

Human Reliability Data

- Used NUREG/CR-1278 (THERP) Method to Quantify Pre-initiator Errors
- Used EPRI TR-100259 "Decision Tree" Method to Quantify Post Initiator Errors


Keowee PRA Human Reliability Analysis



Keowee PRA

Reliability Analysis and Results

Mike Barrett



Keowee Generator System Schematic

Keowee Overview

Keowee Systems

- . Excitation System**
- . Air Circuit Breakers**
- . Auxiliary AC Power**
- . Auxiliary DC Power**
- . Generator**
- . Keowee Start-up Controls**

Keowee Overview (cont'd)

Keowee Systems (cont'd)

- . Turbine**
- . Governor**
- . High Pressure Oil System**
- . Governor Air System**
- . Governor Oil System**
- . Guide Bearing Oil System**
- . Turbine Sump System**

Keowee Overview (cont'd)

Switchyard and Oconee Components and Systems

- . Underground Cable**
- . Transformer CT4**
- . Switchyard DC Power System**
- . External Grid Trouble Protection System**
- . Switchyard Power Circuit Breakers**
- . Transformer CT3**

Modeling

Objectives

- **Address all potential modes of operation of the Keowee units**
- **Include all components/systems necessary for the emergency operation of the Keowee units**
- **Include in the models the important failure modes that have been experienced**

Modeling (cont'd)

Scope

- **Keowee components important for Keowee to provide emergency power to Oconee**
- **The underground path up to and including CT4**
- **The overhead path up to and including CT3**
- **Switchyard isolation logic**

Modeling (cont'd)

14 Individual Fault Trees


- . High Level Logic Model**
- . 13 System/Component Trees**


Modeling (cont'd)


High Level Logic Model




- . Combines the individual sytem/component failures into an overall Keowee power supply failure**
- . Factors in the various operating configurations of the Keowee units**
- . Provides intermediate gate results for determining the reliability of individual units/paths**

Keowee Fault Tree Overview









Modeling (cont'd)


System/Component Fault Tress


- . Air Circuit Breakers**
- . Guide Bearing Oil**
- . Switchyard DC Power**
- . Generator Excitation**
- . Cooling Water**
- . Generator**
- . External Grid Trouble Protection System**

Modeling (cont'd)

System/Component Fault Tress (cont'd)

- . Governor Oil and Air**
- . Turbine Sump**
- . Power Paths**
- . Governor and Turbine**
- . Auxiliary AC and DC Power**
- . Keowee Start**





Results

Base case analysis considers:


- . the current operating mode, restricted to one unit generating to the grid,**
- . operator recovery from certain unit failures.**

**Probability that Keowee fails to supply power to
Oconee 7.05E-03**

Results (cont'd)


1)	Both Keowee Units Unavailable Due To Common Maintenance	5.23E-03	5.23E-03
2)	A Single Keowee Unit Is Unavailable Due To Maintenance	1-3.80E-02	1.55E-04
	Common Cause Failure Of Both Unit's WL Filters Due To Intake Debris	2.55E-03	
	Failure To Recover Flow Through Clogged Main Strainer	6.30E-02	
3)	A Single Keowee Unit Is Unavailable Due To Maintenance	1-3.80E-02	1.54E-04
	Keowee Unit 1 Only Is Supplying The Grid	1-0.0	
	Keowee Unit 2 Only Is Supplying The Grid	1-2.44E-02	
	Keowee Unit 1 and 2 Are Supplying The Grid	1-0.0	
	Units 1 & 2 Excit Fail Due To Common Cause Failure Of The Breaker	1.64E-04	1.64E-04

**Relative Importance of the Top Ten Basic Events for
"Oconee Emergency Power From Keowee Fails"**



- Both Keowee Units Unavailable Due To Common Maintenance
- A Single Keowee Unit Is Unavailable Due To Maintenance
- ▨ Common Cause Failure Of Both Unit's WL Filters Due To Intake Debris
- Failure To Recover Flow Through Clogged Main Strainer
- Units 1 & 2 Excit Fail Due To Common Cause Failure Of The Breakers
- KHU-1 Voltage Adjust Failure Drives Generator Output Too High/Low
- ▨ Keowee Unit 1 Generator Fault While the Unit Runs
- ▨ Failure To Recover Keowee Auxiliary Power Breakers
- ▨ Common Cause Failure Of All Keowee Auxiliary Power Breakers
- ▨ Air Circuit Breaker 7 Fails To Close Due To Mechanical Failure
- ▨ Remainder

Relative Importance of the Top Ten Basic Events for "Oconee Emergency Power From Keowee Fails" Excluding Common Cause, Maintenance and Recoveries



- KHU-1 Voltage Adjust Failure Drives Generator Output Too High/Low
- Keowee Unit 1 Generator Fault While the Unit Runs
- Air Circuit Breaker 7 Fails To Close Due To Mechanical Failure
- KHU-1 Base Adjust Fails To Maintain Generator Output Within Acceptable Range
- Keowee Unit 1 Gov. Fails to Position Wicket Gates With Unit Running
- Keowee Unit 1 Turbine Fails With the Unit Running
- Keowee Battery No. 1 Fails During Discharge
- KHU-2 Voltage Adjust Failure Drives Generator Output Too High/Low
- Keowee Unit 2 Generator Fault While the Unit Runs
- ACB Air Supply Fails Causing Low Pressure In All ACB Accumulators
- Remainder

Results (cont'd)

Overhead and Underground Supply Failure Probabilities

· Underground Power Supply	2.8E-02
· Overhead Power Supply	6.6E-02

Note: Common cause failures and double maintenance are not included in these results.

Results (cont'd)

Unit & Path Failure Probabilities

. Overhead path	³ 9.4E-02/
. Underground path	1.1E-03
. Operational unit (KU2)	1.9E-02
. Standby unit (KU1)	2.5E-02

Results (cont'd)



Gate Name	Result - Generic Data with no credit for recoveries	Result - Bayesian Updated Data with no credit for recoveries
KEOWTOP	1.3E-02	1.0E-02
KU1RUN	3.0E-02	1.6E-02
KU1STARTF	1.6E-02	9.2E-03
KU2RUN	1.8E-02	1.2E-02
KU2STARTF	1.1E-02	7.8E-03

Results (cont'd)

Sensitivity Studies

	<u>1 Unit</u> <u>Operational</u>	<u>2 Units</u> <u>Operational</u>
<u>Recovered</u>	7.05E-03	6.88E-03
<u>Unrecovered</u>	1.01E-02	9.75E-03

Experience vs. Model Prediction



DATA SUMMARY

	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994 (7/94)
Yearly Failure Rate	0.0043	0.0	0.0051	0.0	0.0046	0.0015	0.0036	0.0134	0.0068	0.0047	0.0051
3-Yr Average (85-87)			0.0017								
3-Yr Average (88-90)						0.0033					
3-Yr Average (91-93)								0.0084			
Reliability Model Prediction (Grid Cycled Unit)						0.0077					
Reliability Model Prediction (Standby Unit)						0.0092					
Overall Experience Average						0.0045					

KEOWEE 24 Hr. RUN FAILURE PROBABILITIES

Reliability Model Prediction (Standby Unit)	0.016
Reliability Model Prediction (Grid Cycled Unit)	0.012
Overall Experience (10 Year Average)	0.012

Modifications

Part AL1

**Deal with the single failure concern over the
differential relaying zone overlap (ACB-1)**

**Automatically transfer the available overhead unit
to the underground path**

Modifications (cont'd)

Part BL1

**Prevent connecting Keowee To Oconee when the
Keowee unit is generating at too high a
frequency**

- . overspeed on load rejection**
- . governor failure**

**Open and reclose the underground breaker if that
unit is generating to the grid**

Modifications (cont'd)

BL1 (cont'd)

ACB-3 fail to close probability $\sim 8.7\text{E-}03$

**Applicable only when unit is generating to the grid
 $\sim 6\%$ of the time**

Failure contribution $\sim 5.2\text{E-}04$

Modifications (cont'd)

BL1 (cont'd)

Prevent closure of ACBs 1 through 4 if frequency is too high

Prevent closure of breakers SK1 and SK2 if frequency is too high, most significant new failure mode is on the order of $7.0E-06$

Trip ACBs 1 through 4 if governor failure is detected

Keowee PRA

AC Power Reliability Results

By Duncan Brewer

Outline

- . Objectives
- . Oconee AC Power System Overview
- . Method
- . Fault Tree
- . Application of Recoveries
- . Results


Objective

- To Determine the Reliability of the Oconee AC Power System
- To Allow Importance Ranking of Keowee Systems and Components Relative to the Complete Oconee Power System
- To Account for the Impact of Initiating Events on the Overhead Path

Oconee AC Power System Overview


- . One Keowee Unit Aligned to Overhead Path
- . One Keowee Unit Aligned to the Underground Path
- . The 100 kV Path from Lee Combustion Turbine Through Central Switchyard and CT5 Transformer
- . Any One Can Power Both Main Feeder Busses


OCONEE AC POWER SYSTEM





Method


- Started with Oconee IPE Model for AC Power System
- Linked with DC Power System from Oconee IPE
- Cut Out Old Keowee Model
- Linked in the New Keowee Model
- Combined the Keowee and Oconee Data Bases
- Solved the New Tree
- Applied Keowee and Oconee Recoveries






















Recoveries

- Applied Keowee Recoveries - Only One Allowed per Cut Set
- Applied Oconee Recoveries
- Did Not Apply Offsite Power Recovery


Results

- Three Loss of Offsite Power Initiating Events are Modeled
 - Loss of the Grid (T5FEEDF) = $2.73\text{E-}2$ / YR
 - Loss of the Switchyard (T5SUBF) = $4.86\text{E-}2$ / YR
 - Weather Related LOOP (T5WEATH) = $1.44\text{E-}2$ / YR
- Frequency of Loss of all AC Power to the Main Feeder Buses = $5.8\text{E-}5$ / YR

**Initiating Event Contribution to Loss of Power to Oconee
Main Feeder Busses
(Frequency=5.8E-5/yr)**



**Basic Event Contribution to Loss of Power to Oconee Main
Feeder Busses
(Frequency=5.8E-5/yr)**



Keowee PRA

AC Power - Core Melt Frequency Results

By Duncan Brewer

Outline

- Objectives
- Overview
- Method
- Fault Tree
- Application of Recoveries
- Results

Objectives

- To Determine the Oconee Core Damage Frequency for Sequences Involving Keowee
- To Allow Importance Ranking of Keowee Systems and Components Relative to the Contribution to Core Damage
- To Compare to the "Black Box" Representation of Keowee in the Oconee IPE Submittal

ONS Core Damage Model Overview

Core Damage Sequences Involving Keowee that Result from a LOOP Initiating Event Take Two Forms:

- RCP Seal LOCA without Primary System Makeup Capability
- Failure of SSHR without the Ability to Perform Feed and Bleed Cooling

ONS Core Damage Model Overview


The "RCP Seal LOCA without Primary System Makeup Capability" Sequence Requires the Following Failures:

- All AC Power (HPI Cooling to the RCP Seals)
- SSF Fails to Provide RCP Seal Cooling

ONS Core Damage Model Overview

The "Failure of SSHR without the Ability to Perform Feed and Bleed Cooling" Sequence Requires the Following Failures:

- All AC Power (Fails the Motor Driven Em. Feedwater Pumps and HPI Cooling)
- Failure of the Turbine Driven Em. Feedwater Pump
- Failure of the SSF Aux. Service Water Pump



LEGEND			
	SHUTOFF VALVE		NORMALLY OPEN
	NORMALLY CLOSED		NORMALLY THROTTLED
	FLOW CONTROL VALVE		CHECK VALVE (ALL TYPES)
	RELIEF VALVE		F-FLOW
			L-LEVEL
			P-PRESSURE
			T-TEMPERATURE
			E-ELECTRIC
			H-HYDRAULIC
			P-PISTON
			S-SOLENOID
			PNEUMATIC
			ESI-RECEIVES ENGINEERED SAFEGUARD SIGNAL

THIS DRAWING IS A SUMMARY FLOW DIAGRAM FOR COMPLETE SYSTEM DESIGN INFORMATION REFER TO FLOW DIAGRAMS LISTED BELOW:


OSFD-188A-1.1	REACTOR COOLANT SYSTEM
OSFD-188A-1.2	PRESSURIZER
OSFD-188A-1.3	HP1 - LETDOWN
OSFD-188A-1.4	INJECTION
OSFD-188A-1.5	DECAY HEAT LINE
OSFD-188A-1.6	PUMPS AUX SPRAY
OSFD-188A-1.7	CORE FLOOD TANKS


REVISIONS									
NO.	REVISIONS	DATE	BY	CHKD	DATE	APPROV	DATE	INSTRUC	DATE
1	RELEASED FOR INFORMATION	10/1/77	10/1/77	10/1/77	10/1/77	10/1/77	10/1/77	10/1/77	10/1/77
2									
3									
4									
5									
6									
7									
8									
9									
10									

UNIT 1 ONLY
ALL VALVES "RC" EXCEPT AS NOTED
DUKE POWER COMPANY
CONNEE NUCLEAR STATION
SUMMARY FLOW DIAGRAM OF
REACTOR COOLANT SYSTEM
(UNIT 1)

Method

- Started with Oconee IPE Model for AC Power System
- Linked with the ONS DC Power System Model, the ONS Emergency Feedwater Model, and SSF Model from Oconee IPE
- Cut Out Old Keowee Model
- Linked in the New Keowee Model
- Combined the Keowee and Oconee Data Bases
- Solved the New Tree
- Applied Keowee and Oconee Recoveries





Recoveries

- Applied Keowee Recoveries - Only One Allowed per Cut Set
- Applied Oconee Recoveries
- Applied Offsite Power Recoveries

Results

- **Frequency of Core Damage Resulting From Loss of Offsite Power = $1.01\text{E-}6$ / YR**
- **This is Comparable to the Oconee IPE Results of $3.2\text{E-}6$ / YR (Higher Maintenance and Common Cause Values in IPE Study)**

**Basic Event Contribution to
Loss of Power Core Damage Sequences
(Frequency=1.01E-6/yr)**

