

INSERVICE INSPECTION REPORT

**UNIT 1 OCONEE 1995 REFUELING
OUTAGE 16**

Location: Hwy 130/183, Seneca, South Carolina 29679

NRC Docket No. 50-269

Commercial Service Date: July 15, 1973

Owner: Duke Power Company
526 South Church St.
Charlotte, N. C. 28201-1006

Revision 0

Prepared By: RTS Rouse Date 2/12/96
Reviewed By: LC Keith Date 2-12-96
Approved By: J. Barbours Date 2/20/96

Copy No. 2 Assigned To NRC Document Control

Controlled X Uncontrolled _____

9603110552 960307
PDR ADOCK 05000269
Q PDR

FORM NIS-1 (back)

- 8. Examination Dates 7/13/94 to 12/10/95 9. Inspection Interval from 7/15/94 to 7/15/2003
- 10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See attached report.
- 11. Abstract of Conditions Noted. See attached report.
- 12. Abstract of Corrective Measures Recommended and Taken. See attached report.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date 2/21 19 96 Signed Duke Power Co. By J. Barlow
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of N.C. and employed by *The HSBI&I Co. of Hartford, Ct. have inspected the components described in this Owners Data Report during the period 7-13-94 to 12-10-95 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 2-26-96 19 96

JMB Chapman Commissions NC914
Inspector's Signature National Board, State, Province and No.

*The Hartford Steam Boiler Inspection & Insurance Co.
200 Ashford Center North
Suite 300
Atlanta Ga., 30338

CONTROLLED DISTRIBUTION

Copy No.

Assigned To

Original

Duke Power Company Quality Assurance
Technical Services

1

Oconee Component Engineering

2

NRC Document Control

UNCONTROLLED DISTRIBUTION

3

Hartford Steam Boiler Inspection and
Insurance Company (AIA)

°/° C. A. Ireland

4

L. A. Wiens
Office of NRR
USNRC
Washington, DC 20555

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Revision</u>
1.	General Information	0
2.	Summary of Inservice Inspections for Outage 16	0
3.	Third Ten Year Inspection Status	0
4.	Final Inservice Inspection Plan for Outage 16	0
5.	Results of Inspections Performed During Outage 16	0
6.	Reportable Indications	0
7.	Personnel, Equipment, and Material Certifications	0
8.	Corrective Action	0
9.	Reference Documents	0
10.	Class 1 and 2 Repairs and Replacements	0

1.0 General Information

This report describes the Inservice Inspection of Duke Power Company's Oconee Nuclear Station, Unit 1, during the 1995 Refueling Outage (also referred to as Outage 16). Outage 16 is in the first inspection period of the third ten year interval.

Included in this report are the final Inservice Inspection Plan, the inspection results for each item, a summary for each category of examination and corrective action taken when unacceptable conditions were found. In addition, there is a section included for repairs and replacements required since July 13, 1994.

1.1 Identification Numbers

<u>Item</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Reactor Vessel	Babcock & Wilcox	620-0003-51-52	N/A	N-101
Steam Generator A	Babcock & Wilcox	620-0003-55-1	N/A	N-103
Steam Generator B	Babcock & Wilcox	620-0003-55-2	N/A	N-104
Pressurizer	Babcock & Wilcox	620-0003-59	N/A	N-102

1.2 Authorized Nuclear Inservice Inspector(s)

Name: M. B. Chapman

Employer: The Hartford Steam Boiler Inspection & Insurance Company

Business Address: The Hartford Steam Boiler Inspection & Insurance Co.
200 Ashford Center North
Suite 300
Atlanta, GA 30338

2.0 Summary of Inservice Inspection for Outage 16

The information shown below provides an abstract of ASME Section XI Class 1, Class 2, and Augmented Items scheduled and examined during Outage 16 at Oconee Nuclear Station Unit 1.

2.1 Class 1 Inspection

Examination Category B-A Pressure Retaining Welds in Reactor Vessel

Item Number	Description	Total Scheduled During Outage	Total Examined During Outage
B01.010	Shell Welds		
B01.011	Circumferential	0	0
B01.012	Longitudinal	0	0
B01.020	Head Welds		
B01.021	Circumferential	0	0
B01.022	Meridional Welds	NA	NA
B01.030	Shell to Flange Welds	1	1
B01.040	Head to Flange Welds	0	0
B01.050	Repair Welds		
B01.051	Beltline Region	N/A	N/A
TOTALS		1	1

Examination Category B-B Pressure Retaining Welds in Vessels Other than Reactor Vessels

Item Number	Description	Total Scheduled During Outage	Total Examined During Outage
	Pressurizer		
B02.010	Shell to Head Welds		
B02.011	Circumferential	2	2
B02.012	Longitudinal	1	1

Examination Category B-B (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B02.020	Head Welds		
B02.021	Circumferential	NA	NA
B02.022	Meridional Welds	NA	NA
	Steam Generator		
B02.030	Head Welds		
B02.031	Circumferential	N/A	N/A
B02.032	Meridional	N/A	N/A
B02.040	Tubesheet to Head Weld	0	0
	Heat Exchangers (Primary Side)		
B02.050	Head Welds		
B02.051	Circumferential	0	0
B02.052	Meridional	NA	NA
	Shell Welds		
B02.060	Tubesheet to Head Welds	0	0
B02.070	Longitudinal Welds	NA	NA
B02.080	Tubesheet-To-Shell Welds	NA	NA
TOTALS		3	3

Examination Category B-D Full Penetration Welds of Nozzles in Vessels Inspection Program B

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B03.090	Nozzle-To-Vessel Welds	2	Ref. RFR ONS-006
B03.100	Nozzle Inside Radius Section	2	Ref. RFR ONS-006
	Pressurizer		
B03.110	Nozzle-To-Vessel Welds	3	3
B03.120	Nozzle Inside Radius Section	3	3

Examination Category B-D (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Steam Generators (Primary Side)		
B03.130	Nozzle-To-Vessel Welds	2	2
B03.140	Nozzle Inside Radius Section	2	2
	Heat Exchangers (Primary Side)		
B03.150	Nozzle-To-Vessel Welds	0	0
B03.160	Nozzle Inside Radius Section	0	0
TOTALS		14	10

Examination Category B-E Pressure Retaining Partial Penetration Welds in Vessels

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Partial Penetration Welds		
B04.010			
B04.011	Vessel Nozzles	NA	NA
B04.012	Control Rod Drive Nozzles	0	0
B04.013	Instrumentation Nozzles	0	0
	Pressurizer		
B04.020	Heater Penetration Welds	NA	NA
TOTALS		0	0

Examination Category B-F

Pressure Retaining Dissimilar Metal Welds

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	<i>Reactor Vessel</i>		
B05.010	Nominal Pipe Size 4" or Larger Nozzle to Safe End Butt Welds	0	0
B05.020	Nominal Pipe Size Less Than 4" Nozzle to Safe End Butt Weld	NA	NA
B05.030	Nozzle-To-Safe End Socket Welds	NA	NA
	<i>Pressurizer</i>		
B05.040	Nominal Pipe Size 4" or Larger Nozzle to Safe End Butt Welds	0	0
B05.050	Nominal Pipe Size Less Than 4" Nozzle to Safe End Butt Weld	2	2
B05.060	Nozzle-To-Safe End Socket Welds	NA	NA
	<i>Steam Generators</i>		
B05.070	Nominal Pipe Size 4" or Larger Nozzle to Safe End Butt Welds	NA	NA
B05.080	Nominal Pipe Size Less Than 4" Nozzle to Safe End Butt Weld	NA	NA
B05.090	Nozzle-To-Safe End Socket Welds	NA	NA
	<i>Heat Exchangers</i>		
B05.100	Nominal Pipe Size 4" or Larger Nozzle to Safe End Butt Welds	NA	NA
B05.110	Nominal Pipe Size Less Than 4" Nozzle to Safe End Butt Weld	NA	NA
B05.120	Nozzle-To-Safe End Socket Welds	NA	NA
	<i>Piping</i>		
B05.130	Nominal Pipe Size 4" or Larger Dissimilar Metal Butt Welds	1	1

Examination Category B-F (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B05.140	Nominal Pipe Size Less Than 4" Dissimilar Metal Butt Welds	4	4
B05.150	Dissimilar Metal Socket Welds	NA	NA
TOTALS		7	7

Examination Category B-G-1 Pressure Retaining Bolting, Greater Than 2" in Diameter

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B06.010	Closure Head Nuts	20	20
B06.020	Closure Studs (in place)	NA	NA
B06.030	Closure Studs, (when removed)	20	20
B06.040	Threads in Flange	0	0
B06.050	Closure Washers, Bushings	1	1
	Pressurizer		
B06.060	Bolts and Studs	0	0
B06.070	Flange Surface (when connection disassembled)	0	0
B06.080	Nuts , Bushings and Washers	1	1
	Steam Generators		
B06.090	Bolts and Studs	NA	NA
B06.100	Flange Surface (when connection disassembled)	NA	NA
B06.110	Nuts , Bushings and Washers	NA	NA
	Heat Exchangers		
B06.120	Bolts and Studs	NA	NA

Examination Category B-G-1 (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B06.130	Flange Surface (when connection disassembled)	NA	NA
B06.140	Nuts , Bushings and Washers	NA	NA
	Piping		
B06.150	Bolts and Studs	NA	NA
B06.160	Flange Surface (when connection disassembled)	NA	NA
B06.170	Nuts , Bushings and Washers	NA	NA
	Pumps		
B06.180	Bolts and Studs	0	0
B06.190	Flange Surface (when connection disassembled)	0	0
B06.200	Nuts , Bushings and Washers	0	0
	Valves		
B06.210	Bolts and Studs	NA	NA
B06.220	Flange Surface (when connection disassembled)	NA	NA
B06.230	Nuts , Bushings and Washers	NA	NA
TOTALS		42	42

Examination Category B-G-2

Pressure Retaining Bolting, 2" and Less
in Diameter

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B07.010	Bolts, Studs, and Nuts	NA	NA
	Pressurizer		
B07.020	Bolts, Studs, and Nuts	0	0
	Steam Generators		
B07.030	Bolts, Studs, and Nuts	2	2
	Heat Exchangers		
B07.040	Bolts, Studs, and Nuts	NA	NA
	Piping		
B07.050	Bolts, Studs, and Nuts	2	2
	Pumps		
B07.060	Bolts, Studs, and Nuts	1	1
	Valves		
B07.070	Bolts, Studs, and Nuts	0	0
	CRD Housings		
B07.080	Bolts, Studs, and Nuts In CRD Housing When Disassembled	2	2
TOTALS		7	7

Examination Category B-H

Integral Attachments for Vessels

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B08.010	Integrally Welded Attachments	NA	NA
	Pressurizer		
B08.020	Integrally Welded Attachments	NA	NA
	Steam Generators		
B08.030	Integrally Welded Attachments	NA	NA
	Heat Exchangers		
B08.040	Integrally Welded Attachments	NA	NA
TOTALS		NA	NA

Examination Category B-J

Pressure Retaining Welds in Piping

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B09.010	Nominal Pipe Size 4" or Larger		
B09.011	Circumferential Welds	7	7
B09.012	Longitudinal Welds ¹	8	8
B09.020	Nominal Pipe Size Less Than 4"		
B09.021	Circumferential Welds	5	5
B09.022	Longitudinal Welds	NA	NA
B09.030	Branch Pipe Connection Welds		

¹ Longitudinal welds that intersect circumferential welds are examined as required by Table IWB 2500-1, Examination Category B-J. However, for reporting purposes, the totals do not reflect the number of longitudinal welds examined during this outage.

Examination Category B-J (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B09.031	Nominal Pipe Size 4" or Larger	1	1
B09.032	Nominal Pipe Size Less Than 4"	0	0
B09.040	Socket Welds	0	0
TOTALS		21	21

Examination Category B-K-1

Integral Attachments for Piping, Pumps and Valves

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Piping		
B10.010	Integrally Welded Attachments	NA	NA
	Pumps		
B10.020	Integrally Welded Attachments	NA	NA
	Valves		
B10.030	Integrally Welded Attachments	NA	NA
TOTALS		NA	NA

Examination Category B-L-1, B-M-1

Pressure Retaining Welds in Pump Casings and Valve Bodies

B-L-2, B-M-2

Pump Casings and Valve Bodies

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Pumps		
B12.010	Pump Casing Welds (B-L-1)	0	0
B12.020	Pump Casing (B-L-2) (when disassembled for Maintenance, Repair or Volumetric Examination)	0	0
B12.030	Valves, Less Than Nominal Pipe Size 4" Valve Body Welds (B-M-1)	NA	NA
B12.040	Valves, Nominal Pipe Size 4" or Larger Valve Body Welds (B-M-1)	NA	NA
B12.050	Valve Body, Exceeding 4" Nominal Pipe Size (B-M-2)	0	0
TOTALS		0	0

Examination Category B-N-1

Interior of Reactor Vessel

B-N-2

Integrally Welded Core Support Structures and Interior Attachments to Reactor Vessels

B-N-3

Removable Core Support Structures

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B13.010	Vessel Interior (B-N-1)	0	0
	Reactor Vessel (PWR)		
B13.050	Interior Attachments Within The Beltline Region (B-N-2)	NA	NA

Examination Category B-N-1, B-N-2 & B-N-3 (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel (PWR)		
B13.070	Core Support Structure (B-N-3)	0	0
TOTALS		0	0

Examination Category B-O Pressure Retaining Welds in Control Rod Housings

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B14.010	Welds in CRD Housing	1	1
TOTALS		1	1

Examination Category B-P All Pressure Retaining Components

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Reactor Vessel		
B15.010	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.011	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001
	Pressurizer		
B15.020	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.021	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001

Examination Category B-P (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Steam Generators		
B15.030	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.031	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001
	Heat Exchangers		
B15.040	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.041	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001
	Piping		
B15.050	Pressure Retaining Boundary	1	1
B15.051	Pressure Retaining Boundary	0	0
	Pumps		
B15.060	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.061	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001
	Valves		
B15.070	Pressure Retaining Boundary	Covered under B15.050.001	Covered under B15.050.001
B15.071	Pressure Retaining Boundary	Covered under B15.051.001	Covered under B15.051.001
TOTALS		1	1

Examination Category B-Q

Steam Generator Tubing

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
B16.010	Steam Generator Tubing in Straight Tube Design	NA ²	NA
B16.020	Steam Generator Tubing in U-Tube Design	NA	NA
TOTALS		NA	NA

Examination Category F-A

Component Supports

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
F1.010	Class 1 Piping Supports (Reference Section 4.0 of this report)	5	5
F1.040	Class 1 Supports Other Than Piping (Reference Section 4.0 of this report)	0	0
F1.050	Class 1 Snubbers	15	15
TOTALS		20	20

² Steam Generator Tubing is examined and documented by Diversified Services Group of the Electric System Support Department as required by the Station Technical Specifications and is not included in this report.

2.2 Class 2 Inspections

Examination Category C-A Pressure Retaining Welds in Pressure Vessel

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C01.010	Shell Circumferential Welds	0	0
C01.020	Head Circumferential Welds	0	0
C01.030	Tubesheet to Shell Weld	1	1
TOTALS		1	1

Examination Category C-B Pressure Retaining Nozzle Welds in Vessels

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C02.010	Nozzles in Vessels $\leq 1/2$ " Nominal Thickness		
C02.011	Nozzle-to-Shell (or Head) Weld	0	0
C02.020	Nozzles Without Reinforcing Plate In Vessels $> 1/2$ " Nominal Thickness		
C02.021	Nozzle-to-Shell (or Head) Weld	1	1
C02.022	Nozzle Inside Radius Section	1	1
C02.030	Nozzles With Reinforcing Plate in Vessels $> 1/2$ " Nominal Thickness		
C02.031	Reinforcing Plate Welds to Nozzle and Vessel	0	0

Examination Category C-B (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C02.032	Nozzle-to-Shell (or Head) Welds When Inside of Vessel Is Accessible	N/A	N/A
C02.033	Nozzle-to-Shell (or Head) Welds When Inside of Vessel is Inaccessible	3	0 (Welds not examined during pressure test)
TOTALS		5	2

Examination Category C-C Integral Attachments For Vessels, Piping, Pumps, and Valves

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Pressure Vessels		
C03.010	Integrally Welded Attachments	0	0
	Piping		
C03.020	Integrally Welded Attachments	14	14
	Pumps		
C03.030	Integrally Welded Attachments	1	1
	Valves		
C03.040	Integrally Welded Attachments	NA	NA
TOTALS		15	15

Examination Category C-D

Pressure Retaining Bolting Greater Than 2" in Diameter

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Pressure Vessels		
C04.010	Bolts and Studs	NA	NA
	Piping		
C04.020	Bolts and Studs	NA	NA
	Pumps		
C04.030	Bolts and Studs	NA	NA
	Valves		
C04.040	Bolts and Studs	0	0
TOTALS		0	0

Examination Category C-F-1

Pressure Retaining Welds in Austenitic Stainless Steel or High Alloy Steel Piping

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C05.010	Piping Welds $\geq 3/8$ " Nominal Wall Thickness for Piping > NPS 4		
C05.011	Circumferential Weld	1	1
C05.012	Longitudinal Welds ³	NA	NA
C05.020	Piping Welds $> 1/5$ " Nominal Wall Thickness for Piping \geq NPS 2 and \leq NPS 4		
C05.021	Circumferential Welds	18	18
C05.022	Longitudinal Welds ³	NA	NA

³ Longitudinal welds that intersect circumferential welds are examined as required by Table IWC 2500-1, Examination Category C-F. However, for reporting purposes, the totals do not reflect the number of longitudinal welds examined during this outage.

Examination Category C-F-1 (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C05.030	Socket Welds	0	0
C05.040	Pipe Branch Connections of Branch Piping \geq NPS 2		
C05.041	Circumferential Weld	5	5
C05.042	Longitudinal Weld ³	NA	NA
TOTALS		24	24

Examination Category C-F-2 Pressure Retaining Welds in Carbon Steel or Low Alloy Steel Piping

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
C05.050	Piping Welds $\geq 3/8$ " Nominal Wall Thickness for Piping > NPS 4		
C05.051	Circumferential Weld	9	9
C05.052	Longitudinal Weld ³	1	1
C05.060	Piping Welds > $1/5$ " Nominal Wall Thickness for Piping \geq NPS 2 and \leq NPS 4		
C05.061	Circumferential Weld	NA	NA
C05.062	Longitudinal Weld ³	NA	NA
C05.070	Socket Welds	NA	NA
C05.080	Pipe Branch Connections of Branch Piping \geq NPS 2		
C05.081	Circumferential Weld	2	2
C05.082	Longitudinal Weld ³	NA	NA
TOTALS		12	12

Examination Category C-G

Pressure Retaining Welds in Pumps and Valves

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Pumps		
C06.010	Pump Casing Welds	NA	NA
	Valves		
C06.020	Valve Body Welds	1	1
TOTALS		1	1

Examination Category C-H

All Pressure Retaining Components

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
	Pressure Vessel		
C07.010	Pressure Retaining Components	covered under C07.030	covered under C07.030
C07.020	Pressure Retaining Components	covered under C07.040	covered under C07.040
	Piping		
C07.030	Pressure Retaining Components	13	13
C07.040	Pressure Retaining Components	0	0
	Pumps		
C07.050	Pressure Retaining Components	covered under C07.030	covered under C07.030
C07.060	Pressure Retaining Components	covered under C07.040	covered under C07.040
	Valves		
C07.070	Pressure Retaining Components	covered under C07.030	covered under C07.030
C07.080	Pressure Retaining Components	covered under C07.040	covered under C07.040
TOTALS		13	13

Examination Category F-A

Component Supports

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
F1.020	Class 2 Supports (Reference Section 4.0 of this report)	16	16
F1.040	Class 2 Supports Other Than Piping (Reference Section 4.0 of this report)	1	1
F1.050	Class 2 Snubbers (Reference Section 4.0 of this report)	41	41
TOTALS		58	58

2.3 Augmented Inspections

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
G01.001	Reactor Coolant Pump Flywheel	4	0 (Not disassembled)
G02.001	HPI Nozzle Safe End Examinations	0	0
G03.001	Pressurizer Surge Line Examinations	0	0
G04.001	Thermal Stress Piping (NRC Bulletin 88-08)	10	10
G05.001	Pressurizer Spray Piping Thermal Transient Inspection	0	0
G06.001	Auxiliary Feedwater Header Water Hammer Examinations (PSC21-82)	1	1
G07.001	Augmented Examination of Longitudinal Piping Welds With A Nominal Wall Thickness < 3/8" and > NPS 4"	0	0

Augmented Inspections (Continued)

<i>Item Number</i>	<i>Description</i>	<i>Total Scheduled During Outage</i>	<i>Total Examined During Outage</i>
G08.001	Pressurizer Sensing/ Sampling Nozzle Safe Ends	0	0
G09.001	Class 2 Piping Welds NPS > 4" With Nominal Wall Thickness < 3/8"	8	8
G10.001	Class 1 RTE Mounting Bosses	0	0
G11.001	Reactor Coolant Pumps 3A2 and 3B1 Alternate Examinations	NA	NA
G12.001	HPI Upgrade	2	2

A detailed description of each examination listed in Sections 2.1 through 2.3 are located in Section 3 of this report. Results of each examination are located in Section 4 of this report.

3.0 Second Ten Year Inspection Status

The completion status of inspections required by the 1989 ASME Section XI Code, no Addenda, is summarized in this section. The requirements are listed by the ASME Section XI Examination Category as defined in Table IWB-2500-1 for Class 1 Inspections, and in Table IWC-2500-1 for Class 2 Inspections. Augmented inspections are also included.

Class 1 Inspections

<u>Examination Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>⁴Deferral Allowed</u>
B-A	Pressure Retaining Welds in Reactor Vessel	15 Welds	1 Welds	6.66 %	Yes
B-B	Pressure Retaining Welds in Vessels Other than Reactor Vessel	11 Welds	3 Welds	27.27%	No
B-D	Full Penetration Welds of Nozzles in Vessels	30 Inspections	7 Inspections	23.33 % (Ref. ONS-006)	Partial
B-E	Pressure Retaining Partial Penetration Welds in Vessels	31 Welds	0 Welds	0 %	No
B-F	Pressure Retaining Dissimilar Metal Welds	31 Welds	7 Welds	22.58 %	No
B-G-1	Pressure Retaining Bolting Greater than 2 Inch Diameter	134 Items	42 Items	31.34 %	Yes
B-G-2	Pressure Retaining Bolting 2 Inches and Less in Diameter	25 Items	7 Item	28 %	No
B-H	Integral Attachment for Vessels	N/A	N/A	N/A	N/A
B-J	Pressure Retaining Welds in Piping	134 Welds	12 Welds	8.95 %	No

⁴Deferral of inspection to the end of the interval as allowed by ASME Section XI Tables IWB and IWC 2500-1.

Class 1 Inspections (Continued)

<u>Examination Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
B-K-1	Integral Attachments for Piping, Pumps and Valves	N/A	N/A	N/A	N/A
B-L-1	Pressure Retaining Welds in Pump Casings	1 Weld	0 Welds	0 %	Yes
B-L-2	Pump Casings	1 Casing	0 Casings	0 %	Yes
B-M-1	Pressure Retaining Welds in Valve Bodies	N/A	N/A	N/A	N/A
B-M-2	Valve Body > 4 in. Nominal Pipe Size	3 Valves	0 Valves	0 %	Yes
B-N-1	Interior of Reactor Vessel	3 Items	0 Items	0 %	No
B-N-2	Integrally Welded Core Support Structures and Interior Attachments to Reactor Vessels	N/A	N/A	N/A	N/A
B-N-3	Removable Core Support Structures	1 Item	0 Items	0 %	Yes
B-O	Pressure Retaining Welds in Control Rod Housings	3 Housings	1 Housing	33.33 %	Yes
B-P	All Pressure Retaining Components				No
	System Leakage Test	5 Components	1 Component	20 %	
	System Hydrostatic Test	1 Component	0 Components	0 %	
B-Q	Steam Generator Tubing	N/A	N/A	N/A	N/A
F1.01	Class 1 Component Supports	25 Supports	5 Supports	20 %	No

Class 1 Inspections (Continued)

<u>Examination Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
F1.40	Class 1 Component Supports (Supports Other Than Piping Supports)	4 Supports	0 Supports	0 %	No
F1.50	Class 1 Component Supports (Snubbers)	15 Supports	15	100 %	No

Class 2 Inspections

<u>Examination Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
C-A	Pressure Retaining Welds in Pressure Vessels	14 Welds	1 Welds	7.14 %	No
C-B	Pressure Retaining Nozzle Welds in Vessels	12 Welds	1 Welds	8.33 %	No
C-C	Integral Attachments for Vessels, Piping, Pumps and Valves	94 Attachments	14 Attachments	14.89 %	No
C-D	Pressure Retaining Bolting Exceeding 2 Inches in Diameter	1	0	0 %	NA
C-F-1	Pressure Retaining Welds in Austentic Stainless Steel or High Alloy Piping	145 Welds	24 Welds	16.55 %	No
C-F-2	Pressure Retaining Welds in Carbon or Low Alloy Steel Piping	62 Welds	11 Welds	17.74 %	No
C-G	Pressure Retaining Welds in Pumps and Valves	1	1	100 %	N/A
C-H	All Pressure Retaining Components				No
	System or Component Inservice Inspection/Functional Test	76 Components	1 Components	1.32 %	

Class 2 Inspections (Continued)

<u>Examination Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
	System Hydrostatic Test	38 Components	0 Components	0 %	
F1.02	Class 2 Component Supports	105 Supports	16 Supports	15.23 %	No
F1.40	Class 2 Component Supports (Supports Other Than Piping Supports)	10 Supports	1 Supports	10 %	No
F1.50	Class 2 Component Supports (Snubbers)	41 Supports	41	100 %	No

Augmented Inspections

<u>Description</u>	<u>Percentage Complete</u>
Reactor Coolant Pump Flywheels (Item No. Series G01)	0 % (RCP was not disassembled)
HPI Nozzle Safe End Examinations (Item No. Series G02)	0 % (Not scheduled for examination)
Pressurizer Surge Line Drain Line (Item No. Series G03)	0 % (Not scheduled for examination)
Thermal Stress Piping (Item No. Series G04)	100 % of EOC 16
Pressurizer Spray Piping Thermal Transient Inspection (Item No. Series G05)	0 % (Not scheduled for examination)
Auxiliary Feedwater Header Water Hammer (Item No. Series G06)	100 % of EOC 16
Augmented Examination of Longitudinal Piping Welds With A Nominal Wall Thickness < $\frac{3}{8}$ " and > NPS 4" (Item No. Series G07)	0 % (Not scheduled for examination)
Pressurizer Sensing/ Sampling Nozzle Safe Ends (Item No. Series G08)	0 % (Not scheduled for examination)

Augmented Inspections (Continued)

Class 2 Piping Welds NPS Greater Than 4" With A Nominal Wall Thickness Less Than $\frac{3}{8}$ " (Item No. Series G09)	100% of EOC 16
Class 1 RTE Mounting Bosses (Item No. Series G10)	0 % (Not scheduled for examination)
HPI Upgrade (Item No. Series G12)	100 % of EOC 16

4.0 Final Inservice Inspection Plan For Outage 16

The final ISI Plan shown in this section lists all ASME Section XI Class 1 and ASME Section XI Class 2, and Augmented examinations credited for Outage 16 at Oconee Nuclear Station Unit 1.

The information shown below is a field description for the reporting format included in this section of the report:

A. Items examined by NDE methods

Item Number	=	ASME Section XI Tables IWB-2500-1 (Class 1), IWC-2500-1 (Class 2), IWF-2500-1 (Class 1 and Class 2), Augmented Requirements
ID Number	=	Unique Identification Number
Iso / Dwg Numbers	=	Location and/or Detail Drawings
Proc	=	Examination Procedures
Insp Req	=	Examination Technique - Magnetic Particle, Dye Penetrant, etc.
Mat / Sch	=	General Description of Material
Diam / Thick	=	Diameter/Thickness
Cal Blocks	=	Calibration Block Number
Comments	=	General and/or Detail Description

**CATEGORY B-A, Pressure Retaining Welds
in Reactor Vessel**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 1
02/07/96

Shell-to-Flange Weld

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B01.030.002	1-RPV-WR19	ISI OCN1-001 OM-201-1877	ISI-138 NDE-650	UT	CS	171.000 12.000	50304	Reactor Vessel Flange Pc. 7 to Nozzle Belt Upper Course Pc. 8. UT from Flange Surface (manual scan)
Class A				Rx Head Flange to RV Nozzle belt				

Total B01.030 Items: 1

Total Category B-A Items: 1

**CATEGORY B-B, Pressure Retaining Welds
in Vessels Other Than Reactor Vessels**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 2
02/07/96

Pressurizer

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Shell-to-Head Welds; Circumferential ****								
B02.011.001	1-PZR-WP76	ISI OCN1-002	NDE-620	UT	CS	84.000	40387	Pressurizer Upper Head Pc. 5 to Upper Shell Course Pc. 1. Material thickness ranges from 6.50" to 4.750" due to taper of material.
	Circumferential	OM-201-1878	NDE-640			4.750		
Class A				PZR (01) to PZR (05)				
B02.011.003	1-PZR-WP4	ISI OCN1-002	NDE-620	UT	CS	84.000	40387	Lower shell to heater belt shell (inspect in the third interval during the first, second and third periods per IWB 2420(B).)
	Circumferential	OM-201-1878	NDE-640			6.188		
Class A				PZR (03) to 04/41				
Total B02.011 Items:		2						
**** Shell-to-Head Welds; Longitudinal ****								
B02.012.001	1-PZR-WP1-1	ISI OCN1-002	NDE-620	UT	CS	84.000	40387	Pressurizer Upper Shell Course Pc. 1 to Pc. 1.
	Longitudinal	OM-201-1878	NDE-640			6.188		
Class A				PZR Upper Shell Course to PZR Upper Shell Course				
Total B02.012 Items:		1						
Total Category B-B Items:		3						

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

Reactor Vessel

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

**Plan Report
Page 3
02/07/96**

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle-to-Vessel Welds ****								
B03.090.001A	1-RPV-WR13	ISI OCN1-001 OM-201-1877	ISI-138	UT	CS	60.000 12.000	40390	X- Outlet Nozzle to Vessel Pc. 19 to Pc. 08 & 09. UT From Nozzle ID.
Class A					Nozzle Rx Head Nozzle to Rx Nozzle belt			
B03.090.002A	1-RPV-WR13A	ISI OCN1-001 OM -201-1877	ISI-138	UT	CS	60.000 12.000	50304	Z- Outlet Nozzle to Vessel Pc. 19 to Pc. 08 & 09. UT From Nozzle ID. Note: For inspection in Outage 1 see Request for Relief ONS-006.
Class A					Nozzle RX Head Nozzle to RX Nozzle Belt			
Total B03.090 Items:		2						

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

Reactor Vessel

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

**Plan Report
Page 4
02/07/96**

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle Inside Radius Section ****								
B03.100.001	1-RPV-WR13	ISI OCN1-001 OM-201-1877	ISI-138	UT	CS	60.000 12.000	50304	X-Outlet Nozzle to Vessel Pc. 19 to Pc. 08 & 09. (Inside Radius Section). Note: For inspection in Outage 1 see Request for Relief ONS-006.
Class A					Nozzle RX Head Nozzle to RX Nozzle Belt			
B03.100.002	1-RPV-WR13A	ISI OCN1-001 OM-201-1877	ISI-138	UT	CS	60.000 12.000	50304	Z-Outlet Nozzle to Vessel Pc. 19 to Pc. 08 & 09. (Inside Radius Section). Note: For inspection in Outage 1 see Request for Relief ONS-006.
Class A					Nozzle RX Head Nozzle to RX Nozzle Belt			
Total B03.100 Items:		2						

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 5
02/07/96

Pressurizer

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle-to-Vessel Welds ****								
B03.110.002	1-PZR-WP34	ISI OCN1-002	NDE-620	UT	CS	7.750	40394	Pzr Spray Nozzle Pc. 9 to Upper Head Pc. 5.
	Circumferential	B&W129261E	NDE-640			4.750		
	Class A							Pzr Spray Nozzle to Pzr Upper Head
B03.110.003	1-PZR-WP33-3	ISI OCN1-002	NDE-620	UT	CS	6.875	40394	Pzr Relief Nozzle Pc. 31 to Upper Head Pc. 5
	Circumferential	OM-201-1878	NDE-640			4.750		between W & Z Axis.
	Class A	B&W129262E						Pzr Relief Nozzle to Pzr Upper Head
B03.110.004	1-PZR-WP33-2	ISI OCN1-002	NDE-620	UT	CS	6.875	40394	Pzr Relief Nozzle Pc. 31 to Upper Head Pc. 5 on Y &
	Circumferential	OM-201-1878	NDE-640			4.750		X Axis.
	Class A	B&W129262E						Pzr Relief Nozzle to Pzr Upper Head

Total B03.110 Items: 3

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 6
02/07/96

Pressurizer

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle Inside Radius Section ****								
B03.120.002	1-PZR-WP34	ISI OCN1-002 OM-201-1878 B&W129261E	NDE-680	UT	CS	7.750 4.750	40394	Pressurizer Spray Nozzle Pc. 9 to Upper Head Pc. 5. (Inside Radius Section).
Class A								Pzr Spray Nozzle to Pzr Upper Head
B03.120.003	1-PZR-WP33-3	ISI OCN1-002 OM-201-1878 B&W129262E	NDE-680	UT	CS	6.875 4.750	40394	Pressurizer Relief Nozzle Pc. 31 to Upper Head Pc. 5 between W & Z Axis. (Inside Radius Section).
Class A								Pzr Relief Nozzle to Pzr Upper Head
B03.120.004	1-PZR-WP33-2	ISI OCN1-002 OM-201-1878 B&W129262E	NDE-680	UT	CS	6.875 4.750	40394	Pressurizer Relief Nozzle Pc. 31 to Upper Head Pc. 5 on Y & X Axis. (Inside Radius Section).
Class A								Pzr Relief Nozzle to Pzr Upper Head

Total B03.120 Items: 3

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 7
02/07/96

Steam Generators (Primary Side)

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle-to-Vessel Welds ****								
B03.130.001	1-SGA-WG50-2	ISI-OCN1-003	NDE-620	UT	CS	38.380	40393	Steam Generator 1A Outlet Nozzle Pc. 65 to Head
	Circumferential	OM-201-1873	NDE-640			8.500		Pc. 07 W-Z Axis.
Class A		B&W129317E			SGA Lower Head to Nozzle Outlet Nozzle			
B03.130.002	1-SGA-WG50-1	ISI-OCN1-003	NDE-620	UT	CS	38.380	40393	Steam Generator 1A Outlet Nozzle Pc. 65 to Head
	Circumferential	OM-201-1873	NDE-640			8.500		Pc. 07 Y-Z Axis.
Class A		B&W129317E			SGA Lower Head to Nozzle Outlet Nozzle			
Total B03.130 Items:		2						

**CATEGORY B-D, Full Penetration Welds of
Nozzles in Vessels**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 8
02/07/96

Steam Generators (Primary Side)

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle Inside Radius Section ****								
B03.140.001	1-SGA-WG50-2	ISI-OCN1-003 OM-201-1873 B&W129317E	NDE-680	UT	CS	38.380 8.500	40393	Steam Generator 1A Outlet Nozzle Pc. 65 to Head Pc. 7. W-Z Axis. (Inside Radius Section).
Class A					SGA Lower Head to Outlet Nozzle			
B03.140.002	1-SGA-WG50-1	ISI-OCN1-003 OM-201-1873 B&W129317E	NDE-680	UT	CS	38.380 8.500	40393	Steam Generator 1A Outlet Nozzle Pc. 65 to Head Pc. 7. Y-Z Axis. (Inside Radius Section).
Class A					SGA Lower Head to Outlet Nozzle			

Total B03.140 Items: 2

Total Category B-D Items: 14

**CATEGORY B-F, Pressure Retaining
Dissimilar Metal Welds**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 9
02/07/96**

Pressurizer

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Less Than NPS 4; Nozzle-to-Safe End Butt Welds ****								
B05.050.002	1-PZR-WP91-2	ISI OCN1-002	NDE-35	PT	SS/CS	2.500		Pressurizer Relief Nozzle Pc. 31 to Safe End Pc. 32
	Circumferential	B&W129262E				0.000		X-Y Axis.
	Class A				Nozzle Piece 31 to			
	Dissimilar				Safe End Pc.32			
B05.050.003	1-PZR-WP91-3	ISI OCN1-002	NDE-35	PT	SS/CS	2.500		Pressurizer Relief Nozzle Pc. 31 to Safe End Pc. 32
	Circumferential	B&W129262E				0.000		Z-W Axis.
	Class A				Nozzle Piece 31 to			
	Dissimilar				Safe End Pc.32			
Total B05.050 Items:	2							

**CATEGORY B-F, Pressure Retaining
Dissimilar Metal Welds**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 10
02/07/96**

Piping

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** NPS 4 or Larger; Dissimilar Metal Butt Welds ****								
B05.130.001	1-PIA1-7	ISI OCN1-007 OM-201-1845	NDE-610	UT	SS/CS	33.500 2.330	40350	Examine from the pipe side.
Class A	Circumferential Stress weld Dissimilar							Pipe to Safe end
B05.130.001A	1-PIA1-7	ISI OCN1-007 OM-201-1845	NDE-610	UT	SS/CS	33.500 2.330	40397	Examine from the safe end side.
Class A	Circumferential Stress weld Dissimilar							Pipe to Safe end
B05.130.001B	1-PIA1-7	ISI OCN1-007 OM-201-1845	NDE-35	PT	SS/CS	33.500 2.330		
Class A	Circumferential Stress weld Dissimilar							Pipe to Safe end

Total B05.130 Items: 3

**CATEGORY B-F, Pressure Retaining
Dissimilar Metal Welds**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 11
02/07/96**

Piping

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
-------------	-----------	-----------------	------	----------	---------	--------	------------	----------

****** Less Than NPS 4; Dissimilar Metal Butt Welds ******

B05.140.001	1-PIA1-11	ISI OCN1-007 OM-201-1870	NDE-35	PT	CS/Inconel	3.500 0.816		Nozzle to Safe end
Class A								
	Circumferential							
	Dissimilar							
B05.140.003	1-PDA1-11	ISI OCN1-011 OM-201-1845	NDE-35	PT	SS/CS	3.500 0.750		Nozzle Pressure injection nozzle to Safe end
Class A								
	Circumferential							
	Dissimilar							
B05.140.009	1-50-01-34	1-50-01(1)	NDE-35	PT	SS/Inconel	1.500 0.281		Pipe to Elbow
Class A								
	Circumferential							
	Dissimilar							
B05.140.010	1-50-01-2	1-50-01(2) OFD-100A-1.1	NDE-35	PT	SS/Inconel	1.500 0.281		to Elbow
Class A								
	Circumferential							
	Dissimilar							

Total B05.140 Items: 4

Total Category B-F Items: 9

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 12
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** Closure Head Nuts ****								
B06.010.001	1-RPV-26-203-01	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.002	1-RPV-26-203-02	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.003	1-RPV-26-203-03	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.004	1-RPV-26-203-04	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.005	1-RPV-26-203-05	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.006	1-RPV-26-203-06	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.007	1-RPV-26-203-07	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.008	1-RPV-26-203-08	OM-201-0005 B&W128723E	NDE-25	MT	CS		9.250 1.300	Reactor Vessel Closure Nut
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 13
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B06.010.009	1-RPV-26-203-09	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.010	1-RPV-26-203-10	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.011	1-RPV-26-203-11	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.012	1-RPV-26-203-12	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.013	1-RPV-26-203-13	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.014	1-RPV-26-203-14	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.015	1-RPV-26-203-15	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				
B06.010.016	1-RPV-26-203-16	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250 1.300		Reactor Vessel Closure Nut
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 14
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
B06.010.017	1-RPV-26-203-17	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250	1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.018	1-RPV-26-203-18	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250	1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.019	1-RPV-26-203-19	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250	1.300	Reactor Vessel Closure Nut
Class A				to				
B06.010.020	1-RPV-26-203-20	OM-201-0005 B&W128723E	NDE-25	MT	CS	9.250	1.300	Reactor Vessel Closure Nut
Class A				to				

Total B06.010 Items: 20

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 15
02/07/96

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Closure Studs, when removed ****								
B06.030.001	1-RPV-25-203-01	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.001A	1-RPV-25-203-01	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.002	1-RPV-25-203-02	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.002A	1-RPV-25-203-02	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.003	1-RPV-25-203-03	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.003A	1-RPV-25-203-03	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.004	1-RPV-25-203-04	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.004A	1-RPV-25-203-04	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice-Inspection Database Management System**

**Plan Report
Page 16
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B06.030.005	1-RPV-25-203-05	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.005A	1-RPV-25-203-05	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.006	1-RPV-25-203-06	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.006A	1-RPV-25-203-06	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.007	1-RPV-25-203-07	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.007A	1-RPV-25-203-07	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.008	1-RPV-25-203-64	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.008A	1-RPV-25-203-64	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 17
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B06.030.009	1-RPV-25-203-09	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.009A	1-RPV-25-203-09	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.010	1-RPV-25-203-10	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.010A	1-RPV-25-203-10	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.011	1-RPV-25-203-11	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.011A	1-RPV-25-203-11	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.012	1-RPV-25-203-12	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.012A	1-RPV-25-203-12	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 18
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
B06.030.013	1-RPV-25-203-13	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.013A	1-RPV-25-203-13	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.014	1-RPV-25-203-14	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.014A	1-RPV-25-203-14	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.015	1-RPV-25-203-15	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.015A	1-RPV-25-203-15	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.016	1-RPV-25-203-62	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.016A	1-RPV-25-203-62	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 19
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B06.030.017	1-RPV-25-203-17	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.017A	1-RPV-25-203-17	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.018	1-RPV-25-203-18	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.018A	1-RPV-25-203-18	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.019	1-RPV-25-203-19	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.019A	1-RPV-25-203-19	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.020	1-RPV-25-203-20	OM-201-0005 B&W128723E	NDE-944	UT	CS	6.500 0.000	40420	Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				
B06.030.020A	1-RPV-25-203-20	OM-201-0005 B&W128723E	NDE-25	MT	CS	6.500 0.000		Reactor Vessel Closure Stud - Removed. Stud Length = 63.250.
Class A				to				

Total B06.030 Items: 40

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 20
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
**** Closure Washers, Bushings ****								
B06.050.001	1-RPV-WASH-BUSH	B&W128723E	QAL-13	VT-1	CS	9.750 0.214		Reactor Vessel Closure Washers and Bushings. Stud Holes 1 - 20.
Class A				to				

Total B06.050 Items: 1

**CATEGORY B-G-1, Pressure Retaining
Bolting, Greater than 2" In Diameter**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 21
02/07/96

Pressurizer

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nuts, Bushings, and Washers ****								
B06.080.001	1-PZR-MW-NUTS	24893F	QAL-13	VT-1	CS	2.750 0.000		Pressurizer Manway Nuts Pc. 68; Including Bushings and Washers.
Class A				to				
Total B06.080 Items:		1						
Total Category B-G-1 Items:		62						

**CATEGORY B-G-2, Pressure Retaining
Bolting, 2" And Less In Diameter**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 22
02/07/96**

Steam Generators

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
**** Bolts, Studs, and Nuts ****								
B07.030.002	1-SGA-LMW-BOLTS	OM-201-550	QAL-13	VT-1	SS		0.000	Steam Generator 1A Lower Head Manway Studs and Nuts (Total 16 Studs Pc. 111 and Nuts Pc. 109).
Class A		OM-201-352		to			0.000	
B07.030.006	1-SGA-LHIC-BOLTS	OM-201-550	QAL-13	VT-1	SS		0.000	Steam Generator 1A Lower Head Inspection Cover Studs and Nuts. (Total 12 Studs Pc. 112 and Nuts Pc. 110).
Class A		OM-201-352		to			0.000	
Total B07.030 Items:		2						

**CATEGORY B-G-2, Pressure Retaining
Bolting, 2" And Less In Diameter**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 23
02/07/96

Piping

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
**** Bolts, Studs, and Nuts ****								
B07.050.003	1-PZR-RC67-BOLT	B&W129262E OM-201-1026	QAL-13	VT-1	CS	1.125 0.000		Pressurizer Relief Valve RC-67 Nozzle Flange Bolting (Between W&X Axis) Total 8 Bolts; 16 Nuts .
Class A				to				
B07.050.004	1-PZR-RC68-BOLT	B&W129262E OM-201-1026	QAL-13	VT-1	CS	1.125 0.000		Pressurizer Relief Valve RC-68 Nozzle Flange Bolting (Noz. 15 degrees off Y- Axis) Total 8 Bolts; 16 Nuts.
Class A				to				
Total B07.050 Items:		2						

**CATEGORY B-G-2, Pressure Retaining
Bolting, 2" And Less In Diameter**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 24
02/07/96

Pumps

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
**** Bolts, Studs, and Nuts ****								
B07.060.003	1-RCP-1B1-SEAL	OM-201D-34	QAL-13	VT-1	CS		2.000	Reactor Coolant Pump 1B1 Lower Seal Housing Bolts - 12 Cap Screws Pc. 26.
Class A		OM-201D-0057		to			0.000	Inspect lower seal house bolting from only 1 reactor coolant pump.
Total B07.060 Items:		1						

**CATEGORY B-G-2, Pressure Retaining
Bolting, 2" And Less In Diameter**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 25
02/07/96

CRD Housings

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Bolts, Studs, and Nuts ****								
B07.080.001	1-RPV-CRD-BOLTS	OM-201-2248 DPS 706599-1056 B&W152006E	QAL-13	VT-1	CS	1.250 0.000		CRD Housing Bolts (Total 8 Bolts) 2 Connections inspected to date; CRD # 38, # 59.(Inspect only if Disassembled). Reference Request for Relief ONS-004 & ONS-005.
Class A				to				
B07.080.002	1-RPV-CRD-RINGS	OM-201-2248 DPS 706599-1056 B&W152006E	QAL-13	VT-1	CS	11.500 1.250		CRD Housing Rings ; 1 Pair per CRD Housing. 2 Connections inspected to date ; CRD # 38, #59.(Inspect only if Disassembled)
Class A				to				
Total B07.080 Items:		2						
Total Category B-G-2 Items:		7						

CATEGORY B-J, Pressure Retaining Welds In Piping

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 26
02/07/96**

NPS 4 or Larger

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Welds ****								
B09.011.001	1-PIA1-9	ISI OCN1-007 OM-201-1846	NDE-610	UT	SS	36.500 2.330	40397	
Class A	Circumferential Stress weld Dissimilar							Safe end to RC pump 1A1
B09.011.001A	1-PIA1-9	ISI OCN1-007 OM-201-1846	NDE-35	PT	SS	36.500 2.330		
Class A	Circumferential Stress weld Dissimilar							Safe end to RC pump 1A1
B09.011.004	1-PIA1-5	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS	33.500 2.330		Reference Request for Relief 95-GO-03 for calibration block.
Class A	Circumferential							Elbow to Pipe
B09.011.004A	1-PIA1-5	ISI OCN1-007 B&W131914E6	NDE-25	MT	CS	33.500 2.330		
Class A	Circumferential							Elbow to Pipe
B09.011.005	1-PIA1-4	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS	33.500 2.330		Reference Request for Relief 95-GO-03 for calibration block.
Class A	Circumferential Stress weld							Pipe to Elbow
B09.011.005A	1-PIA1-4	ISI OCN1-007 B&W131914E6	NDE-25	MT	CS	33.500 2.330		
Class A	Circumferential Stress weld							Pipe to Elbow
B09.011.007	1-PIA1-2	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS	33.500 2.330		Reference Request for Relief 95-GO-03 for calibration block.
Class A	Circumferential Stress weld							Pipe to Elbow
B09.011.007A	1-PIA1-2	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS	33.500 2.330		
Class A	Circumferential Stress weld							Pipe to Elbow

CATEGORY B-J, Pressure Retaining Welds In Piping

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 28
02/07/96**

NPS 4 or Larger

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
B09.012.002 Class A	1-PIA1-62LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.002A Class A	1-PIA1-62LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	
				Elbow to Elbow				
B09.012.003 Class A	1-PIA1-45LI Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Inspect with Item Number B09.011.007. Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.003A Class A	1-PIA1-45LI Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	Inspect with Item Number B09.011.007A
				Elbow to Elbow				
B09.012.004 Class A	1-PIA1-45LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Inspect with Item Number B09.011.007. Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.004A Class A	1-PIA1-45LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	Inspect with Item Number B09.011.007A
				Elbow to Elbow				
B09.012.007 Class A	1-PDA1-53LO Longitudinal	ISI OCN1-011 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.007A Class A	1-PDA1-53LO Longitudinal	ISI OCN1-011 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	
				Elbow to Elbow				

CATEGORY B-J, Pressure Retaining Welds In Piping

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 29
02/07/96**

NPS 4 or Larger

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
B09.012.008 Class A	1-PDA1-53LI Longitudinal	ISI OCN1-011 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.008A Class A	1-PDA1-53LI Longitudinal	ISI OCN1-011 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	
				Elbow to Elbow				
B09.012.051 Class A	1-PIA1-62LI Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Inspect with Item Number B09.011.005. Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.051A Class A	1-PIA1-62LI Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	Inspect with Item Number B09.011.005A
				Elbow to Elbow				
B09.012.052 Class A	1-PIA1-62LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-600	UT	CS		33.500 2.330	Inspect with Item Number B09.011.005. Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Elbow				
B09.012.052A Class A	1-PIA1-62LO Longitudinal	ISI OCN1-007 B&W 131914E6	NDE-25	MT	CS		33.500 2.330	Inspect with Item Number B09.011.005A
				Elbow to Elbow				

Total B09.012 Items: 16

CATEGORY B-J, Pressure Retaining Welds In Piping

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 30
02/07/96**

Less Than NPS 4

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Welds ****								
B09.021.032	1-51A-04-25C	1-51A-04 OFD-101A-1.4	NDE-35	PT	SS	2.500 0.375		Elbow to Valve 1HP-127
Class A	Circumferential							
B09.021.033	1-51A-04-23C	1-51A-04 OFD-101A-1.4	NDE-35	PT	SS	2.500 0.375		Elbow to Pipe
Class A	Circumferential							
B09.021.034	1-51A-04-14C	1-51A-04 OFD-101A-1.4	NDE-35	PT	SS	2.500 0.375		Elbow to Pipe
Class A	Circumferential							
B09.021.037	1-51A-04-11C	1-51A-04 OFD-101A-1.4	NDE-35	PT	SS	2.500 0.375		Pipe to Elbow
Class A	Circumferential							
B09.021.038	1-51A-04-9C	1-51A-04 OFD-101A-1.4	NDE-35	PT	SS	2.500 0.375		Pipe to Elbow
Class A	Circumferential							
Total B09.021 Items:		5						

CATEGORY B-J, Pressure Retaining Welds In Piping

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 Inservice Inspection Database Management System

Plan Report
 Page 31
 02/07/96

Branch Pipe Connection Welds

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** NPS 4 or Larger ****								
B09.031.003	1-PIB1-10	ISI OCN1-009	NDE-600	UT	CS	12.000		Reference Request for Relief 95-GO-03 for calibration block.
	Branch	OM-201-595				2.250		
	Class A				Pipe to Nozzle Drain nozzle			
B09.031.003A	1-PIB1-10	ISI OCN1-009	NDE-25	MT	CS	12.000		
	Branch	OM-201-595				2.250		
	Class A				Pipe to Nozzle Drain nozzle			
Total B09.031 Items:	2							
Total Category B-J Items:	36							

**CATEGORY B-O, Pressure Retaining Welds
in Control Rod Housings**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 32
02/07/96**

Reactor Vessel

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** Welds in CRD Housing ****								
B14.010.001	1-RPV-CRD-47WH9	OM-201-2186 OM-201-1059	NDE-35	PT	SS/Inconel	4.025 0.650		CRDM Housing Body MK-67 to Adapter MK-55.
	Class A							Housing Body to Adapter
B14.010.004	1-RPV-CRD-47W60	DPS 706599-1056 OFD-100A-1.1	NDE-35	PT	SS/CS	5.000 0.500		CRDM Base to Motor Tube - CRDM # 47.
	Class A							Base to Motor Tube
B14.010.007	1-RPV-CRD-47	DPS 706599-1056 OFD-100A-1.1	NDE-35	PT	SS/CS	4.300 0.400		CRDM Motor Tube to Extension - CRDM #47.
	Class A							Motor Tube to Extension
B14.010.010	1-RPV-CRD-47W61	DPS 706605-1058 OFD-100A-1.1	NDE-35	PT	SS	4.190 0.380		Peripheral CRDM Extension to Cap - CRDM #47.
	Class A							Extension to Cap
Total B14.010 Items:		4						
Total Category B-O Items:		4						

CATEGORY C-B, Pressure Retaining Nozzle

Welds In Vessels

**Nozzles Without Reinforcing Plate In Vessels >
1/2 in. Nom. Thickness**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

Plan Report
Page 34
02/07/96

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Nozzle-to-Shell (or Head) Weld ****								
C02.021.002	1-SGB-WG23-2	ISI-OCN1-004	NDE-620	UT	CS	29.000	40338	Steam Generator 1B Outlet Nozzle, X-Y Axis. Pc. 14
	Circumferential	OM-201-1873	NDE-640			6.750		to Shell Pc. 03.
	Class B	OM-201-0034			Outlet Nozzle to Shell			
C02.021.002A	1-SGB-WG23-2	ISI-OCN1-004	NDE-25	MT	CS	29.000		Steam Generator 1B Outlet Nozzle, X-Y Axis. Pc. 14
	Circumferential	OM-201-1873				6.750		to Shell Pc. 03.
	Class B	OM-201-0034			Outlet Nozzle to Shell			
Total C02.021 Items:		2						
**** Nozzle Inside Radius Section ****								
C02.022.002	1-SGB-WG23-2	ISI-OCN1-004	NDE-680	UT	CS	29.000	40338	Steam Generator 1B Outlet Nozzle, X-Y Axis. Piece
		OM-201-1873				6.750		14 to Shell Pc. 03. (Inside Radius Section).
	Class B				Outlet Nozzle to Shell			
Total C02.022 Items:		1						
Total Category C-B Items:		3						

**CATEGORY C-C, Integral Attachments For
Vessels, Piping, Pumps, And Valves**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 35
02/07/96**

Piping

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** Integrally Welded Attachments ****								
C03.020.001	1-01A-H10A	0-480A	NDE-25	MT	CS		24.250	Calcalaton No. OSC-1296-06; Problem No. 1-01-07; System 01A;PAGE# 6 (2)-24.23A MAIN STEAM FROM PEN 26 TO SG 1A
	Constant support	OFD-122A-1.1					1.500	
	Class B			to				
C03.020.009	1-01A-H5B	0-481A	NDE-25	MT	CS		24.250	Calcalaton No. OSC-1296-06; Problem No. 1-01-08; System 01A;PAGE# 6 (1)-25.18; MAIN STEAM FROM PEN 28 TO SG 1B
	Constant support	OFD-122A-1.1					1.000	
	Class B			to				
C03.020.030	1-51-SR20	0-437A	NDE-35	PT	SS		4.000	Calculation No. OSC-1539, page 72; Problem No. 1-51-07. Reactor Coolant Pump Seal Injection
	Rigid support	OFD-101A-1.4					0.750	
	Class B	1-51-07		to				
C03.020.031	1-51-SR38	0-439A	NDE-35	PT	SS		4.000	Calculation No. OSC-1639, page 30.5; Problem No. 1-51-04. High Pressure Injection
	Rigid support	OFD-101A-1.4					1.000	
	Class B	1-51-04		to				
C03.020.033	1-51-SR47	0-439C	NDE-35	PT	SS		4.000	Calcalaton No. OSC-1537 Page 55.1; Problem No. 1-51-5 . System 51
	Rigid support	OFD-101A-1.3					0.750	
	Class B			to				
C03.020.034	1-51-SR48	0-439E	NDE-35	PT	SS		4.000	Calcalaton No. OSC-1537 Page 55.1; Problem No. 1-51-5 . System 51
	Rigid support	OFD-101A-1.3					0.750	
	Class B			to				
C03.020.035	1-51-SR49	0-444	NDE-35	PT	SS		4.000	Calculation No. OSC-1639, page 30.5; Problem No. 1-51-04. High Pressure Injection
	Rigid support	OFD-101A-1.4					0.750	
	Class B	1-51-04		to				
C03.020.037	1-51-SR51	0-444	NDE-35	PT	SS		4.000	Calculation No. OSC-1639, page 30.5; Problem No. 1-51-04. High Pressure Injection
	Rigid support	OFD-101A-1.4					0.750	
	Class B	1-51-04		to				

**CATEGORY C-C, Integral Attachments For
Vessels, Piping, Pumps, And Valves**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 36
02/07/96**

Piping

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS	
C03.020.038	1-51A-H115	0-435B	NDE-35	PT	SS	4.000		Calcalaton No. OSC-1410	
	Rigid support	OFD-101A-1.3				0.750		Page104; Problem No. 1-51-13 . System 51 . HPI CROSS CONNECT & HEADER	
	Class B			to					
C03.020.039	1-51A-H91	0-439C	NDE-35	PT	SS	4.000		Calculation No. OSC-1639, page 32.2; Problem No.	
	Rigid support	OFD-101A-1.4				0.750		1-51-04. High Pressure Injection.	
	Class B	1-51-04		to					
C03.020.043	1-53B-H1	2-0-436E	NDE-35	PT	SS	14.000		Calcalaton No. OSC-407;	
	Rigid restraint	OFD-102A-1.1				0.216		Problem No. 1-53-1;SHT.2 OF 4 PAGE# 105.1; SYSTEM 53 LP INJECTION LINE	
	Class B			to					
C03.020.067	1-JWC-1707	0-490B-2A	NDE-25	MT	CS	0.000		Main Fdwtr. A-Rigid W-Z Axis	
	Rigid support	OM-201-0176				1.000		Attach. closest to W Axis	
	Class B			to					
C03.020.068	1-JWC-1708	0-490B-2A	NDE-25	MT	CS	0.000		Main Fdwtr. A-Rigid W-Z Axis	
	Rigid support	OM-201-0176				1.000		Attach. closest to Z Axis	
	Class B			to					
Total C03.020 Items:		13							
Total Category C-C Items:		13							

**CATEGORY C-F-1, Pressure Retaining Welds
in Austenitic SS or High Alloy Piping**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 37
02/07/96**

**Piping Welds 3 3/8 in. Nominal Wall Thickness
for Piping > NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** Circumferential Weld ****								
C05.011.003	1-53A-01-30L	1-53A-01(3)	NDE-600	UT	SS	10.000		Reference Request for Relief 95-GO-03 for calibration block. Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 53A Category C05.011.
	Circumferential	OFD-102A-1.2				1.125		
	Class B				Valve 1LP-48 to Pipe			
C05.011.003A	1-53A-01-30L	1-53A-01(3)	NDE-35	PT	SS	10.000		
	Circumferential	OFD-102A-1.2				1.125		
	Class B				Valve 1LP-48 to Pipe			

Total C05.011 Items: 2

**CATEGORY C-F-1, Pressure Retaining Welds
In Austenitic SS or High Alloy Piping**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 38
02/07/96

**Piping Welds > 1/5 in. Nom Wall For Piping³
NPS 2 And 2 NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Weld ****								
C05.021.001	1-51A-01-79A	1-51A-01(3) OFD-101A-1.3	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential						Elbow to Valve 1HP-148	
C05.021.001A	1-51A-01-79A	1-51A-01(3) OFD-101A-1.3	NDE-35	PT	SS	4.000 0.531		
Class B	Circumferential						Elbow to Valve 1HP-148	
C05.021.002	1-51A-02-15B	1-51A-02 OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential						Pipe to Tee	
C05.021.002A	1-51A-02-15B	1-51A-02 OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		
Class B	Circumferential						Pipe to Tee	
C05.021.007	1-51A-122-19	1-51A-122 OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential						Pipe to Valve 1HP-410	
C05.021.007A	1-51A-122-19	1-51A-122 OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		
Class B	Circumferential						Pipe to Valve 1HP-410	
C05.021.012	1-51A-123-12	1-51A-123 OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential						Elbow to Pipe	
C05.021.012A	1-51A-123-12	1-51A-123 OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		
Class B	Circumferential						Elbow to Pipe	

**CATEGORY C-F-1, Pressure Retaining Welds
in Austenitic SS or High Alloy Piping**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report

Page 39

02/07/96

Piping Welds > 1/5 in. Nom Wall For Piping³

Oconee 1

NPS 2 And² NPS 4

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
C05.021.018	1-51A-124-10	1-51A-124 OFD-101A-1.3	NDE-600	UT	SS		4.000 0.531	Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential			Elbow to Pipe				
C05.021.018A	1-51A-124-10	1-51A-124 OFD-101A-1.3	NDE-35	PT	SS		4.000 0.531	
Class B	Circumferential			Elbow to Pipe				
C05.021.024	1-51A-125-13	1-51A-125 OFD-101A-1.4	NDE-600	UT	SS		4.000 0.531	Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential			Elbow to Pipe				
C05.021.024A	1-51A-125-13	1-51A-125 OFD-101A-1.4	NDE-35	PT	SS		4.000 0.531	
Class B	Circumferential			Elbow to Pipe				
C05.021.030	1-51A-127-4	1-51A-127 OFD-101A-1.3	NDE-600	UT	SS		4.000 0.531	Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential			Elbow to Pipe				
C05.021.030A	1-51A-127-4	1-51A-127 OFD-101A-1.3	NDE-35	PT	SS		4.000 0.531	
Class B	Circumferential			Elbow to Pipe				
C05.021.045	1-51A-01-89A	1-51A-01(4) OFD-101A-1.3	NDE-600	UT	SS		4.000 0.531	Inspecting this weld in order to meet 7.5% of system 53B. Borrowing from system 51A category C5.21. Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential			Tee to Tee				
C05.021.045A	1-51A-01-89A	1-51A-01(4) OFD-101A-1.3	NDE-35	PT	SS		4.000 0.531	Inspecting this weld in order to meet 7.5% of system 53B. Borrowing from system 51A category C5.21
Class B	Circumferential			Tee to Tee				

**CATEGORY C-F-1, Pressure Retaining Welds
In Austenitic SS or High Alloy Piping**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 40
02/07/96

**Piping Welds > 1/5 in. Nom Wall For Piping³
NPS 2 And 2 NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
C05.021.051 Class B	1-51A-02-16BA Circumferential	1-51A-02 OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 53B. Borrowing from system 51A category C5.21. Reference Request for Relief 95-GO-03 for calibration block.
				Pipe to Elbow				
C05.021.051A Class B	1-51A-02-16BA Circumferential	1-51A-02 OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 53B. Borrowing from system 51A category C5.21
				Pipe to Elbow				
C05.021.061 Class B	1-51A-03-99B Circumferential	1-51A-03(2) OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 54A. Borrowing from system 51A category C5.21. Reference Request for Relief 95-GO-03 for calibration block.
				Pipe to Elbow				
C05.021.061A Class B	1-51A-03-99B Circumferential	1-51A-03(2) OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 54A. Borrowing from system 51A category C5.21
				Pipe to Elbow				
C05.021.068 Class B	1-51A-136-24 Circumferential	1-51A-136 OFD-101A-1.1	NDE-600	UT	SS	2.500 0.552		Reference Request for Relief 95-GO-03 for calibration block.
				Pipe to Elbow				
C05.021.068A Class B	1-51A-136-24 Circumferential	1-51A-136 OFD-101A-1.1	NDE-35	PT	SS	2.500 0.552		
				Pipe to Elbow				
C05.021.074 Class B	1-51A-01-71A Circumferential	1-51A-01(3) OFD-101A-1.3	NDE-600	UT	SS	3.000 0.438		Inspecting this weld in order to meet 7.5% of system 56. Borrowing from system 51A category C5.21. Reference Request for Relief 95-GO-03 for calibration block.
				Elbow to Valve 1HP-114				
C05.021.074A Class B	1-51A-01-71A Circumferential	1-51A-01(3) OFD-101A-1.3	NDE-35	PT	SS	3.000 0.438		Inspecting this weld in order to meet 7.5% of system 56. Borrowing from system 51A category C5.21
				Elbow to Valve 1HP-114				

**CATEGORY C-F-1, Pressure Retaining Welds
In Austenitic SS or High Alloy Piping**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report

Page 41

02/07/96

Piping Welds > 1/5 in. Nom Wall For Piping³

Oconee 1

NPS 2 And 2 NPS 4

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
C05.021.076	1-51A-01-13A	1-51A-01(1) OFD-101A-1.3	NDE-600	UT	SS	3.000 0.216		Reference Request for Relief 95-GO-03 for calibration block. Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Elbow				
C05.021.076A	1-51A-01-13A	1-51A-01(1) OFD-101A-1.3	NDE-35	PT	SS	3.000 0.216		Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Elbow				
C05.021.082	1-51A-01-106A	1-51A-01(4) OFD-101A-1.3	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block. Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Valve 1HP-115				
C05.021.082A	1-51A-01-106A	1-51A-01(4) OFD-101A-1.3	NDE-35	PT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Valve 1HP-115				
C05.021.088	1-51A-02-21B	1-51A-02 OFD-101A-1.4	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block. Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Tee				
C05.021.088A	1-51A-02-21B	1-51A-02 OFD-101A-1.4	NDE-35	PT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Pipe to Tee				
C05.021.094	1-51A-02-7B	1-51A-02 OFD-101A-1.3	NDE-600	UT	SS	4.000 0.531		Reference Request for Relief 95-GO-03 for calibration block. Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Elbow to Elbow				
C05.021.094A	1-51A-02-7B	1-51A-02 OFD-101A-1.3	NDE-35	PT	SS	4.000 0.531		Inspecting this weld in order to meet 7.5% of system 51B. Borrowing from system 51A Category C5.21
Class B	Circumferential			Elbow to Elbow				

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 Inservice Inspection Database Management System

Plan Report
 Page 42
 02/07/96

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

**CATEGORY C-F-1, Pressure Retaining Welds
 In Austenitic SS or High Alloy Piping**

Piping Welds > 1/5 in. Nom Wall For Piping³

NPS 2 And 2 NPS 4

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK CAL BLOCKS	COMMENTS
C05.021.103	1-RCP-FTR1A-SH-1	OM-201-0473	NDE-12	RT	SS	4.000	Reactor Coolant Pump Seal Supply Filter 1A Pc. 10 to Pc. 1 Outlet End.
Class B	Circumferential Term end	OFD-101A-1.4				0.531	
				Filter Hub to Filter Housing			
C05.021.103A	1-RCP-FTR1A-SH-1	OM-201-0473	NDE-35	PT	SS	4.000	
Class B	Circumferential Term end	OFD-101A-1.4				0.531	
				Filter Hub to Filter Housing			
C05.021.104	1-RCP-FTR1A-SH-2	OM-201-0473	NDE-12	RT	SS	4.000	Reactor Coolant Pump Seal Supply Filter 1A Pc. 10 to Pc. 1 Inlet End.
Class B	Circumferential Term end	OFD-101A-1.4				0.531	
				Filter Hub to Filter Housing			
C05.021.104A	1-RCP-FTR1A-SH-2	OM-201-0473	NDE-35	PT	SS	4.000	
Class B	Circumferential Term end	OFD-101A-1.4				0.531	
				Filter Hub to Filter Housing			

Total C05.021 Items: 36

**CATEGORY C-F-1, Pressure Retaining Welds
In Austenitic SS or High Alloy Piping**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 43
02/07/96

**Pipe Branch Connections of Branch Piping³
NPS 2**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Weld ****								
C05.041.002	1-53B-01-87BA	1-53B-01(2) OFD-102A-1.2	NDE-35	PT	SS	8.000 0.250		Reinforcing collar at weld 87B.
Class B	Branch							Reinforcing collar to Pipe
C05.041.011	1-53B-06-21KA	1-53B-06(1) OFD-102A-1.2	NDE-35	PT	SS	8.000 0.148		
Class B	Branch							Pipe to Pipe
C05.041.012	1-53B-06-21KB	1-53B-06(1) OFD-102A-1.2	NDE-35	PT	SS	10.000 0.165		Reinforcing collar for weld 21KA.
Class B	Branch							Reinforcing collar to Pipe
C05.041.024	1-53B-02-121ZA	1-53B-13 OFD-102A-1.1	NDE-35	PT	SS	4.000 0.120		
Class B	Branch							Pipe to Pipe
C05.041.025	1-53B-02-121Z	1-53B-13 OFD-102A-1.1	NDE-35	PT	SS	4.000 0.120		Reinforcing collar weld at weld 121ZA.
Class B	Branch							Reinforcing collar to Pipe
Total C05.041 Items:		5						

**CATEGORY C-F-2, Pressure Retaining Welds
in Carbon Or Low Alloy Steel Piping**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 44
02/07/96

**Piping Welds 3/8 in. Nominal Wall Thickness
for Piping > NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Weld ****								
C05.051.006	1-MS17B-A	1-01A-1(1)	NDE-600	UT	CS	34.000		Grinnell subassembly MS17B. Reference Request for Relief 95-GO-03 for calibration block.
	Circumferential					1.164		
	Class B			Elbow to Pipe				
C05.051.006A	1-MS17B-A	1-01A-1(1)	NDE-25	MT	CS	34.000		
	Circumferential					1.164		
	Class B			Elbow to Pipe				
C05.051.009	1-01A-01-29C	1-01A-01(3) OFD-122A-1.1	NDE-600	UT	CS	12.000		Reference Request for Relief 95-GO-03 for calibration block.
	Circumferential					0.562		
	Class B			Pipe to Elbow				
C05.051.009A	1-01A-01-29C	1-01A-01(3) OFD-122A-1.1	NDE-25	MT	CS	12.000		
	Circumferential					0.562		
	Class B			Pipe to Elbow				
C05.051.012	1-01A-02-11BA	1-01A-02 OFD-122A-1.1	NDE-600	UT	CS	24.000		Reference Request for Relief 95-GO-03 for calibration block.
	Circumferential					0.969		
	Class B	Term end		Reducer to Nozzle SG 1A				
C05.051.012A	1-01A-02-11BA	1-01A-02 OFD-122A-1.1	NDE-25	MT	CS	24.000		
	Circumferential					0.969		
	Class B	Term end		Reducer to Nozzle SG 1A				
C05.051.017	1-01A-1-99	1-01A-01(2) OFD-122A-1.3	NDE-600	UT	CS	8.000		Reference Request for Relief 95-GO-03 for calibration block.
	Circumferential					0.500		
	Class B			Elbow to Pipe				
C05.051.017A	1-01A-1-99	1-01A-01(2) OFD-122A-1.3	NDE-25	MT	CS	8.000		
	Circumferential					0.500		
	Class B			Elbow to Pipe				

**CATEGORY C-F-2, Pressure Retaining Welds
in Carbon Or Low Alloy Steel Piping**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 45
02/07/96**

**Piping Welds ³ 3/8 in. Nominal Wall Thickness
for Piping > NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
C05.051.030	1-FWD88-C	1-FWD88	NDE-600	UT	CS	14.000		Grinnell subassembly FWD88. Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential					0.750	Elbow to Pipe	
C05.051.030A	1-FWD88-C	1-FWD88	NDE-25	MT	CS	14.000		
Class B	Circumferential					0.750	Elbow to Pipe	
C05.051.033	1-20B-21-16-2	1-20B-21 OFD-116A-1.1	NDE-600	UT	CS	48.000		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential					0.500	Valve to Pipe 1PRV-1	
C05.051.033A	1-20B-21-16-2	1-20B-21 OFD-116A-1.1	NDE-25	MT	CS	48.000		
Class B	Circumferential					0.500	Valve to Pipe 1PRV-1	
C05.051.036	1-LPSW-344-21	1-LPSW-344 OFD-124B-1.2	NDE-600	UT	CS	8.000		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential					0.500	Pipe to Elbow	
C05.051.036A	1-LPSW-344-21	1-LPSW-344 OFD-124B-1.2	NDE-25	MT	CS	8.000		
Class B	Circumferential					0.500	Pipe to Elbow	
C05.051.040	1-LPSW-345-17	1-LPSW-345 OFD-124B-1.2	NDE-600	UT	CS	8.000		Reference Request for Relief 95-GO-03 for calibration block.
Class B	Circumferential					0.500	Flange to Pipe	
C05.051.040A	1-LPSW-345-17	1-LPSW-345 OFD-124B-1.2	NDE-25	MT	CS	8.000		
Class B	Circumferential					0.500	Flange to Pipe	

**CATEGORY C-F-2, Pressure Retaining Welds
In Carbon Or Low Alloy Steel Piping**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 46
02/07/96

**Piping Welds 3/8 in. Nominal Wall Thickness
for Piping > NPS 4**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
C05.051.049	1-LPSW-346-21	1-LPSW-346	NDE-600	UT	CS	8.000		Reference Request for Relief 95-GO-03 for calibration block.
	Circumferential	OFD-124B-1.2				0.500		
Class B				Elbow to Pipe				
C05.051.049A	1-LPSW-346-21	1-LPSW-346	NDE-25	MT	CS	8.000		
	Circumferential	OFD-124B-1.2				0.500		
Class B				Elbow to Pipe				
Total C05.051 Items:		18						
**** Longitudinal Weld ****								
C05.052.002	1-20B-21-16-2L	1-20B-21	NDE-600	UT	CS	48.000		Reference Request for Relief 95-GO-03 for calibration block. Examine with C05.051.033
	Longitudinal	OFD-116A-1.1				0.500		
Class B				Valve to Pipe 1PRV-1				
C05.052.002A	1-20B-21-16-2L	1-20B-21	NDE-600	MT	CS	48.000		Reference Request for Relief 95-GO-03 for calibration block. Examine with C05.051.033A
	Longitudinal	OFD-116A-1.1				0.500		
Class B				Valve to Pipe 1PRV-1				
Total C05.052 Items:		2						

**CATEGORY C-F-2, Pressure Retaining Welds
in Carbon Or Low Alloy Steel Piping**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 47
02/07/96

Pipe Branch Connections of Branch Piping³
NPS 2

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Circumferential Weld ****								
C05.081.004	1-03-09-40D	1-03-09	NDE-25	MT	CS	14.000		
	Branch	OFD-121B-1.3				0.750		
	Class B			Pipe to Tee				
C05.081.006	1-FWD67-A	1-FWD67	NDE-25	MT	CS	20.000		Grinnell subassembly FWD67
	Branch					1.031		
	Class B			Pipe to Pipe				

Total C05.081 Items: 2

Total Category C-F-2 Items: 65

**CATEGORY C-G, Pressure Retaining Welds
In Pumps And Valves**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 48
02/07/96

Valves

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Valve Body Welds ****								
C06.020.001	1-FDW-345	OM-245-659	NDE-25	MT	CS	6.000		Valve body weld on valve 1FDW-345
	Circumferential	OFD-121D-1.1				1.136		
	Class B							Valve Body Neck to Valve Body
<hr/>								
Total C06.020 Items:		1						
Total Category C-G Items:		1						

**CATEGORY D-B, Systems In Support Of ECC,
CHR, Atmos. Cleanup, And Reactor RHR**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 49
02/07/96

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Component Supports and Restraints ****								
D02.020.006	1-03-NPS-H16	0-478A	QAL-14	VT-3	NA		3.000	Calclaton No. OSC-1224-16
	Rigid restraint	OFD-121D-1.1					0.203	Page 44; Problem No.1- 03A-14.
	Class C			to				System 03A AUX. SERVICE WATER PIPE
D02.020.009	1-03A-DE063	1-0-400B	QAL-14	VT-3	NA		6.000	Calclaton No. OSC-342
	Rigid restraint	OFD-121D-1.1					0.500	Page 103; Problem No. 03A-9 . System 03A
	Class C			to				6"EMER. F.WTR. BYPASS
D02.020.031	1-03A-H72	1-0-437B	QAL-14	VT-3	NA		6.000	Calclaton No. OSC-1224-19
	Rigid restraint	OFD-121D-1.1					0.500	Page 27; Problem No.1- 03A-13.
	Class C			to				System 03A AUX. SERVICE WATER PIPE
D02.020.066	1-04A-R5	2-0-439B	QAL-14	VT-3	NA		6.000	Calclaton No. OSC-1404
	Rigid restraint	OFD-121B-1.5					1.000	Page 77; Problem No.1- 04A-06.
	Class C			to				System 04A OTSG SECONDARY SIDE DRAIN TO COND.
D02.020.067	1-04A-R6	2-0-439B	QAL-14	VT-3	NA		6.000	Calclaton No. OSC-1404
	Rigid restraint	OFD-121B-1.5					0.375	Page 77; Problem No.1- 04A-06.
	Class C			to				System 04A OTSG SECONDARY SIDE DRAIN TO COND.
D02.020.068	1-07A-H12	6-0-402A	QAL-14	VT-3	NA		24.000	Calclaton No. OSC-361
	Rigid restraint	OFD-121A-1.7					1.750	Page 88.1;
	Class C			to				Problem No.1-07A-01 System 07A
D02.020.072	1-08-H4051	0-400A	QAL-14	VT-3	NA		10.000	Calculation Number OSC-1902 Sheet 2of 2; Problem
	Rigid restraint	OFD-122A-1.4					0.250	1-08-01 Page 39. System 08 Emergency Feedwater
	Class C			to				Pump Turbine Exhaust to Condenser1B.
D02.020.075	1-14B-ASR17	0-436E	QAL-14	VT-3	NA		8.000	Calculation No. OSC-394, page 78; Problem No.
	Rigid restraint	OFD-121D-1.2					0.500	4-14-3, sh. 3. Auxiliary Feed water Lines from
	Class C	4-14-3		to				Auxiliary Sevice Water Pump

**CATEGORY D-B, Systems In Support Of ECC,
CHR, Atmos. Cleanup, And Reactor RHR**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 50
02/07/96**

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
D02.020.078	1-14B-CLF-901 Rigid restraint Class C	0-400B OFD-124A-1.1	QAL-14	VT-3 to	NA	18.000 0.322		Calculation No. OS-395 Page 40, problem no. 1-14A-01 page 1 of 2. Low Pressure Service Water
D02.020.084	1-14B-H2 Rigid restraint Class C	1-0-439B OFD-124B-1.2 1-14-06	QAL-14	VT-3 to	NA	14.000 0.500		File OSC-1541 pg. 100. Low Pressure Service Water Supply from Penetration 21, 30, 31 and 32 to Coolers 1A & 1B.
D02.020.089	1-14B-RMC-0503 Rigid restraint Class C	0-439B OFD-124B-1.2 1-14-04	QAL-14	VT-3 to	NA	8.000 0.237		File OSC-376 pg. 78. Low Pressure Service Water Discharge I. E. B. 79-14, System 14B, sheet 1 of 3
D02.020.095	1-14B-SR43 Rigid restraint Class C	1-0-439B OFD-124B-1.2 1-14-04	QAL-14	VT-3 to	NA	18.000 0.322		File OSC-376 pg. 78. Low Pressure Service Water Discharge I. E. B. 79-14, System 14B, sheet 1 of 3
D02.020.099	1-14B-SR60 Rigid restraint Class C	0-437A OFD-124B-1.1	QAL-14	VT-3 to	NA	20.000 1.000		Calcalton No. OSC-1541; Problem No. 1-14-06 SHT. 1 OF 3. System 14B;PAGE 100.1; LPSW SUPPLY TO RB COMPONENT COOLERS & LP COOLERS 1A & 1B
D02.020.102	1-57-H1 Rigid restraint Class C	0-481A OFD-100A-1.2	QAL-14	VT-3 SS to	NA	12.000 0.750		Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
Total D02.020 Items:		14						

**CATEGORY D-B, Systems In Support Of ECC,
CHR, Atmos. Cleanup, And Reactor RHR**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 51
02/07/96**

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Mechanical and Hydraulic Snubbers ****								
D02.030.003	1-03-H4171	0-401B	QAL-14	VT-3	NA		24.000	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building. Inspect with Item No. F01.050.057
	Mech snubber	OFD-121B-1.3					0.322	
	Class C			to				
Total D02.030 Items:		1						

**CATEGORY D-B, Systems In Support Of ECC,
CHR, Atmos. Cleanup, And Reactor RHR**

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 52
02/07/96**

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Spring Type Supports ****								
D02.040.004	1-03-H50	0-551	QAL-14	VT-3	NA	24.000		Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
	Spring hanger	OFD-121B-1.3		to		0.187		
	Class C							
D02.040.008	1-03-H63	0-439A	QAL-14	VT-3	NA	24.000		Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
	Spring hanger	OFD-121B-1.3		to		0.187		
	Class C							
D02.040.015	1-14B-H20	0-436D	QAL-14	VT-3	NA	16.000		Calcalaton No. OSC-396; Problem No. 1-14-04 SHT.2 OF 3. System 14B;PAGE 77; LP SERVICE WATER DISCHARGE
	Spring hanger	OFD-124B-1.1		FIG# 163 to		0.187		
	Class C							

Total D02.040 Items: 3

**CATEGORY D-B, Systems In Support Of ECC,
CHR, Atmos. Cleanup, And Reactor RHR**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 53
02/07/96

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
**** Constant Load Type Supports ****								
D02.050.001	1-04A-R12	2-0-439B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-1404
	Constant support	OFD-121B-1.5					0.437	Page 77;Problem No.1- 04A-06.
Class C				to				System 04A OTSG SECONDARY SIDE DRAIN TO COND.
<hr/>								
Total D02.050 Items:		1						
Total Category D-B Items:		19						

**CATEGORY D-C, Systems In Support Of RHR
From Spent Fuel Storage Pool**

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 54
02/07/96

Integral Attachment

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
**** Component Supports and Restraints ****								
D03.020.001	1-56-DE034	4-0-437B	QAL-14	VT-3	NA		8.000	Calcalaton No. OS-421 Page 95; Problem No.4-56-02. System 56 Spent Fuel Cooling Fig.162 Size 8
	Rigid restraint	OFD-104A-1.2					0.125	
	Class C			to				
D03.020.003	1-56-H17	5-0-437B	QAL-14	VT-3	NA		8.000	Calcalaton No. OSC-1359-02 Page 28 ; Problem No.4-56-07 Spent Fuel Cooling (Suction Side) System 56 (Fig. 162 Size 8)
	Rigid restraint	OFD-104A-1.1					0.125	
	Class C			to				
D03.020.008	1-56-H5133	0-437B	QAL-14	VT-3	NA		8.000	Calcalaton No. OSC-1359-02 Page 28 ; Problem No.4-56-07 Spent Fuel Cooling (Suction Side) System 56
	Rigid restraint	OFD-104A-1.1					0.125	
	Class C			Fig.162 to				
D03.020.012	1-56-JTC-2903	0-443	QAL-14	VT-3	NA		8.000	Calcalaton No. OSC-421 Page 94; Problem No.4-56-02 Spent Fuel Cooling System 56
	Rigid restraint	OFD-104A-1:1					0.500	
	Class C			to				
Total D03.020 Items:		4						
Total Category D-C Items:		4						

CATEGORY F-A, Supports (Category A)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 55
02/07/96

**Class 1 Mech. Conn. to Press. Retaining Comp.
& Bld. Structure**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIAT/THK	CAL BLOCKS	COMMENTS
F01.010.005	1-51A-H6228	0-478A	QAL-14	VT-3	NA		2.500	Calcalaton No. OSC-1660-11; Problem No. 1-55-03;SHT.1 OF 4; System 51A;PAGE# 65; RC PUMP PIPING TO HP INJECTION LETDOWN COOLERS
	Rigid restraint	OFD-101A-1.1					0.000	
Class A				to				
Total F01.010 Items:		1						
F01.012.003	1-50-H2A	0-479A	QAL-14	VT-3	NA		10.000	Pressurizer Surge Lines. Inspect with Item No. F01.050.003
	Hyd snubber	OFD-100A-1.1					0.000	
Class A				to				
F01.012.006	1-53A-H39C	0-481A	QAL-14	VT-3	NA		1.500	File OSC-1314-06 page 129. Pressurizer Relief Valve System
	Spring hanger	OFD-100A-1.2					0.000	
Class A		1-50-01		to				
F01.012.008	1-53A-H6200	0-479A	QAL-14	VT-3	NA		3.000	Calcalaton No. OSC-1301-06; Problem No. 1-53-07; PAGE# 91; SYSTEM 53A; DECAY HEAT REMOVAL SYS
	Spring hanger	OFD-102A-1.1					0.000	
Class A				to				
F01.012.009	1-57-H13-A	0-481A	QAL-14	VT-3	NA		4.000	Calcalaton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System. Inspect with Item No. F01.050.022
	Hyd snubber	OFD-100A-1.2					0.000	
Class A				to				
Total F01.012 Items:		4						

CATEGORY F-A, Supports (Category A)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 56
02/07/96

Class 2 Weld Connections to Building Structure

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.020.008	1-14-H54	0-480A	QAL-14	VT-3	NA		8.000	Calculation No. OSC-1407, Problem 1-14-14 sh. 17. Low Pressure Service Water from Penetration 32 to Cooler
	Rigid restraint	OFD-124B-1.3					0.000	
	Class B	1-14-14		to				
F01.020.009	1-14-H63	0-480A	QAL-14	VT-3	NA		8.000	Calculation No. OSC-1407, Problem 1-14-14 sh. 17. Low Pressure Service Water from Penetration 32 to Cooler
	Rigid restraint	OFD-124B-1.3					0.000	
	Class B	1-14-14		ss to				
F01.020.016	1-51A-H100	0-439A	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 32.2; Problem No. 1-51-04. High Pressure Injection.
	Rigid support	OFD-101A-1.4					0.000	
	Class B	1-51-04		to				
F01.020.022	1-51B-DE051	2-0-437A	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1539, page 73; Problem No. 1-51-07. High Pressure Injection.
	Rigid support	OFD-101A-1.4					0.000	
	Class B	1-51-07		to				
F01.020.027	1-53B-H1	2-0-436E	QAL-14	VT-3	NA		14.000	Calculaton No. OSC-407; Problem No. 1-53-1;SHT.2 OF 4 PAGE# 105.1; SYSTEM 53 LP INJECTION LINE
	Rigid restraint	OFD-102A-1.1					0.216	
	Class B			to				
F01.020.037	1-54A-DE10	0-435B	QAL-14	VT-3	NA		8.000	Calculaton No. OS-415 Page 50; Problem No. 1-54-2 Sheet 1 of 1. System 54A Auxiliary Building. Examine during outage 16 for surveillance item from second interval.
	Rigid restraint	OFD-103A-1.1					0.125	
	Class B			Sway Strut Fig162 to				
F01.020.038	1-54A-H23	3-0-439A	QAL-14	VT-3	NA		8.000	Calculaton No. OS-416 Page 58.1; Problem No. 1-54-03, Sheet 1 of 1. System 54A Auxiliary Building.
	Rigid restraint	OFD-103A-1.1					0.000	
	Class B			to				
F01.020.043	1-56-SR18	0-437B	QAL-14	VT-3	NA		8.000	Calculaton No. OS-421 Page 95;Problem No.4-56-02. System 56 Spent Fuel Cooling
	Rigid restraint	OFD-104A-1.2					0.500	
	Class B			to				

Total F01.020 Items: 8

CATEGORY F-A, Supports (Category B)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 57
02/07/96

Class 2 Weld Connections to Building Structure

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.021.005	1-14-H19B	0-479A	QAL-14	VT-3	NA		8.000	File OSC-1407 Sh 16. Low Pressure Service Water from Penetration 32 to Cooler1B. Problem No.1-14-14
	Rigid restraint	OFD-124B-1.2					0.000	
Class B		1-14-14		to				
F01.021.008	1-14-H6	0-479A	QAL-14	VT-3	NA		6.000	File OSC-1409 pg. 16. Low Pressure Service Water - Reactor Bldg. Cooling (sheet 1). Problem No;1-14-15
	Rigid restraint	OFD-124B-1.2					0.216	
Class B		1-14-15		to				
F01.021.013	1-51A-H91	0-439C	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 32.2; Problem No. 1-51-04. High Pressure Injection.
	Rigid support	OFD-101A-1.4					0.750	
Class B		1-51-04		to				
F01.021.024	1-56-DE001	0-439C	QAL-14	VT-3	NA		8.000	Calculation No. OSC-421 Page 93; Problem No.4-56-02 Spent Fuel Cooling System 56
	Rigid restraint	OFD-104A-1.1					0.000	
Class B				to				
Total F01.021 Items:		4						
F01.022.012	1-51A-H3	1-0-444	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1537 Page 56.1; Problem No. 1-51-5 . System 51
	Spring hanger	OFD-101A-1.3					0.500	
Class B				to				
F01.022.016	1-53B-H1	3-0-444	QAL-14	VT-3	NA		12.000	Calculation No. OSC-407; Problem No. 1-53-1;SHT.2 OF 4 PAGE# 105.1; SYSTEM 53 LP INJECTION LINE
	Spring hanger	OFD-102A-1.1					1.000	
Class B				to				
F01.022.017	1-53B-H10	4-0-435B	QAL-14	VT-3	NA		14.000	Calculation No. OS-407; Problem No. 1-53-1;SHT.1 OF 4 PAGE#104; SYSTEM 53B; LP INJECTION LINE
	Spring hanger	OFD-102A-1.1					0.237	
Class B				to				

CATEGORY F-A, Supports (Category C)

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 58
02/07/96

Class 2 Weld Connections to Building Structure

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
F01.022.024	1-54A-R5	3-0-435B	QAL-14	VT-3	NA		8.000	Calcalaton No. OSC-1628 Page 60; Problem No. 1-54-01 Sheet 1 of 1. System 54A Auxiliary Building.
	Rigid restraint	OFD-103A-1.1					0.000	
Class B				Sway Strut to				

Total F01.022 Items: 4

CATEGORY F-A, Supports (Category A)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 59
02/07/96

**Class 3 Weld/Mech Conns at Inter Joints in
Multiconn Int & Nonint Supp**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.030.017 Class C	1-04A-H17 Rigid restraint	2-0-439B OFD-121B-1.5	QAL-14	VT-3 to	NA		6.000 0.000	Calcaluton No. OSC-1404 Page 77; Problem No.1- 04A-06. System 04A OTSG SECONDARY SIDE DRAIN TO COND. This hanger is currently required to be examined during Outage 1. As this hanger is adjacent to hanger F01.031.006 (reportable Outage 1) it is also being examined per IWF-2430(a).
F01.030.020 Class C	1-07A-GTE-1901 Rigid restraint	0-400B OFD-121A-1.8	QAL-14	VT-3 to	NA		8.000 0.000	Calcaluton No. OSC-362 Page 56; Problem No.1-07A-2 L.P.& H.P.Condensate System 07A
F01.030.021 Class C	1-07A-SR8 Rigid restraint	0-400B OFD-121A-1.8	QAL-14	VT-3 to	NA		8.000 0.000	Calcaluton No. OSC-362 Page 55; Problem No.1-07A-2 L.P.& H.P.Condensate System 07A
F01.030.022 Class C	1-08-H4050 Rigid restraint	0-400A OFD-122A-1.4	QAL-14	VT-3 to	NA		10.000 0.000	Calculation Number OSC-1902 Sheet 2 of 2; Problem 1-08-01 Page 39. System 08 Emergency Feedwater Pump Turbine Exhaust to Condenser1B.
F01.030.035 Class C	1-56-DE009 Rigid restraint	0-438C OFD-104A-1.1	QAL-14	VT-3 to	NA		8.000 0.000	Calcaluton No. OSC-421 Page 94; Problem No.4-56-02 Spent Fuel Cooling System 56
F01.030.036 Class C	1-56-H17 Rigid restraint	5-0-437B OFD-104A-1.1	QAL-14	VT-3 to	NA		8.000 0.125	Calcaluton No. OSC-1359-02 Page 28 ; Problem No.4-56-07 Spent Fuel Cooling (Suction Side) System 56 (Fig. 162 Size 8)
F01.030.041 Class C	1-57-H1 Rigid restraint	0-481A OFD-100A-1.2	QAL-14	VT-3 SS to	NA		12.000 0.750	Calcaluton No. OS-1313-06 Page 44.1; Problem No.1-57-01. System 57 Pressurizer Relief Valve System

CATEGORY F-A, Supports (Category A)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 60
02/07/96

**Class 3 Weld/Mech Conns at Inter Joints in
Multiconn Int & Nonint Supp**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
F01.030.042	1-04A-H16	2-0-439B	QAL-14	VT-3	NA		6.000	Calcalton No. OSC-1404 Page 77;Problem No.1- 04A-06. System 04A OTSG SECONDARY SIDE DRAIN TO COND. This hanger is being added to Outage 1 because it is adjacent to hanger F01.031.006 (reportable Outage 1). This hanger will be examined per IWF-2430(a).
	Rigid restraint	OFD-121B-1.5					0.000	
Class C								
to								

Total F01.030 Items: 8

F01.031.002	1-03-H6175	0-480A	QAL-14	VT-3	NA		6.000	Calcalton No. OSC-1224-16 Page 41;Problem No.1- 03A-14. System 03A AUX. SERVICE WATER PIPE
	Rigid restraint	OFD-121D-1.1					0.000	
Class C								
to								
F01.031.006	1-04A-R5	2-0-439B	QAL-14	VT-3	NA		6.000	Calcalton No. OSC-1404 Page 77;Problem No.1- 04A-06. System 04A OTSG SECONDARY SIDE DRAIN TO COND.
	Rigid restraint	OFD-121B-1.5					1.000	
Class C								
to								
F01.031.008	1-08-H4055	0-400A	QAL-14	VT-3	NA		10.000	Calculation Number OSC-1902 Sheet 2 of 2; Problem 1-08-01 Page 39. System 08 Emergency Feedwater Pump Turbine Exhaust to Condenser1B.
	Rigid restraint	OFD-122A-1.4					0.000	
Class C								
to								
F01.031.016	1-04A-R6	2-0-439B	QAL-14	VT-3	NA		6.000	Calcalton No. OSC-1404 Page 77;Problem No.1- 04A-06. System 04A OTSG SECONDARY SIDE DRAIN TO COND. This hanger was added to the ISI Plan per IWF-2430(a); for the reportable hanger F01.031.006 id'd during Outage 1, third interval.
	Rigid restraint	OFD-121B-1.5					0.375	
Class C								
to								

Total F01.031 Items: 4

F01.032.004	1-03-H63	0-439A	QAL-14	VT-3	NA		24.000	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
	Spring hanger	OFD-121B-1.3					0.187	
Class C								
to								

CATEGORY F-A, Supports (Category C)

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 61
02/07/96**

**Class 3 Weld/Mech Conns at Inter Joints in
Multiconn Int & Nonint Supp**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
F01.032.006	1-04A-R12	2-0-439B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-1404
	Constant suppor	OFD-121B-1.5					0.437	Page 77;Problem No.1- 04A-06.
Class C				to				System 04A OTSG SECONDARY SIDE DRAIN TO COND.

Total F01.032 Items: 2

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report

Page 62

02/07/96

Clearances of Guides & Stops, Align of Supps,

Oconee 1

Assembly of Supp Items

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
F01.040.006	1-DHRC-A-SUPPORT	OM-201-286 OFD-102A-1.2	QAL-14	VT-3	NA		0.000 0.000	Decay Heat Removal Cooler 1A
Class B				to				
Total F01.040 Items:		1						

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 63
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.050.001 Class A	1-50-H12 Hyd snubber	0-479A OFD-100A-1.1	QAL-14	VT-3 to	NA		2.500 0.000	Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50
F01.050.002 Class A	1-50-H1A Hyd snubber	0-479A OFD-100A-1.1	QAL-14	VT-3 to	NA		10.000 0.000	Pressurizer Surge Lines
F01.050.003 Class A	1-50-H2A Hyd snubber	0-479A OFD-100A-1.1	QAL-14	VT-3 to	NA		10.000 0.000	Pressurizer Surge Lines.
F01.050.004 Class A	1-50-H3 Hyd snubber	0-481A OFD-100A-1.2 1-50-01	QAL-14	VT-3 to	NA		2.500 0.154	File OSC-1314-06 page 129. Pressurizer Relief Valve System
F01.050.005 Class A	1-50-H3A Hyd snubber	0-479A OFD-100A-1.1	QAL-14	VT-3 to	NA		10.000 0.000	Pressurizer Surge Lines
F01.050.006 Class A	1-50-H7 Hyd snubber	0-481A OFD-100A-1.1	QAL-14	VT-3 to	NA		2.500 0.500	Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50
F01.050.007 Class A	1-50-H8 Hyd snubber	0-480A OFD-100A-1.1	QAL-14	VT-3 to	NA		2.500 0.000	Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50
F01.050.008 Class A	1-50-H9 Hyd snubber	0-480A OFD-100A-1.1	QAL-14	VT-3 to	NA		2.500 0.000	Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 64
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.050.009	1-50-H10 Hyd snubber Class A	0-480A OFD-100A-1.1	QAL-14	VT-3 to	NA	2.500 0.000		Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50
F01.050.011	1-50-H11 Hyd snubber Class A	0-481A OFD-100A-1.2 1-50-01	QAL-14	VT-3 to	NA	2.500 0.000		File OSC-1314-06 page 129. Pressurizer Relief Valve System.
F01.050.012	1-51A-H17A Hyd snubber Class A	0-479A OFD-101A-1.4 1-51-15	QAL-14	VT-3 to	NA	2.500 0.145		Calculation No. OSC-1304-06, page 61; Problem No. 1-51-15. High Pressure Injection.
F01.050.013	1-53A-H5A Hyd snubber Class B	0-479A OFD-102A-1.1	QAL-14	VT-3 to	NA	12.000 0.000		Calcalaton No. OSC-1301-06; Problem No. 1-53-07; Page #92; System 53A; Decay Heat Removal System
F01.050.014	1-53A-H5B Hyd snubber Class B	0-479A OFD-102A-1.1	QAL-14	VT-3 to	NA	12.000 0.000		Calcalaton No. OSC-1301-06; Problem No. 1-53-07; Page #92; System 53A; Decay Heat Removal System.
F01.050.015	1-03-H7B Hyd snubber Class B	0-480A OFD-121B-1.3	QAL-14	VT-3 to	NA	24.000 0.237		Calculation No. OSC-1297-06 ; Problem No. 1-03-05 . System 03 Steam Generator 1B .
F01.050.016	1-50-H11 Hyd snubber Class A	0-480A OFD-100A-1.1	QAL-14	VT-3 to	NA	1.500 0.000		Calcalaton No. OSC-1314-06 Page 129; Problem No.1-50-01 Pressurizer Spray System System 50.
F01.050.017	1-03-H10A Hyd snubber Class B	0-480B OFD-121B-1.3	QAL-14	VT-3 to	NA	20.000 0.000		Calculation No. OSC-1297-06; Problem No. 1-03-06 Sheet 1 of 2; System 03 Steam Generator 1A .

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 65
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK CAL BLOCKS	COMMENTS
F01.050.018	1-53A-H40C	0-481A	QAL-14	VT-3	NA	1.500	File OSC-1314-06 page 129. Pressurizer Relief Valve System
Class A	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.019	1-53A-H41C	0-481A	QAL-14	VT-3	NA	2.500	File OSC-1314-06 page 129. Pressurizer Relief Valve System
Class A	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.020	1-57-H10	0-481A	QAL-14	VT-3	NA	6.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
Class C	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.021	1-57-H11	0-481A	QAL-14	VT-3	NA	6.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
Class C	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.022	1-57-H13-A	0-481A	QAL-14	VT-3	NA	4.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System.
Class A	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.023	1-57-H14	0-481A	QAL-14	VT-3	NA	8.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System.
Class C	Hyd snubber	OFD-100A-1.2		to		0.216	
F01.050.024	1-57-H15	0-481A	QAL-14	VT-3	NA	8.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
Class C	Hyd snubber	OFD-100A-1.2		to		0.000	
F01.050.025	1-57-H17	0-481A	QAL-14	VT-3	NA	6.000	Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
Class C	Hyd snubber	OFD-100A-1.2		to		0.000	

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 66
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
F01.050.026	1-57-H18	0-481A	QAL-14	VT-3	NA	6.000		Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
	Hyd snubber	OFD-100A-1.2				0.000	to	
	Class C							
F01.050.027	1-57-H22	0-481A	QAL-14	VT-3	NA	6.000		Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
	Hyd snubber	OFD-100A-1.2				0.000	to	
	Class C							
F01.050.028	1-57-H26	0-481A	QAL-14	VT-3	NA	6.000		Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System
	Hyd snubber	OFD-100A-1.2				0.000	to	
	Class C							
F01.050.029	1-57-H9	0-481A	QAL-14	VT-3	NA	6.000		Calcalton No. OS-1313-06 Page 44.1;Problem No.1-57-01. System 57 Pressurizer Relief Valve System.
	Hyd snubber	OFD-100A-1.2				1.000	to	
	Class C							
F01.050.030	1-01A-H10B	0-481B	QAL-14	VT-3	NA	24.250		Calcalton No. OSC-1296-06; Problem No. 1-01-08; System 01A;Page# 6 (1)-25.18; Main Steam From Pen 28 TO SG 1B
	Hyd snubber	OFD-122A-1.1				0.437	PIPE FAB SKETCH 6" PIPE to	
	Class B							
F01.050.031	1-01A-H11A	0-481B	QAL-14	VT-3	NA	24.250		Calcalton No. OSC-1296-06; Problem No. 1-01-07; System 01A;Page# 6 (2)-24.23A Main Steam From Pen 26 TO SG 1A
	Hyd snubber	OFD-122A-1.1				0.437	PIPE FAB SKETCH 6" PIPE to	
	Class B							
F01.050.032	1-01A-H11B	0-481B	QAL-14	VT-3	NA	24.250		Calcalton No. OSC-1296-06; Problem No. 1-01-08; System 01A;Page# 6 (1)-25.18; Main Steam From Pen 28 TO SG 1B
	Hyd snubber	OFD-122A-1.1				0.437	PIPE FAB SKETCH 6" PIPE to	
	Class B							
F01.050.033	1-01A-H12A	0-481B	QAL-14	VT-3	NA	24.250		Calcalton No. OSC-1296-06; Problem No. 1-01-07; System 01A;Page# 6 (2)-24.23A Main Steam From Pen 26 TO SG 1A
	Hyd snubber	OFD-122A-1.1				0.375	to	
	Class B							

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 67
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.050.034	1-01A-DE005	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.000	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht.1 of 3; System 01A;Page# 131.1; Main Steam Piping.
Class B	Hyd snubber			to				
F01.050.035	1-01A-DE006	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.000	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht.1 of 3; System 01A;Page# 131.1; Main Steam Piping.
Class B	Hyd snubber			to				
F01.050.036	1-01A-R-2-1	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.687	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht.1 of 3; System 01A;Page# 131.1; Main Steam Piping
Class B	Hyd snubber			to				
F01.050.037	1-01A-R-2-2	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.687	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht. 1 of 3; System 01A;Page# 131.1; Main Steam Piping
Class B	Hyd snubber			to				
F01.050.038	1-01A-R12	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.000	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht.2 of 3; System 01A;Page# 132; Main Steam Piping
Class B	Hyd snubber			to				
F01.050.039	1-01A-R9-1	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.687	Calcutaton No. OSC-320; Problem No. 1-01-01;Sht.1 of 3; System 01A; Page# 131.1; Main Steam Piping
Class B	Hyd snubber			to				
F01.050.040	1-01A-R9-2	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.687	Calcutaton No. OSC-320; Problem No. 1-01-01; sht. 1 of 3; System 01A; Page# 131.1; Main Steam Piping
Class B	Hyd snubber			to				
F01.050.041	1-01A-R9-3	0-550 OFD-122A-1.1	QAL-14	VT-3	NA		34.000 0.687	Calcutaton No. OSC-320; Problem No. 1-01-01; Sht. 1 of 3; System 01A; Page# 131.1; Main Steam Piping
Class B	Hyd snubber			to				

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 68
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
F01.050.042	1-01A-R9-4	0-550	QAL-14	VT-3	NA		34.000	Calcalaton No. OSC-320; Problem No. 1-01-01; Sht.1 of 3; System 01A; Page# 131.1; Main Steam Piping
Class B	Hyd snubber	OFD-122A-1.1		to			0.687	
F01.050.043	1-03-R12	0-551	QAL-14	VT-3	NA		24.000	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
Class C	Hyd snubber	OFD-121B-1.3		to			1.000	
F01.050.044	1-03-R7	0-551	QAL-14	VT-3	NA		24.000	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
Class C	Hyd snubber	OFD-121B-1.3		to			1.000	
F01.050.045	1-03A-SR56	1-0-400B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-342 Page 104; Problem No. 03A-9 . System 03A 6" Emergency Feedwater Bypass
Class C	Hyd snubber	OFD-121D-1.1		to			0.000	
F01.050.046	1-03A-SR57	1-0-400B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-342 Page 104; Problem No. 03A-9 . System 03A 6" Emergency Feedwater Bypass
Class C	Hyd snubber	OFD-121D-1.1		to			0.000	
F01.050.047	1-03A-SR58	1-0-400B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-342 Page 104; Problem No. 03A-9 . System 03A 6" Emergency Feedwater Bypass
Class C	Hyd snubber	OFD-121D-1.1		to			0.000	
F01.050.048	1-03A-SR59	1-0-400B	QAL-14	VT-3	NA		6.000	Calcalaton No. OSC-342 Page 104; Problem No. 03A-9 . System 03A 6" Emergency Feedwater Bypass
Class C	Hyd snubber	OFD-121D-1.1		to			0.000	
F01.050.049	1-03A-SR50	1-0-401A	QAL-14	VT-3	NA		6.000	Calculation Number OSC-339; Problem Number 1-03A-5 Sheet 1 of 4; System 03A Emergency Feedwater.
Class C	Hyd snubber	OFD-121B-1.3		to			0.000	

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 69
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.050.050	1-03A-SR63	1-0-438B OFD-121D-1.1	QAL-14	VT-3	NA		6.000 0.000	Calcalaton No. OSC-342 Page 102; Problem No. 03A-9 . System 03A 6" Emergency Feedwater Bypass
Class C	Hyd snubber			to				
F01.050.051	1-03A-SR64	1-0-439B OFD-121D-1.1	QAL-14	VT-3	NA		6.000 0.000	Calcalaton No. OSC-1224-19 Page 27; Problem No.1- 03A-13. System 03A Aux. Service Water Pipe
Class C	Hyd snubber			to				
F01.050.052	1-01A-H40	1-1-0-401A OFD-122A-1.2	QAL-14	VT-3	NA		12.000 0.000	Calcalaton No. OSC-321 Page 111; Problem No. 1-01-2 Sht. 2 of 5 System 01A; Main Steam Bypass To Condenser
Class B	Hyd snubber			to				
F01.050.053	1-01A-H44	1-1-0-401A OFD-122A-1.2	QAL-14	VT-3	NA		12.000 0.000	Calcalaton No. OSC-321; Problem No. 1-01-2 Sht. 3 of 5. System 01A; Main Steam Bypass To Condenser
Class B	Hyd snubber			to				
F01.050.054	1-01A-R6	4-1-0-403C OFD-122A-1.4	QAL-14	VT-3	NA		6.000 0.250	Calculation Number OSC-325 Sheet 1 of 3; Problem 1-01-06 Page 88. System 01A . Steam Supply to Emergency Feedwater Pump Turbine.
Class C	Hyd snubber			to				
F01.050.055	1-01A-R2	4-2-0-403C OFD-122A-1.4	QAL-14	VT-3	NA		6.000 0.000	Calculation Number OSC-325 Sheet 2 of 3; Problem 1-01-06 Page 89.1. System 01A . Steam Supply to Emergency Feedwater Pump Turbine.
Class C	Hyd snubber			to				
F01.050.056	1-03A-DE058	0-401A OFD-121D-1.1	QAL-14	VT-3	NA		6.000 0.000	Calcalaton No. OSC-339 Page 79; Problem No. 1-03A-5 . System 03A 6" Emergency Feedwater To 24" Main Feedwater.
Class C	Mech snubber			to				
F01.050.057	1-03-H4171	0-401B OFD-121B-1.3	QAL-14	VT-3	NA		24.000 0.322	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
Class C	Mech snubber			to				

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 Inservice Inspection Database Management System

Plan Report
 Page 71
 02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK	CAL BLOCKS	COMMENTS
F01.050.066	1-53B-DE057	0-438C	QAL-14	VT-3	NA		8.000	Calcalton No. OS-408; Problem No. 1-53-02; Sht.2 of 3; Page #73.3; System 53B; Decay Heat Removal System & LP Injection
Class B	Mech snubber	OFD-102A-1.1		to			0.000	
F01.050.067	1-51A-H102	0-439A	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 32.2; Problem No. 1-51-04. High Pressure Injection.
Class B	Mech snubber	OFD-101A-1.4 1-51-04		to			0.000	
F01.050.068	1-51A-H97	0-439A	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 32.2; Problem No. 1-51-04. High Pressure Injection.
Class B	Mech snubber	OFD-101A-1.4 1-51-04		to			0.000	
F01.050.069	1-54A-R16	0-439A	QAL-14	VT-3	NA		8.000	Calcalton No. OS-416 Page 58.1; Problem No. 1-54-03, Sheet 1 of 1. System 54A Auxiliary Building.
Class B	Mech snubber	OFD-103A-1.1		to			1.000	
F01.050.070	1-51A-H80	0-439C	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 33; Problem No. 1-51-04. High Pressure Injection.
Class B	Mech snubber	OFD-101A-1.4 1-51-04		to			0.000	
F01.050.071	1-51A-H86	0-439C	QAL-14	VT-3	NA		4.000	Calculation No. OSC-1639, page 32.2; Problem No. 1-51-04. High Pressure Injection.
Class B	Mech snubber	OFD-101A-1.4 1-51-04		to			0.000	
F01.050.072	1-53A-GPD-H0010	0-479A	QAL-14	VT-3	NA		12.000	Calcalton No. OSC-1301-06; Problem No. 1-53-07; Page #92; System 53A; Decay Heat Removal System
Class B	Mech snubber	OFD-102A-1.1		to			0.000	
F01.050.073	1-03-H6068	0-479F	QAL-14	VT-3	NA		6.000	Calcalton No. OSC-1224-16 Page 42; Problem No.1- 03A-14. System 03A Aux. Service Water Pipe.
Class C	Mech snubber	OFD-121D-1.1		to			0.000	

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 72
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
F01.050.074	1-03-H6020	0-480A	QAL-14	VT-3	NA	6.000		Calcalaton No. OSC-1224-16
	Mech snubber	OFD-121D-1.1				0.000		Page 42; Problem No.1- 03A-14.
Class C				to				System 03A Aux. Service Water Pipe
F01.050.075	1-03-H6070	0-480A	QAL-14	VT-3	NA	6.000		Calcalaton No. OSC-1224-16
	Mech snubber	OFD-121D-1.1				0.000		Page 41; Problem No.1- 03A-14.
Class C				to				System 03A Aux Service Water Pipe.
F01.050.076	1-03-H6071	0-480A	QAL-14	VT-3	NA	6.000		Calcalaton No. OSC-1224-16
	Mech snubber	OFD-121D-1.1				0.000		Page 42; Problem No.1- 03A-14.
Class B				to				System 03A Aux. Service Water Pipe.
F01.050.077	1-57-NW1Z	0-480A	QAL-14	VT-3	NA	12.000		Calcalaton No. OSC-1313-06
	Mech snubber	OFD-107A-1.1				0.000		Page 44.1; Problem No.1-57-01
Class C				to				Pressurizer Relief Valve System System 57
F01.050.078	1-57-H23	0-481A	QAL-14	VT-3	NA	12.000		Calcalaton No. OS-1313-06
	Mech snubber	OFD-100A-1.2				0.000		Page 44.1; Problem No.1-57-01.
Class C				to				System 57 Pressurizer Relief Valve System
F01.050.079	1-01A-R11	0-550	QAL-14	VT-3	NA	34.000		Calcalaton No. OSC-320;
	Mech snubber	OFD-122A-1.1				0.000		Problem No. 1-01-01; Sht.2 of 3; System 01A; Page #
Class B				to				132; Main Steam Piping
F01.050.080	1-01A-R4	0-550	QAL-14	VT-3	NA	34.000		Calcalaton No. OSC-320;
	Mech snubber	OFD-122A-1.1				0.000		Problem No. 1-01-01; Sht.2 of 3; System 01A; Page
Class B				to				# 132; Main Steam Piping
F01.050.081	1-01A-R5	0-550	QAL-14	VT-3	NA	34.000		Calcalaton No. OSC-320;
	Mech snubber	OFD-122A-1.1				0.000		Problem No. 1-01-01; Sht.2 of 3; System 01A; Page#
Class B				to				132; Main Steam Piping

CATEGORY F-A, Supports

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 73
02/07/96

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK CAL BLOCKS	COMMENTS
F01.050.082	1-01A-R6	0-550	QAL-14	VT-3	NA	34.000	Calcalaton No. OSC-320; Problem No. 1-01-01; Sht. 2 of 3; System 01A; Page # 132; Main Steam Piping.
Class B	Mech snubber	OFD-122A-1.1		to		1.000	
F01.050.083	1-01A-R7	0-550	QAL-14	VT-3	NA	34.000	Calcalaton No. OSC-320; Problem No. 1-01-01; Sht. 1 of 3; System 01A; Page # 131.1; Main Steam Piping.
Class B	Mech snubber	OFD-122A-1.1		to		1.000	
F01.050.084	1-03-R13	0-551	QAL-14	VT-3	NA	24.000	Calculation No. OS-336 Page 45a.1; Problem No. 1-03-01 Sheet 1 of 2. System 03 Auxiliary and Turbine Building.
Class C	Mech snubber	OFD-121B-1.3		to		0.000	
F01.050.085	1-03A-H115	1-0-400B	QAL-14	VT-3	NA	6.000	Calcalaton No. OSC-1214 Page 25; Problem No.1- 03A-11. System 03A 6" Emergency Feedwater
Class C	Mech snubber	OFD-121D-1.1		to		0.000	
F01.050.086	1-03A-H123	1-0-400B	QAL-14	VT-3	NA	6.000	Calcalaton No. OSC-1214 Page 25; Problem No.1- 03A-11. System 03A 6" Emergency Feedwater
Class C	Mech snubber	OFD-121D-1.1		to		0.000	
F01.050.087	1-03A-SR62	1-0-437A	QAL-14	VT-3	NA	6.000	Calcalaton No. OSC-339 Page 81; Problem No. 1-03A-5 . System 03A 6" Emergency Feedwater to 24" Main Feedwater.
Class C	Mech snubber	OFD-121D-1.1		to		0.000	
F01.050.088	1-01A-H43	1-1-0-401A	QAL-14	VT-3	NA	12.000	Calcalaton No. OSC-321; Problem No. 1-01-2 Sht. 3 of 5. System 01A; Main Steam Bypass To Condenser.
Class B	Mech snubber	OFD-122A-1.2		to		0.000	
F01.050.089	1-01A-R11	4-2-0-400A	QAL-14	VT-3	NA	6.000	Calculation Number OSC-325 Sheet 3 of 3; Problem 1-01-06 Page 91. System 01A Steam Supply to Emergency Feedwater Pump Turbine.
Class C	Mech snubber	OFD-122A-1.4		to		0.250	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 Inservice Inspection Database Management System

Plan Report
 Page 74
 02/07/96

CATEGORY F-A, Supports

Spring Supports & Constant Load Supports

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIATHK CAL	BLOCKS	COMMENTS
F01.050.090	1-07A-H39	6-0-400A	QAL-14	VT-3	NA	20.000		Calcalaton No. OSC-361 Page 85.1 Problem No.1-07A-01 L.P.& H.P.Condensate System 07A
	Mech snubber	OFD-121A-1.8		to		0.000		
Class C								
F01.050.091	1-07A-H40	6-0-400A	QAL-14	VT-3	NA	20.000		Calcalaton No. OSC-361 Page 85.1 Problem No.1-07A-01 L.P.& H.P.Condensate System 07A
	Mech snubber	OFD-121A-1.8		to		0.000		
Class C								
F01.050.092	1-07A-H41	6-0-400A	QAL-14	VT-3	NA	24.000		Calcalaton No. OSC-361 Page 85.1 Problem No.1-07A-01 L.P.& H.P.Condensate System 07A
	Mech snubber	OFD-121A-1.8		to		0.000		
Class C								

Total F01.050 Items: 91

Total Category F-A Items: 127

CATEGORY AUG, Augmented Inspections

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

Plan Report
Page 75
02/07/96

NRC Bulletin 88-08

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
G04.001.001 Class A	1-51A-11-87 Circumferential	1-51A-11(3) OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Pipe to Safe-End	
G04.001.002 Class A	1-51A-11-88 Circumferential	1-51A-11(3) OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Pipe to Valve 1HP-152	
G04.001.003 Class A	1-51A-11-89 Circumferential	1-51A-11(3) OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Pipe to Safe-End	
G04.001.004 Class A	1-51A-11-90 Circumferential	1-51A-11(3) OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Pipe to Valve 1HP-153	
G04.001.005 Class A	1-51A-10-1 Circumferential	1-51A-10 OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Valve 1HP-152 to Elbow	
G04.001.006 Class A	1-51A-10-2 Circumferential	1-51A-10 OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Elbow to Pipe	
G04.001.007 Class A	1-51A-10-6 Circumferential	1-51A-10 OFD-101A-1.4	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Elbow to Pipe	
G04.001.010 Class A	1-51A-5-81C Circumferential	1-51A-5	NDE-600	UT	SS	2.500 0.375		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
							Elbow to Valve 1HP-153	

CATEGORY AUG, Augmented Inspections

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 76
02/07/96**

NRC Bulletin 88-08

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
G04.001.011	1-51A-5-79C	1-51A-5	NDE-600	UT	SS	2.500		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
	Circumferential					0.375		
	Class A			Pipe to Elbow				
G04.001.012	1-51A-5-77C	1-51A-5	NDE-600	UT	SS	2.500		Inspect 100% of weld & 1" of base material (axial & circumferential). Reference Section 7 of the ISI Plan, Volume 1.
	Circumferential					0.375		
	Class A			Pipe to Elbow				

Total G04.001 Items: 10
Total Category AUG Items: 10

CATEGORY AUG, Augmented Inspections

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 77
02/07/96

**Auxiliary Feedwater Header B&W Safety
Concern 21-82 Water Hammer**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI A/THK	CAL BLOCKS	COMMENTS
G06.001.033	1-03A-11-1VEN	1-03A-11	NDE-600	UT	CS	6.000		Vender Weld Ring Header. Calibration block is not needed as examination will be performed in accordance with NDE-600, which does not require the use of calibration block for carbon steel material.
Class B	Circumferential	OFD-121B-1.3		Pipe to Elbow		0.432		
G06.001.033A	1-03A-11-1VEN	1-03A-11	NDE-25	MT	CS	6.000		
Class B	Circumferential	OFD-121B-1.3		Pipe to Elbow		0.432		
Total G06.001 Items:		2						
Total Category AUG Items:		2						

CATEGORY AUG, Augmented Inspections

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 78
02/07/96**

**Circumferential Pipe Welds With A Nom. Wall
Thk. < 3/8" and > NPS 4"**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DIA/THK	CAL BLOCKS	COMMENTS
G09.001.001	1-51A-01-3A	1-51A-01(1)	NDE-35	PT	SS	6.000		
	Circumferential	OFD-101A-1.3				0.280		Pipe to Valve 1HP-103
	Class B							
G09.001.007	1-53B-01-90B	1-53B-01(5)	NDE-35	PT	SS	8.000		
	Circumferential	OFD-102A-1.2				0.148		Pipe to Elbow
	Class B							
G09.001.013	1-53B-03-33F	1-53B-03(4)	NDE-35	PT	SS	10.000		
	Circumferential	OFD-102A-1.2				0.250		Elbow to Pipe
	Class B							
G09.001.019	1-53B-06-114K	1-53B-06(3)	NDE-35	PT	SS	10.000		
	Circumferential	OFD-102A-1.2				0.250		Elbow to Pipe
	Class B							
G09.001.025	1-53B-13-115J	1-53B-13	NDE-35	PT	SS	8.000		
	Circumferential	OFD-102A-1.1				0.148		Elbow to Pipe
	Class B							
G09.001.031	1-54A-01-05A	1-54A-01(2)	NDE-35	PT	SS	10.000		
	Circumferential	OFD-102A-1.1				0.250		Pipe to Elbow
	Class B							
G09.001.037	1-54A-04-21C	1-54A-04(1)	NDE-35	PT	SS	8.000		
	Circumferential	OFD-103A-1.1				0.250		Pipe to Elbow
	Class B							
G09.001.043	1-54A-04-75C	1-54A-04(3)	NDE-35	PT	SS	8.000		
	Circumferential	OFD-103A-1.1				0.250		Pipe to Elbow
	Class B							

Total G09.001 Items: 8

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work SEE REMARKS

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F

Pressure _____ psig Test Temp. _____ °F

Pressure _____ psig Test Temp. _____ °F

9. Remarks A. REMOVED EXISTING S/R AND REPLACED WITH ITEMS 8-11.

B. REMOVED ITEMS 7 AND 8 AND REPLACED WITH ITEMS 9-11.

C. CUT ITEM 8, 5/8" ROD, TO ADJUST S/R TO CORRECT ELEVATION.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed W. McClure
Owner or Owner's Designee, Title

Date 12/5, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-16-95 to 12-5-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 12-5, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12/5/95

2. Plant **Oconee Nuclear Station**
 Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 2 of 23
 WJM

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95012179
 Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**
 Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or LMM # 12960

4. Identification of System HP (51A) Class B

5. (a) Applicable Construction Code B31.7 19 68 Edition, 2 Addenda, 6-68 Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	HANGER 1-51A-0-439C-H90	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	HANGER 1-51A-0-439C-H89	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	HANGER 1-51A-0-439C-H88	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12/5/95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 3 of 3

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95012179
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM# 12960

4. Identification of System PR Class B

5. (a) Applicable Construction Code B31.7 1968 Edition, 2 Addenda, 6-68 Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	HANGER 1-67-439C-H5358	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REROUTED SECTION OF HPI PIPING & RELATED HANGERS.

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. AND PRESSURE AND NDE PER ASME CODE CASE N-416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed DB Mason
 Owner or Owner's Designee, Title

Date 1-4, 1996

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-16-95 to 12-5-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

JMB Chapman
 Inspector's Signature

Commissions 82914
 National Board, State, Providence and Endorsements

Date 1-4, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12-5-95
 Sheet 1 of 3

2. Plant **Oconee Nuclear Station**
 Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95012179
 Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**
 Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 12960

4. Identification of System HP Class 2

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	PIPING	DPC	NA	NA		7/73	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-22-95

Sheet 1 of 2

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95018692
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 12976

4. Identification of System HP Class 2

5. (a) Applicable Construction Code B.31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1-HP-5	EDWARD	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	VLV 1-HP-5	ANCHOR DARLING	V2223-007	21	Body SR V-296 Bonnet SR W-56A DISK V-749	1994	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work SEE REMARKS

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks A. INSTALLED NEW HANGER
B. REPLACED EXISTING U-BOLT WITH NEW U-BOLT
C. CUT OUT ITEMS 3, 4 & 5 AND REPLACED WITH NEW MATERIAL
D. CUT OUT ITEMS 2 & 3 AND REPLACED WITH NEW MATERIAL
 (Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed W. M. C. Clue Date 12/3, 19 95
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of NC and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-12-95 to 1-2-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W. B. Chapman Commissions NC914
 Inspector's Signature National Board, State, Providence and Endorsements

Date 1-2, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12/3/95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 2 of 2

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 950/8692
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 2976

4. Identification of System HP Class 2

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, — NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	HANGER 1-51A-437A-DE001	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	HANGER 1-51A-439A-LC-2503	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	HANGER 1-51-0-439D-LC-2504	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D	HANGER 1-51A-439A-RD-2500	DPC	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

**Oconee Nuclear Station
Problem Investigation Process
Problem Investigation Form**

PIP Serial No: 1-O95-1427
MSE Serial No:

LER Serial No:
Other Report:

No Maintenance Rule for this PIP.

End of the Document for PIP No: 1-O95-1427
The status of this PIP is: Closed
The duration of this PIP was 19 days.

Oconee Nuclear Station

Problem Investigation Process

Problem Investigation Form

PIP Serial No: 1-095-1427	LER Serial No:
MSE Serial No:	Other Report:

The issue of water hammer occurring on this line is documented in PIP 1-94-0701 and will be resolved by corrective action to that PIP.

Immediate Corrective Action, Work Order 95086699, reinstalled the anchors to the proper torque. No further corrective actions are required for this PIP.

Originated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/29/95

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By:	KWGEORGE	TKR7315	MCE	11/13/95
Assigned To:	PAWELLS	RAH8344	MCE	11/13/95
Due Date:	11/30/95			
Ready for Approval:	PAWELLS	RAH8344	MCE	11/29/95
Approved By:	RAHEINEC	RAH8344	MCE	11/29/95
Concurrence:	HDUMEYER	LVW7310	SRG	11/29/95

Remarks:

IV. Corrective Actions

No Corrective Actions for this PIP.

V. Final and Overall PIP Approval

Criterion XVI Review:

XVI Review Not Required for this PIP.

<u>Overall PIP Approval:</u>	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By:	HDUMEYER	LVW7310	SRG	11/20/95
Assigned To:			MCE	11/29/95
Due Date:				
Ready for Approval:				
Approved By:	RAHEINEC	RAH8344	MCE	11/29/95

VI. Attachments

Environmental:

No Environmental for this PIP.

Maintenance Rule:

Oconee Nuclear Station

Problem Investigation Process

Problem Investigation Form

PIP Serial No:	1-095-1427	LER Serial No:	
MSE Serial No:		Other Report:	

Assigned To: SRG 11/13/95
 Due Date:
 Ready For Approval:
 Approved By: HDUMEYER LVW7310 SRG 11/29/95

Investigation Report:

Responsible Group for Investigation Report: Date:
 Investigator: Group: Act Date:
 Date Due to VP or Sta. Mgr:
 Date Regulatory or Agency Rpt Due:
 Date Investigation Report Approved:
 NRC Cause Codes:

III. Problem Evaluation

System(s) Affected: MSC Miscellaneous

Affected Equipment:	Comp.	Manufacturer
<u>WMS Equipment ID No.</u>	<u>Code</u>	<u>Name</u>

Problem Evaluation: Group: MCE Status: Closed

The steam generator drain line has had problems with damage to hangers and anchors pulling out of concrete in the past due to water hammer. PIP 1-094-0701 documents such a problem that occurred on this same line. Root cause of anchors pulling out of the concrete is a transient load (water hammer) on this support. The pipe supports on this line are not designed to withstand water hammer loads.

A secondary cause was the anchors were not properly torqued upon original installation. If installed at minimum embedment properly, these anchors will fail by spalling concrete. No concrete was damaged, which indicates that the anchors were not torqued properly upon installation. Procedures are in place today which prevent this from reoccurring.

Originated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/29/95

<u>Event</u>	<u>Cause Cd</u>	<u>Cause Description</u>	<u>Primary</u>	<u>Causing Group(s)</u>
F2	F5	Equipment/Material Use Practices	Yes	UNK
F2	M2o	Unanticipated interaction of systems or components	Yes	SES

Responsible Group(s) for Proposed Resolution: MCE Mech/Civil Eq. Eng.

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By:	KWGEORGE	TKR7315	MCE	11/13/95
Assigned To:	PAWELLS	RAH8344	MCE	11/13/95
Due Date:	11/30/95			
Ready for Approval:	PAWELLS	RAH8344	MCE	11/29/95
Approved By:	RAHEINEC	RAH8344	MCE	11/29/95
Concurrence:	HDUMEYER	LVW7310	SRG	11/29/95

Proposed Resolution From: Group: MCE Status: Closed

Oconee Nuclear Station

Problem Investigation Process

Problem Investigation Form

PIP Serial No:	1-095-1427	LER Serial No:	
MSE Serial No:		Other Report:	

Comments:

Operability not required due to unit status.

Originated By: HDUMEYER Team: LVW7310 Group: SRG Date: 11/13/95

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By :	HDUMEYER	LVW7310	SRG	11/13/95
Assigned To :			SRG	11/13/95
Due Date:				
Approved By:	HDUMEYER	LVW7310	SRG	11/13/95
Evaluated By :	HDUMEYER	LVW7310	SRG	11/13/95

Past Operability:

Sys/Comp Operable?(Y,N,C,E) : Y	Status:	Closed
Responsible Group: MCE		
Required Mode: N/A	Due Date:	11/30/95

Comments:

Piping system was evaluated for past operability based on S/R 1-04A-2-0-439B-R5 being inoperable. Piping was analyzed assuming S/R R5 was inactive. Pipe stresses were below allowables, but S/R 1-04A-2-0-439B-H12 exceed operability allowables on its U-bolt. Piping was then analyzed with both R5 and H12 considered inactive. Piping stresses and support stresses were reviewed and all found to be within operable allowables. See OSC-4840 for documentation of this review.

Piping was found to be past operable.

Originated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/29/95

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By :	KWGEORGE	TKR7315	MCE	11/13/95
Assigned To :	PAWELLS	RAH8344	MCE	11/13/95
Due Date:				11/30/95
Checked By:	JPPATEL	RAH8344	MCE	11/29/95
Approved By:	RAHEINEC	RAH8344	MCE	11/29/95
Evaluated By :	HDUMEYER	LVW7310	SRG	11/29/95

Reportability:

Problem Reportability?(Y,N,E) :		
Reportable Per:		
Responsible Group for Reportability: SRG		Due Date:

Comments:

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By:	HDUMEYER	LVW7310	SRG	11/20/95

Oconee Nuclear Station

Problem Investigation Process

Problem Investigation Form

PIP Serial No:	1-O95-1427	LER Serial No:	
MSE Serial No:		Other Report:	

that this work be completed prior to Unit 1 startup.

Originated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/10/95

Problem Found While Working with Document No. :

Immediate Corrective Action Work Request / Work Order No. :

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date:</u>
Problem Identified By:	PAWELLS	RAH8344	MCE	11/10/95
Problem Entered By:	PAWELLS	RAH8344	MCE	11/10/95

II. Significance

Is the Problem Significant?	N	Action Category:	3
Significance Codes:			
MSE No:	LER No:	OEP No:	
Other Report Nos:			
Event Codes: F2	Equipment Failure (CFAR or Important Component)		

Screening Remarks:

This event meets the MSE significance criteria in that a past operability evaluation is required by Eng. Present operability is not in question due to unit status.

Screened by the CST.

Originated By: HDUMEYER Team: LVW7310 Group: SRG Date: 11/13/95

PIP downgraded based on operability results.

Last Updated By: HDUMEYER Team: LVW7310 Group: SRG Date: 11/29/95

Responsible Group for Proposed Resolution(s):	MCE	Mech/Civil Eq. Eng.
Responsible Group for Problem Evaluation:	MCE	Mech/Civil Eq. Eng.
Responsible Group for Overall PIP approval:	MCE	Mech/Civil Eq. Eng.

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date:</u>
Screened By:	HDUMEYER	LVW7310	SRG	11/13/95

This PIP has been downgraded from an MSE to an LSE status

Present Operability:

Sys/Comp Operable?(Y,N,C,E) : Y	Status:	Closed
Responsible Group: SRG		
Required Mode:	Due Date:	

Oconee Nuclear Station

Problem Investigation Process

Problem Investigation Form

PIP Serial No:	1-095-1427	LER Serial No:	
MSE Serial No:		Other Report:	

I. Problem ID

Discovered Time/Date: 11/10/95 Occurred Time/Date:

Unit(s):	1	Status at Time Discovered:	Unit 1	Unit 2	Unit 3
		Mode:	N/A	N/A	N/A
		% Power:			

Unit Status Remarks:

System(s) Affected: MSC Miscellaneous

Affected Equipment:	Comp.	Manufacturer
<u>WMS Equipment ID No.</u>	<u>Code</u>	<u>Name</u>

Location of Problem - Bldg: AB Column Line: P-69 Elev: 828

Location Remarks:
In East Pen Room

Method Used to Discover Problem:
Evaluation of In-Service Inspection (ISI) discrepancy

Brief Problem Description:
Pipe Support S/R 1-04A-2-0-439B-R5 was inspected per ISI. Inspection showed sleeve anchors had slipped out of concrete about 1/4".

Detail Problem Description:
Pipe Support S/R 1-04A-2-0-439B-R5 was inspected as part of the ISI program. This support is on the Steam Generator Flush and Drain line. Inspection of this hanger revealed that some anchors had slipped out of the concrete about 1/4". Civil Engineering has reviewed this support and determined it to be unacceptable for continued service in its current condition.

Originated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/10/95


Last Updated By: PAWELLS Team: RAH8344 Group: MCE Date: 11/10/95

Other Units/Components/Systems/Areas Affected (Y,N,U): N

Industry Plants Affected (Y,N,U): N

Immediate Corrective Actions:
Work Request 95046806 was initiated to reseal and retorque the anchors that had slipped out. Request was made

WELD LIST				BILL OF MATERIAL			
IDENT NO.	PIECE NO.	DIAM.	THICK.	PC NO.	QTY	DESCRIPTION	MATL.
58-1	1 TO 2	138" I.D.	4.188 MIN.	1	1	SHELL SECTION	SA 212 GR. B
WG8-2	2 TO 3	138" I.D.	4.188 MIN.	2	2	SHELL SECTION	SA 212 GR. B
WG8-3	3 TO 2	138" I.D.	4.188 MIN.	3	1	SHELL SECTION	SA 212 GR. B
WG8-4	5 TO 6	138" I.D.	4.188 MIN.	4	1	SHELL SECTION	SA 212 GR. B
WG23-1	14 TO 3	29.00"	6.625 MIN.	5	1	SHELL SECTION	SA 212 GR. B
WG23-2	14 TO 3	29.00"	6.625 MIN.	6	1	SHELL SECTION	SA 212 GR. B
WG25	70 TO 8	48.63"	8.000 MIN.	7	1	LOWER HEAD	SA 302 GR. B
WG50-1	65 TO 7	38.38"	8.000 MIN.	8	1	UPPER HEAD	SA 302 GR. B
WG50-2	65 TO 7	38.38"	8.000 MIN.	14	2	24" STEAM OUTLET NOZZLE	SA 508 CL. 1
WG57	95 TO 7	135" I.D.	N/A	50	1	LOWER TUBE SHEET	SA 508 CL. 2
WG58-1	8 TO 51	119" I.D.	8.000 MIN.	51	1	UPPER TUBE SHEET	SA 508 CL. 1
WG58-2	7 TO 50	119" I.D.	8.000 MIN.	65	2	28" PRIMARY OUTLET NOZZLE	SA 508 CL. 1
WG59	6 TO 50	138" I.D.	6.625 MIN.	70	1	36" PRIMARY INLET NOZZLE	SA 508 CL. 1
WG60	1 TO 51	138" I.D.	6.625 MIN.	95	1	SUPPORT SKIRT TRANSITION RING	SA 302 GR. D



REFERENCE DWGS:
 OM 201-1873
 OM 201-178


NOTES:

- ALL I.D. NUMBERS SHALL BE PRECEDED BY "ISGA-".
- PIECE NUMBERS ARE SHOWN IN CIRCLES.

1.	Add Top and Bottom Views & Rev. Drawing	AWC	JH	JOE	TITLE
0.	ORIGINAL	7-20-50	2-21-51	7-2-51	STEAM GENERATOR "A" WELD OUTLINE
NO.	REVISION	DRWN	FWO	APPD	DWG NO. ISI-OCNI-003
		DATE	DATE	DATE	REV. 1

WELD LIST				BILL OF MATERIAL			
IDENT NO.	PIECE NO.	DIAM.	THICK.	PC. NO.	QTY	DESCRIPTION	MATL.
WPI-1	1 TO 1	N/A	6.188	1	1	UPPER SHELL COURSE	SA 212 GR. B
WPI-2	2 TO 2	N/A	6.188	2	1	MIDDLE SHELL COURSE	SA 212 GR. B
WPI-3	3 TO 3	N/A	6.188	3	1	LOWER SHELL COURSE	SA 212 GR. B
WP3-1	1 TO 2	84" I.D.	6.188	4	1	HEATER BELT SHELL	SA 212 GR. B
WP3-2	2 TO 3	84" I.D.	6.188	5	1	UPPER HEAD	SA 212 GR. B
WP4	3 TO 4 & 41	84" I.D.	6.188	6	1	LOWER HEAD	SA 212 GR. B
WP6	40 TO 41	84" I.D.	13.563	8	1	PRESSURIZER SURGE NOZZLE	SA 508 CL. I
WP7-1	4 TO 40 & 41	N/A	6.188	9	1	PRESSURIZER SPRAY NOZZLE	SA 508 CL. I
WP7-2	4 TO 40 & 41	N/A	6.188	30	6	SAMPLING NOZZLE	SA 508 GR. B
WP15	6 TO 8		4.750	31	3	PRESSURIZER RELIEF NOZZLE	SA 508 CL. I
WP23	8 TO 37	10" NPS	1.063	32	3	PRESSURIZER RELIEF NOZZLE SAFE END	SA 182 F316
WP26-1	30 TO 4		6.188	37	1	PRESSURIZER SURGE NOZZLE SAFE END	SA 336 CL. F8M
WP26-2	30 TO 4		6.188	40	1	LOWER HEATER BELT FORGING	SA 508 CL. I
WP26-3	30 TO 4		6.188	41	1	UPPER HEATER BELT FORGING	SA 508 CL. I
WP26-4	30 TO 1		6.188	42	6	SAMPLING NOZZLE SAFE END	SB-166
WP26-5	30 TO 1		6.188	45	1	PRESSURIZER SPRAY NOZZLE SAFE END	SB-166
WP26-6	30 TO 1		6.188	110	8	PRESSURIZER SUPPORT LUG ASSEMBLY	SA-516 GR. 70
WP26-7	30 TO 4		6.188				
WP28	6 TO 4 & 40	84" I.D.	4.750				
WP33-1	31 TO 5		4.750				
WP33-2	31 TO 5		4.750				
WP33-3	31 TO 5		4.750				
WP34	9 TO 5		4.750				
WP45	45 TO 9	4" NPS	0.750				
WP63-1	42 TO 30		1.1875				
WP63-2	42 TO 30		1.1875				
WP63-3	42 TO 30		1.1875				
WP63-4	42 TO 30		1.1875				
WP63-5	42 TO 30		1.1875				
WP63-6	42 TO 30		1.1875				
WP76	1 TO 5	84" I.D.	4.750				
WP82-X	110 TO 3	N/A	3.500				
WP82-XY	110 TO 3	N/A	3.500				
WP82-YZ	110 TO 3	N/A	3.500				
WP82-ZW	110 TO 3	N/A	3.500				
WP82-W	110 TO 3	N/A	3.500				
WP82-WX	110 TO 3	N/A	3.500				

WELD LIST (CONT.)			
I.D. NO.	PC. NO.	DIAM.	THICK.
WP91-1	31 TO 32	2 1/2" NPS	1.000
WP91-2	31 TO 32	2 1/2" NPS	1.000
WP91-3	31 TO 32	2 1/2" NPS	1.000
WP63-7	42 TO 30	SAMPLING	1.1875



NOTES:
 1. ALL I.D. NUMBERS SHALL BE PRECEDED BY "IPRZ -"
 2. PIECE NUMBERS ARE SHOWN IN CIRCLES.

NO.	REVISION	DRWN	RVWD	APPD	DATE	DATE	DATE	TITLE	DWG NO.	REV.
2	REV. WELD QUAD.	AWJ	AWJ	JOR	7-23-81	7-23-81	7-23-81	PRESSURIZER WELD OUTLINE	ISI-OCNI-002	2
1	ADD. REF. DWGS.	AWJ	AWJ	JOR	7-23-81	7-23-81	7-23-81			
0	ORIG.	AWJ	FWH	CBC	7-23-81	7-23-81	7-23-81			

This weld was limited to 73.8% coverage of the required volume because of the proximity of five restraints which prevent scanning the required weld volume and near surface volume from the tube sheet side.

All three units are being documented in this request for relief as outlined in NRC correspondence dated May 5, 1995 concerning NRC Inspection Report No. 50-269/95-05, 50-270/95-05, and 50-287.

For welds and components listed in this request for relief, all configurations, including interferences, are the same for Units 2 and 3. If for some reason, the actual examination coverage of the welds referenced in this request for relief for Units 2 and 3 are less than those listed for Unit 1; additional requests for relief will be submitted on a case by case basis.

V. Alternate Examinations or Testing:

Duke Power company will continue to perform ultrasonic examination of all welds identified in Section 1 of this request (for all units) to the maximum extent practical, within the limits of original design and construction, in accordance with the requirements of ASME Section V, Article 4, and ASME Section XI, Appendix I, 1989 Edition.

VI. Justification for the Granting of Relief:

Duke Power Company will continue to ultrasonically examine the welds, including inside radii, to the extent practical within the limits of original design and construction. This will provide reasonable assurance of weld/component integrity. Thus, an acceptable level of quality and safety will have been achieved and public health and safety will not be endangered by allowing relief from the aforementioned Code requirements.

VII. Implementation Schedule:

Unit 1, Refueling Outage 16
Unit 2, Refueling Outages 17 and 18
Unit 3, Refueling Outage 16

Evaluated By: R. J. Rose Date 2/8/96

Reviewed By J. O. Barlow Date 2/20/96

barriers, obtaining at least 90% of the weld length as outlined in Code Case N-460 is not possible with existing ultrasonic technology.

The specified Code requirements identified in Section 2 of this request, require scanning of the examination volume(s) using three angle beams and a straight beam from both sides of the weld. When scanning for reflectors parallel to the weld, the angle beams shall be aimed at right angles to the weld axis, with the search unit(s) manipulated so that the ultrasonic beams pass through the entire volume of weld metal. The adjacent base metal in the examination volume must be completely scanned by both angle beams from both directions (any combination of two angle beams will satisfy the requirement).

When scanning for reflectors transverse to the weld, the angle beam search units shall be aimed parallel to the axis of longitudinal and circumferential welds. The search unit shall be manipulated so that the ultrasonic beams pass through all of the examination volume.

Scanning shall be done in two directions 180 degrees to each other to the extent possible. Areas blocked by geometric conditions shall be examined from at least one direction.

Code Case N-460 allows credit for full volume coverage if it can be shown that at least 90% of the required volume has been examined.

IV. Basis for Relief:

Pressurizer Nozzle-to-Shell Weld 1-PZR-WP34 (Item Number B03.110.002) was examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, and ASME Section XI, Appendix I, 1989 Edition.

This weld is limited to 70.75% coverage of the required volume because of the nozzle configuration.

Pressurizer Nozzle-to-Shell Welds 1-PZR-WP33-3 and 1-PZR-WP33-2 (Item Numbers B03.110.003 and B03.110.004 respectively) were examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, and ASME Section XI, Appendix I, 1989 Edition.

These welds are limited to 66.5% coverage of the required volume because of the nozzle configuration.

Steam Generator Tubesheet-to-Shell Weld 1-SGA-WG60 (Item Number C01.030.001) was examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, and ASME Section XI, Appendix I, 1989 Edition.

Duke Power Company

Station Oconee Unit 1, 2 & 3

10-YEAR INTERVAL REQUEST FOR RELIEF NO. 96-01

I. System/Component(s) for Which Relief is Requested:

a. Pressurizer Nozzle-to-Vessel Welds:

- 1-PZR-WP34, Item Number B03.110.002
- 1-PZR-WP33-3, Item Number B03.110.003
- 1-PZR-WP33-2, Item Number B03.110.004

- 2-PZR-WP34, Item Number B03.110.002
- 2-PZR-WP33-3, Item Number B03.110.003
- 2-PZR-WP33-2, Item Number B03.110.004

- 3-PZR-WP34, Item Number B03.110.002
- 3-PZR-WP33-3, Item Number B03.110.003
- 3-PZR-WP33-2, Item Number B03.110.004

b. Steam Generator Tubesheet-to-Shell Welds:

- 1-SGA-WG60, Item Number C01.030.001
- 2-SGA-WG60, Item Number C01.030.001
- 3-SGA-WG60, Item Number C01.030.001

II. Code Requirement:

Figure IWB-2500-7, Examination Category B-D, Full Penetration Welds Of Nozzles In Vessels - Inspection Program B.

Figure IWC-2500-1, Examination Category C-A, Pressure Retaining Welds In Pressure Vessel; Note 1 "Includes essentially 100% of the weld length".

III. Code Requirement from which Relief is Requested:

Relief is requested from the requirement of examining essentially 100% of the weld length. The applicable code required is ASME Section V, Article 4, T-441.3.2, Scanning Requirements, 1989 Edition with no Addenda as modified by Code Case N-460. Due to part geometry and actual physical

practical in accordance with the requirements of ASME Section V, Article 4, 1989 Edition.

4. In Section IV of the request for relief, you specify the percent coverage for the Unit 3 welds only. No examinations have yet been performed this interval on the corresponding similar Unit 1 and 2 welds which are also identified in this request for relief. Since our evaluation which supports approval of the request for relief is dependent in part on the percent coverage achieved for the welds, it would appear that case by case relief would still be necessary should corresponding welds on Units 1 and 2 receive less coverage than those described for Unit 3.

A: Duke concurs that coverage on corresponding identical Unit 1 and 2 welds should be greater than or equal to the coverages approved for Unit 3 in the request for relief. Accordingly, if the coverages for corresponding identical welds on Unit 1 or 2 are less than those approved for Unit 3, then additional request for relief will be filed on an individual basis for these welds.

Attachment

Questions and Answers

1. Please verify for the welds identified in Part I of the request for relief, that the physical configuration, including interferences, is identical for Units 1, 2, and 3. This request for verification is because technical information is only provided for Unit 3 in the request for relief.

A: For the welds identified in Part I of the request for relief, the physical configuration, including interferences, is identical for Units 1, 2, and 3. This conclusion is based on a combination of drawing reviews and field experience.

2. In Section V of the request for relief, you identify the alternate examinations that you will perform on Unit 3 Reactor Pressure Vessel (RPV) welds. However, since the request for relief is also for the same welds on Units 1 and 2, please confirm that the alternate examinations you have specified in Section V for Unit 3 will also be performed for Units 1 and 2.

A: Duke Power Company will also continue to perform ultrasonic examination of Item Numbers B01.021.001 (RPV Head Weld) and B01.040.001 (RPV Head-to-Flange Weld) for Units 1 and 2, to the maximum extent practical in accordance with the requirements of ASME Section V, Article 4, 1989 Edition, and Regulatory Guide 1.150, Revision 1, Appendix A.

3. In Section V of the request for relief, you identify the alternate examinations that you will perform on Units 1 and 3 Steam Generator A welds, but no mention is made regarding alternate examinations on the similar Unit 2 welds. Do you intend to perform the same alternate examinations on the Unit 2 welds identified in Section I, parts c and d?

A: Due to an administrative oversight, the Unit 2 Steam Generator A welds identified in Section I, parts c and d, were not included in Section V of the request for relief. Therefore, the following statement should be added to Section V of the existing request for relief:

Duke Power Company will also continue to perform an ultrasonic examination of Item Numbers B03.130.003, B03.130.004, B03.140.003, and B03.140.004 (Steam Generator A Primary Outlet Nozzle-to-Lower Head Weld and Inside Radius), for Unit 2, to the maximum extent

U. S. Nuclear Regulatory Commission
February 27, 1996
Page 3

bxc (w/ attchs): T. J. Coleman
R. G. Rouse
D. A. Nix

bxc (w/o attchs): J. O. Barbour
J. E. Burchfield
B. W. Carney
M. B. Chapman
J. C. Shropshire
ELL EC050
ISI Relief Request File



U. S. Nuclear Regulatory Commission
February 27, 1996
Page 2

xc (w/attch): Mr. L. A. Wiens
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Mike Anderson
Lockheed of Idaho
2351 North Boulevard
Idaho Falls, ID, 83415-2209

xc(w/o attch): Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Max Batavia
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(864)885-3499 Office
(864)885-3564 Fax



DUKE POWER

February 27, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, -270, and -287
Third Ten Year Inservice Inspection Interval
Request for Relief No. 95-04
Supplemental Information

Per a telephone conference on February 12, 1996, the NRC requested additional information to clarify information provided in Request for Relief 95-04 dated October 5, 1995. Please find attached the additional information in support of the request for relief.


If there are any questions or further information is needed you may contact D. A. Nix at (803) 885-3634.

Very truly yours,

J. W. Hampton
Site Vice President

Attachment

UNCONTROLLED



NO.	DESCRIPTION	DATE	BY
1	RELOCATED WG-68 ZONE GRID TO F-7 CHGD WELD DET LONE 2-1 CHGD LOC 1 DET SECTION D-0 ADDED DET & CHART ZONE 2-B	7/1/67	A. Hunt
2	RELOCATED MC-20, ADDED MC-18 & CHGD TABLE 'D' TO AGREE	1/20/68	C. Hunt
3	ADDED LOWER MC-8 WELD NUMBER AND 8 D DELETED WELD NUMBERS WG-24, WG-25, WG-27, WG-97, WG-98, WG-99 (A, B, C, D) AND FROM SECTION 12 D (7, 1) AND 69-1) CHGD MIN THK AND PERM FOR WELD WG-68 (7-F) W/CH	2/6/68	A. Hunt
4	CHGD WG-50 FROM SECT 'CC' TO SECT 'B-B'	10/6/68	A. Hunt
5	REMOVED CONTRACT N°S 420-0004-S, 420-0009-S AND ADD UNIT #1 & SHEET #1 IN TITLE BLOCK. DELETED WG-117 & 118. CHGD MC-20 TO MC-18 (BG-9 BE-44) SECT 'D-0'	7/3/68	A. Hunt
6	CHGD SECT 'E' (MC-18) FROM SINGLE WALL TO DOUBLE WALL. SHFT & MOVED LOCATION OF SECT 'E' FROM (H-10) TO (D-2). ADDED TUBESHEET PLUG 2-RAY INFORMATION (H-10). JSE/ED	11/1/68	A. Hunt
7	REMOVED BACKING RING #1 WELD WG-50 ZONE (1-2). DELETED WELD WG-29 & SECT. A-A (D-4, B-10) ETC.	2/1/69	A. Hunt

STEAM GENERATOR

WELD ID
 2-SGA-WG50-2
 2-SGA-WG50-1




ITEM NOS.
 B03.130.001
 B03.140.001
 B03.130.002
 B03.140.002

NOTES

1. FOR GENERAL NOTES SEE LOCATION

WELD LIST				BILL OF MATERIAL			
IDENT NO.	PIECE NO.	DIAM.	THICK.	PC. NO.	QTY	DESCRIPTION	MATL.
WG8-1	1 TO 2	138" I.D.	4.188 MIN.	1	1	SHELL SECTION	SA 212 GR. B
WG8-2	2 TO 3	138" I.D.	4.188 MIN.	2	2	SHELL SECTION	SA 212 GR. B
WG8-3	3 TO 2	138" I.D.	4.188 MIN.	3	1	SHELL SECTION	SA 212 GR. B
WG8-4	5 TO 6	138" I.D.	4.188 MIN.	4	1	SHELL SECTION	SA 212 GR. B
WG23-1	14 TO 3	29.00"	6.625 MIN.	5	1	SHELL SECTION	SA 212 GR. B
WG23-2	14 TO 3	29.00"	6.625 MIN.	6	1	SHELL SECTION	SA 212 GR. B
WG25	70 TO 8	48.63"	8.000 MIN.	7	1	LOWER HEAD	SA 302 GR. B
WG50-1	65 TO 7	38.38"	8.000 MIN.	8	1	UPPER HEAD	SA 302 GR. B
WG50-2	65 TO 7	38.38"	8.000 MIN.	14	2	24" STEAM OUTLET NOZZLE	SA 508 CL. 1
WG57	95 TO 7	135" I.D.	N/A	50	1	LOWER TUBE SHEET	SA 508 CL. 2
WG58-1	8 TO 51	119" I.D.	8.000 MIN.	51	1	UPPER TUBE SHEET	SA 508 CL. 1
WG58-2	7 TO 50	119" I.D.	8.000 MIN.	65	2	28" PRIMARY OUTLET NOZZLE	SA 508 CL. 1
WG59	6 TO 50	138" I.D.	6.625 MIN.	70	1	36" PRIMARY INLET NOZZLE	SA 508 CL. 1
WG60	1 TO 51	138" I.D.	6.625 MIN.	95	1	SUPPORT SKIRT TRANSITION RING	SA 307 GR. C

UNCONTROLLED



B03.130.002
 B03.140.002 (INSIDE RADIUS) **BOTTOM VIEW**
 B03.130.001
 B03.140.001 (INSIDE RADIUS)

REFERENCE DWGS:
 CS 201-1873
 OM 201-178


NOTES:

1. ALL I.D. NUMBERS SHALL BE PRECEDED BY "ISGA-"
2. PIECE NUMBERS ARE SHOWN IN CIRCLES.

NO.	REVISION	DATE	DATE	DATE	TITLE	DWG NO.	REV.
		DATE	DATE	DATE			
1.	Had Test Port Views & Section Drawings	ALL	JKH	JOE	STEAM GENERATOR "A" WELD OUTLINE	ISI-OCNI-003	1
0.	ORIGINAL						

REVISIONS

NO.	DESCRIPTION	DATE	APPROVED
1	PLAN VIEW RELOCATED LIFTING LUGS 90° CLOCKWISE X/D/AMS	7/2/68	G. R. ...
2	(5B) ADDED THERMOCOUPLE PENETRATIONS (4F) ADDED SECTION C-C BURN/ALS	6-7-68	G. R. ...
3	(ZONE C-B) RELOCATED SECT. A-A INDICATION (ZONE T-II) REMOVED REF. TO CONTRACTS 620-0004 & 620-0009. (ZONE C-B) IN SECT. B-B: EXTENDED VIEW TO INCLUDE WH-152 (WH-38, 42, 44-1), GA-3 WAS - 150.	11/2/68	RDP
4	(6C) RELOCATED CALLOUT FOR SECT. A-A (360MM) & DELETED WH-152 (WH-38, 42) CMBD CONFIG. OF WELD PREP TO SUIT DETAIL DWG. REL/REN	8/10/68	K. ...
5	(SECTION 'A-A'/'B-B') MOVED SOURCE & PENETRATOR OUTSIDE OF CRDM HOUSING & (SECTION 'B-B') FINE GRAIN FILM WAS AA OR EQUIV, 200KV TO 400KV X-RAY WAS IR-152, & ADDED MIN FOCAL DIST 36" 104/SGS	7/11/70	SGS




UNCONTROLLED

WELD LIST				BILL OF MATERIAL			
IDENT NO.	PIECE NO.	DIAM.	THICK.	PC. NO.	QTY	DESCRIPTION	MATL.
WRI	A1 TO A2	171" I.D.	9.500	A1	1	LOWER SHELL ASSY. UPPER COURSE	SA 533 GR. B
WRIA	10 TO A1	171" I.D.	9.500	A2	1	LOWER SHELL ASSY. LOWER COURSE	SA 533 GR. B
A1 - WR2	A1 TO A1	N/A	9.500	6	1	LOWER HEAD ASSY. CAP SECTION	SA 533 GR. B
A1 - WR2A	A1 TO A1	N/A	9.500	7	1	REACTOR VESSEL FLANGE	SA 508 CL. 2
A2 - WR2	A2 TO A2	N/A	9.500	8	1	NOZZLE BELT UPPER COURSE	SA 508 CL. 2
A2 - WR2A	A2 TO A2	N/A	9.500	9	1	NOZZLE BELT LOWER COURSE	SA 508 CL. 2
A10 - WR2	A10 TO A10	N/A	9.500	10	1	UPPER SHELL ASSY. LOWER COURSE	SA 533 GR. B
A10 - WR2A	A10 TO A10	N/A	9.500	17	2	CORE FLOOD NOZZLE	SA 508 CL. 2
WR12	18 TO 8 B 9	48" O.D.	12.000	18	4	INLET NOZZLE	SA 508 CL. 2
WR12A	18 TO 8 B 9	48" O.D.	12.000	19	2	OUTLET NOZZLE	SA 508 CL. 2
WR12B	18 TO 8 B 9	48" O.D.	12.000	22	1	UPPER HEAD FLANGE	SA 508 CL. 2
WR12C	18 TO 8 B 9	48" O.D.	12.000	23	1	UPPER HEAD RING SECTION	SA 508 CL. 2
WR13	19 TO 8 B 9	60" O.D.	12.000	24	1	UPPER HEAD CAP SECTION	SA 533 GR. B
WR13A	19 TO 8 B 9	60" O.D.	12.000	36	1	LOWER HEAD RING SECTION	SA 508 CL. 2
WR17	9 TO 10	171" I.D.	9.500	37	1	REACTOR VESSEL SUPPORT SKIRT	SA 516 GR. 70
WR18	8 TO 9	168" I.D.	12.000	89	2	CORE FLOOD NOZZLE SAFE END	SA 336-65A-FRM
WR19	7 TO 8	171" I.D.	12.000				
WR34	A2 TO 36	170" I.D.	5.500				
WR35	36 TO 6	143" I.D.	5.375				
WR36	36 TO 37	175" I.D.	2.000				
WR53	89 TO 17	15.625" Q.D.	1.688				
WR53A	89 TO 17	15.625" Q.D.	1.688				
WR54	17 TO 8	25.0"	12.000				
WR54A	17 TO 8	25.0"	12.000				
WH5	24 TO 23		6.625				
WH7	23 TO 22	147" I.D.	6.625				

UNCONTROLLED

REFERENCE DWGS.
OM 201-1877
OM 201-1122



NOTES:		Add. Ref. Dwgs.				TITLE		
1.	ALL I.D. NUMBERS SHALL BE PRECEDED BY "IRPV-"	AS	AW	AP	REACTOR VESSEL WELD OUTLINE			
2.	PIECE NUMBERS ARE SHOWN IN CIRCLES.	AD	AW	AP				
		DR	RV	AP				
NO.	REVISION	DATE	DATE	DATE	DWG NO.	ISI-OCNI-001		REV 1

VI. Justification for the Granting of Relief:

As stated above, Duke Power Company will continue to ultrasonically examine the welds and components (inside radius) to the extent practical within the limits of original design and construction. This will provide reasonable assurance of weld / component integrity. Thus, an acceptable level of quality and safety will have been achieved and public health and safety will not be endangered by allowing relief from the aforementioned Code requirements.

VII. Implementation Schedule:

Unit 3, Refueling Outage 15

* Unit 1, Refueling Outages 16 & 17

Unit 2, Refueling Outage 15

Evaluated By: RT & Rowe Date 10/2/95

Reviewed By: J C Sharpshin Date 10/2/95

Because of geometric conditions, i.e., lifting lugs adjacent to the weld, 81.85% of the near surface volume and 79.85% of the weld and base metal volumes were covered. In order to achieve more coverage of the required volumes the lifting lugs would have to be moved away from the weld area.

Item Number B01.040.001 (3RPV-WH7), RPV Head-to-Flange Weld was examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, 1989 Edition. The additional requirements of Regulatory Guide 1.150, Revision 1, Appendix A were also used in the examination.

Because of geometric conditions, i.e., single sided access, 63.35% of the near surface volume and 48.55% of the weld and base metal volumes were covered. In order to achieve more coverage of the required volumes, the weld must be at a greater distance from the flange.

Item Numbers B03.130.001 (3-SGA-WG50-2, nozzle weld), B03.130.002 (3-SGA-WG50-1, nozzle weld), B03.140.001 (3-SGA-WG50-2, inside radius) and B03.140.002 (3-SGA-WG50-1, inside radius), Steam Generator A Primary Outlet Nozzle-to-Lower Head Weld were examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, 1989 Edition.

Because of geometric conditions, i.e., single sided access and support skirt location, 15.6% of the required examination volume was covered. In order to achieve more coverage the support skirt would have to be cut away from the nozzle.

- * All three units for Oconee are being addressed in this request for relief as addressed in NRC correspondence dated May 5, 1995 concerning NRC Inspection Report No. 50-269/95-05, 50-270/95-05, 50-287/95-05.

V. Alternate Examinations or Testing:

Duke Power Company will continue to perform an ultrasonic examination of Item Numbers B01.021.001, 3RPV-WH5, RPV Head Weld and B01.040.001, 3RPV-WH7, RPV Head-to-Flange Weld to the maximum extent practical in accordance with the requirements of ASME Section V, Article 4, 1989 Edition and Regulatory Guide 1.150, Revision 1, Appendix A.

Duke Power Company will continue to perform an ultrasonic examination of Item Numbers B03.130.002, B03.130.001, B03.140.002 and B03.140.001, Steam Generator A Primary Outlet Nozzle-to-Lower Head Weld and Inside Radius to the maximum extent practical in accordance with the requirements of ASME Section V, Article 4, 1989 Edition.

Section XI Table IWB-2500-1, Examination Category B-A, Pressure Retaining Welds In Reactor Vessel, Figure IWB-2500-5, Note 2 requires essentially 100% of the weld length be examined.

Section XI Table IWB-2500-1, Examination Category B-D, Full Penetration Welds Of Nozzles In Vessels - Inspection Program B, Figures IWB-2500-7(a) through IWB-2500-7(d) requires essentially 100% of the nozzle weld and radius be examined.

III. Code Requirement from which Relief is Requested:

Relief is requested from the requirement of examining essentially 100% of the weld length. Due to part geometry and actual physical barriers, obtaining even 90% of the weld length as outlined in Code Case N-460 is not possible.

ASME Section V, Article 4, T-441.3.2 Scanning Requirements, 1989 Edition with no addenda as modified by Code Case N-460.

This Paragraph requires scanning of the examination volume(s) using three angle beams and a straight beam from both sides of the weld. When scanning for reflectors parallel to the weld, the angle beams shall be aimed at right angles to the weld axis, with the search unit(s) manipulated so that the ultrasonic beams pass through the entire volume of weld metal. The adjacent base metal in the examination volume must be completely scanned by two angle beams, but need not be completely scanned by both angle beams from both directions (any combination of two angle beams will satisfy the requirement).

When scanning for reflectors transverse to the weld, the angle beam search units shall be aimed parallel to the axis of longitudinal and circumferential welds. The search unit shall be manipulated so that the ultrasonic beams pass through all of the examination volume.

Scanning shall be done in two directions 180 degrees to each other to the extent possible. Areas blocked by geometric conditions shall be examined from at least one direction.

Code Case N-460 allows credit for full volume coverage if it can be shown that at least 90% of the required volume has been examined.

IV. Basis for Relief:

Item Number B01.021.001 (3RPV-WH5), RPV Head Weld was examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section V, Article 4, 1989 Edition. The additional requirements of Regulatory Guide 1.150, Revision 1, Appendix A were also used in the examination.

Duke Power Company

Station Oconee Unit 1, 2 & 3

10-YEAR INTERVAL REQUEST FOR RELIEF NO. 95-04

I. System/Component(s) for Which Relief is Requested:

a. Reactor vessel head welds;

1-RPV-WH5, Item Number B01.021.001
2-RPV-WH5, Item Number B01.021.001
3-RPV-WH5; Item Number B01.021.001

b. Reactor vessel head-to-flange welds:

1-RPV-WH7, Item Number B01.040.001
2-RPV-WH7, Item Number B01.040.001
3-RPV-WH7, Item Number B01.040.001

c. Steam generator nozzle-to-vessel welds:

* 1-SGA-WG50-2, Item Number B03.130.001
* 1-SGA-WG50-1, Item Number B03.130.002
2-SGA-WG50-2, Item Number B03.130.003
2-SGA-WG50-1, Item Number B03.130.004
3-SGA-WG50-2, Item Number B03.130.001
3-SGA-WG50-1; Item Number B03.130.002

d. Steam generator nozzle inside radius welds:

* 1-SGA-WG50-2, Item Number B03.140.001
* 1-SGA-WG50-1, Item Number B03.140.002
2-SGA-WG50-2, Item Number B03.140.003
2-SGA-WG50-1, Item Number B03.140.004
3-SGA-WG50-2, Item Number B03.140.001
3-SGA-WG50-1, Item Number B03.140.002

II. Code Requirement:

Section XI Table IWB-2500-1, Examination Category B-A, Pressure Retaining Welds In Reactor Vessel, Figure IWB-2500-3, Note 2 requires essentially 100% of the weld length be examined.

IWB-2500-1. No recordable indications were detected.

During the third period of the second ten year inspection interval all reactor vessel nozzle-to-vessel and respective nozzle-to-pipe welds were examined using ARIS. Included in this examination was the 36" outlet nozzle-to-vessel and nozzle-to-pipe welds examined during the first period. The re-examination of these 36" outlet nozzles was performed meeting the requirements of the 1989 ASME Section XI Code. Credit will be applied to the third interval, first period requirement for the 36" outlet nozzle-to-vessel welds. Category B-D, Items B3.90 and B3.100. These examinations will not be performed during the first period of the third inspection interval.

Following this inspection sequence will substantially reduce radiation exposure (2 man-rem), critical path time (300 man hours), contaminated shipments, and generation of rad-waste, without effecting the safe operation or reliability of the of the reactor vessel.

IV. Alternate Examination:

Automated re-examination of all the reactor vessel nozzle-to-vessel welds, including respective nozzle-to-pipe welds will be deferred to the last period of the third ten year inspection interval.

V. Implementation Schedule:

Examinations are scheduled to be performed during the third inspection period as follows:

Refueling Outage 21, 2003	(Unit 1)
Refueling Outage 20, 2003	(Unit 2)
Refueling Outage 21, 2004	(Unit 3)

Evaluated By:

J. J. Hogg, Jr.

Date

8-18-94

Reviewed By:

J. Barkner

Date

8/23/94

Oconee 3

<u>Item No.</u>	<u>ID No.</u>	<u>Description</u>
B03.090.001A	3-RPV-WR13	Noz to Vsl
B03.090.002A	3-RPV-WR13A	Noz to Vsl
B03.100.001	3-RPV-WR13	Inside Radius
B03.100.002	3-RPV-WR13A	Inside Radius
B09.011.001	3-PHA-1	Noz to Pipe
B09.011.003	3-PHB-1	Noz to Pipe

b. Function:

Welded connection between the reactor pressure vessel and respective reactor coolant piping providing a flow path to the steam generator.

c. ASME Section XI Code Class:

Class 1

d. Construction Code and Class (If Applicable):

ASME Section III, 1965 Edition with Summer 1967 Addenda; Class 1

e. Valve Category (If Applicable):

N/A

II. Reference Code Requirement that has been determined to be impractical:

ASME Boiler and Pressure Vessel Code Section XI, 1989 Edition, no addenda, Table IWB-2500-1 (Category B-D), Item Numbers B3.90 and B3.100. NOTE (2): At least 25% but not more than 50% (credited) of the nozzles shall be examined by the end of the first inspection period of each inspection interval.

ASME Boiler and Pressure Vessel Code Section XI, paragraph IWB-2420(a): The sequence of component examinations established during the first inspection interval shall be repeated during each successive inspection interval to the extent practical.

III. Basis for Requesting Relief:

During the first period of the second ten year inspection interval at Oconee Nuclear Station the reactor vessel 36" outlet nozzle-to-vessel welds, including nozzle-to-pipe welds, were examined using Babcock & Wilcox's Automated Reactor Inspection Tool (ARIS). The two nozzle welds examined met the 25% requirement of Table

DUKE POWER COMPANY
Request for Relief From
Inservice Inspection Requirement

Station: Oconee

Unit: 1, 2 & 3

Requesting Department: Nuclear Generation

Reference Code: ASME Section XI, 1989 Edition, no addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Reactor Pressure Vessel 36" outlet nozzle-to-vessel welds and outlet nozzle-to-pipe welds (Unit 1 OM-201-5) Attachment ("A"); (Unit 2 OM-1201-4) Attachment ("B"); (Unit 3 OM-2201-52) Attachment ("C").

Oconee 1

<u>Item No.</u>	<u>ID No.</u>	<u>Description</u>
B03.090.001A	1-RPV-WR13	Noz. to Vsl
B03.090.002A	1-RPV-WR13A	Noz. to Vsl
B03.100.001	1-RPV-WR13	Inside Radius
B03.100.002	1-RPV-WR13A	Inside Radius
B09.011.065	1-PHA-1	Noz. to Pipe
B09.011.077	1-PHB-1	Noz. to Pipe

Oconee 2

<u>Item No.</u>	<u>ID No.</u>	<u>Description</u>
B03.090.001A	2-RPV-WR13	Noz. to Vsl
B03.090.002A	2-RPV-WR13A	Noz. to Vsl
B03.100.001	2-RPV-WR13	Inside Radius
B03.100.002	2-RPV-WR13A	Inside Radius
B09.011.019	2-PHA-1	Noz. to Pipe
B09.011.021	2-PHB-1	Noz. to Pipe

9.0 **Reference Documents**

The following reference documents apply to the inservice inspection performed during Outage 16 at Oconee 1.

Duke Power Company Request for Relief ONS-006

Duke Power Company Request for Relief 95-04

Duke Power Company Request for Relief 96-01

PIP O95-1427

8.0 Corrective Action

PIP O-95-1427 was originated to document a reportable indication identified during visual examination of Item Number F01.031.006. Copy of PIP O-95-1427 is located in Section 9.0 of this report.

7.0 Personnel, Equipment and Material Certifications

All personnel who performed or evaluated the results of inservice inspections from July 13, 1994 to December 10, 1995 at Oconee Nuclear Station, Unit 1, were certified in accordance with the requirements of 1989 Edition of ASME Section XI with no addenda. The appropriate certification records for each Duke Power Company inspector are on file at Oconee Nuclear Station or copies can be obtained by contacting Duke Power's Corporate Office in Charlotte, North Carolina. The certification records for the Babcock & Wilcox inspectors are on file at the Babcock & Wilcox Offices in Lynchburg, Virginia.

Records of periodic calibration of Duke Power Company inspection equipment are on file at Oconee Nuclear Station or copies can be obtained by contacting Duke Power's Corporate Office in Charlotte, North Carolina. Records of periodic calibration of Babcock & Wilcox inspection equipment are on file at the Babcock & Wilcox Offices in Lynchburg, Virginia.

6.0 Reportable Indications

Outage 16 had one reportable indication on Item Number F01.031.006. PIP O-95-1427 was originated to document this condition. Copy of PIP O-95-1427 is located in Section 9.0 of this report.

5.2 Limited examinations (i.e., less than 90% of the required examination coverage obtained) identified during Outage 16 are shown below. A copy of the Request for Relief is contained in Section 9.0 of this report

<u>Item Number</u>	<u>Request for Relief Serial Number</u>
B03.110.002	96-01
B03.110.003	96-01
B03.110.004	96-01
B03.130.001	95-04
B03.130.002	95-04
B03.140.001	95-04
B03.140.002	95-04
C01.030.001	96-01

OCONEE UNIT NUMBER 1 - 3rd INTERVAL
CLASS B (CATEGORY C-H) RESULTS
THROUGH OUTAGE NUMBER 16

ITEM NO.	DRAWING	1ST PERIOD			2ND PERIOD			3RD PERIOD		
		EXAM. DATE	STATUS	RESULTS	EXAM. DATE	STATUS	RESULTS	EXAM. DATE	STATUS	RESULTS
C07.030.001	OFDL-101A-1.1	12/07/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.002	OFDL-101A-1.2	12/02/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT TESTED	N/A
C07.030.003	OFDL-101A-1.3	12/04/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.004	OFDL-101A-1.4	12/07/95	PARTIAL	RECORDABLE	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.005	OFDL-101A-1.5	12/02/95	COMPLETE	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.006	OFDL-102A-1.1	12/04/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT TESTED	N/A
C07.030.007	OFDL-102A-1.2	12/04/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT TESTED	N/A
C07.030.008	OFDL-102A-1.3	11/02/95	PARTIAL	RECORDABLE	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.010	OFDL-104A-1.1	12/02/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.011	OFDL-104A-1.2	12/04/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT TESTED	N/A
C07.030.017	OFDL-110A-1.1	12/07/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.031	OFDL-124B-1.2	11/28/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A
C07.030.032	OFDL-124B-1.4	12/07/95	PARTIAL	CLEAR	//	NOT TESTED	N/A	//	NOT REQUIRED	N/A

B. Items examined by Pressure Testing

Item Number	=	ASME Section XI Tables IWB-2500-1 (Class 1), IWC-2500-1 (Class 2)
Drawing	=	Number of the Flow Diagram
Examination Date	=	Latest examination date
Condition	=	Partial or Complete test C = Complete for the period N = Not complete for the period
Period Status 1, 2, 3		
Status	=	Clear, Recordable or Reportable
Comments	=	General and/or Detail Description

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 14
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
G04.001.007	1-51A-10-6	51A	11/08/95	CLR	---	N	
G04.001.010	1-51A-5-81C	51A	11/08/95	CLR	100.0%	N	No scan due to valve. 100% coverage obtained using multiple angles. (60 shear & 60 L waves).
G04.001.011	1-51A-5-79C	51A	11/08/95	CLR	100.0%	N	No scan due to configuration. 100% coverage obtained using multiple angles.
G04.001.012	1-51A-5-77C	51A	11/08/95	CLR	100.0%	N	100% coverage obtained using multiple angles.
G06.001.033	1-03A-11-1VEN	03A	11/27/95	CLR	---	N	
G06.001.033A	1-03A-11-1VEN	03A	11/24/95	CLR	---	N	
G09.001.001	1-51A-01-3A	51A	10/02/95	CLR	---	N	
G09.001.007	1-53B-01-90B	53B	09/28/95	CLR	---	N	
G09.001.013	1-53B-03-33F	53B	11/14/95	CLR	---	N	
G09.001.019	1-53B-06-114K	53B	09/28/95	CLR	---	N	
G09.001.025	1-53B-13-115J	53B	09/25/95	CLR	---	N	
G09.001.031	1-54A-01-05A	54A	10/02/95	CLR	---	N	
G09.001.037	1-54A-04-21C	54A	10/09/95	CLR	---	N	
G09.001.043	1-54A-04-75C	54A	10/02/95	CLR	---	N	
G12.001.001	1-51B-10-10HC	51B	10/05/95	CLR	---	N	
G12.001.019	1-51B-7-34F	51B	11/27/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 13
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
F01.050.070	1-51A-H80	51A	10/02/95	CLR	---	N	
F01.050.071	1-51A-H86	51A	10/02/95	CLR	---	N	
F01.050.072	1-53A-GPD-H0010	53A	11/22/95	CLR	---	N	
F01.050.073	1-03-H6068	03	11/16/95	CLR	---	N	
F01.050.074	1-03-H6020	03	11/16/95	CLR	---	N	
F01.050.075	1-03-H6070	03	11/22/95	REC	---	N	Pin-to-pin cps are acceptable. However, base plate does not have bearing at both south anchors. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95
F01.050.076	1-03-H6071	03	11/16/95	CLR	---	N	
F01.050.077	1-57-NW1Z	57	11/22/95	CLR	---	N	
F01.050.078	1-57-H23	57	11/21/95	CLR	---	N	
F01.050.079	1-01A-R11	01A	10/18/95	CLR	---	N	
F01.050.080	1-01A-R4	01A	10/18/95	CLR	---	N	
F01.050.081	1-01A-R5	01A	10/16/95	CLR	---	N	
F01.050.081	1-01A-R5	01A	11/30/95	CLR	---	N	
F01.050.082	1-01A-R6	01A	11/30/95	CLR	---	N	
F01.050.083	1-01A-R7	01A	11/21/95	CLR	---	N	
F01.050.084	1-03-R13	03	11/30/95	CLR	---	N	
F01.050.085	1-03A-H115	03A	10/05/95	CLR	---	N	
F01.050.086	1-03A-H123	03A	10/05/95	CLR	---	N	
F01.050.087	1-03A-SR62	03A	09/20/95	CLR	---	N	
F01.050.088	1-01A-H43	01A	10/16/95	CLR	---	N	
F01.050.089	1-01A-R11	01A	10/18/95	CLR	---	N	
F01.050.090	1-07A-H39	07A	11/30/95	CLR	---	N	
F01.050.091	1-07A-H40	07A	10/05/95	CLR	---	N	
F01.050.092	1-07A-H41	07A	10/18/95	CLR	---	N	
G04.001.001	1-51A-11-87	51A	11/08/95	CLR	100.0%	N	No scan due to nozzle. 100% coverage obtained using multiple angles (60 shear & 60 L)
G04.001.002	1-51A-11-88	51A	11/08/95	CLR	100.0%	N	No scan due to valve. 100% coverage obtained using multiple angles. (60 shear & 60 L wave).
G04.001.003	1-51A-11-89	51A	11/08/95	CLR	100.0%	N	No scan due to nozzle. 100% coverage obtained using multiple angles. (60 shear & 60 L wave).
G04.001.004	1-51A-11-90	51A	11/08/95	CLR	100.0%	N	No scan due to nozzle. 100% coverage obtained using multiple angles. (60 shear & 60 L wave).
G04.001.005	1-51A-10-1	51A	11/08/95	CLR	100.0%	N	No scan due to valve. 100% coverage obtained using multiple angles. (60 shear & 60 L wave).
G04.001.006	1-51A-10-2	51A	11/08/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 12
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
F01.050.042	1-01A-R9-4	01A	11/21/95	CLR	---	N	
F01.050.043	1-03-R12	03	11/30/95	CLR	---	N	
F01.050.044	1-03-R7	03	11/05/95	CLR	---	N	
F01.050.045	1-03A-SR56	03A	10/05/95	CLR	---	N	
F01.050.046	1-03A-SR57	03A	10/05/95	CLR	---	N	
F01.050.047	1-03A-SR58	03A	10/18/95	CLR	---	N	
F01.050.048	1-03A-SR59	03A	10/18/95	CLR	---	N	
F01.050.049	1-03A-SR50	03A	10/17/95	CLR	---	N	
F01.050.050	1-03A-SR63	03A	09/20/95	CLR	---	N	
F01.050.051	1-03A-SR64	03A	10/02/95	CLR	---	N	
F01.050.052	1-01A-H40	01A	10/17/95	CLR	---	N	
F01.050.053	1-01A-H44	01A	10/16/95	CLR	---	N	
F01.050.054	1-01A-R6	01A	10/16/95	REC	---	N	Item #2 of bill of materials, the top part of rear bracket is rubbing bottom portion of structural I beam. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95 (See inspection record for additional justification).
F01.050.055	1-01A-R2	01A	10/16/95	CLR	---	N	
F01.050.056	1-03A-DE058	03A	11/30/95	CLR	---	N	
F01.050.057	1-03-H4171	03	10/03/95	CLR	---	N	
F01.050.058	1-53B-DE056	53B	09/20/95	REC	---	N	Insulation mud all over the cylinder of the mechanical snubber. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95
F01.050.059	1-53B-DE059	53B	09/26/95	CLR	---	N	
F01.050.060	1-53B-DE066	53B	09/20/95	REC	---	N	Insulation mud all over the cylinder of the mechanical snubber. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95
F01.050.061	1-54A-DE-020	54A	09/20/95	CLR	---	N	
F01.050.062	1-54A-DE015	54A	09/20/95	REC	---	N	Insulation mud all over cylinder of the mechanical snubber. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95
F01.050.063	1-51A-DE001A	51A	09/20/95	CLR	---	N	
F01.050.064	1-53B-DE060	53B	09/26/95	CLR	---	N	
F01.050.065	1-53B-DE055	53B	10/25/95	CLR	---	N	
F01.050.066	1-53B-DE057	53B	10/25/95	CLR	---	N	
F01.050.067	1-51A-H102	51A	10/02/95	CLR	---	N	
F01.050.068	1-51A-H97	51A	09/21/95	CLR	---	N	
F01.050.069	1-54A-R16	54A	10/02/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 11
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
F01.050.013	1-53A-H5A	53A	11/05/95	CLR	---	N	
F01.050.014	1-53A-H5B	53A	11/22/95	CLR	---	N	
F01.050.015	1-03-H7B	03	11/16/95	CLR	---	N	
F01.050.016	1-50-H11	50	11/22/95	CLR	---	N	
F01.050.017	1-03-H10A	03	11/30/95	CLR	---	N	
F01.050.018	1-53A-H40C	53A	11/21/95	CLR	---	N	
F01.050.019	1-53A-H41C	53A	11/30/95	CLR	---	N	
F01.050.020	1-57-H10	57	11/30/95	CLR	---	N	
F01.050.021	1-57-H11	57	11/30/95	CLR	---	N	
F01.050.022	1-57-H13-A	57	11/30/95	CLR	---	N	
F01.050.023	1-57-H14	57	11/21/95	CLR	---	N	
F01.050.024	1-57-H15	57	11/21/95	REC	---	N	Cold Piston setting is out of tolerance. The Cold setting is acceptable per Specification OS-0027.00-00-0002. TJC 11/29/95
F01.050.025	1-57-H17	57	11/30/95	CLR	---	N	
F01.050.026	1-57-H18	57	11/30/95	REC	---	N	Cold piston setting out of tolerance per sketch. DLO Setting is acceptable per hanger specification OS-0027.00-00-0002 Sect. 9.2. TJC
F01.050.027	1-57-H22	57	11/30/95	CLR	---	N	
F01.050.028	1-57-H26	57	11/30/95	CLR	---	N	
F01.050.029	1-57-H9	57	11/30/95	CLR	---	N	
F01.050.030	1-01A-H10B	01A	11/30/95	CLR	---	N	
F01.050.031	1-01A-H11A	01A	11/05/95	CLR	---	N	
F01.050.032	1-01A-H11B	01A	11/30/95	CLR	---	N	
F01.050.033	1-01A-H12A	01A	11/30/95	CLR	---	N	
F01.050.034	1-01A-DE005	01A	11/21/95	CLR	---	N	
F01.050.035	1-01A-DE006	01A	11/21/95	CLR	---	N	
F01.050.036	1-01A-R-2-1	01A	11/21/95	CLR	---	N	
F01.050.037	1-01A-R-2-2	01A	11/21/95	CLR	---	N	
F01.050.038	1-01A-R12	01A	11/30/95	REC	---	N	Fluid reservoir is only 40% full & fluid is present on body of suppressor. Jam nut on screw eye at beam attachment is loose. Civil Engineering review has found this support to be acceptable for service. WR was written to repair any leaks on this snubber prior to unit startup. PA Wells 12/1/95
F01.050.039	1-01A-R9-1	01A	11/21/95	CLR	---	N	
F01.050.040	1-01A-R9-2	01A	11/21/95	CLR	---	N	
F01.050.041	1-01A-R9-3	01A	11/21/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 10
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
							Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95
F01.030.022	1-08-H4050	08	09/06/95	CLR	---	N	
F01.030.035	1-56-DE009	56	10/25/95	CLR	---	N	
F01.030.036	1-56-H17	56	10/05/95	CLR	---	N	
F01.030.041	1-57-H1	57	11/22/95	CLR	---	N	
F01.030.042	1-04A-H16	04A	11/27/95	REC	---	N	Rod hangers removed, rod not loaded & not welded per sketch. Civil Engineering review has found this support to be acceptable for service. PA Wells 12/1/95 (See inspection record for additional justification).
F01.031.002	1-03-H6175	03	11/22/95	CLR	---	N	
F01.031.006	1-04A-R5	04A	10/12/95	REJ	---	N	2 1/4" gap below pipe is 1 1/2" - tolerance is -0 +1; not welded in accordance with sketch. Civil Engineering has found this support to be unacceptable for service in its as -found condition. PIP 1-95-1427 was originated to document operability. PA Wells 11/14/95
F01.031.008	1-08-H4055	08	09/06/95	CLR	---	N	
F01.031.016	1-04A-R6	04A	11/21/95	REC	---	N	This hanger has never been painted, needs rust & scale removed. Also, slag present on some welds. Civil Engineering review has found this support to be acceptable for service. PA Wells 12/1/95 (See inspection record for further justification).
F01.032.004	1-03-H63	03	10/02/95	REC	---	N	Pipe not bearing on middle lug on pipe saddle, west rod is bent & nuts don't have full thread on bolts on item #2. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/29/95 (See inspection record for additional justification).
F01.032.006	1-04A-R12	04A	10/30/95	CLR	---	N	Inspected with D02.050.001
F01.040.006	1-DHRC-A-SUPPORT	53A	09/26/95	CLR	---	N	
F01.050.001	1-50-H12	50	11/22/95	CLR	---	N	
F01.050.002	1-50-H1A	50	11/30/95	CLR	---	N	
F01.050.003	1-50-H2A	50	11/30/95	CLR	---	N	
F01.050.004	1-50-H3	50	11/22/95	CLR	---	N	
F01.050.005	1-50-H3A	50	11/30/95	CLR	---	N	
F01.050.006	1-50-H7	50	11/30/95	CLR	---	N	
F01.050.007	1-50-H8	50	11/21/95	CLR	---	N	
F01.050.008	1-50-H9	50	11/05/95	CLR	---	N	
F01.050.009	1-50-H10	50	11/22/95	CLR	---	N	
F01.050.011	1-50-H1	50	11/21/95	CLR	---	N	
F01.050.012	1-51A-H17A	51A	11/21/95	CLR	---	N	

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
In-Service Inspection Database Management System
Oconee Inservice Inspection Listing
Interval 3 Outage 1

Run D
Page 9
02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
							discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. P A Wells 12/1/95
F01.020.043	1-56-SR18	56	10/25/95	CLR	---	N	
F01.021.005	1-14-H19B	14	11/22/95	REC	---	N	No gaps visible around pipe - sketch indicates 1/16" clearance sides & top. Civil Engineering review has found this support to be acceptable for service. The indication noted was determined not to be a discrepancy. PA Wells 11/30/95 (See additional justification documented in inspection package)
F01.021.008	1-14-H6	14	11/22/95	REC	---	N	East stanchion - no gap above pipe west stanchion - gap north of stanchion is 0.160" (0.125" max.) Civil engineering review has found this support to be acceptable for service. The discrepancies were determined to be not significant and no root cause investigation is required. PA Wells 11/29/95 (For further justification see inspection package)
F01.021.013	1-51A-H91	51A	09/21/95	CLR	---	N	
F01.021.024	1-56-DE001	56	10/12/95	CLR	---	N	
F01.022.012	1-51A-H3	51A	11/02/95	CLR	---	N	
F01.022.016	1-53B-H1	53B	09/20/95	CLR	---	N	
F01.022.017	1-53B-H10	53B	09/26/95	CLR	---	N	
F01.022.024	1-54A-R5	54A	09/20/95	CLR	---	N	
F01.030.017	1-04A-H17	04A	11/27/95	REC	---	N	Rod hangers removed, not welded per sketch & jam nuts do not have full thread engagement. After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 11/29/95 (See inspection package for additional justification)
F01.030.017	1-04A-H17	04A	10/02/95	REC	---	N	This inspection was performed after hanger 1-04A-2-0-439B-R5 (F01.031.066) was found to be unacceptable for continued service. Items #1 shown welded 3/16" fillet outside both sides typ. Actual welds are shown on attached sketch (see inspection record). After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95
F01.030.020	1-07A-GTE-1901	07A	09/06/95	CLR	---	N	
F01.030.021	1-07A-SR8	07A	09/06/95	REC	---	N	3/16" weld instead of 1/4" as indicated on sketch. After evaluation it was determined that this discrepancy is not service induced.

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 8
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
D02.020.099	1-14B-SR60	14B	10/03/95	CLR	---	N	
D02.020.102	1-57-H1	57	11/22/95	CLR	---	N	
D02.030.003	1-03-H4171	03	10/03/95	CLR	0.00%	N	
D02.040.004	1-03-H50	03	11/28/95	CLR	---	N	
D02.040.008	1-03-H63	03	10/02/95	CLR	0.00%	N	
D02.040.015	1-14B-H20	14B	09/26/95	CLR	0.00%	N	
D02.050.001	1-04A-R12	04A	10/30/95	CLR	---	N	
D03.020.001	1-56-DE034	56	10/03/95	REC	---	N	Item #1 not welded to pipe. After evaluation it was determined that this is not a discrepancy. No weld is called out on the sketch between the saddle & the pipe. No action is required. PA Wells 11/30/95
D03.020.003	1-56-H17	56	10/05/95	CLR	---	N	
D03.020.008	1-56-H5133	56	10/05/95	CLR	---	N	
D03.020.012	1-56-JTC-2903	56	11/16/95	REC	---	N	Attachment sketch shows pipe welded along pipe axis to item #3. East side is inaccessible. No weld exists west side in this location. After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95
F01.010.005	1-51A-H6228	51A	12/01/95	CLR	---	N	
F01.012.003	1-50-H2A	50	11/30/95	REC	---	N	Cylinder rods (lower) bearing against clamp - no freedom of movement. Civil Engineering review has found this support to be acceptable for service. PA Wells 11/30/95 (For additional justification see inspection package).
F01.012.006	1-53A-H39C	53A	11/30/95	CLR	---	N	
F01.012.008	1-53A-H6200	53A	11/30/95	CLR	---	N	
F01.012.009	1-57-H13-A	57	11/30/95	CLR	---	N	
F01.020.008	1-14-H54	14	11/30/95	CLR	---	N	
F01.020.009	1-14-H63	14	11/30/95	CLR	---	N	
F01.020.016	1-51A-H100	51A	09/21/95	REC	---	N	No weld exist on inside of box at top. After evaluation it was discovered that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95
F01.020.022	1-51B-DE051	51B	11/02/95	CLR	---	N	
F01.020.027	1-53B-H1	53B	10/05/95	CLR	---	N	
F01.020.037	1-54A-DE10	54A	09/20/95	CLR	---	N	
F01.020.038	1-54A-H23	54A	10/12/95	REC	---	N	Items #2 shown welded east & west side typ. Actually welded north & south sides typical. After evaluation it was determined that this

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 7
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
C05.051.036	1-LPSW-344-21	14B	10/25/95	CLR	---	N	
C05.051.036A	1-LPSW-344-21	14B	10/25/95	CLR	---	N	
C05.051.040	1-LPSW-345-17	14B	11/09/95	CLR	100.0%	N	No scan due to flange configuration. 100% coverage obtained using additional angle (7 degree).
C05.051.040A	1-LPSW-345-17	14B	11/09/95	CLR	---	N	
C05.051.049	1-LPSW-346-21	14B	10/25/95	CLR	---	N	
C05.051.049A	1-LPSW-346-21	14B	10/25/95	CLR	---	N	
C05.052.002	1-20B-21-16-2L	20B	11/13/95	CLR	---	N	
C05.052.002A	1-20B-21-16-2L	20B	11/14/95	CLR	---	N	
C05.081.004	1-03-09-40D	03	11/19/95	CLR	---	N	
C05.081.006	1-FWD67-A	03A	11/19/95	CLR	---	N	
C06.020.001	1-FDW-345	03A	11/19/95	CLR	---	N	
D02.020.006	1-03-NPS-H16	03	11/16/95	CLR	---	N	
D02.020.009	1-03A-DE063	03A	10/09/95	CLR	---	N	
D02.020.031	1-03A-H72	03A	10/02/95	CLR	---	N	
D02.020.066	1-04A-R5	04A	10/12/95	REC	---	N	Sect. EE shows Items #16 welded all around. Actually welded top, bottom, outside edges. After evaluation it was determined that this discrepancy is not service induced. Therefore the support is acceptable for service per Article IWF-3112 of ASME Section XI. PA Wells 12/1/95
D02.020.068	1-07A-H12	07A	09/06/95	CLR	---	N	
D02.020.072	1-08-H4051	08	09/06/95	CLR	---	N	
D02.020.075	1-14B-ASR17	14B	10/11/95	REC	---	N	1/4" weld is approximately 3/16" only. After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of the ASME Code.
D02.020.078	1-14B-CLF-901	14B	09/20/95	REC	---	N	Missing weld and rust/pits. Civil Engineering review has found this support to be acceptable for service. PA Wells 12/5/95
D02.020.084	1-14B-H2	14B	10/30/95	CLR	---	N	
D02.020.089	1-14B-RMC-0503	14B	10/12/95	REC	---	N	Not welded in accordance with the hanger sketch. After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95
D02.020.095	1-14B-SR43	14B	10/12/95	REC	---	N	Hanger not welded in accordance with sketch. After evaluation it was determined that this discrepancy is not service induced. Therefore, the support is acceptable for service per Article IWF-3112 of Section XI of ASME Code. PA Wells 12/1/95

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
In-Service Inspection Database Management System
Oconee Inservice Inspection Listing

Run D
Page 6
02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
C05.021.061A	1-51A-03-99B	51A	10/23/95	CLR	---	N	
C05.021.068	1-51A-136-24	51A	11/17/95	REC	---	Y	
C05.021.068A	1-51A-136-24	51A	11/17/95	CLR	---	N	
C05.021.074	1-51A-01-71A	51A	11/07/95	CLR	100.0%	N	Limitation was due to valve to elbow configuration. 100% coverage was obtained by use of multiple angles.
C05.021.074A	1-51A-01-71A	51A	11/03/95	CLR	---	N	
C05.021.076	1-51A-01-13A	51A	11/02/95	CLR	---	N	
C05.021.076A	1-51A-01-13A	51A	11/02/95	CLR	---	N	
C05.021.082	1-51A-01-106A	51A	11/02/95	REC	---	Y	
C05.021.082A	1-51A-01-106A	51A	11/02/95	CLR	---	N	
C05.021.088	1-51A-02-21B	51A	11/08/95	REC	---	Y	
C05.021.088A	1-51A-02-21B	51A	11/14/95	CLR	---	N	
C05.021.094	1-51A-02-7B	51A	11/08/95	CLR	---	N	
C05.021.094A	1-51A-02-7B	51A	11/14/95	CLR	---	N	
C05.021.103	1-RCP-FTR1A-SH-1		10/25/95	CLR	---	N	
C05.021.103A	1-RCP-FTR1A-SH-1		10/24/95	CLR	---	N	
C05.021.104	1-RCP-FTR1A-SH-2		10/25/95	CLR	---	N	
C05.021.104A	1-RCP-FTR1A-SH-2		10/24/95	CLR	---	N	
C05.041.002	1-53B-01-87BA	53B	09/28/95	CLR	---	N	
C05.041.011	1-53B-06-21KA	53B	10/09/95	CLR	---	N	
C05.041.012	1-53B-06-21KB	53B	10/09/95	CLR	---	N	
C05.041.024	1-53B-02-121ZA	53B	09/28/95	CLR	---	N	
C05.041.025	1-53B-02-121Z	53B	09/28/95	CLR	---	N	
C05.051.006	1-MS17B-A	01A	11/28/95	REC	---	Y	
C05.051.006A	1-MS17B-A	01A	11/24/95	CLR	---	N	
C05.051.009	1-01A-01-29C	01A	11/28/95	REC	---	Y	
C05.051.009A	1-01A-01-29C	01A	11/24/95	CLR	---	N	
C05.051.012	1-01A-02-11BA	01A	11/19/95	REC	---	Y	
C05.051.012A	1-01A-02-11BA	01A	11/17/95	CLR	---	N	
C05.051.017	1-01A-1-99	01A	11/28/95	REC	---	Y	
C05.051.017A	1-01A-1-99	01A	11/24/95	CLR	---	N	
C05.051.030	1-FWD88-C	03A	11/27/95	CLR	---	N	
C05.051.030A	1-FWD88-C	03A	11/24/95	CLR	---	N	
C05.051.033	1-20B-21-16-2	20B	11/13/95	CLR	100.0%	N	100% coverage obtained using 70 degree angle as a supplemental angle for coverage
C05.051.033A	1-20B-21-16-2	20B	11/14/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 5
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
C03.020.033	1-51-SR47	51	10/30/95	CLR	---	N	
C03.020.034	1-51-SR48	51	10/02/95	CLR	---	N	
C03.020.035	1-51-SR49	51	09/26/95	CLR	---	N	
C03.020.037	1-51-SR51	51	09/26/95	CLR	---	N	
C03.020.038	1-51A-H115	51A	09/20/95	CLR	---	N	
C03.020.039	1-51A-H91	51A	09/19/95	CLR	---	N	
C03.020.043	1-53B-H1	53B	09/19/95	CLR	---	N	
C03.020.067	1-JWC-1707	56	11/22/95	CLR	---	N	
C03.020.068	1-JWC-1708	56	11/22/95	CLR	---	N	
C05.011.003	1-53A-01-30L	53A	11/21/95	CLR	100.0%	N	One sided examination due to valve. 100% coverage due to 60 degree L for far side.
C05.011.003A	1-53A-01-30L	53A	11/24/95	CLR	---	N	
C05.021.001	1-51A-01-79A	51A	11/07/95	CLR	100.0%	N	Limitation was due to valve to elbow configuration. 100% coverage was obtained by use of multiple angles.
C05.021.001A	1-51A-01-79A	51A	11/03/95	CLR	---	N	
C05.021.002	1-51A-02-15B	51A	10/24/95	CLR	---	N	
C05.021.002A	1-51A-02-15B	51A	10/09/95	CLR	---	N	
C05.021.007	1-51A-122-19	51A	10/24/95	CLR	---	N	
C05.021.007	1-51A-122-19	51A	10/24/95	REC	---	Y	
C05.021.007A	1-51A-122-19	51A	10/30/95	CLR	---	N	
C05.021.012	1-51A-123-12	51A	10/23/95	CLR	---	N	
C05.021.012	1-51A-123-12	51A	10/23/95	CLR	---	N	
C05.021.012A	1-51A-123-12	51A	10/23/95	CLR	---	N	
C05.021.018	1-51A-124-10	51A	11/07/95	CLR	---	N	
C05.021.018A	1-51A-124-10	51A	11/20/95	CLR	---	N	
C05.021.024	1-51A-125-13	51A	10/23/95	CLR	---	N	
C05.021.024	1-51A-125-13	51A	10/23/95	CLR	---	N	
C05.021.024A	1-51A-125-13	51A	10/23/95	CLR	---	N	
C05.021.030	1-51A-127-4	51A	10/26/95	CLR	---	N	
C05.021.030A	1-51A-127-4	51A	10/26/95	CLR	---	N	
C05.021.045	1-51A-01-89A	51A	10/26/95	CLR	---	N	
C05.021.045A	1-51A-01-89A	51A	10/26/95	CLR	---	N	
C05.021.051	1-51A-02-16BA	51A	10/24/95	CLR	---	N	
C05.021.051A	1-51A-02-16BA	51A	10/09/95	CLR	---	N	
C05.021.061	1-51A-03-99B	51A	10/23/95	CLR	---	N	
C05.021.061	1-51A-03-99B	51A	10/23/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 4
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
B09.012.001	1-PIA1-62LI	50	11/18/95	CLR	---	N	
B09.012.001A	1-PIA1-62LI	50	11/18/95	CLR	---	N	
B09.012.002	1-PIA1-62LO	50	11/18/95	CLR	---	N	
B09.012.002A	1-PIA1-62LO	50	11/18/95	CLR	---	N	
B09.012.003	1-PIA1-45LI	50	11/18/95	CLR	---	N	
B09.012.003A	1-PIA1-45LI	50	11/21/95	CLR	---	N	
B09.012.004	1-PIA1-45LO	50	11/18/95	CLR	---	N	
B09.012.004A	1-PIA1-45LO	50	11/24/95	CLR	---	N	
B09.012.007	1-PDA1-53LO	50	11/13/95	CLR	---	N	
B09.012.007A	1-PDA1-53LO	50	11/13/95	CLR	---	N	
B09.012.008	1-PDA1-53LI	50	11/13/95	CLR	---	N	
B09.012.008A	1-PDA1-53LI	50	11/13/95	CLR	---	N	
B09.012.051	1-PIA1-62LI	50	11/18/95	CLR	---	N	
B09.012.051A	1-PIA1-62LI	50	11/18/95	CLR	---	N	
B09.012.052	1-PIA1-62LO	50	11/18/95	CLR	---	N	
B09.012.052A	1-PIA1-62LO	50	11/18/95	CLR	---	N	
B09.021.032	1-51A-04-25C	51A	11/08/95	CLR	---	N	
B09.021.033	1-51A-04-23C	51A	11/08/95	CLR	---	N	
B09.021.034	1-51A-04-14C	51A	11/08/95	CLR	---	N	
B09.021.037	1-51A-04-11C	51A	11/08/95	CLR	---	N	
B09.021.038	1-51A-04-9C	51A	11/08/95	CLR	---	N	
B09.031.003	1-PIB1-10	50	11/21/95	CLR	100.0%	N	100 % coverage obtained by using a combination of 45 & 60 degree transducers
B14.010.001	1-RPV-CRD-47WH9	50	11/24/95	CLR	---	N	
B14.010.004	1-RPV-CRD-47W60	50	11/12/95	CLR	---	N	
B14.010.007	1-RPV-CRD-47	50	11/12/95	CLR	---	N	
B14.010.010	1-RPV-CRD-47W61	50	11/12/95	CLR	---	N	
C01.030.001	1-SGA-WG60		11/20/95	CLR	0.00%	N	Percent of coverage varies due to location of support/restraint. See inspection report for more detail.
C02.021.002	1-SGB-WG23-2	03	11/21/95	REC	---	N	
C02.021.002A	1-SGB-WG23-2	03	11/19/95	CLR	---	N	
C02.022.002	1-SGB-WG23-2	03	11/21/95	CLR	---	N	
C03.020.001	1-01A-H10A	01A	11/17/95	CLR	---	N	
C03.020.009	1-01A-H5B	01A	11/20/95	CLR	---	N	
C03.020.030	1-51-SR20	51	09/20/95	CLR	---	N	
C03.020.031	1-51-SR38	51	10/02/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing
 Interval 3 Outage 1

Run D
 Page 3
 02/07/96

Plant: Oconee 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
B06.030.015A	1-RPV-25-203-15		11/16/95	CLR	---	N	
B06.030.016	1-RPV-25-203-62		11/16/95	CLR	---	N	
B06.030.016A	1-RPV-25-203-62		11/16/95	CLR	---	N	
B06.030.017	1-RPV-25-203-17		11/16/95	CLR	---	N	
B06.030.017A	1-RPV-25-203-17		11/16/95	CLR	---	N	
B06.030.018	1-RPV-25-203-18		11/16/95	CLR	---	N	
B06.030.018A	1-RPV-25-203-18		11/16/95	CLR	---	N	
B06.030.019	1-RPV-25-203-19		11/16/95	CLR	---	N	
B06.030.019A	1-RPV-25-203-19		11/16/95	CLR	---	N	
B06.030.020	1-RPV-25-203-20		11/16/95	CLR	---	N	
B06.030.020A	1-RPV-25-203-20		11/16/95	CLR	---	N	
B06.050.001	1-RPV-WASH-BUSH		11/17/95	CLR	---	N	
B06.080.001	1-PZR-MW-NUTS		12/05/95	CLR	---	N	
B07.030.002	1-SGA-LMW-BOLTS		11/11/95	CLR	---	N	
B07.030.006	1-SGA-LHIC-BOLTS		11/28/95	CLR	---	N	Inspection was done with bolting in place.
B07.050.003	1-PZR-RC67-BOLT		11/22/95	CLR	---	N	
B07.050.004	1-PZR-RC68-BOLT		11/22/95	CLR	---	N	
B07.060.003	1-RCP-1B1-SEAL		11/22/95	CLR	---	N	Bolting inspected in place.
B07.080.001	1-RPV-CRD-BOLTS		11/28/95	CLR	---	N	Inspected CRD #s 2, 3, 4, 5, 6, 8, 15, 18, 47, 48, 49, 52, 54, 56, 58, 62, 64, 65 & 67. No apparent service induced damage.
B07.080.002	1-RPV-CRD-RINGS		11/28/95	CLR	---	N	Inspected CRD #s 2, 3, 4, 5, 6, 8, 15, 18, 47, 48, 49, 52, 54, 56, 58, 62, 64, 65, & 67. No apparent service induced damage.
B09.011.001	1-PIA1-9	50	11/19/95	CLR	---	N	
B09.011.001A	1-PIA1-9	50	11/18/95	CLR	---	N	
B09.011.004	1-PIA1-5	50	11/18/95	CLR	---	N	
B09.011.004A	1-PIA1-5	50	11/18/95	CLR	---	N	
B09.011.005	1-PIA1-4	50	11/18/95	CLR	100.0%	N	Limited scan due to nozzle weld in area of interest. 100% coverage obtained by scanning across weld cap in 2 directions.
B09.011.005A	1-PIA1-4	50	11/18/95	CLR	---	N	
B09.011.007	1-PIA1-2	50	11/18/95	CLR	---	N	
B09.011.007A	1-PIA1-2	50	11/18/95	CLR	---	N	
B09.011.008	1-PIA1-1	50	11/18/95	CLR	---	N	
B09.011.008A	1-PIA1-1	50	11/18/95	CLR	---	N	
B09.011.011	1-PDA1-4	50	11/13/95	CLR	---	N	
B09.011.011A	1-PDA1-4	50	11/13/95	CLR	---	N	
B09.011.036	1-PIB1-5	50	11/21/95	REC	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 2
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
B06.010.014	1-RPV-26-203-14		11/16/95	CLR	---	N	
B06.010.015	1-RPV-26-203-15		11/16/95	CLR	---	N	
B06.010.016	1-RPV-26-203-16		11/16/95	CLR	---	N	
B06.010.017	1-RPV-26-203-17		11/16/95	CLR	---	N	
B06.010.018	1-RPV-26-203-18		11/16/95	CLR	---	N	
B06.010.019	1-RPV-26-203-19		11/16/95	CLR	---	N	
B06.010.020	1-RPV-26-203-20		11/16/95	CLR	---	N	
B06.030.001	1-RPV-25-203-01		11/16/95	CLR	---	N	
B06.030.001A	1-RPV-25-203-01		11/16/95	CLR	---	N	
B06.030.002	1-RPV-25-203-02		11/16/95	CLR	---	N	
B06.030.002A	1-RPV-25-203-02		11/16/95	CLR	---	N	
B06.030.003	1-RPV-25-203-03		11/16/95	CLR	---	N	
B06.030.003A	1-RPV-25-203-03		11/16/95	CLR	---	N	
B06.030.004	1-RPV-25-203-04		11/16/95	CLR	---	N	
B06.030.004A	1-RPV-25-203-04		11/16/95	CLR	---	N	
B06.030.005	1-RPV-25-203-05		11/16/95	CLR	---	N	
B06.030.005A	1-RPV-25-203-05		11/16/95	CLR	---	N	
B06.030.006	1-RPV-25-203-06		11/16/95	CLR	---	N	
B06.030.006A	1-RPV-25-203-06		11/16/95	CLR	---	N	
B06.030.007	1-RPV-25-203-07		11/16/95	CLR	---	N	
B06.030.007A	1-RPV-25-203-07		11/16/95	CLR	---	N	
B06.030.008	1-RPV-25-203-64		11/16/95	CLR	---	N	
B06.030.008A	1-RPV-25-203-64		11/16/95	CLR	---	N	
B06.030.009	1-RPV-25-203-09		11/16/95	CLR	---	N	
B06.030.009A	1-RPV-25-203-09		11/16/95	CLR	---	N	
B06.030.010	1-RPV-25-203-10		11/16/95	CLR	---	N	
B06.030.010A	1-RPV-25-203-10		11/16/95	CLR	---	N	
B06.030.011	1-RPV-25-203-11		11/16/95	CLR	---	N	
B06.030.011A	1-RPV-25-203-11		11/16/95	CLR	---	N	
B06.030.012	1-RPV-25-203-12		11/16/95	CLR	---	N	
B06.030.012A	1-RPV-25-203-12		11/16/95	CLR	---	N	
B06.030.013	1-RPV-25-203-13		11/16/95	CLR	---	N	
B06.030.013A	1-RPV-25-203-13		11/16/95	CLR	---	N	
B06.030.014	1-RPV-25-203-14		11/16/95	CLR	---	N	
B06.030.014A	1-RPV-25-203-14		11/16/95	CLR	---	N	
B06.030.015	1-RPV-25-203-15		11/16/95	CLR	---	N	

DUKE POWER COMPANY
 QUALITY ASSURANCE TECHNICAL SERVICES
 In-Service Inspection Database Management System
 Oconee Inservice Inspection Listing

Run D
 Page 1
 02/07/96

Plant: Oconee 1

Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	SYSTEM	INSP DATE	INSP STATUS	INSP LIMITED	GEO REF	COMMENTS
B01.030.002	1-RPV-WR19	50	11/08/95	CLR	---	N	
B02.011.001	1-PZR-WP76	50	11/16/95	REC	90.70%	N	
B02.011.003	1-PZR-WP4	50	11/21/95	REC	---	N	
B02.012.001	1-PZR-WP1-1	50	11/16/95	CLR	---	N	
B03.110.002	1-PZR-WP34	50	11/16/95	REC	89.64%	Y	
B03.110.003	1-PZR-WP33-3	50	11/16/95	REC	89.22%	Y	
B03.110.004	1-PZR-WP33-2	50	11/16/95	REC	89.22%	Y	
B03.120.002	1-PZR-WP34	50	11/16/95	CLR	---	N	
B03.120.003	1-PZR-WP33-3	50	11/16/95	CLR	---	N	
B03.120.004	1-PZR-WP33-2	50	11/16/95	CLR	---	N	
B03.130.001	1-SGA-WG50-2	50	11/13/95	REC	75.00%	Y	
B03.130.002	1-SGA-WG50-1	50	11/13/95	REC	75.00%	Y	
B03.140.001	1-SGA-WG50-2	50	11/13/95	CLR	44.00%	N	
B03.140.002	1-SGA-WG50-1	50	11/13/95	CLR	44.00%	N	
B05.050.002	1-PZR-WP91-2	50	11/18/95	CLR	---	N	
B05.050.003	1-PZR-WP91-3	50	11/18/95	CLR	---	N	
B05.130.001	1-PIA1-7	50	11/19/95	CLR	---	N	
B05.130.001A	1-PIA1-7	50	11/19/95	CLR	---	N	
B05.130.001B	1-PIA1-7	50	11/18/95	CLR	---	N	
B05.140.001	1-PIA1-11	50	11/19/95	CLR	---	N	
B05.140.003	1-PDA1-11	50	11/19/95	CLR	---	N	
B05.140.009	1-50-01-34	50	11/17/95	CLR	---	N	
B05.140.010	1-50-01-2	50	11/19/95	CLR	---	N	
B06.010.001	1-RPV-26-203-01		11/16/95	CLR	---	N	
B06.010.002	1-RPV-26-203-02		11/16/95	CLR	---	N	
B06.010.003	1-RPV-26-203-03		11/16/95	CLR	---	N	
B06.010.004	1-RPV-26-203-04		11/16/95	CLR	---	N	
B06.010.005	1-RPV-26-203-05		11/16/95	CLR	---	N	
B06.010.006	1-RPV-26-203-06		11/16/95	CLR	---	N	
B06.010.007	1-RPV-26-203-07		11/16/95	CLR	---	N	
B06.010.008	1-RPV-26-203-08		11/16/95	CLR	---	N	
B06.010.009	1-RPV-26-203-09		11/16/95	CLR	---	N	
B06.010.010	1-RPV-26-203-10		11/16/95	CLR	---	N	
B06.010.011	1-RPV-26-203-11		11/16/95	CLR	---	N	
B06.010.012	1-RPV-26-203-12		11/16/95	CLR	---	N	
B06.010.013	1-RPV-26-203-13		11/16/95	CLR	---	N	

5.0 Results Of Inspections Performed During Outage 16

The results of each examination shown in the final ISI Plan (Section 4 of this report) are included in this section. The completion date and status for each examination are shown. Limited examinations are described in further detail in Section 5.2. All examinations revealing reportable indications are described in further detail in Section 6.

5.1 The information shown below is a field description for the reporting format included in this section of the report:

A. Items examined by NDE methods

Item Number	=	ASME Section XI Tables IWB-2500-1 (Class 1), IWC-2500-1 (Class 2), IWF-2500-1 (Class 1 and Class 2), Augmented Requirements
ID Number	=	Unique Identification Number
Insp Date	=	Date of Examination
Insp Status	=	CLR Clear REC Recordable REP Reportable
Insp Limited	=	Indicates inspection was limited. Coverage obtained is listed
Geo. Ref. (Geometric Reflector applies only to UT)	=	<u>Y</u> Yes <u>N</u> No
Comments	=	General and/or Detail Description

OCONEE UNIT NUMBER 1 - 3rd INTERVAL
CLASS A (CATEGORY B-P) LEAKAGE TEST RESULTS
ITEM NUMBER: B15.050.001

<u>OUTAGE NUMBER</u>	<u>EXAMINATION DATE</u>	<u>STATUS:</u>	<u>RESULTS</u>
EOC # 16	12/07/95	CLEAR	COMPLETE
EOC # 17	//	N/A	NOT TESTED
EOC # 18	//	N/A	NOT TESTED
EOC # 19	//	N/A	NOT TESTED
EOC # 20	//	N/A	NOT REQUIRED
EOC # 21	//	N/A	NOT TESTED

B. Items examined by Pressure Testing

Item Number	=	ASME Section XI Tables IWB-2500-1 (Class 1), IWC-2500-1 (Class 2)
Drawing Number	=	Number of the Flow Diagram
Revision	=	Revision of the Flow Diagram
Test	=	Type of Pressure Test
Comp	=	Vessel, Piping or Pump
Comp Name	=	Example: Reactor Vessel, etc.; for piping - System designation will be used
Req. Insp.	=	Type inspection performed, i.e., VT2
Req. Proc	=	Required inspection procedure
Comments	=	General and/or Detail Description

CATEGORY

**DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System**

**Plan Report
Page 80
02/07/96**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL	BLOCKS	COMMENTS
G12.001.001	1-51B-10-10HC	1-51B-10	NDE-35	PT	SS		4.000		
	Circumferential	OFD-101A-1.1					0.120		
Class B	Term end								Elbow to Nozzle 1B RC Seal Cooler Inlet
G12.001.019	1-51B-7-34F	1-51B-7	NDE-35	PT	SS		2.500		
	Circumferential	OFD-109A-1.1					0.120		
Class B									Pipe to Valve 2HP13

Total G12.001 Items: 2

Total Category Items: 2

CATEGORY AUG, Augmented Inspections

DUKE POWER COMPANY
QUALITY ASSURANCE TECHNICAL SERVICES
Inservice Inspection Database Management System

Plan Report
Page 79
02/07/96

**Circumferential Pipe Welds With A Nom. Wall
Thk. < 3/8" and > NPS 4"**

Oconee 1

Inservice Inspection Plan for Interval 3 Outage 1

ITEM NUMBER	ID NUMBER	ISO/DWG NUMBERS	PROC	INSP REQ	MAT/SCH	DI/THK	CAL BLOCKS	COMMENTS
-------------	-----------	-----------------	------	----------	---------	--------	------------	----------

Total Category AUG Items: 8

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95030867-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B.31.7 1968 Edition, 6-68 Addenda, N/D Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	N/A	N/A	N/A			<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	GENERAL NUCLEAR	N/A	N/A	N/A	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	MVI	N/A	N/A	N/A	1991	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D	CRDM DRIVE	DIAMOND POWER	# 27	N/A	PART # 703255-1058	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E	CRDM DRIVE	B+W *	# 106	N/A	PART # 703255-1058	1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting and drive CRDM nozzle #7

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure 2201 psig

Test Temp. 532 °F

Pressure _____ psig

Test Temp. _____ °F

Pressure _____ psig

Test Temp. _____ °F

9. Remarks *CRDM DRIVE WAS Refurbished by B+W

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hansen QC Specialist
Owner or Owner's Designee, Title

Date 5-30, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of NC and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M. B. Chapman
Inspector's Signature

Commissions NC914

National Board, State, Providence and Endorsements

Date 5-31, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-24-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95034253-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # _____

4. Identification of System MS Class B

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	Texas Bolt	N/A	N/A	Heat # S095	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	A + G Manufacturing	N/A	N/A	Heat # NAG	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D	Bolting	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced Body to Bonnet bolting on valve IMS-79

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed Pat Hooper QC Specialist
Owner or Owner's Designee, Title

Date 5-24, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-24-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
Inspector's Signature

Commissions NC 914
National Board, State, Providence and Endorsements

Date 5-24, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95034262-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31-7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	<u>Bolting</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	<u>Bolting</u>	<u>MVI</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1991</u>	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	<u>Bolting</u>	<u>GENERAL NUCLEAR</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1992</u>	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM NOZZLE # 21

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure	<u>2201</u> psig	Test Temp.	<u>532</u> °F
Pressure	_____ psig	Test Temp.	_____ °F
Pressure	_____ psig	Test Temp.	_____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Henson QC SPECIALIST Date 5-30, 19 95
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N. C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.S. Chapman
 Inspector's Signature

Commissions NC914
 National Board, State, Providence and Endorsements

Date 5-30, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95030848-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 8-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	N/A	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	MVI	n/a	n/a	n/a	1991	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	GENERAL NUCLEAR	n/a	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95034258-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # n/a

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B.31.7 19 68 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	n/a	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	General Nuclear	n/a	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	B+W	n/a	n/a	n/a	1980	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM nozzle # 29

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure 2155 psig CRH 530-95 Test Temp. 600 °F CRH 5-30-95

Pressure 2201 psig Test Temp. 532 °F

Pressure _____ psig Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hanson QC SPECIALIST
Owner or Owner's Designee, Title

Date 5-30, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
Inspector's Signature

Commissions NC914

National Board, State, Providence and Endorsements

Date 5-30, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95034260-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	n/a	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	GENERAL NUCLEAR	n/a	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	B&W	n/a	n/a	n/a	1975	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM NO331c #28

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure	<u>2201</u> psig	Test Temp.	<u>532</u> °F
Pressure	_____ psig	Test Temp.	_____ °F
Pressure	_____ psig	Test Temp.	_____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hanson QC SPECIALIST Date 5-30, 19 95
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W.B. Chapman Commissions NC914
 Inspector's Signature National Board, State, Providence and Endorsements

Date 5-31, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

2. Plant **Oconee Nuclear Station**
 Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95030836-01
 Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**
 Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	GENERAL NUCLEAR	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	MVI	n/a	n/a	1991	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D						<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E						<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F						<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM nozzle # 69

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure <u>2201</u> psig	Test Temp. <u>532</u> °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hanson QC Specialist Date 5-30, 19 95
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M. B. Chapman
 Inspector's Signature

Commissions NC 914
 National Board, State, Providence and Endorsements

Date 5-31, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95034255-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	n/a	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	GENERAL NUCLEAR	n/a	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced Bolting CRDM nozzle # 13

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure 2201 psig Test Temp. 532 °F

Pressure _____ psig Test Temp. _____ °F

Pressure _____ psig Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Hansen QC SPECIALIST Date 5-30, 19 95
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
Inspector's Signature

Commissions NC 914

National Board, State, Providence and Endorsements

Date 5-31, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95030847-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	General NUCLEAR	N/A	N/A	N/A	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	MVI	N/A	N/A	N/A	1991	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM nozzle 45

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure	<u>2201</u>	psig	Test Temp.	<u>532</u>	°F
Pressure	_____	psig	Test Temp.	_____	°F
Pressure	_____	psig	Test Temp.	_____	°F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Henson QC Specialist Date 5-30, 19 95
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman Commissions NC 914
Inspector's Signature National Board, State, Providence and Endorsements

Date 5-31, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 6-12-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 94086683-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System HP Class 2

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, N/A Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Stem/Plug Assembly	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Stem/Plug Assembly	Fisher Controls Co.	N/A	N/A	Part # 14A3722X182	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced Stem/Plug assembly in Valve 1HP-31

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed *A. Johnson* QC Specialist
 Owner or Owner's Designee, Title

Date 6-12, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of NC and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 6-16-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M. S. Chapman
 Inspector's Signature

Commissions NC 914
 National Board, State, Providence and Endorsements

Date 6-16, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 5-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95031013-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # n/a

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B.31.7 1968 Edition, 6-68 Addenda, no Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	n/a	n/a	n/a	n/a	n/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	MVI	n/a	n/a	n/a	1991	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	GENERAL NUCLEAR	n/a	n/a	n/a	1992	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting CRDM NOZZLE #16

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure	<u>2201</u>	psig	Test Temp.	<u>532</u>	°F
Pressure	_____	psig	Test Temp.	_____	°F
Pressure	_____	psig	Test Temp.	_____	°F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hanson QC SPECIALIST Date 5-30, 19 95
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 4-29-95 to 5-30-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
 Inspector's Signature

Commissions NC914
 National Board, State, Providence and Endorsements

Date 6-1, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95023297
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-7301

4. Identification of System RC Class A

5. (a) Applicable Construction Code ASME III 19 67 Edition, Summer Addenda, 1332-2, 1332-3, 1332-4 Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda 1339-1, 1336, 1359-1, 1338-3 211.1

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	OTSG-B	B+W	620-0003-55-2	N-104	N/A	1969	<input checked="" type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Plugged and Stabilized tubes 1B OTSG

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Hanson
 Owner or Owner's Designee, Title

Date 12-2, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-4-95 to 12-2-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
 Inspector's Signature

Commissions NC 914
 National Board, State, Providence and Endorsements

Date 12-2, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95023293
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-7300

4. Identification of System RC Class A

5. (a) Applicable Construction Code ASME III 19 67 Edition, Summer Addenda, 1332-2, 1332-3, 1332-4, 1339-1 Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda 1336, 1359-1, 1338-3 alt. 1

6. Identification of Components Repaired or Replaced and Replacement Components

Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	<u>1A OTSG</u>	<u>B+W</u>	<u>620-0003-551</u>	<u>N-103</u>	<u>N/A</u>	<u>1969</u>	<input checked="" type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement <input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Plugged, stabilized tubes 1A OTSG

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Henson
 Owner or Owner's Designee, Title

Date 12-2, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-4-95 to 12-2-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

J.M.B. Chapman
 Inspector's Signature

Commissions N2914
 National Board, State, Providence and Endorsements

Date 12-2, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95
Sheet 1 of 2

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95024419
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-744

4. Identification of System LP Class 2

5. (a) Applicable Construction Code ASME B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1 BS-5	CHAPMAN	01027-1-02-2 NA			NA	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	PIPING	DPC	NA	NA		7/93	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	Texas Bolt	N/A	N/A		N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D	Bolting	A+G Eng.	N/A	N/A		N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work DELETED VLV. 1BS-5 FROM SYS. & REPLACED WITH PIPE & FLANGES.

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. AND PRESSURE AND NDE PER ASME CODE CASE N-416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed [Signature]

Date 12-6, 1995

Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-14-95 to 12-6-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions NC914

National Board, State, Providence and Endorsements

Date 12-6, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12-1-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95077012
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-8550

4. Identification of System HP Class 2

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VALVE 1HP-427	BLN	955051-1-2	N/A	N/A	1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	VALVE 1HP-427	BORG WARNER	unavailable	w/a	VALVE WAS 1" NPS	w/a	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced valve LHP-427 with item no. DMV-1042

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F

Pressure _____ psig Test Temp. _____ °F

Pressure _____ psig Test Temp. _____ °F

9. Remarks Performed SYS. leakage test at SYS Temp and pressure and NDE per ASME CODE CASE N-416-1 in lieu of hydro

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed J. S. Mason
Owner or Owner's Designee, Title

Date 12-7, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Providence of N. C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-8-95 to 12-7-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.B. Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 12-7, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1a. Date 11-30-95

Sheet 1 of 2

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95024518
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp N/A Authorization No. N/A Expiration Date N/A

3b. NSM or MM # OE 7412

4. Identification of System LP Class 2

5. (a) Applicable Construction Code ASME B31.7 19 68 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1BS-6	CRANE	N/A	N/A		N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	PIPING	DPC	N/A	N/A		7/73	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	TEXAS BOLT	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D	Bolting	A+G ENGINEERING	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work MADE A CONFIGURATION CHANGE TO EXISTING SUPPORT BY (SEE REMARKS) SE

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks DELETING U-BOLT AND SADDLE AND INSTALLED NEW SUPPORT ROD.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed W. McClure Date 11/30, 19 95
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-12-95 to 12-6-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W.B. Chapman
Inspector's Signature

Commissions NC917

National Board, State, Providence and Endorsements

Date 12-6, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1a. Date 12-1-95

Sheet 1 of 2

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95038518
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 8061

4. Identification of System MS Class 2

5. (a) Applicable Construction Code B31.1 1967 Edition, 7-67 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A MECHANICAL SNUBBER ON S/R 1-01A-0-550-DE005	PACIFIC SCIENTIFIC	6576	N/A	DE005 (A)	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B HYDRAULIC SNUBBER ON S/R 1-01A-0-550-DE005	LISEGA	61314-62	N/A	DE005 (A)	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C MECHANICAL SNUBBER ON S/R 1-01A-0-550-DE005	PACIFIC SCIENTIFIC	3679	N/A	DE005 (A)	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D HYDRAULIC SNUBBER ON S/R 1-01A-0-550-DE005	LISEGA	61314-61	N/A	DE005 (B)	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E MECHANICAL SNUBBER ON S/R 1-01A-0-550-DE005	PACIFIC SCIENTIFIC	6596	N/A	DE005 (C)	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
F HYDRAULIC SNUBBER ON S/R 1-01A-0-550-DE005	LISEGA	61314-63	N/A	DE005 (C)	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced (4) existing PS snubbers with New Liseza Snubbers xc

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig

Test Temp. _____ °F

Pressure _____ psig

Test Temp. _____ °F

Pressure _____ psig

Test Temp. _____ °F

9. Remarks Performed functional test per MP/1A/3018/1009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed C.R. Hansen
Owner or Owner's Designee, Title

Date 12-1, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-31-95 to 12-1-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

J.B. Chapman
Inspector's Signature

Commissions N.C. 914
National Board, State, Providence and Endorsements

Date 12-1, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11/30/95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95038508-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 8056

4. Identification of System MS Class B

5. (a) Applicable Construction Code B31.1 1967 Edition, 7 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	MECHANICAL SNUBBER ON S/R 1-OIA-0-441-DE001	PACIFIC SCIENTIFIC	4648	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	HYDRAULIC SNUBBER ON S/R 1-DIA-0-441-DE001	LISEGA	61306-58	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED EXISTING PACIFIC SCIENTIFIC SNUBBER WITH NEW LISEGA SNUBBER

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL TEST PER M/P/O/A/3 018/009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed Wm C. Clue
Owner or Owner's Designee, Title

Date 11/30, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-21-95 to 12-1-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W. B. Chapman
Inspector's Signature

Commissions NC 914
National Board, State, Providence and Endorsements

Date 12-1, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1a. Date 12-1-95

Sheet 1 of 2

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95038521-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NBM or MM # 8062

4. Identification of System MS Class B

5. (a) Applicable Construction Code B31.1 1967 Edition, 7-67 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A Mechanical SNubber on S/R 1-01A-0-550-DE006	PACIFIC Scientific	6593	N/A	DE006 (A)	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B Hydraulic SNubber on S/R 1-01A-0-550-DE006	LISEGA	61297-02	N/A	DE006 (A)	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C Mechanical SNubber on S/R 1-01A-0-550-DE006	PACIFIC Scientific	61297 ²⁵ 3909	N/A	DE006 (B)		<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D Hydraulic SNubber on S/R 1-01A-0-550-DE006	LISEGA	61297-03	N/A	DE006 (B)		<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
E Mechanical SNubber on S/R 1-01A-0-550-DE006	PACIFIC Scientific	6199	N/A	DE006 (B)		<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
F Hydraulic SNubber on S/R 1-01A-0-550-DE006	LISEGA	61290-51	N/A	DE006 (C)		<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced (4) existing PS Smbbers with New LiseGA Smbbers ;

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL TEST PER MP/0/A/3018/009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed CR Hanson Date 12-1, 1995
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-21-95 to 12-1-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

MB Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 12-1, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 1-15-96

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95086652
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 8555

4. Identification of System 51A Class B

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	1A LETDOWN COOLER	GRAHAM MFG. CO.	34097-1	*		*	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	1A LETDOWN COOLER	GRAHAM MFG. CO.	95-18792-1	23288		1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C		* INFORMATION NOT LEGIBLE					<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED 1A LETDOWN COOLER.

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. & PRESSURE & NDE PER ASME CODE CASE N-416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed A. Z. Blumhagen
Owner or Owner's Designee, Title

Date 1-15, 19 96

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-14-95 to 1-15-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

JMB Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 1-15, 19 96

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95071686-07
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # NA

4. Identification of System LP Class 2

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	<u>PIPING</u>	<u>DPC</u>	<u>NA</u>	<u>NA</u>		<u>7/73</u>	<input checked="" type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work MADE WELD REPAIR TO WELD 1-LP-4-36 DUE TO BEING REJECTED ON RT.

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. AND PRESSURE & NDE PER CODE CASE N416-1 OF ASME IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed B. Z. Stubaugh
 Owner or Owner's Designee, Title

Date 1-4, 1996

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-11-95 to 1-4-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W. B. Chapman
 Inspector's Signature

Commissions N.C. 914
 National Board, State, Providence and Endorsements

Date 1-4, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12-11-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95061776
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # _____

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Valve	Dresser	BLO8895	N/A		N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	Valve	Dresser	BT04975	N/A		1979	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced valve IRC-68

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure	<u>2200</u> psig	Test Temp.	_____ °F
Pressure	_____ psig	Test Temp.	_____ °F
Pressure	_____ psig	Test Temp.	_____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed [Signature] Date 1-3, 1996
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-26-95 to 1-4-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NC914
Inspector's Signature National Board, State, Providence and Endorsements

Date 1-4, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12-11-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95061774
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # _____

4. Identification of System RC Class 1

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Valve	Dresser	BL-8891	N/A		1970	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	Valve	Dresser	BL 8889	N/A		N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced valve IRC-67

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure 2200 psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed J.S. Mason

Date 1-3, 1996

Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-22-95 to 1-4-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

J.W.B. Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 1-4, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-29-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95059750-06
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System FDW Class 2

5. (a) Applicable Construction Code B31.1 1967 Edition, 7-67 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	A+G Engineering	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C	Bolting	TEXAS Bolt	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced bolting MAIN Feedwater Nozzle AO16

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F
Pressure _____ psig	Test Temp. _____ °F

9. Remarks _____

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed Charles R. Huson QA Specialist
Owner or Owner's Designee, Title

Date 11-29, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-11-95 to 11-29-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

J. B. Chapman
Inspector's Signature

Commissions NC914
National Board, State, Providence and Endorsements

Date 11-29, 19 95

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 9/12/95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95054810-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System OIA (ms) Class B

5. (a) Applicable Construction Code ANSI B31.1 1967 Edition, 7 Addenda, N/A Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	SNUBBER ON HANGER 1-OIA-1-1-0- 4OIA-H44	ITT GRINNELL	32920	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	SNUBBER ON HANGER 1-OIA-1-1-0- 4OIA-H44	ITT GRINNELL	10368	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REMOVED/REPLACED SHUBBER WITH NEW SHUBBER S/N 10368 S/N 32920

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL VERIFICATION PER MP10/A/3018/009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair or replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed Wm Cleave
 Owner or Owner's Designee, Title

Date 9/12, 19 95

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 8-14-95 to 9-12-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

MB Chapman
 Inspector's Signature

Commissions NC 914
 National Board, State, Providence and Endorsements

Date 9-12, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 9/12/95
Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95054809-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System OIA Class B

5. (a) Applicable Construction Code ANSI B31-1^{w/m} 1967 Edition, 7 Addenda, N/A Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	SNUBBER ON HANGER 1-OIA-3-0-401A-R5	ITT GRINNELL	18601	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	SNUBBER ON HANGER 1-OIA-3-0-401A-R5	ITT GRINNELL	30223	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work SN 30223
REMOVED/REPLACED EXISTING SNUBBER WITH SNUBBER S/N# 18601

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL TEST PER MP/O/A/3018/009A.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed W. McClure
Owner or Owner's Designee, Title

Date 9/12, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of NC and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 8-14-95 to 9-12-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W. McClure
Inspector's Signature

Commissions NC 914

National Board, State, Providence and Endorsements

Date 9-12, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11/30/85

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
 Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95038522-01
 Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**
 Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. ~~NSM~~ or MM # 8063

4. Identification of System MS Class B

5. (a) Applicable Construction Code B31.1 1967 Edition, 7 Addenda, _____ Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	MECHANICAL SNUBBER ON S/R 1-01A-D-550-RT	PACIFIC SCIENTIFIC	5701	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	MECHANICAL SNUBBER ON S/R 1-01A-D-550-RT	LISEGA	61316-72	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED EXISTING PACIFIC SCIENTIFIC SNUBBER WITH NEW LISEGA SNUBBER.

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL TEST PER MP/O/A/3018/009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed WT McClure Date 11/30, 1995
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-21-95 to 12-1-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

MB Chapman Commissions NC914
 Inspector's Signature National Board, State, Providence and Endorsements

Date 12-1, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11/30/95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95038516-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 8058

4. Identification of System MS Class B

5. (a) Applicable Construction Code B31.1 19 67 Edition, 7 Addenda, _____ Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	MECHANICAL SNUBBER ON S/R 1-01A-0-441-DE002	PACIFIC SCIENTIFIC	25185	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	HYDRAULIC SNUBBER ON S/R 1-01A-0-441-DE002	LISEGA	61306-57	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED EXISTING PACIFIC SCIENTIFIC SNUBBER WITH NEW LISEGA SNUBBER

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F
Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED FUNCTIONAL TEST PER MP/O/A/3018/009A

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed W. McClure
Owner or Owner's Designee, Title

Date 11/30, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-21-95 to 12-1-95; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

W.B. Chapman
Inspector's Signature

Commissions NC 914
National Board, State, Providence and Endorsements

Date 12-1, 1995

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95028305
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-7322

4. Identification of System HP Class 2

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number.	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1-HP-27	ROCKWELL	N/A	NA		NA	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	1-HP-27	CONTROL COMPONENTS INC.	658951-1.3	NA		1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C	PIPING	DPC	NA	NA		7/73	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED VLV. 1 HP-27 W/ ITEM No. DMV-1022

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SVS. LEAKAGE TEST AT TEMP. + PRESSURE AND NDE PER ASME CODE CASE N416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed E. S. Mason
 Owner or Owner's Designee, Title

Date 12-13, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-7-95 to 1-4-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M. B. Chapman
 Inspector's Signature

Commissions NC914
 National Board, State, Providence and Endorsements

Date 1-4, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-22-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 9502B303-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # 05-7321

4. Identification of System HP Class 2

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1-HP-26	CONTROL COMP.	658951-1-4	1513		1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	VLV. 1-HP-26	ROCKWELL	K3628JM	-		-	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work Replaced valve 1 HP-26

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks Tested per ASME Code Case N-416-1

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed [Signature]
 Owner or Owner's Designee, Title

Date 12-13, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-7-95 to 1-2-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
 Inspector's Signature

Commissions NC914
 National Board, State, Providence and Endorsements

Date 1-2, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-22-95

Sheet 1 of 1

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95028302-01
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-7329

4. Identification of System HP Class 2

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1-HP-410	CONTROL COMP.	SN658951-2-4	NA		1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	No <input checked="" type="checkbox"/> Yes
B	VLV. 1-HP-410	WESTINGHOUSE	04002GM88FNE 0D000W75000Z	W18311		1978	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED VLV. 1HP-410 W/ITEM No. DMV-1023

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. AND PRESSURE AND NDE PER ASME CODE CASE N-416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed J. S. Mason

Date 12-13, 1995

Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-7-95 to 1-2-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

J. S. Chapman
Inspector's Signature

Commissions N.C. 914
National Board, State, Providence and Endorsements

Date 1-2, 1996

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 11-30-95

2. Plant **Oconee Nuclear Station**
Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95028299
Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
Address **526 S. Church Street, Charlotte, NC 28201-1006**
Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # OE-7328

4. Identification of System HP Class Z

5. (a) Applicable Construction Code ANSI B31.7 1968 Edition, 6/68 Addenda, NO Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	VLV. 1 HP-409	WESTINGHOUSE	0400ZGM8BFNE 0D000W750001	NA		NA	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
B	VLV. 1 HP-409	CONTROL COMPONENTS INC.	658951-2-3	NA		1995	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

Form NIS-2 (Back)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in. (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

7. Description of Work REPLACED VLV. 1 HP 409 WITH A ITEM NO. DMV-1023

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Exempt

Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F
 Pressure _____ psig Test Temp. _____ °F

9. Remarks PERFORMED SYS. LEAKAGE TEST AT SYS. TEMP. AND PRESSURE AND NDE PER ASME CODE CASE N-416-1 IN LIEU OF HYDRO.

(Applicable Manufacturer's Data Records to be Attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this **repair or replacement** conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Expiration Date N/A

Signed [Signature]
 Owner or Owner's Designee, Title

Date 12-13, 1995

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Providence of N.C. and employed by **HSBI and I Company of Hartford Connecticut** have inspected the components described in this Owner's Report during the period 11-7-95 to 1-2-96; and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
 Inspector's Signature

Commissions N.C. 914
 National Board, State, Providence and Endorsements

Date 1-7, 1996

10.0 Class 1 and 2 Repairs and Replacements

As required by ASME Section XI 1989 Edition, no Addenda, a record (Form NIS-2) of the Class 1 and Class 2 Repairs and Replacements for work performed from July 13, 1994 through December 10, 1995 is provided and is included in this section of the report. The individual work request documents are on file at Oconee Nuclear Station.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

1. Owner **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**

1a. Date 12-11-95

2. Plant **Oconee Nuclear Station**
 Address **P.O. Box 1439, Seneca, S.C. 29679**

Sheet 1 of 1

2a. Unit 1 2 3 Shared (specify Units _____)

3a. Work Order # 95048044-01
 Repair Organization Job # _____

3. Work Performed By **Duke Power Company**
 Address **526 S. Church Street, Charlotte, NC 28201-1006**
 Type Code Symbol Stamp **N/A** Authorization No. **N/A** Expiration Date **N/A**

3b. NSM or MM # N/A

4. Identification of System RC Class A

5. (a) Applicable Construction Code B31.7 1968 Edition, 6-68 Addenda, NO Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

	Column 1	Column 2	Column 3	Column 4	Column 5	Col. 6	Column 7	Column 8
	Name of Component	Name of Manufacturer	Manufacturer Serial Number	National Board Number	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (yes or no)
A	Bolting	N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input checked="" type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
B	Bolting	GENERAL NUCLEAR	1668, 1614, 1718 1602, 1725, 1666, 1935, 1665	N/A	N/A	N/A	<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input checked="" type="checkbox"/> Replacement	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
C							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
D							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
E							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes
F							<input type="checkbox"/> Repaired <input type="checkbox"/> Replaced <input type="checkbox"/> Replacement	<input type="checkbox"/> No <input type="checkbox"/> Yes

