


**Joseph M. Farley Nuclear Plant; Edwin I. Hatch Nuclear Plant;
Vogtle Electric Generating Plant
Annual Radioactive Effluent Release Reports for 2014**

Enclosure 3

Vogtle Annual Radioactive Effluent Release Report for 2014

ACKNOWLEDGEMENT OF OWNERSHIP

The contents of this Annual Radioactive Effluent Release Report, contained herein, are true and accurate to the best of my knowledge. I understand that I am ultimately responsible for the information that has been captured within these pages.

A handwritten signature in black ink, appearing to read "Judy S. [unclear]", is written over a solid horizontal line.

Chemistry Manager

SOUTHERN NUCLEAR COMPANY
VOGTLE ELECTRIC GENERATING PLANT- UNITS 1 AND 2
NRC DOCKET NOS. 50-424 AND 50-425
FACILITY OPERATING LICENSE NOS. NPF-68 AND NPF-81
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FOR
JANUARY 1, 2014 TO DECEMBER 31, 2014

Prepared by: Celeste Olive / Celeste Olive

Reviewed by: Timothy E. Fowler / Timothy E. Fowler

**VOGTLE ELECTRIC GENERATING PLANT
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
TABLE OF CONTENTS**

SECTION	TITLE	PAGE
1.0	Liquid Effluents	8
1.1	Regulatory Requirements	8
1.1.1	Concentration Limits	8
1.1.2	Dose Limits	8
1.2	Effluent Concentration Limit (ECL)	8
1.3	Measurements and Approximations of Total Radioactivity	9
1.3.1	Total Radioactivity Determination	9
1.3.2	Total Error Estimation	11
1.4	Liquid Effluent Release Data	12
1.5	Radiological Impact Due to Liquid Releases	12
1.6	Liquid Effluents – Batch Releases	12
1.7	Liquid Effluents - Abnormal Releases	12
Table 1-1A	Liquid Effluents – Summation of All Releases Unit 1 (Quarters 1,2,3, and 4)	13
Table 1-1B	Liquid Effluents – Summation of All Releases Unit 2 (Quarters 1,2,3, and 4)	14
Table 1-1C	Liquid Effluents – Summation of All Releases Site (Quarters 1,2,3, and 4)	15
Table 1-2A	Liquid Effluents –Unit 1 (Quarters 1,2,3, and 4)	16
Table 1-2B	Liquid Effluents –Unit 1 (Quarters 1,2,3, and 4)	19

Table 1-2C	Liquid Effluents –Unit 1 (Quarters 1,2,3, and 4)	22
Table 1-3A	Doses to a Member of the Public Due to Liquid Releases Unit 1 (Quarters 1,2,3, and 4)	25
Table 1-3B	Doses to a Member of the Public Due to Liquid Releases Unit 2 (Quarters 1,2,3, and 4)	26
Table 1-3C	Doses to a Member of the Public Due to Liquid Releases Site (Quarters 1,2,3, and 4)	27
Table 1-4	Minimum Detectable Concentration - Liquid	28
Table 1-5A	Liquid Effluents Batch Release Summary Unit 1 (Quarters 1,2,3, and 4)	29
Table 1-5B	Liquid Effluents Batch Release Summary Unit 2 (Quarters 1,2,3, and 4)	30
Table 1-5C	Liquid Effluents Batch Release Summary Site (Quarters 1,2,3, and 4)	31
Table 1-6A	Liquid Effluents Abnormal Release Summary Unit 1 (Quarters 1,2,3, and 4)	32
Table 1-6B	Liquid Effluents Abnormal Release Summary Unit 1 (Quarters 1,2,3, and 4)	33
Table 1-6C	Liquid Effluents Abnormal Release Summary Site (Quarters 1,2,3, and 4)	34
2.0	Gaseous Effluents	35
2.1	Regulatory Requirements	35
2.1.1	Dose Rate Limits	35
2.1.2	Air Doses Due to Noble Gases in Gaseous Releases	35

2.1.3	Doses to a Member of the Public	35
2.2	Measurements and Approximations of Total Radioactivity	36
2.2.1	Sample Collection and Analysis	36
2.2.2	Total Quantities of Radioactivity, Dose Rates, and Cumulative Doses	37
2.2.2.1	Fission and Activation Gases	37
2.2.2.2	Radioiodines, Tritium and Particulate Releases	37
2.2.2.3	Gross Alpha Release	37
2.2.3	Total Error Estimation	38
2.3	Gaseous Effluent Release Data	39
2.4	Radiological Impact Due to Gaseous Releases	40
2.5	Gaseous Effluents - Batch Releases	40
2.6	Gaseous Effluents - Abnormal Releases	40
Table 2-1A	Gaseous Effluents Summation of All Releases Unit 1 (Quarters 1,2,3, and 4)	41
Table 2-1B	Gaseous Effluents Summation of All Releases Unit 2 (Quarters 1,2,3, and 4)	42
Table 2-1C	Gaseous Effluents Summation of All Releases Site (Quarters 1,2,3, and 4)	43
Table 2-2A	Gaseous Effluents Mixed Mode Releases Unit 1 (Quarters 1,2,3, and 4)	44
Table 2-2B	Gaseous Effluents Mixed Mode Releases Unit 2 (Quarters 1,2,3, and 4)	46

Table 2-2C	Gaseous Effluents Mixed Mode Releases Site (Quarters 1,2,3, and 4)	48
Table 2-3A	Gaseous Effluents Ground Level Releases Unit 1 (Quarters 1,2,3, and 4)	50
Table 2-3B	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	52
Table 2-3C	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	54
Table 2-4A	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	56
Table 2-4B	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	57
Table 2-4C	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	58
Table 2-5A	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	59
Table 2-5B	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	60
Table 2-5C	Gaseous Effluents Ground Level Releases Unit 2 (Quarters 1,2,3, and 4)	61
Table 2-6	Minimum Detectable Concentrations - Gaseous	62
Table 2-7A	Gaseous Effluents - Batch Release Summary Unit 1 (Quarters 1,2,3, and 4)	63

Table 2-7B	Gaseous Effluents - Batch Release Summary Unit 2 (Quarters 1,2,3, and 4)	64
Table 2-7C	Gaseous Effluents - Batch Release Summary Site (Quarters 1,2,3, and 4)	65
Table 2-8A	Gaseous Effluents - Abnormal Release Summary Unit 1 (Quarters 1,2,3, and 4)	66
Table 2-8B	Gaseous Effluents - Abnormal Release Summary Unit 2 (Quarters 1,2,3, and 4)	67
Table 2-8C	Gaseous Effluents - Abnormal Release Summary Site (Quarters 1,2,3, and 4)	68
3.0	Solid Waste	69
3.1	Regulatory Requirements	69
3.1.1	Solid Radioactive Waste System	69
3.1.2	Reporting Requirements	69
3.2	Solid Waste Data	69
Table 3-1	Solid Waste and Irradiated Fuel Shipments	70
4.0	Doses to Members of the Public Inside the Site Boundary	75
4.1	Regulatory Requirements	75
4.2	Demonstration of Compliance	75
Table 4-1	Doses to Members of the Public Due to Activities Inside the Site Boundary	76
5.0	Total Dose from Uranium Fuel Cycle (40CFR190)	78
5.1	Regulatory Requirements	78
5.2	Demonstration of Compliance	78

6.0	Meteorological Data	78
7.0	Program Deviations	79
7.1	Inoperable Liquid or Gaseous Effluent Monitoring	
	Instrumentation	79
7.1.1	Regulatory Requirement	79
7.1.2	Description of Deviations	79
7.2	Tanks Exceeding Curie Content Limits	80
7.2.1	Regulatory Requirements	80
7.2.2	Description of Deviations	80
8.0	Changes to the Vogtle Electric Generating Plant Offsite	
	Dose Calculation Manual (ODCM)	80
8.1	Regulatory Requirements	80
8.2	Description of Changes	80
9.0	Major Changes to Liquid, Gaseous, or Solid Radwaste	
	Treatment Systems	81
9.1	Regulatory Requirements	81
9.2	Description of Major Changes	81
Appendix A	Carbon-14	82

1.0 Liquid Effluents

1.1 Regulatory Requirements

1.1.1 Concentration Limits

In accordance with Technical Specification 5.5.4.b, the concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS shall be limited at all times to ten times the concentrations specified in 10 CFR 20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to $1 \text{ E-}04 \text{ } \mu\text{Ci/ml}$ total activity.

1.1.2 Dose Limits

The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released, from each unit, to UNRESTRICTED AREAS shall be limited as follows:

- a. During any calendar quarter to less than or equal to 1.5 mrems to the whole body and to less than or equal to 5 mrems to any organ, and
- b. During any calendar year to less than or equal to 3 mrems to the whole body and to less than or equal to 10 mrems to any organ.

1.2 Effluent Concentration Limit (ECL)

ECL values used for determining the allowable liquid radwaste release rates and concentrations for the principal gamma emitters, I-131, tritium, Sr-89, Sr-90 and Fe-55 are taken from 10 CFR Part 20, Appendix B, Table 2, Column 2. A tolerance factor of up to 10 is utilized to allow flexibility in establishing practical monitor set points which can accommodate effluent releases at concentrations higher than the ECL values stated in 10 CFR 20, Appendix B, Table 2, Column 2.

For dissolved or entrained noble gases in liquid radwaste, the ECL is $1\text{E-}04 \text{ } \mu\text{Ci/ml}$ total activity.

For gross alpha in liquid radwaste, the ECL is $2 \text{ E-}09 \text{ } \mu\text{Ci/ml}$.

For all the above radionuclides or categories of radioactivity, the overall ECL fraction is determined in accordance with 10 CFR Part 20, Appendix B. The method utilizing the ECL fraction to determine release rates and liquid radwaste effluent radiation monitor set points is described in Subsection 1.3 of this report.

1.3 Measurements and Approximations of Total Radioactivity

1.3.1 Total Radioactivity Determination

Prior to the release of any tank containing liquid radwaste, and following the required recirculation, samples are collected and analyzed in accordance with the Offsite Dose Calculation Manual (ODCM) Table 2-3 "Radioactive Liquid Waste Sampling and Analysis Program". A sample from each tank which is planned for release is analyzed for principal gamma emitters, I-131, and dissolved and entrained noble gases by gamma spectroscopy. Monthly and quarterly composites are prepared for analysis by extracting aliquots from each sample taken from the tanks, which are released. Liquid radwaste sample analyses are performed as follows:

MEASUREMENT	FREQUENCY	METHOD
1. Gamma Isotopic	Each Batch	Gamma Spectroscopy with computerized data reduction.
2. Dissolved or entrained noble gases	Each Batch	Gamma Spectroscopy with computerized data reduction
3. Tritium	Monthly Composite	Distillation and liquid scintillation counting
4. Gross Alpha	Monthly Composite	Gas flow proportional counting
5. Sr-89 & Sr-90	Quarterly Composite	Chemical separation and gas flow proportional or scintillation counting
6. Fe-55	Quarterly Composite	Chemical separation and liquid scintillation counting

1.3.1 Total Radioactivity Determination cont'd

Gamma isotopic measurements are performed using germanium detectors with a resolution of 2.1 keV or lower. A peak search of the resulting gamma ray spectrum is performed by the computer system. Energy and net count data for all significant peaks are determined, and a quantitative reduction or MDC calculation is performed. This ensures that the MDC's are met for the nuclides specified in ODCM Chapter 10 (i.e., Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144). The quantitative calculations, corrections for counting time, decay time, sample volume, sample geometry, detector efficiency, baseline counts, branching ratio and MDC calculations, are made based on the counts at the location in the spectrum where the peak for that radionuclide would be located, if present.

Tritium, Gross Alpha, Sr-89, Sr-90, Fe-55 and Ni-63 are, in some cases, analyzed offsite.

ECL fraction is determined using radionuclide concentrations of a tank planned for release, the most current results available for tritium, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 and the corresponding ECL values.

This ECL fraction is used, with appropriate safety factors, tolerance factors, and the minimum assured dilution stream flow to calculate maximum permissible release rates and a liquid effluent monitor setpoint. The monitor setpoint is calculated to assure that the limits of the Offsite Dose Calculation Manual (ODCM) are not exceeded.

A monitor reading in excess of the calculated setpoint results in an automatic termination of the liquid radwaste discharge. Liquid effluent discharge is also automatically terminated if the dilution stream flow rate falls below the minimum assured dilution flow rate used in the setpoint calculations and established as a setpoint on the dilution stream flow monitor.

Radionuclide concentrations, safety factors, dilution stream flow rate, and liquid effluent radiation monitor calibrations are entered into the computer and a pre-release printout is generated. If the release is not permissible, appropriate warnings will be displayed on the computer screen. If the release is permissible, it is approved by the Chemistry Department and sent to the Operations Department for approval and release. When the release is completed, the necessary data from the release (i.e., release volume, etc.) are provided by the Operations Department to the Chemistry Department. These data are input to the computer and a post-release printout is generated. The post release printout contains the actual release rates, release concentrations and quantities, actual dilution flow, and calculated doses to an individual.

Typically achieved liquid effluent sample analyses minimum detectable concentrations are reported in Table 1-4.

1.3.2 Total Error Estimation

The total or maximum error associated with the effluent measurement includes the cumulative errors resulting from the total operation of sampling and measurement. Because it may be very difficult to assign error terms for each parameter affecting the final measurement, detailed statistical evaluation of error is not suggested. The objective should be to obtain an overall estimate of the error associated with measurements of radioactive materials released in effluents (Reference Reg. Guide 1.23 Rev 1). Total Error is calculated by the root mean square method. The root mean square value is the square root of the arithmetic mean (average) of the squares of the original values.

- a. Fission and activation total release was calculated from sample analysis results and release point flow rates.

Sampling and statistical error	10%
Counting Equipment Calibration	10%
Tank Volumes and System Flow Rates	20%
TOTAL ERROR	24.5%

- b. Total Tritium release was calculated from sample analysis results and release point volumes.

Sampling and statistical errors	10%
Counting equipment calibration	10%
Tank volumes and system flow rate	20%
TOTAL ERROR	24.5%

- c. Dissolved and entrained gases were calculated from sample analysis results and release point volumes.

Sampling and statistical error	20%
Counting equipment calibration	10%
Tank volumes and system flow rate	20%
TOTAL ERROR	30%

- d. Gross alpha radioactivity was calculated from sample analysis results and release point volumes.

Sampling and statistical error	10%
Counting Equipment calibration	10%
Tank volumes and system flowrates	20%
TOTAL ERROR	24.5%

1.3.2 Total Error Estimation cont'd

- e. Volume of waste prior to dilution was calculated from level indicators on the tanks and pump discharge flow rates and times.

Level Indicator error	10%
Operator Interpretation of gauge	10%
TOTAL ERROR	14%

- f. Volume of dilution water used was calculated from flow totalizers and pump discharge flow rates and times.

Flow totalizer error	10%
Operator interpretation of gauge	10%
TOTAL ERROR	14%

- g. Gross alpha, Sr-89, Sr-90, Fe-55, Ni-63 and H-3 radioactivity has an additional error associated with sample compositing.

Compositing sample error	5%
--------------------------	----

1.4 Liquid Effluent Release Data

Regulatory Guide 1.21 Rev. 1 Tables 2A and 2B are found in this report as Tables 1-1A, 1-1B, 1-1C, 1-2A, 1-2B and 1-2C. Data is presented on a quarterly basis as required by Regulatory Guide 1.21 Rev. 1 for all four quarters.

1.5 Radiological Impact Due to Liquid Releases

Doses to an individual due to radioactivity in liquid effluent were calculated in accordance with the Offsite Dose Calculation Manual. Results are presented in Table 1-3A for Unit 1 and 1-3B for Unit 2, for all four quarters.

1.6 Liquid Effluents – Batch Releases

Batch release information for liquid effluents is presented in Table 1-5A for Unit 1 and Table 1-5B for Unit 2.

1.7 Liquid Effluents - Abnormal Releases

There were no abnormal liquid releases during 2014

Table 1-1 A
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Summation of All Releases
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Products					
1. Total Release (not including tritium, gases, alpha)	Curies	2.62E-02	9.05E-03	3.33E-02	3.34E-02
2. Average diluted concentration during period	uCi/mL	2.18E-09	2.71E-09	4.48E-09	6.86E-09
3. Percent of Applicable Limit	%	*	*	*	*
B. Tritium					
1. Total Release	Curies	4.38E+02	1.89E+02	3.40E+02	1.09E+02
2. Average diluted Concentration during period	uCi/mL	3.65E-05	5.66E-05	4.58E-05	2.24E-05
3. Percent of Applicable Limit	%	*	*	*	*
C. Dissolved and Entrained Gases					
1. Total Release	Curies	7.03E-06	4.30E-04	3.15E-04	1.80E-05
2. Average diluted Concentration during period	uCi/mL	5.86E-13	1.28E-10	4.25E-11	3.70E-12
3. Percent of Applicable Limit	%	*	*	*	*
D: Gross Alpha Radioactivity					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
E: Waste Vol Release (Pre-Dilution)					
	Liters	3.64E+07	4.09E+07	4.59E+07	3.35E+07
F. Volume of Dilution Water Used					
	Liters	1.20E+10	3.30E+09	7.37E+09	4.83E+09

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

Table 1-1 B
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Summation of All Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Products					
1. Total Release (not including tritium, gases, alpha)	Curies	2.61E-02	9.25E-03	3.33E-02	3.34E-02
2. Average diluted concentration during period	uCi/mL	2.35E-09	2.74E-09	4.48E-09	6.88E-09
3. Percent of Applicable Limit	%	*	*	*	*
B. Tritium					
1. Total Release	Curies	4.39E+02	2.23E+02	3.40E+02	1.09E+02
2. Average diluted Concentration during period	uCi/mL	3.94E-05	6.60E-05	4.58E-05	2.24E-05
3. Percent of Applicable Limit	%	*	*	*	*
C. Dissolved and Entrained Gases					
1. Total Release	Curies	7.03E-06	4.30E-04	3.15E-04	1.80E-05
2. Average diluted Concentration during period	uCi/mL	6.32E-13	1.27E-10	4.25E-11	3.71E-12
3. Percent of Applicable Limit	%	*	*	*	*
D: Gross Alpha Radioactivity					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
E: Waste Vol Release (Pre-Dilution)					
	Liters	3.59E+07	3.98E+07	3.75E+07	2.56E+07
F. Volume of Dilution Water Used					
	Liters	1.11E+10	3.34E+09	7.38E+09	4.83E+09

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

Table 1-1 C
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Summation of All Releases
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Products					
1. Total Release (not including tritium, gases, alpha)	Curies	5.23E-02	1.83E-02	6.65E-02	6.67E-02
2. Average diluted concentration during period	uCi/mL	2.26E-09	2.73E-09	4.48E-09	6.87E-09
3. Percent of Applicable Limit	%	*	*	*	*
B. Tritium					
1. Total Release	Curies	8.77E+02	4.12E+02	6.80E+02	2.17E+02
2. Average diluted Concentration during period	uCi/mL	3.79E-05	6.13E-05	4.58E-05	2.24E-05
3. Percent of Applicable Limit	%	*	*	*	*
C. Dissolved and Entrained Gases					
1. Total Release	Curies	1.41E-05	8.59E-04	6.31E-04	3.60E-05
2. Average diluted Concentration during period	uCi/mL	6.08E-13	1.28E-10	4.25E-11	3.70E-12
3. Percent of Applicable Limit	%	*	*	*	*
D: Gross Alpha Radioactivity					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
E: Waste Vol Release (Pre-Dilution)					
	Liters	7.24E+07	8.07E+07	8.34E+07	5.91E+07
F. Volume of Dilution Water Used					
	Liters	2.31E+10	6.63E+09	1.48E+10	9.65E+09

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

Table 1-2 A
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

<u>Continuous Mode</u>					
Nuclides Released	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
Fe-55	Curies	4.08E-05	4.59E-04	0.00E+00	0.00E+00
Total For Period	Curies	4.08E-05	4.59E-04	0.00E+00	0.00E+00
Tritium					
H-3	Curies	6.88E-02	9.29E-02	7.52E-02	7.37E-02
Dissolved And Entrained Gases					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha Radioactivity					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

*Zeros in this table indicate that no radioactivity was present at detectable levels. See Table 1-4 for typical minimum detectable concentrations.

Table 1-2 A
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
Co-60	Curies	2.81E-03	6.12E-04	4.32E-03	6.36E-04
Sr-89	Curies	6.32E-06	1.56E-07	0.00E+00	0.00E+00
Co-57	Curies	1.65E-05	5.08E-06	2.87E-05	1.14E-07
Zn-65	Curies	9.59E-05	1.09E-05	6.33E-05	2.22E-06
Te-125M	Curies	1.10E-02	5.36E-04	1.02E-02	2.50E-02
Fe-59	Curies	1.19E-05	0.00E+00	1.49E-04	4.26E-05
Cs-134	Curies	1.19E-04	9.26E-05	6.58E-05	2.86E-06
Mo-99	Curies	0.00E+00	0.00E+00	4.03E-07	0.00E+00
Sb-125	Curies	2.69E-04	0.00E+00	2.57E-04	2.94E-04
Tc-99M	Curies	0.00E+00	0.00E+00	4.10E-07	0.00E+00
Rb-86	Curies	0.00E+00	1.51E-06	0.00E+00	0.00E+00
Sn-117M	Curies	3.00E-06	0.00E+00	1.27E-05	2.81E-05
Sr-90	Curies	0.00E+00	0.00E+00	8.42E-07	0.00E+00
Te-129	Curies	0.00E+00	0.00E+00	0.00E+00	2.57E-05
Te-131M	Curies	0.00E+00	0.00E+00	0.00E+00	5.37E-06
Rh-105	Curies	0.00E+00	0.00E+00	2.03E-05	1.30E-05
Mn-54	Curies	1.80E-04	4.18E-05	3.52E-04	4.15E-05
Cr-51	Curies	4.58E-04	0.00E+00	1.97E-03	5.25E-04
Fe-55	Curies	3.25E-03	1.02E-03	6.24E-03	2.00E-03
Zr-95	Curies	0.00E+00	0.00E+00	2.00E-04	1.59E-05
Te-132	Curies	0.00E+00	0.00E+00	1.35E-05	1.26E-05
Nb-95	Curies	1.22E-05	1.52E-06	3.84E-04	5.80E-05
Cs-137	Curies	8.43E-04	7.33E-04	6.79E-04	1.82E-04
Ni-63	Curies	1.58E-03	7.83E-04	1.64E-03	2.99E-03
I-132	Curies	0.00E+00	0.00E+00	1.36E-05	6.72E-06
Co-58	Curies	5.42E-03	4.76E-03	6.61E-03	1.47E-03
Total For Period	Curies	2.61E-02	8.59E-03	3.33E-02	3.34E-02

Table 1-2 A
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	Batch Mode			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Tritium					
H-3	Curies	4.38E+02	1.89E+02	3.40E+02	1.09E+02
Dissolved And Entrained Gases					
Xe-133	Curies	7.03E-06	4.12E-04	3.15E-04	1.80E-05
Xe-131M	Curies	0.00E+00	0.00E+00	2.10E-07	0.00E+00
Xe-135	Curies	0.00E+00	1.73E-05	1.87E-07	0.00E+00
Total For Period	Curies	7.03E-06	4.30E-04	3.15E-04	1.80E-05
Gross Alpha Radioactivity					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-2 B
Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

		<u>Continuous Mode</u>			
Nuclides Released	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
No Nuclides Found		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3		7.40E-02	5.53E-02	5.60E-02	3.03E-02
Dissolved And Entrained Gases					
No Nuclides Found		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha Radioactivity					
No Nuclides Found		0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-2 B
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Batch Mode

Nuclides Released	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
Zn-65	Curies	9.59E-05	1.09E-05	6.33E-05	2.22E-06
Sb-125	Curies	2.69E-04	0.00E+00	2.57E-04	2.94E-04
Te-129	Curies	0.00E+00	0.00E+00	0.00E+00	2.57E-05
Te-131M	Curies	0.00E+00	0.00E+00	0.00E+00	5.37E-06
Sn-117M	Curies	3.00E-06	0.00E+00	1.27E-05	2.81E-05
I-132	Curies	0.00E+00	0.00E+00	1.36E-05	6.72E-06
Rb-86	Curies	0.00E+00	1.51E-06	0.00E+00	0.00E+00
Zr-95	Curies	0.00E+00	0.00E+00	2.00E-04	1.59E-05
Co-58	Curies	5.42E-03	4.99E-03	6.61E-03	1.47E-03
Fe-59	Curies	1.19E-05	0.00E+00	1.49E-04	4.26E-05
Mn-54	Curies	1.80E-04	4.18E-05	3.52E-04	4.15E-05
Cs-134	Curies	1.19E-04	9.26E-05	6.58E-05	2.86E-06
Rh-105	Curies	0.00E+00	0.00E+00	2.03E-05	1.30E-05
Sr-89	Curies	6.32E-06	1.56E-07	0.00E+00	0.00E+00
Sr-90	Curies	0.00E+00	0.00E+00	8.42E-07	0.00E+00
Nb-95	Curies	1.22E-05	1.52E-06	3.84E-04	5.80E-05
Cs-137	Curies	8.43E-04	8.12E-04	6.79E-04	1.82E-04
Co-60	Curies	2.81E-03	7.38E-04	4.32E-03	6.36E-04
Tc-99M	Curies	0.00E+00	0.00E+00	4.10E-07	0.00E+00
Co-57	Curies	1.65E-05	5.08E-06	2.87E-05	1.14E-07
Te-125M	Curies	1.10E-02	5.36E-04	1.02E-02	2.50E-02
Mo-99	Curies	0.00E+00	0.00E+00	4.03E-07	0.00E+00
Cr-51	Curies	4.58E-04	0.00E+00	1.97E-03	5.25E-04
Fe-55	Curies	3.25E-03	1.13E-03	6.24E-03	2.00E-03
Te-132	Curies	0.00E+00	0.00E+00	1.35E-05	1.26E-05
Ni-63	Curies	1.58E-03	8.36E-04	1.64E-03	2.99E-03
Total For Period	Curies	2.61E-02	9.25E-03	3.33E-02	3.34E-02

Table 1-2 B

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Liquid Effluents
 Unit: 2
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Tritium					
H-3	Curies	4.38E+02	2.23E+02	3.40E+02	1.09E+02
Dissolved And Entrained Gases					
Xe-133	Curies	7.03E-06	4.12E-04	3.15E-04	1.80E-05
Xe-135	Curies	0.00E+00	1.73E-05	1.87E-07	0.00E+00
Xe-131M	Curies	0.00E+00	0.00E+00	2.10E-07	0.00E+00
Total For Period	Curies	7.03E-06	4.30E-04	3.15E-04	1.80E-05
Gross Alpha Radioactivity					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-2 C
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

		<u>Continuous Mode</u>			
Nuclides Released	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
Fe-55	Curies	4.08E-05	4.59E-04	0.00E+00	0.00E+00
Total For Period	Curies	4.08E-05	4.59E-04	0.00E+00	0.00E+00
Tritium					
H-3	Curies	4.78E-02	0.00E+00	2.46E-02	1.97E-02
Dissolved And Entrained Gases					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha Radioactivity					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-2 C
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission & Activation Products					
Co-58	Curies	1.08E-02	9.75E-03	1.32E-02	2.93E-03
Sn-117M	Curies	6.00E-06	0.00E+00	2.54E-05	5.62E-05
Cs-137	Curies	1.69E-03	1.54E-03	1.36E-03	3.63E-04
Rh-105	Curies	0.00E+00	0.00E+00	4.05E-05	2.61E-05
Cr-51	Curies	9.16E-04	0.00E+00	3.94E-03	1.05E-03
Ni-63	Curies	3.16E-03	1.67E-03	3.29E-03	5.98E-03
Sb-125	Curies	5.38E-04	0.00E+00	5.14E-04	5.89E-04
Te-125M	Curies	2.21E-02	1.07E-03	2.05E-02	5.00E-02
Fe-55	Curies	6.49E-03	2.15E-03	1.25E-02	4.00E-03
I-132	Curies	0.00E+00	0.00E+00	2.72E-05	1.34E-05
Cs-134	Curies	2.39E-04	1.85E-04	1.32E-04	5.71E-06
Co-60	Curies	5.63E-03	1.35E-03	8.65E-03	1.27E-03
Mn-54	Curies	3.60E-04	8.35E-05	7.05E-04	8.30E-05
Rb-86	Curies	0.00E+00	3.02E-06	0.00E+00	0.00E+00
Te-129	Curies	0.00E+00	0.00E+00	0.00E+00	5.15E-05
Fe-59	Curies	2.39E-05	0.00E+00	2.97E-04	8.51E-05
Co-57	Curies	3.31E-05	1.02E-05	5.74E-05	2.27E-07
Sr-90	Curies	0.00E+00	0.00E+00	1.68E-06	0.00E+00
Nb-95	Curies	2.45E-05	3.04E-06	7.68E-04	1.16E-04
Te-131M	Curies	0.00E+00	0.00E+00	0.00E+00	1.07E-05
Zr-95	Curies	0.00E+00	0.00E+00	4.01E-04	3.18E-05
Sr-89	Curies	1.26E-05	3.12E-07	0.00E+00	0.00E+00
Zn-65	Curies	1.92E-04	2.19E-05	1.27E-04	4.45E-06
Tc-99M	Curies	0.00E+00	0.00E+00	8.20E-07	0.00E+00
Mo-99	Curies	0.00E+00	0.00E+00	8.06E-07	0.00E+00
Te-132	Curies	0.00E+00	0.00E+00	2.70E-05	2.52E-05
Total For Period	Curies	5.22E-02	1.79E-02	6.65E-02	6.67E-02

Table 1-2 C
Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Tritium					
H-3	Curies	8.77E+02	4.12E+02	6.80E+02	2.17E+02
Dissolved And Entrained Gases					
Xe-131M	Curies	0.00E+00	0.00E+00	4.19E-07	0.00E+00
Xe-133	Curies	1.41E-05	8.25E-04	6.30E-04	3.60E-05
Xe-135	Curies	0.00E+00	3.47E-05	3.74E-07	0.00E+00
Total For Period	Curies	1.41E-05	8.59E-04	6.31E-04	3.60E-05
Gross Alpha Radioactivity					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-3 A

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Doses to a member of the public due to Liquid Releases
 Unit: 1
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
GI-Li	5.00E+00	mRem	8.13E-03	1.63E-01	3.68E-03	7.37E-02	1.13E-02	2.27E-01	7.72E-03	1.54E-01
Lung	5.00E+00	mRem	7.42E-03	1.48E-01	4.00E-03	7.99E-02	9.32E-03	1.86E-01	3.52E-03	7.04E-02
Kidney	5.00E+00	mRem	9.60E-03	1.92E-01	5.38E-03	1.08E-01	1.23E-02	2.47E-01	8.13E-03	1.63E-01
Bone	5.00E+00	mRem	4.78E-03	9.56E-02	4.59E-03	9.18E-02	5.98E-03	1.20E-01	4.44E-03	8.88E-02
Thyroid	5.00E+00	mRem	6.53E-03	1.31E-01	3.31E-03	6.61E-02	8.22E-03	1.64E-01	3.00E-03	6.00E-02
Total Body	1.50E+00	mRem	1.04E-02	6.95E-01	7.40E-03	4.93E-01	1.26E-02	8.37E-01	4.13E-03	2.75E-01
Liver	5.00E+00	mRem	1.23E-02	2.47E-01	9.37E-03	1.87E-01	1.48E-02	2.97E-01	5.12E-03	1.02E-01

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor	Limit
GI-Li	1.00E+01	mRem	3.09E-02	3.09E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Total Body	3.00E+00	mRem	3.45E-02	1.15E+00	Maximum Individual Liquid	Liquid Effluent TB Annual
Thyroid	1.00E+01	mRem	2.11E-02	2.11E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Lung	1.00E+01	mRem	2.43E-02	2.43E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Liver	1.00E+01	mRem	4.17E-02	4.17E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Bone	1.00E+01	mRem	1.98E-02	1.98E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Kidney	1.00E+01	mRem	3.55E-02	3.55E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual

Table 1-3 B
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Doses to a member of the public due to Liquid Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Liver	5.00E+00	mRem	1.24E-02	2.47E-01	1.13E-02	2.27E-01	1.49E-02	2.97E-01	5.12E-03	1.02E-01
Thyroid	5.00E+00	mRem	6.53E-03	1.31E-01	4.34E-03	8.68E-02	8.22E-03	1.64E-01	3.00E-03	6.00E-02
Total Body	1.50E+00	mRem	1.04E-02	6.95E-01	9.05E-03	6.03E-01	1.26E-02	8.37E-01	4.13E-03	2.75E-01
Kidney	5.00E+00	mRem	9.60E-03	1.92E-01	6.74E-03	1.35E-01	1.23E-02	2.47E-01	8.13E-03	1.63E-01
Bone	5.00E+00	mRem	4.78E-03	9.56E-02	5.32E-03	1.06E-01	5.98E-03	1.20E-01	4.44E-03	8.88E-02
Lung	5.00E+00	mRem	7.43E-03	1.49E-01	5.12E-03	1.02E-01	9.32E-03	1.86E-01	3.52E-03	7.04E-02
GI-Li	5.00E+00	mRem	8.13E-03	1.63E-01	4.75E-03	9.50E-02	1.13E-02	2.27E-01	7.72E-03	1.54E-01

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor	Limit
Thyroid	1.00E+01	mRem	2.21E-02	2.21E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
GI-Li	1.00E+01	mRem	3.19E-02	3.19E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Liver	1.00E+01	mRem	4.37E-02	4.37E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Kidney	1.00E+01	mRem	3.68E-02	3.68E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Bone	1.00E+01	mRem	2.05E-02	2.05E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Total Body	3.00E+00	mRem	3.62E-02	1.21E+00	Maximum Individual Liquid	Liquid Effluent TB Annual
Lung	1.00E+01	mRem	2.54E-02	2.54E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual

Table 1-3 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Doses to a member of the public due to Liquid Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Lung	5.00E+00	mRem	1.49E-02	2.97E-01	9.12E-03	1.82E-01	1.86E-02	3.73E-01	7.04E-03	1.41E-01
Kidney	5.00E+00	mRem	1.92E-02	3.84E-01	1.21E-02	2.42E-01	2.47E-02	4.94E-01	1.63E-02	3.25E-01
Bone	5.00E+00	mRem	9.56E-03	1.91E-01	9.91E-03	1.98E-01	1.20E-02	2.39E-01	8.88E-03	1.78E-01
Thyroid	5.00E+00	mRem	1.31E-02	2.61E-01	7.65E-03	1.53E-01	1.64E-02	3.29E-01	6.00E-03	1.20E-01
Liver	5.00E+00	mRem	2.47E-02	4.94E-01	2.07E-02	4.14E-01	2.97E-02	5.94E-01	1.02E-02	2.05E-01
GI-Lli	5.00E+00	mRem	1.63E-02	3.25E-01	8.43E-03	1.69E-01	2.27E-02	4.53E-01	1.54E-02	3.09E-01
Total Body	1.50E+00	mRem	2.08E-02	1.39E+00	1.65E-02	1.10E+00	2.51E-02	1.67E+00	8.25E-03	5.50E-01

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor	Limit
GI-Lli	1.00E+01	mRem	6.28E-02	6.28E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Thyroid	1.00E+01	mRem	4.31E-02	4.31E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Bone	1.00E+01	mRem	4.03E-02	4.03E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Kidney	1.00E+01	mRem	7.23E-02	7.23E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Liver	1.00E+01	mRem	8.53E-02	8.53E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual
Total Body	3.00E+00	mRem	7.07E-02	2.36E+00	Maximum Individual Liquid	Liquid Effluent TB Annual
Lung	1.00E+01	mRem	4.96E-02	4.96E-01	Maximum Individual Liquid	Liquid Effluent Organ Annual

Table 1-4
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
MINIMUM DETECTABLE CONCENTRATIONS – LIQUID SAMPLE ANALYSES

Starting: 1-Jan-2014

Ending: 31-Dec-2014

The values in this table represent a priori Minimum Detectable Concentrations (MDC) that are typically achieved in laboratory analyses of liquid radwaste samples.

RADIONUCLIDE	MDC	UNITS
Mn-54	2.73E-08	μCi/ml
Fe-59	8.33E-08	μCi/ml
Co-58	3.78E-08	μCi/ml
Co-60	6.76E-08	μCi/ml
Zn-65	1.32E-07	μCi/ml
Mo-99	4.31E-07	μCi/ml
Cs-134	3.06E-08	μCi/ml
Cs-137	4.51E-08	μCi/ml
Ce-141	6.99E-08	μCi/ml
Ce-144	2.95E-07	μCi/ml
I-131	5.97E-08	μCi/ml
Xe-133	9.11E-08	μCi/ml
Xe-135	4.27E-08	μCi/ml
Fe-55	1.00E-06	μCi/ml
Sr-89	5.00E-08	μCi/ml
Sr-90	7.00E-09	μCi/ml
H-3	2.00E-06	μCi/ml
Gross Alpha	7.00E-08	μCi/ml

Table 1-5 A
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Batch Release Summary
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		37	34	51	27	149
2. Total time period for Batch releases	(Minutes)	7.88E+03	5.46E+03	1.26E+04	4.74E+03	3.12E+04
3. Maximum time period for a batch release	(Minutes)	4.08E+02	4.75E+02	5.84E+02	4.99E+02	5.84E+02
4. Average time period for a batch release	(Minutes)	2.13E+02	1.71E+02	2.48E+02	1.76E+02	2.10E+02
5. Minimum time period for a batch release	(Minutes)	4.50E+01	4.50E+01	4.70E+01	5.30E+01	4.50E+01
6. Average stream flow during periods of release of liquid effluent into a flowing stream *	(CFS)	1.68E+04	8.99E+03	6.49E+03	5.38E+03	2.62E+04

*Average river flowrate taken from USGS Monitoring Station 02197500, Savannah River at Burton's Ferry Bridge near Millhaven, GA. 32 miles downstream of Plant Vogtle.

Table 1-5 B
Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Batch Release Summary
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		37	34	51	27	149
2. Total time period for Batch releases	(Minutes)	7.88E+03	5.97E+03	1.26E+04	4.74E+03	3.12E+04
3. Maximum time period for a batch release	(Minutes)	4.08E+02	4.75E+02	5.84E+02	4.99E+02	5.84E+02
4. Average time period for a batch release	(Minutes)	2.13E+02	1.76E+02	2.48E+02	1.76E+02	2.10E+02
5. Minimum time period for a batch release	(Minutes)	4.50E+01	4.50E+01	4.70E+01	5.30E+01	4.50E+01
6. Average stream flow during periods of release of liquid effluent into a flowing stream *	(CFS)	1.68E+04	8.99E+03	6.49E+03	5.38E+03	2.62E+04

*Average river flowrate taken from USGS Monitoring Station 02197500, Savannah River at Burton's Ferry Bridge near Millhaven, GA. 32 miles downstream of Plant Vogtle.

Table 1-5 C
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Batch Release Summary
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		37	34	51	27	149
2. Total time period for Batch releases	(Minutes)	7.88E+03	5.97E+03	1.26E+04	4.74E+03	3.12E+04
3. Maximum time period for a batch release	(Minutes)	4.08E+02	4.75E+02	5.84E+02	4.99E+02	5.84E+02
4. Average time period for a batch release	(Minutes)	2.13E+02	1.76E+02	2.48E+02	1.76E+02	2.10E+02
5. Minimum time period for a batch release	(Minutes)	4.50E+01	4.50E+01	4.70E+01	5.30E+01	4.50E+01
6. Average stream flow during periods of release of liquid effluent into a flowing stream *	(CFS)	1.68E+04	8.99E+03	6.49E+03	5.38E+03	2.62E+04

*Average river flowrate taken from USGS Monitoring Station 02197500, Savannah River at Burton's Ferry Bridge near Millhaven, GA. 32 miles downstream of Plant Vogtle.

Table 1-6 A

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Abnormal Release Summary
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-6 B

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Abnormal Release Summary
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 1-6 C

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Liquid Effluents - Abnormal Release Summary
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Liquid Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

2.0 Gaseous Effluents

2.1 Regulatory Requirements

The ODCM Specifications presented in this section are for Unit 1 and Unit 2.

2.1.1 Dose Rate Limits

The dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the SITE BOUNDARY shall be limited to the following:

- a. For noble gases, Less than or equal to 500 mrems/yr. to the whole body and less than or equal to 3000 mrems/yr. to the skin and,
- b. For Iodine-131, for Iodine-133, for tritium and for all radionuclides in particulate form with half lives greater than 8 days: Less than or equal to 1500 mrems/yr. to any organ.

2.1.2 Air Doses Due to Noble Gases in Gaseous Releases

The air dose due to noble gases released in gaseous effluents, from each unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 5 mrads for gamma radiation and less than or equal to 10 mrads for beta radiation, and
- b. During any calendar year: Less than or equal to 10 mrads for gamma radiation and less than or equal to 20 mrads for beta radiation.

2.1.3 Doses to a Member of the Public

The dose to a MEMBER OF THE PUBLIC from Iodine-131, Iodine-133, tritium and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released, from each unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following.

- a. During any calendar quarter: Less than or equal to 7.5 mrems to any organ.
- b. During any calendar year: Less than or equal to 15 mrems to any organ.

2.2 Measurements and Approximations of Total Radioactivity

2.2.1 Sample Collection and Analysis

Gaseous Effluents at the Vogtle Electric Generating Plant are currently confined to five paths: plant vents (Unit 1 and Unit 2), the condenser air ejector, the steam packing exhauster systems (Unit 1 and Unit 2), and the Radwaste Processing Facility (RPF).

Waste gas decay tanks are batch released through the Unit 1 plant vent. The containment purges are released through their respective plant vents. Containment atmosphere is also released via the containment equipment hatch during periods when the equipment hatch is open with containment purge/vent being stopped. Approval was granted by the NRC to open the equipment hatch during fuel movement; a release permit is generated when the equipment hatch is opened and the containment exhaust fan is not discharging to the plant vent. Any detected activity in the containment equipment hatch permit is included in the Ground Release Table of the effluent report.

All of the paths with the exception of the RPF can be continuously monitored for gaseous radioactivity. The RPF is equipped with an integrated-type sample collection device for collecting particulates. Plant vent, containment, steam jet air ejector, steam-packing exhauster are equipped with an integrated-type sample collection device for collecting particulates and iodines. During this reporting period, there were no continuous radioactive releases through the condenser air ejector and the steam packing exhauster system vents. Batch Waste Gas Decay Tank releases are analyzed for noble gases before each release. The containment atmosphere is analyzed for noble gases prior to each release and for tritium at least on a monthly basis.

Sample analysis results and release flow rates form the basis for calculating released quantities of radionuclide specific radioactivity, dose rates associated with gaseous releases, and cumulative doses for the current quarter and year.

With each release period and batch release, radioactivity, dose rates, and cumulative doses are calculated. Cumulative dose results are tabulated, along with the percent of the ODCM limits for each release for the current quarter and year.

Typically achieved minimum detectable concentrations for gaseous effluent sample analyses are reported in Table 2-6.

Appendix A

Vogtle Electric Generating Plant

CARBON-14

Carbon-14 (C-14) is a naturally-occurring radionuclide with a 5730 year half life. Nuclear weapons testing in the 1950s and 1960s significantly increased the amount of C-14 in the atmosphere. Nuclear power plants also produce C-14, but the amount is infinitesimal compared to what has been distributed in the environment due to weapons testing and what is produced by natural cosmic ray interactions.

As nuclear plants have improved gaseous waste processing systems and improved fuel performance, the percentages of “principal radionuclides” in gaseous effluents have changed, and C-14 has become a larger percentage. “Principal radionuclides” are determined based on public dose contribution or the amount of activity discharged compared to other radionuclides of the same effluent type. In Revision 2 (June 2009) of Regulatory Guide 1.21 (RG 1.21), “Measuring, Evaluating, and Reporting Radioactive Material in Liquid and Gaseous Effluents and Solid Waste,” the NRC recommended re-evaluating “principal radionuclides” and reporting C-14 as appropriate. In 2010 Radioactive Effluent Release Reports, virtually all U. S. nuclear power plants started reporting C-14 amounts released and resulting doses to the maximally exposed member of the public.

Because C-14 is considered a hard-to-detect radionuclide which must be chemically separated from the effluent stream before it can be measured, RG 1.21 provides the option of calculating the C-14 source term based on power generation. The Electric Power Research Institute (EPRI) developed an accepted methodology for calculating C-14, and published the results in Technical Report 1021106 (December 2010), “Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents.” Evaluation of C-14 in radioactive liquid effluents is not required because the quantity and dose contribution has been determined to be insignificant.

At Plant Vogtle, the annual quantity of C-14 released in gaseous effluents was estimated to be 12.08 Curies (per unit). Approximately 30% of the C-14 released is in the form of $^{14}\text{CO}_2$ and is incorporated into plants through photosynthesis. Ingestion dose results from this pathway. The remaining 70% is estimated to be organic. Both the organic and inorganic forms of C-14 contribute to inhalation dose. A child is the maximally exposed individual, and bone dose is the highest organ dose. Using the dose calculation methodology from the Vogtle ODCM, the resulting bone dose to a child located at the controlling receptor location would be 8.46E-02 mrem in a year which is 0.56% of the regulatory limit of 15 mrem per year (per unit) to any organ due to gaseous effluents. The resulting total body dose to a child located at the controlling receptor location would be 1.69E-02 mrem in a year which is 0.11% of the regulatory limit of 15 mrem per year (per unit) total body dose due to gaseous effluents

2.2.2 Total Quantities of Radioactivity, Dose Rates, and Cumulative Doses

The methods for determining release quantities of radioactivity, dose rates, and cumulative doses are as follows:

2.2.2.1 Fission and Activation Gases

The released radioactivity is determined from sample analysis results collected as described above and average release flow rates over the period represented by the collected sample. Dose rates due to noble gases, radioiodines, tritium, and particulates are calculated. Calculated dose rates are compared to the dose rate limits specified in ODCM 3.1.2 for noble gases, radioiodines, tritium, and particulates. Dose rate calculation methodology is presented in the ODCM.

Beta and gamma air doses due to noble gases are calculated for the location in the unrestricted area with the potential for the highest exposure due to gaseous releases. Air doses are calculated for each release period and cumulative totals are kept for each unit for the calendar quarter and year. Cumulative air doses are compared with the dose limits specified in ODCM 3.1.3. Current percent of the ODCM limits are shown on the printout for each release period. Air dose calculation methodology is presented in the ODCM.

2.2.2.2 Radioiodines, Tritium and Particulate Releases

The released quantities of radioiodines, tritium and particulates are determined using the weekly samples and release flow rates for the two plant vent release points.

After each quarter, the particulate filters from each plant vent are combined, for strontium analysis. Strontium concentrations are input to the composite file of the computer to be used for release dose rate and individual dose calculations.

Doses to a Member of the Public due to radioiodines, tritium and particulates are calculated for the controlling receptor, which is described in Table 3-7 of the ODCM. Doses are calculated for each release period, and cumulative totals are kept for each unit for the current calendar quarter and year. Cumulative doses are compared to the dose limits specified in ODCM 3.1.4.

Current percent of ODCM limits are shown in this report for each release period.

2.2.2.3 Gross Alpha Release

The gross alpha release is calculated each month by counting the particulate filters for each week for gross alpha activity. The four or five weeks' numbers are then recorded on a data sheet and the activity is summed at the end of the month. This concentration is used for release calculations.

2.2.3 Total Error Estimation

The total or maximum error associated with the effluent measurement will include the cumulative errors resulting from the total operation of sampling and measurement. Because it may be very difficult to assign error terms for each parameter affecting the final measurement, detailed statistical evaluation of error are not suggested.

The objective should be to obtain an overall estimate of the error associated with measurements of radioactive materials released in liquid and gaseous effluents and solid waste.

Estimated errors are based on errors in counting equipment calibration, counting statistics, vent-flow rates, vent sample flow rates, non-steady release rates, chemical yield factors, and sample losses for such items as charcoal cartridges. Total Error is calculated by the root mean square method. The root mean square value is the square root of the arithmetic mean (average) of the squares of the original values.

- a. Fission and activation total release was calculated from sample analysis results and release point flow rates.

Sampling and statistical error in counting	10%
Counting equipment calibration	10%
Vent flow Rates	10%
Non-steady release rates	20%
TOTAL ERROR	26.5%

- b. I-131 releases were calculated from each weekly sample:

Statistical error in counting	10%
Counting equipment calibration	10%
Vent Flow Rates	10%
Vent Sample Flow Rates	50%
Non-Steady release rates	10%
Losses from charcoal cartridges	10%
TOTAL ERROR	55%

- c. Particulates with half-lives greater than 8 day releases were calculated from sample and analysis results and release point flow rates.

Statistical error at MDC concentration	10%
Counting equipment calibration	10%
Vent flow rates	10%
Vent sample flow rates	50%
Non steady release rates	10%
TOTAL ERROR	54%

2.2.3 Total Error Estimation cont'd

- d. Total tritium releases were calculated from sample analysis results and release point flow rates.

Water vapor in sample stream determination	10%
Vent flow rates	10%
Counting calibration and statistics	10%
Non-steady release rates	10%
TOTAL ERROR	20%

- e. Gross Alpha radioactivity was calculated from sample analysis results and release point flow rates.

Statistical error at MDC concentration	10%
Counting equipment calibration	10%
Vent flow rates	10%
Vent sample flow rates	50%
Non Steady release rates	10%
TOTAL ERROR	55%

2.3 Gaseous Effluent Release Data

Regulatory Guide 1.21 Rev. 1 Tables 1A, 1B, and 1C are found in this report as Tables 2-1A, 2-1B, 2-1C, 2-2A, 2-2B, 2-2C, 2-3A, 2-3B, and 2-3C. Data are presented on a quarterly basis as required by Regulatory Guide 1.21 Rev. 1.

To complete table 2-1A, and 2-1B, the total release for each of the four categories (fission and activation gases, iodines, particulates, and tritium) was divided by the number of seconds in the quarter to obtain a release rate in $\mu\text{Ci}/\text{second}$ for each category. However, the percent of the ODCM limits are not applicable because VEGP has no curie limits for gaseous releases. Applicable limits are expressed in terms of dose. Noble gases are limited as specified in ODCM 3.1.2. The other three categories (tritium, radioiodines, and particulates) are limited as a group as specified in ODCM 3.1.2.

Dose rates due to noble gas releases and due to radioiodines, tritium, and particulate releases were calculated as part of the pre-release and post-release permits. No limits were exceeded for this reporting period.

Gross alpha radioactivity is reported in Table 2-1A, and 2-1B as curies released in each quarter.

Limits for cumulative beta and gamma air doses due to noble gases are specified in ODCM 3.1.3. Cumulative air doses are presented in Table 2-4A, and 2-4B along with the percent of the ODCM limits.

Limits for cumulative doses to a Member of the Public due to radioiodines, tritium and particulates, are specified in ODCM 3.1.4. Cumulative doses to a Member of the Public are presented in Table 2-5A, and 2-5B along with percent of ODCM limits.

2.4 Radiological Impact Due to Gaseous Releases

Dose rates due to the release of noble gases were calculated for the site in accordance with ODCM 3.4.1.1. Dose rates due to radioiodines, tritium, and particulates in gaseous releases were calculated in accordance with ODCM 3.4.1.2.

Dose rates were calculated as part of pre-release and post release permits. No limits were exceeded for this reporting period.

Cumulative air doses due to noble gas releases were calculated for each unit in accordance with ODCM 3.4.2. These results are presented in Tables 2-4A and 2-4B.

Cumulative doses to a Member of the Public were calculated for each unit in accordance with ODCM 3.4.3. These results are presented in Tables 2-5A and 2-5B.

Dose rates and doses were calculated using the methodology presented in the Vogtle Electric Generating Plant Offsite Dose Calculation Manual.

2.5 Gaseous Effluents - Batch Releases

Other data pertinent to batch releases of radioactive gaseous effluent from Unit 1 and Unit 2 are listed in Table 2-7A and 2-7B.

2.6 Gaseous Effluents - Abnormal Releases

There were no abnormal releases for 2014.

Table 2-1 A

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Summation Of All Releases
 Unit: 1
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Gases					
1. Total Release	Curies	6.19E+00	5.39E-02	6.19E-02	1.26E-01
2. Average Release rate for period	uCi/sec	7.85E-01	6.84E-03	7.85E-03	1.60E-02
3. Percent of Applicable Limit	%	*	*	*	*
B. Radioiodines					
1. Total Iodine-131	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Percent of Applicable Limit	%	*	*	*	*
C. Particulates					
1. Particulates (Half-Lives > 8 Days)	Curies	4.32E-08	4.36E-08	3.58E-08	0.00E+00
2. Average Release rate for period	uCi/sec	5.48E-09	5.53E-09	4.54E-09	0.000E+00
3. Percent of Applicable Limit	%	*	*	*	*
D. Tritium					
1. Total Release	Curies	8.76E+00	7.78E+00	8.60E+00	1.55E+01
2. Average Release rate for period	uCi/sec	1.11E+00	9.87E-01	1.09E+00	1.96E+00
3. Percent of Applicable Limit	%	*	*	*	*
E. Gross Alpha					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	0.00E+00	0.00E+00

* Applicable limits are expressed in terms of dose. See Tables 2-5A and 2-5B of this report.

Table 2-1 B

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Summation Of All Releases
 Unit: 2
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Gases					
1. Total Release	Curies	1.17E-01	2.68E-02	5.95E-01	2.12E-02
2. Average Release rate for period	uCi/sec	1.48E-02	3.40E-03	7.55E-02	2.69E-03
3. Percent of Applicable Limit	%	*	*	*	*
B. Radioiodines					
1. Total Iodine-131	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	9.93E-07	3.40E-06
3. Percent of Applicable Limit	%	*	*	*	*
C. Particulates					
1. Particulates (Half-Lives > 8 Days)	Curies	3.59E-07	2.34E-08	0.00E+00	0.00E+00
2. Average Release rate for period	uCi/sec	4.56E-08	2.97E-09	0.00E+00	0.000E+00
3. Percent of Applicable Limit	%	*	*	*	*
D. Tritium					
1. Total Release	Curies	5.97E-02	9.64E+00	1.88E+01	3.87E+00
2. Average Release rate for period	uCi/sec	7.58E-03	1.22E+00	2.38E+00	4.91E-01
3. Percent of Applicable Limit	%	*	*	*	*
E. Gross Alpha					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	0.00E+00	0.00E+00

* Applicable limits are expressed in terms of dose. See Tables 2-5A and 2-5B of this report.

Table 2-1 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Summation Of All Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Type of Effluent	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
A. Fission And Activation Gases					
1. Total Release	Curies	6.30E+00	8.07E-02	6.57E-01	1.47E-01
2. Average Release rate for period	uCi/sec	8.00E-01	1.02E-02	8.33E-02	1.87E-02
3. Percent of Applicable Limit	%	*	*	*	*
B. Radioiodines					
1. Total Iodine-131	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	9.93E-07	3.40E-06
3. Percent of Applicable Limit	%	*	*	*	*
C. Particulates					
1. Particulates (Half-Lives > 8 Days)	Curies	4.03E-07	6.70E-08	3.58E-08	0.00E+00
2. Average Release rate for period	uCi/sec	5.11E-08	8.50E-09	4.54E-09	0.000E+00
3. Percent of Applicable Limit	%	*	*	*	*
D. Tritium					
1. Total Release	Curies	8.82E+00	1.74E+01	2.73E+01	1.93E+01
2. Average Release rate for period	uCi/sec	1.12E+00	2.21E+00	3.47E+00	2.45E+00
3. Percent of Applicable Limit	%	*	*	*	*
E. Gross Alpha					
1. Total Release	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Average Release rate for period	uCi/sec	0.00E+00	0.00E+00	0.00E+00	0.00E+00

* Applicable limits are expressed in terms of dose. See Tables 2-5A and 2-5B of this report.

Table 2-2 A

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Mixed Mode Level Releases
 Unit: 1
 Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Xe-135	Curies	5.46E+00	0.00E+00	0.00E+00	0.00E+00
Total For Period	Curies	5.46E+00	0.00E+00	0.00E+00	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
Sr-90	Curies	4.32E-08	4.36E-08	3.58E-08	0.00E+00
Total For Period	Curies	4.32E-08	4.36E-08	3.58E-08	0.00E+00
Tritium					
H-3	Curies	8.40E+00	7.73E+00	8.57E+00	1.54E+01
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-2 A

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Mixed Mode Level Releases
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	6.85E-01	5.39E-02	6.15E-02	1.24E-01
Xe-133	Curies	0.00E+00	0.00E+00	4.18E-04	1.83E-03
Total For Period	Curies	6.85E-01	5.39E-02	6.19E-02	1.26E-01
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	3.31E-01	4.35E-02	2.77E-02	1.04E-01
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-2 B

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Mixed Mode Level Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodines					
I-131	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
Total For Period	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
Particulates					
Sr-89	Curies	3.59E-07	0.00E+00	0.00E+00	0.00E+00
Sr-90	Curies	0.00E+00	2.34E-08	0.00E+00	0.00E+00
Total For Period	Curies	3.59E-07	2.34E-08	0.00E+00	0.00E+00
Tritium					
H-3	Curies	0.00E+00	9.56E+00	8.55E+00	3.87E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-2 B

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Mixed Mode Level Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	2.84E-02	1.85E-02	5.18E-01	1.53E-02
Xe-133	Curies	8.39E-02	8.30E-03	7.32E-02	5.86E-03
Xe-135	Curies	4.52E-03	0.00E+00	5.15E-05	2.78E-05
Total For Period	Curies	1.17E-01	2.68E-02	5.92E-01	2.12E-02
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	5.97E-02	8.71E-02	9.93E+00	3.50E-03
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-2 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Mixed Mode Level Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Xe-135	Curies	5.46E+00	0.00E+00	0.00E+00	0.00E+00
Total For Period	Curies	5.46E+00	0.00E+00	0.00E+00	0.00E+00
Iodines					
I-131	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
Total For Period	Curies	0.00E+00	0.00E+00	7.83E-06	2.68E-05
Particulates					
Sr-89	Curies	3.59E-07	0.00E+00	0.00E+00	0.00E+00
Sr-90	Curies	4.32E-08	6.70E-08	3.58E-08	0.00E+00
Total For Period	Curies	4.03E-07	6.70E-08	3.58E-08	0.00E+00
Tritium					
H-3	Curies	8.40E+00	1.73E+01	1.71E+01	1.92E+01
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-2 C
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Mixed Mode Level Releases
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	7.13E-01	7.24E-02	5.80E-01	1.40E-01
Xe-133	Curies	8.39E-02	8.30E-03	7.36E-02	7.70E-03
Xe-135	Curies	4.52E-03	0.00E+00	5.15E-05	2.78E-05
Total For Period	Curies	8.01E-01	8.07E-02	6.54E-01	1.47E-01
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	3.91E-01	1.31E-01	9.96E+00	1.08E-01
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 A

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Ground Level Releases
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 A

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Ground Level Releases
 Unit: 1
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	4.43E-02	0.00E+00	0.00E+00	0.00E+00
Total For Period	Curies	4.43E-02	0.00E+00	0.00E+00	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	3.03E-02	2.90E-03	0.00E+00	0.00E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 B

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Ground Level Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 B

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Ground Level Releases
 Unit: 2
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	0.00E+00	0.00E+00	3.38E-03	0.00E+00
Total For Period	Curies	0.00E+00	0.00E+00	3.38E-03	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	0.00E+00	0.00E+00	2.75E-01	0.00E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 C

**Vogle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Ground Level Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Continuous Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodines No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gross Alpha No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-3 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Ground Level Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Nuclides Released	Units	<u>Batch Mode</u>			
		1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter
Fission Gases					
Ar-41	Curies	4.43E-02	0.00E+00	3.38E-03	0.00E+00
Total For Period	Curies	4.43E-02	0.00E+00	3.38E-03	0.00E+00
Iodines					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particulates					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium					
H-3	Curies	3.03E-02	2.90E-03	2.75E-01	0.00E+00
Gross Alpha					
No Nuclides Found	Curies	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-4 A

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Air Doses Due to Gaseous Releases
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Cumulative Doses Per Quarter

Type of Radiation	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Gamma Air	5.00E+00	mRad	2.80E-04	5.60E-03	7.35E-06	1.47E-04	8.38E-06	1.68E-04	1.70E-05	3.39E-04
Beta Air	1.00E+01	mRad	2.41E-04	2.41E-03	2.59E-06	2.59E-05	2.96E-06	2.96E-05	6.01E-06	6.01E-05

Cumulative Doses Per Year

Type of Radiation	ODCM Lmt	Units	Year to End Date	% ODCM	Receptor	Limit
Gamma Air	1.00E+01	mRad	3.13E-04	3.13E-03	Site Boundary / Child	Air Dose Gamma Annual 1.21
Beta Air	2.00E+01	mRad	2.53E-04	1.26E-03	Site Boundary / Child	Air Dose Beta Annual 1.21

Table 2-4 B

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Air Doses Due to Gaseous Releases
 Unit: 2
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Type of Radiation	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Gamma Air	5.00E+00	mRad	4.43E-06	8.86E-05	2.57E-06	5.13E-05	7.36E-05	1.47E-03	2.12E-06	4.24E-05
Beta Air	1.00E+01	mRad	2.82E-06	2.82E-05	1.02E-06	1.02E-05	2.69E-05	2.69E-04	8.27E-07	8.27E-06

Cumulative Doses Per Year

Type of Radiation	ODCM Lmt	Units	Year to End Date	% ODCM	Receptor	Limit
Gamma Air	1.00E+01	mRad	8.27E-05	8.27E-04	Site Boundary / Child	Air Dose Gamma Annual 1.21
Beta Air	2.00E+01	mRad	3.16E-05	1.58E-04	Site Boundary / Child	Air Dose Beta Annual 1.21

Table 2-4 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Gaseous Effluents - Ground Level Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Type of Radiation	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Gamma Air	5.00E+00	mRad	2.85E-04	5.69E-03	9.91E-06	1.98E-04	8.19E-05	1.64E-03	1.91E-05	3.82E-04
Beta Air	1.00E+01	mRad	2.44E-04	2.44E-03	3.61E-06	3.61E-05	2.99E-05	2.99E-04	6.84E-06	6.84E-05

Cumulative Doses Per Year

Type of Radiation	ODCM Lmt	Units	Year to End Date	% ODCM	Receptor	Limit
Gamma Air	1.00E+01	mRad	3.96E-04	3.96E-03	Site Boundary / Child	Air Dose Gamma Annual 1.21
Beta Air	2.00E+01	mRad	2.85E-04	1.42E-03	Site Boundary / Child	Air Dose Beta Annual 1.21

Table 2-5 A

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Doses To A Member Of The Public Due To Radioiodines, Tritium, and Particulates in Gaseous Releases
 Unit: 1
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Total Body	7.50E+00	mRem	1.92E-04	2.57E-03	1.69E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03
Liver	7.50E+00	mRem	1.92E-04	2.56E-03	1.68E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03
Thyroid	7.50E+00	mRem	1.92E-04	2.56E-03	1.68E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03
Bone	7.50E+00	mRem	1.71E-06	2.29E-05	1.73E-06	2.31E-05	1.42E-06	1.89E-05	0.00E+00	0.00E+00
Kidney	7.50E+00	mRem	1.92E-04	2.56E-03	1.68E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03
GI-Li	7.50E+00	mRem	1.92E-04	2.56E-03	1.68E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03
Lung	7.50E+00	mRem	1.92E-04	2.56E-03	1.68E-04	2.25E-03	1.86E-04	2.48E-03	3.34E-04	4.46E-03

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor Limit
Total Body	1.500E+01	mRem	8.818E-04	5.878E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21
Kidney	1.500E+01	mRem	8.805E-04	5.870E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21
Thyroid	1.500E+01	mRem	8.805E-04	5.870E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21
Bone	1.500E+01	mRem	4.863E-06	3.242E-05	Maximum Individual / Child Iodine/Part Dose Annual 1.21
GI-Li	1.500E+01	mRem	8.806E-04	5.871E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21
Liver	1.500E+01	mRem	8.805E-04	5.870E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21
Lung	1.500E+01	mRem	8.805E-04	5.870E-03	Maximum Individual / Child Iodine/Part Dose Annual 1.21

Table 2-5 B
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Doses To A Member Of The Public Due To Radioiodines, Tritium, and Particulates in Gaseous Releases
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Thyroid	7.50E+00	mRem	1.29E-06	1.72E-05	2.08E-04	2.78E-03	4.42E-04	5.89E-03	1.30E-04	1.73E-03
Total Body	7.50E+00	mRem	1.30E-06	1.74E-05	2.09E-04	2.78E-03	4.29E-04	5.71E-03	8.38E-05	1.12E-03
Liver	7.50E+00	mRem	1.29E-06	1.72E-05	2.08E-04	2.78E-03	4.29E-04	5.71E-03	8.39E-05	1.12E-03
Kidney	7.50E+00	mRem	1.29E-06	1.72E-05	2.08E-04	2.78E-03	4.29E-04	5.71E-03	8.40E-05	1.12E-03
Bone	7.50E+00	mRem	4.23E-07	5.63E-06	9.29E-07	1.24E-05	4.49E-08	5.99E-07	1.54E-07	2.05E-06
Lung	7.50E+00	mRem	1.29E-06	1.73E-05	2.08E-04	2.78E-03	4.28E-04	5.71E-03	8.37E-05	1.12E-03
GI-Li	7.50E+00	mRem	1.31E-06	1.74E-05	2.08E-04	2.78E-03	4.29E-04	5.71E-03	8.37E-05	1.12E-03

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor	Limit
GI-Li	1.500E+01	mRem	7.220E-04	4.814E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Bone	1.500E+01	mRem	1.550E-06	1.033E-05	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Kidney	1.500E+01	mRem	7.223E-04	4.815E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Liver	1.500E+01	mRem	7.222E-04	4.814E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Thyroid	1.500E+01	mRem	7.818E-04	5.212E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Total Body	1.500E+01	mRem	7.223E-04	4.816E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Lung	1.500E+01	mRem	7.220E-04	4.813E-03	Maximum Individual / Child	Iodine/Part Dose Annual 1.21

Table 2-5 C

**Vogtle Electric Generating Plant
 RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
 Doses To A Member Of The Public Due To Radioiodines, Tritium, and Particulates in Gaseous Releases
 Unit: Site
 Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Cumulative Doses Per Quarter

Organ	ODCM Lmt	Units	1ST Qtr	% ODCM	2ND Qtr	% ODCM	3RD Qtr	% ODCM	4TH Qtr	% ODCM
Bone	7.50E+00	mRem	2.14E-06	2.85E-05	2.66E-06	3.54E-05	1.46E-06	1.95E-05	1.54E-07	2.05E-06
Liver	7.50E+00	mRem	1.93E-04	2.58E-03	3.77E-04	5.03E-03	6.14E-04	8.19E-03	4.18E-04	5.57E-03
GI-Li	7.50E+00	mRem	1.93E-04	2.58E-03	3.77E-04	5.03E-03	6.14E-04	8.19E-03	4.18E-04	5.57E-03
Kidney	7.50E+00	mRem	1.93E-04	2.58E-03	3.77E-04	5.03E-03	6.14E-04	8.19E-03	4.18E-04	5.58E-03
Thyroid	7.50E+00	mRem	1.93E-04	2.58E-03	3.77E-04	5.03E-03	6.28E-04	8.37E-03	4.64E-04	6.19E-03
Total Body	7.50E+00	mRem	1.94E-04	2.58E-03	3.78E-04	5.03E-03	6.15E-04	8.20E-03	4.18E-04	5.57E-03
Lung	7.50E+00	mRem	1.93E-04	2.58E-03	3.77E-04	5.03E-03	6.14E-04	8.19E-03	4.18E-04	5.57E-03

Cumulative Doses per Year

Organ	ODCM Lmt	Units	Year to Ending Date	% ODCM	Receptor	Limit
Lung	1.500E+01	mRem	1.603E-03	1.068E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Thyroid	1.500E+01	mRem	1.662E-03	1.108E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Bone	1.500E+01	mRem	6.413E-06	4.275E-05	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Total Body	1.500E+01	mRem	1.604E-03	1.069E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Liver	1.500E+01	mRem	1.603E-03	1.068E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
Kidney	1.500E+01	mRem	1.603E-03	1.069E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21
GI-Li	1.500E+01	mRem	1.603E-03	1.068E-02	Maximum Individual / Child	Iodine/Part Dose Annual 1.21

Table 2-6

Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT – 2014
MINIMUM DETECTABLE CONCENTRATIONS
GASEOUS SAMPLE ANALYSES
Starting: 1-Jan-2014 **Ending: 31-Dec-2014**

RADIONUCLIDE	MDC	UNITS
Kr-87	1.82E-08	μCi/ml
Kr-88	2.53E-08	μCi/ml
Xe-133	2.05E-08	μCi/ml
Xe-133m	8.63E-08	μCi/ml
Xe-135	7.12E-08	μCi/ml
Xe-138	1.05E-07	μCi/ml
I-131	7.93E-15*	μCi/ml
Mn-54	3.94E-14*	μCi/ml
Fe-59	2.45E-14*	μCi/ml
Co-58	1.39E-14*	μCi/ml
Co-60	1.75E-14*	μCi/ml
Zn-65	2.82E-14*	μCi/ml
Mo-99	9.57E-14*	μCi/ml
Cs-134	1.12E-14*	μCi/ml
Cs-137	8.71E-15*	μCi/ml
Ce-141	8.62E-15*	μCi/ml
Ce-144	2.77E-14*	μCi/ml
Sr-89	1.00E-13	μCi/ml
Sr-90	1.00E-13	μCi/ml
H-3	9.00E-08	μCi/ml
Gross Alpha	1.00E-13	μCi/ml

* Based on an estimated sample volume of 5.7E+08 mls for particulate filters and charcoal cartridges

Table 2-7 A

**Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Batch Release Summary
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		35	52	48	54	189
2. Total time period for batch releases	(Minutes)	2.57E+04	6.31E+03	2.72E+03	3.07E+03	3.78E+04
3. Maximum time period for a batch release	(Minutes)	9.32E+03	2.28E+03	1.00E+02	1.74E+02	9.32E+03
4. Average time period for a batch release	(Minutes)	7.34E+02	1.21E+02	5.67E+01	5.69E+01	2.00E+02
5. Minimum time period for a batch release	(Minutes)	2.30E+01	1.60E+01	3.50E+01	4.00E+00	4.00E+00

Table 2-7 B

**Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Batch Release Summary
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		16	12	23	20	71
2. Total time period for batch releases	(Minutes)	4.62E+03	2.04E+03	2.62E+04	7.54E+03	4.04E+04
3. Maximum time period for a batch release	(Minutes)	3.98E+03	1.49E+03	5.74E+03	1.97E+03	5.74E+03
4. Average time period for a batch release	(Minutes)	2.89E+02	1.70E+02	1.14E+03	3.77E+02	5.69E+02
5. Minimum time period for a batch release	(Minutes)	7.00E+00	3.30E+01	1.90E+01	6.00E+00	6.00E+00

Table 2-7 C

**Vogle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Batch Release Summary
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of batch releases		51	64	71	74	260
2. Total time period for batch releases	(Minutes)	3.03E+04	8.35E+03	2.90E+04	1.06E+04	7.82E+04
3. Maximum time period for a batch release	(Minutes)	9.32E+03	2.28E+03	5.74E+03	1.97E+03	9.32E+03
4. Average time period for a batch release	(Minutes)	5.94E+02	1.30E+02	4.08E+02	1.43E+02	3.01E+02
5. Minimum time period for a batch release	(Minutes)	7.00E+00	1.60E+01	1.90E+01	4.00E+00	4.00E+00

Table 2-8 A

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Abnormal Release Summary
Unit: 1
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-8 B

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Abnormal Release Summary
Unit: 2
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Table 2-8 C

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Gaseous Effluents - Abnormal Release Summary
Unit: Site
Starting: 1-Jan-2014 Ending: 31-Dec-2014**

Gaseous Releases	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year Totals
1. Number of Releases		0	0	0	0	0
2. Total Time For All Releases	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Maximum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4. Average Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5. Minimum Time For A Release	(Minutes)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6. Total activity for all releases	(Curies)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3.0 Solid Waste

3.1 Regulatory Requirements

The ODCM requirements presented in this section are stated in part for Unit 1 and Unit 2.

3.1.1 Solid Radioactive Waste System

10.2.1 Process Control Program (PCP)

Radioactive wastes shall be solidified or dewatered in accordance with the PCP to meet shipping and transportation requirements during transit and disposal site requirements when received at the disposal site.

3.1.2 Reporting Requirements

12.1 PCP states in part:

The Radioactive Effluent Release Report, submitted in accordance with Technical Specification 5.6.3, shall include a summary of the quantities of solid radwaste released from the units, as outlined in Regulatory Guide 1.21 Rev 2.

3.2 Solid Waste Data

Regulatory Guide 1.21 Rev 2, Table 3 is found in this report as Table 3-1. GEL Laboratories performs hard-to-detect analysis for solid waste. Final calculations for nuclides include sample analysis performed on resin from High Integrity Containers. For Gaseous and Liquid composites, the Georgia Power Environmental Laboratory performs hard-to-detect analysis.

Table 3-1
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT AND WASTE DISPOSAL REPORT - 2014
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

JANUARY 1, 2014 THROUGH JUNE 30, 2014

Regulatory Guide 1.21: Effluent and Waste Disposal Semi-Annual Report of Solid Waste and Irradiated Fuel Shipments

PERIOD COVERED: FROM: 1/1/2014 TO: 6/31/2014 FOR UNIT: C (Common U-1 and U-2)

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1.	Type of waste (NRC Waste Class B)	UNIT	6 month period	Est. Total ERROR %
a.	Spent resins, filter sludges, evaporator bottoms, etc. None	m ³	2.69	+/- 25
		Ci	7.47E+1	+/- 25
b.	Dry compressible waste, contaminated equip. etc.	m ³	N/A	N/A
		Ci	N/A	N/A
c.	Irradiated components, control rods, None	m ³	N/A	N/A
		Ci	N/A	N/A
d.	Control Rod Drive Filters None	m ³	N/A	N/A
		Ci	N/A	N/A
e.	Other (describe) equip. etc	m ³	N/A	N/A
	Steam Generator Blow Down Resin (GIC)	Ci	N/A	N/A

1.	Type of waste (NRC Waste Class A)	UNIT	6 month period	Est. Total ERROR %
a.	Spent resins, filter sludges, evaporator bottoms, etc. None	m ³	N/A	N/A
		Ci	N/A	N/A
b.	Dry compressible waste, contaminated equip. etc.	m ³	3.00 E2	+/- 25
		Ci	1.07	+/- 25
c.	Irradiated components, control rods, None	m ³	N/A	N/A
		Ci	N/A	N/A
d.	Control Rod Drive Filters None	m ³	N/A	N/A
		Ci	N/A	N/A
e.	Other (describe) equip. etc	m ³	1.84 E1	+/- 25
	Steam Generator Blow Down Resin (GIC)	Ci	1.96 E-3	+/- 25

2. Estimate of major nuclide composition (by type of waste)

Waste Class B			
	ISOTOPE	PERCENT	CURIES
a	C-14	0.047	3.49E-02
	Mn-54	0.490	3.66E-01
	Fe-55	6.339	4.73E+00
	Co-57	0.039	2.89E-02
	Co-58	0.000	2.07E-04
	Co-60	31.976	2.39E+01
	Ni-59	0.421	3.14E-01
	Ni-63	51.810	3.87E+01
	Zn-65	0.040	2.97E-02
	Sr-90	0.003	2.23E-03
	Tc-99	0.001	1.07E-03
	Sb-125	0.322	2.41E-01
	Cs-134	2.189	1.63E+00
	Cs-137	6.323	4.72E+00
b.	N/A	N/A	N/A
c.	N/A	N/A	N/A
d.	N/A	N/A	N/A
e.	N/A	N/A	N/A

Waste Class A			
	ISOTOPE	PERCENT	CURIES
a.	N/A	N/A	N/A
b.	H-3	0.256	2.74 E-3
	C-14	0.058	6.22 E-4
	Cr-51	6.959	7.44 E-2
	Mn-54	3.491	3.73 E-2
	Fe-55	10.505	1.12 E-1
	Fe-59	0.437	4.67 E-3
	Co-57	0.231	2.47 E-3
	Co-58	44.817	4.79 E-1
	Co-60	20.602	2.20 E-1
	Ni-63	4.838	5.17 E-2
	Zn-65	0.427	4.56 E-3
	Sr-90	0.012	1.26 E-4
	Zr-95	2.399	2.56 E-2
	Nb-95	3.836	4.10 E-2
	Sn-113	0.248	2.65 E-3
	Sb-125	0.446	4.76 E-3
	Cs-134	0.110	1.18 E-3
	Cs-137	0.327	3.49 E-3
c.	N/A	N/A	N/A
d.	N/A	N/A	N/A
e.	H-3	0.394	7.72 E-6
	C-14	0.091	1.78 E-6
	Cr-51	1.851	3.62 E-5
	Mn-54	4.568	8.94 E-5
	Fe-55	15.472	3.03E-4
	Fe-59	0.216	4.23 E-6
	Co-57	0.295	5.77E-6
	Co-58	33.222	6.50 E-4
	Co-60	31.174	6.10 E-4
	Ni-63	7.522	1.47 E-4
	Zn-65	0.532	1.04E-5
	Sr-90	0.018	3.56 E-7
	Zr-95	1.651	3.23 E-5
	Nb-95	1.429	2.80 E-5
	Sn-113	0.243	4.75 E-6
	Sb-125	0.657	1.29 E-5
	Cs-134	0.159	3.12 E-6
	Cs-137	0.506	9.91 E-6

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
1	Hittman Transport	Energy Solutions Barnwell Processing Facility
6	Hittman Transport	Energy Solutions Bear Creek
1	Tri-State Motor Transit	Energy Solutions Gallhear Rd
7 total		

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

TABLE 3-1
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 2014
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

JULY 1, 2014 THROUGH DECEMBER 31, 2014

Regulatory Guide 1.21: Effluent and Waste Disposal Semi-Annual Report of Solid Waste and Irradiated Fuel Shipments

PERIOD COVERED: FROM: 7/1/2014 TO: 12/31/2014 FOR UNIT: C (Common U-1 and U-2)

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1.	Type of waste (NRC Waste Class A)	UNIT	6 month period	Est. Total ERROR %
a.	Spent resins, filter sludges, evaporator bottoms, etc.	m ³	N/A	N/A
		Ci	N/A	N/A
b.	Dry compressible waste, contaminated equip. etc.	m ³	1.79 E+2	25
		Ci	9.08E-1	25
c.	Irradiated components, control rods, None	m ³	N/A	N/A
		Ci	N/A	N/A
d.	Control Rod Drive Filters None	m ³	N/A	N/A
		Ci	N/A	N/A
e.	Other (describe) equip. etc. Steam Generator Blow Down Resin (GIC)	m ³	9.27 E+1	25
		Ci	2.79 E-2	25

2. Estimate of major nuclide composition (by type of waste)

	ISOTOPE	PERCENT	CURIES
a.	N/A	N/A	N/A
b.	H-3	0.001	1.09E-05
	CR-51	0.000	2.14E-07
	Mn-54	0.610	5.54E-03
	FE-55	20.125	1.83E-01
	Co-57	0.053	4.84E-04
	Co-58	6.033	5.48E-02
	Co-60	36.362	3.30E-01
	Ni-63	34.916	3.17E-01
	SR-90	0.000	1.89E-07
	Zr-95	0.475	4.31E-03
	Nb-94	0.000	2.40E-08
	Nb-95	0.900	8.18E-03
	Sn-113	0.000	5.59E-08
	Sb-124	0.000	4.75E-08
	Sb-125	0.000	1.03E-06
	Cs-134	0.000	8.07E-07
	Cs-137	0.524	4.76E-03
	Ce-144	0.000	5.85E-08
c.	N/A	N/A	N/A
d.	N/A	N/A	N/A
e.	Mn-54	0.509	1.42E-4
	Fe-55	19.713	5.50E-3
	Co-57	0.043	1.21E-5
	Co-58	3.553	9.91E-4
	Co-60	37.282	1.04E-2
	Ni-63	37.623	1.05E-2
	Zr-95	0.273	7.61E-5
	Nb-95	0.444	1.24E-4
	Cs-137	0.560	1.56E-4

3. Solid Waste Disposition

	<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
	5	Truck	Energy Solutions Bear Creek Road
	5	Truck	Energy Solutions Gallaher
B.	IRRADIATED FUEL SHIPMENTS (Disposition)		
	<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
	None	N/A	N/A

4.0 Doses to Members of the Public inside the Site Boundary

4.1 Regulatory Requirements

ODCM 7.2.2.3 states in part:

"The report shall also include assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY during the report period; this assessment must be performed in accordance with Chapter 6. All assumptions used in making these assessments (i.e., specific activity, exposure time, and location) shall be included in the report".

4.2 Demonstration of Compliance

The location of concern within the site boundary is the Visitors Center. The activities at the Visitor Center consist of occasional attendance at meetings and/or short visits for informational purposes.

There will be no radiation dose at this location due to radioactive liquid effluents. Delineated in Table 4-1 for this location are the values of the basic data assumed in the dose assessment due to radioactive gaseous effluents. Listed in this table are distance and direction from a point midway between the center of Unit 1 and the Unit 2 reactors, the dispersion and deposition factors for any releases from the plant vent (mixed mode) and from the turbine building (ground level), and the estimated maximum occupancy factor for an individual and the assumed age group of this individual.

The source term is listed in Tables 2-2A, and 2-2B for the mixed mode releases. Similarly, it is listed in tables 2-3A and 2-3B for the ground level releases.

The maximum doses in units of mrem to a MEMBER OF THE PUBLIC due to their activities inside the site boundary during the reporting period are presented in Table 4-1.

Table 4-1
Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Doses to a Member of the Public Due to Activities Inside the Site Boundary

Unit: Site

Starting: 1-Jan-2014

Ending: 31-Dec-2014

Location Name: Visitor's Center Receptor
Distance (kilometers): 4.47E-01
Sector: SE
Occupancy Factor: 4.57E-04

Age Group: Child

Mixed Mode Release	Noble Gas	X/Q (sec/m3): 7.12E-07	
Ground Level Release	Noble Gas	X/Q (sec/m3): 5.93E-06	
Mixed Mode Release	Particulate and Radioiodine	X/Q (sec/m3): 6.74E-07	D/Q (m-2): 5.77E-09
Ground Level Release	Particulate and Radioiodine	X/Q (sec/m3): 5.58E-06	D/Q (m-2): 2.28E-08

	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year
Total Body	mRem	1.05E-09	2.03E-09	3.41E-09	2.25E-09	8.74E-09
Liver	mRem	1.05E-09	2.03E-09	3.41E-09	2.25E-09	8.74E-09
Lung	mRem	1.05E-09	2.03E-09	3.41E-09	2.25E-09	8.74E-09
GI-Lli	mRem	1.05E-09	2.03E-09	3.41E-09	2.25E-09	8.74E-09
Skin	mRem	7.54E-18	0.00E+00	1.37E-13	4.68E-13	6.05E-13
Thyroid	mRem	1.05E-09	2.03E-09	3.43E-09	2.29E-09	8.79E-09
Bone	mRem	4.48E-13	6.62E-13	5.03E-13	5.11E-13	2.12E-12
Kidney	mRem	1.05E-09	2.03E-09	3.41E-09	2.25E-09	8.74E-09

Table 4-1

**Vogtle Electric Generating Plant
RADIOACTIVE EFFLUENT RELEASE REPORT - 2014
Doses to a Member of the Public Due to Activities Inside the Site Boundary**

Unit: Site

Starting: 1-Jan-2014

Ending: 31-Dec-2014

Location Name: Units 3&4 Construction
Distance (kilometers): 4.83E-01
Sector: SW
Occupancy Factor: 2.37E-01

Age Group: Adult

Mixed Mode Release	Noble Gas	X/Q (sec/m3): 9.75E-07	
Ground Level Release	Particulate and Radioiodine	X/Q (sec/m3): 6.96E-06	D/Q (m-2): 2.88E-08
Ground Level Release	Noble Gas	X/Q (sec/m3): 1.81E-05	
Mixed Mode Release	Particulate and Radioiodine	X/Q (sec/m3): 9.17E-07	D/Q (m-2): 7.14E-09

	Units	1ST Quarter	2ND Quarter	3RD Quarter	4TH Quarter	Year
Liver	mRem	8.69E-07	1.62E-06	2.99E-06	1.80E-06	7.28E-06
Lung	mRem	8.70E-07	1.62E-06	2.99E-06	1.80E-06	7.28E-06
Bone	mRem	3.04E-10	4.60E-10	3.31E-10	2.94E-10	1.39E-09
Total Body	mRem	8.69E-07	1.62E-06	2.99E-06	1.80E-06	7.28E-06
Skin	mRem	4.85E-15	0.00E+00	8.79E-11	3.01E-10	3.89E-10
Thyroid	mRem	8.69E-07	1.62E-06	3.00E-06	1.82E-06	7.31E-06
GI-Li	mRem	8.69E-07	1.62E-06	2.99E-06	1.80E-06	7.28E-06
Kidney	mRem	8.69E-07	1.62E-06	2.99E-06	1.80E-06	7.28E-06

5.0 Total Dose from Uranium Fuel Cycle (40CFR190)

5.1 Regulatory Requirements

ODCM 5.1 states in part that the annual (calendar year) dose or dose commitment to any MEMBER OF THE PUBLIC due to releases of radioactivity and to radiation from uranium fuel cycle sources shall be limited to less than or equal to 25 mrems to the whole body or to any organ, except the thyroid, which shall be limited to less than or equal to 75 mrems.

5.2 Demonstration of Compliance

No dose limits stated in ODCM Sections 2.1.3, 3.1.3, and 3.1.4 were exceeded. Therefore, compliance with 40 CFR 190 dose limits was demonstrated in accordance with the requirements of ODCM Section 5.1.3.

6.0 Meteorological Data

ODCM 7.2.2.2 states in part:

The Radioactive Effluent Release Report shall include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing of wind speed, wind direction, atmospheric stability, and precipitation (if measured) on magnetic tape; or in the form of joint frequency distributions of wind speed, wind direction and atmospheric stability.

In lieu of submission with the Radioactive Effluent Release Report, the licensee has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

7.0 Program Deviations

7.1 Inoperable Liquid or Gaseous Effluent Monitoring Instrumentation

7.1.1 Regulatory Requirement

ODCM 7.2.2.6 states in part that the report shall include deviations from the liquid and gaseous effluent monitoring instrumentation operability requirements included in Sections 2.1.1 and 3.1.1, respectively. The report shall include an explanation as to why the inoperability of liquid or gaseous effluent monitoring instrumentation was not corrected within the specified time requirement.

7.1.2 Description of Deviations

(1) The inoperability of liquid and gaseous effluent monitors not corrected within the specified time for this reporting period is detailed below. When applicable, compensatory measures were utilized per ODCM Action Statements:

a. 1RE-0018

This monitor was out of service greater than 30 days due to manpower challenges. A refueling outage was in progress during the same timeframe. The monitor has been returned to service.

b. 1RE-12839

Equipment repair required bypass of steam packing exhaust and steam jet air ejector filters. The monitor was out of service due to having no sample flow. It is not required due to no indications of primary-to-secondary leakage. Additionally, there were 4 other radiation monitors that could provide indication of primary-to-secondary leakage during repair. Sample flow has been restored and the monitor is in service.

c. 2RE-12442

This monitor was out of service greater than 30 days due to an upgrade of the monitor. A redundant radiation monitor and auxiliary monitoring remained in service during most of the replacement duration*. The monitor has been returned to service.

(2) *A Green self-revealing NCV of TS 5.5.4, "Radioactive Effluent Controls Program," was identified for the licensee's failure to maintain continuous monitoring of the minimum required channels on the Unit 2 plant vent radiation monitors and failure to implement the required compensatory measures as required by the ODCM between March 16 and March 26, 2014.

During the period both monitors were inoperable there were no unplanned releases and all planned releases were within regulatory limits. Releases from the waste gas decay system and Unit 2 containment are planned, sampled, permitted, and monitored by another set of radiation monitors prior to release. In addition, radiation monitors installed throughout the auxiliary building would have provided an indication of any elevated airborne conditions indicative of an unplanned release. During the period that both monitors were out of service, dose to the public was determined from two Unit 2 containment releases.

Causal analysis was performed and corrective actions were created to prevent reoccurrence.

7.2 Tanks Exceeding Curie Content Limits

7.2.1 Regulatory Requirements

ODCM 7.2.2.6 states in part that the report shall include a description of the events leading to liquid holdup tanks or gas storage tanks exceeding the limits of Technical Specifications 5.5.12.

7.2.2 Description of Deviations

Limits for outdoor liquid hold-up tanks used for radioactive liquids were not exceeded during this reporting period.

Limits for the gas storage tanks were not exceeded during this reporting period.

8.0 Changes to the Vogtle Electric Generating Plant Offsite Dose Calculation Manual (ODCM)

8.1 Regulatory Requirements

ODCM 7.2.2.5 states in part that changes to the ODCM shall be submitted with the Radioactive Effluent Release Report. These changes may be due to changes in the radiological environmental monitoring program sampling locations as required by ODCM 4.1.1.2.3 or changes to dose calculation locations as required by ODCM 4.1.2.2.2. Land uses and dose calculation locations within five miles of VEGP must be determined by a land use census as required by ODCM 4.1.2.

8.2 Description of Changes

There were no changes made to the VEGP ODCM in 2014.

9.0 Major Changes to Liquid, Gaseous, or Solid Radwaste Treatment Systems

9.1 Regulatory Requirements

ODCM 7.2.2.7 states in part:

As required by Sections 2.1.5 and 3.1.6, licensee initiated MAJOR CHANGES TO RADIOACTIVE WASTE TREATMENT SYSTEMS (liquid and gaseous) shall be reported to the Nuclear Regulatory Commission in the Radioactive Effluent Release Report covering the period in which the change was reviewed and accepted for implementation.

Note 1: In lieu of inclusion in the Radioactive Effluents Release Report, this same information may be submitted as part of the annual FSAR update.

PCP 12.1 states in part:

Licensee major initiated changes to the solid radioactive waste treatment system shall be reported to the Nuclear Regulatory Commission in the Radioactive Effluent Release Report for the period in which the change was implemented.

9.2 Description of Major Changes

Gaseous Radwaste System

There were no major changes to the gaseous radwaste systems in the 2014 assessment period.

Liquid Radwaste System

There were no major changes to the liquid radwaste systems occurred during the 2014 assessment period.

Solid Radwaste System

There were no major changes to the solid radwaste systems in the 2014 assessment period.