## Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Fukushima Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, March 19, 2015

Work Order No.: NRC-1453 Pages 1-188

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1	NITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + +
7	FUKUSHIMA SUBCOMMITTEE
8	+ + + +
9	THURSDAY
10	MARCH 19, 2015
11	+ + + +
12	ROCKVILLE, MARYLAND
13	+ + + +
14	The Subcommittee met at the Nuclear
15	Regulatory Commission, Two White Flint North, Room
16	T2B1, 11545 Rockville Pike, at 1:00 p.m., Stephen
17	Schultz, Chairman, presiding.
18	
19	
20	
21	
22	
23	
24	
25	

1	COMMITTEE MEMBERS:
2	STEPHEN P. SCHULTZ, Chairman
3	RON BALLINGER, Member
4	SANJOY BANERJEE, Member
5	DENNIS C. BLEY, Member
6	CHARLES H. BROWN, JR. Member
7	MICHAEL CORRADINI, Member *
8	DANA A. POWERS, Member
9	JOY REMPE, Member
10	PETER RICCARDELLA, Member *
11	MICHAEL T. RYAN, Member
12	GORDON R. SKILLMAN, Member
13	JOHN W. STETKAR, Member
14	
15	ACRS CONSULTANT:
16	WILLIAM SHACK
17	
18	DESIGNATED FEDERAL OFFICIAL:
19	MICHAEL SNODDERLY
20	
21	
22	
23	
24	
25	

1	ALSO PRESENT:
2	CLINTON ASHLEY, NRC
3	ERIC BOWMAN, NRC
4	DAVID DESAULNIERS, NRC
5	BRYAN FORD, NEI
6	ED LYMAN, Union of Concerned Scientists *
7	ANDREW MALLER, NEI*
8	JOHN McKIRGAN, NRC
9	JOHN MONNINGER, NRC
10	ABI MOHSENI, NRC
11	TIM REED, NRC
12	GEORGE TARTAL, NRC
13	WILLIAM WEBSTER, Dominion
14	BILL WILLIAMSON, AGA* *
15	DAVID YOUNG, NEI
16	
17	*Present via telephone
18	
19	
20	
21	
22	
23	
24	

## AGENDA Opening Remarks and Objectives.....5 Draft Proposed Rule for Mitigation of Beyond-Design-Basis Events......10 Draft Proposed Rule for Mitigation of Beyond-Design-Basis Events......120 Industry Comments on Proposed Rule NGO Comments on Proposed Rule Language and Bases.....

1 PROCEEDINGS 2 1:00 p.m. CHAIR SCHULTZ: Good 3 afternoon. This 4 meeting will now come to order. This is a meeting of the 5 Advisory Committee on Reactor Safeguards, Subcommittee on Fukushima. 6 7 I'm Stephen Schultz, Chairman of the 8 Subcommittee. Members in attendance today are Dick 9 Skillman, Dennis Bley, John Stetkar, Mike Ryan, Ron 10 Ballinger, Charlie Brown, and Joy Rempe. 11 Riccardella is attending on the telephone today, and 12 there may be other Members that will join us later. We also have former ACRS Chairman, Dr. Bill Shack in 13 14 attendance today participating as our consultant on 15 this matter. 16 The purpose of today's meeting is to review 17 the Draft Proposed for Mitigation Rule of 18 Beyond-Design-Basis the associated Events and 19 supporting documents and guidance prepared by the 20 Staff. We have had several meetings with the Staff on 21 this topic and look forward to discussions on their 22 progress and the results and products that they're going 23 to present today.

being conducted in accordance with the provisions of the

This meeting is open to the public. It's

24

Federal Advisory Committee Act. Rules for the conduct of and participation in this meeting have been published in the Federal Register as part of the notice for this meeting.

The Subcommittee intends to gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Mr. Michael Snodderly is the Designated Federal Official for this meeting.

A transcript of the meeting is being kept and will be made available, as stated in the Federal Register Notice. Therefore, we request that participants in this meeting use the microphones located throughout the meeting room when addressing the Subcommittee. All participants should first identify themselves and speak with sufficient clarity and volume so that they may be readily heard.

We have received no written comments or specific requests for time to make oral statements from members of the public regarding today's meeting. I understand that there are individuals on the bridge line today who are listening in on today's proceedings. To effectively coordinate their participation in this meeting we will be placing the incoming bridge line on

1 mute so that those individuals may listen in. At the 2 appropriate time later in the meeting we will provide the opportunity for public comments from the bridge line 3 and for members of the public in attendance. 4 5 I'd like to remind us all to turn off our cell phones and communication devices so there's no 6 7 interruption during the meeting. 8 We'll now proceed with the meeting, and I'd 9 like to call upon Aby Mohseni of the Office of NRR to 10 open the presentations today. Aby. 11 MR. MOHSENI: Thank you very much, 12 Schultz, and good afternoon. My name is Aby Mohseni, and I am the Deputy Director of the Division of Policy and 13 Rulemaking in the Office of Nuclear Reactor Regulation. 14 15 Today we will discuss the Proposed 16 Mitigation of Beyond-Design-Basis Rulemaking. We are 17 todav to engage with the ACRS Fukushima 18 Subcommittee in support of your review of the Proposed 19 MBDBE Rulemaking package. We are seeking ACRS 20 endorsement for issuance of the proposed rule package 21 for public comment. The ACRS Full Committee will meet 22 on April 9th on this same topic. 23 In terms of ACRS support for issuance of the 24 proposed MBDBE rulemaking, our view is that the proposed

rule needs to be sufficient to support informed external

feedback such that the NRC using that feedback can produce a good final product.

Accordingly, you will find that this proposed rule package seeks external feedback on a number of issues for which the NRC expects such a feedback to be key in reaching a final decision. And, of course, we will always find that external stakeholder's feedback improves our rulemaking, and we certainly expect that to occur again for the proposed MBDBE rulemaking.

To support this presentation, I have several members of NRR and from NRO. Tim Reed from our Staff will be leading the discussion of the proposed rulemaking. Tim will focus on the proposed rule language. Supporting Tim as the Lead Technical Expert in mitigation strategies is Eric Bowman from the Japanese Lessons Learned Division. Eric will focus on the supporting draft regulatory guidance. From NRO we have Clint Ashley who will also support the discussion of the draft regulatory guidance; the portions of 13-01 that would be applicable to new reactors.

We also NRO support at the side table. George Tartal will support Tim with regards to the aspects of the proposed rule language that apply to new reactors. There are other members from the Mitigation

of Beyond-Design-Basis Events Rulemaking Working Group in attendance to support questions from the Committee.

We last met with the Subcommittee on November 21, 2014, followed by a Full Committee meeting in December 2014. And since that time, there have been a few changes to the rule language, but in large measure the language has not changed substantially. Our plan today is to walk through the proposed language reasonably quickly and note where the language has changed. Our intent is to provide the maximum time to the ACRS Subcommittee to discuss the parts of this package that ACRS has not seen to date with the focus being on the draft guidance.

We want to thank the ACRS for its flexibility and patience in supporting the Staff with our efforts to provide the materials for the Committee. As the ACRS knows, we are on an aggressive schedule, and we are doing quite a bit in parallel that would normally occur in series.

This rulemaking has been a collaborative effort with several offices, as rulemakings always are, but in this case the Japanese Lessons Learned Division in NRR has been a major player as this rulemaking is addressing many post-Fukushima regulatory actions the JLLD is currently addressing. I will now turn it over

to Tim.

MR. REED: Thanks, Aby. I'm Tim Reed. As Aby just mentioned, I'm the Lead Project Manager for the Mitigation of Beyond-Design-Basis Events Proposed Rulemaking, and I'll walk through the language and give the ACRS an opportunity to walk through to feel free to question, provide questions, comments, whatever you want; and, of course, any time you want.

My intent was to focus on the areas that I think are substantively new but you, of course, can stop me wherever you want. You have at your disposal a lot more information than we previously provided; namely, the Statement of Considerations that supports this language, as well as all the supporting analyses, Draft Reg Guides, what have you. So, with that information it may, in fact, generate a lot more comments and interactions regardless of whether you've seen that language before.

So with that, I'll go to the background slide. There's really nothing new in terms of the background that you haven't heard before, but I think it always goes B- it's a good thing to let stakeholders who are listening into this, maybe haven't heard this before; what this rulemaking is about, how it came to be. It's quite a large rulemaking in terms of its scope,

it has effectively the consolidation of rulemakings, as this Committee is certainly well aware, the Station Blackout Mitigation Strategies rulemaking, and the Onsite Emergency Response Capabilities rulemaking. Those were combined into what we're calling the Mitigation of Beyond-Design-Basis rulemaking, and it goes to addressing a fairly large number of Near-Term Task Force recommendations, and you see the list there. Essentially, all of 4, 7, and 8, as well as 9.1, 9.2., 9.3.

You've seen this list before. Basically, these are elements that have been implemented as part of the Mitigation Strategies Order, collectively with that order. In addition, we're also cleaning up the ERDS language to effectively align with what is in place now, so it doesn't refer to any technology.

And before I go a whole lot further again, this is for folks who may not have been involved with this to date. It's always important to mention that in terms of safety, the orders B- most importantly, the Mitigation Strategies order issued on March 12th of 2012 has been out there for quite a long time, and it's being implemented right now. I think if folks didn't know that they would say what is this? You know, here we are in March of 2015; this event is from four years ago, but

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

the fact is the Agency, the industry has been working very hard, obviously; a huge amount of changes going on, and Lessons Learned from Fukushima, mitigation strategies, and other post-Fukushima regulatory activities that you see there.

And as Aby mentioned, many of these are coming into this rulemaking. We're making those generically applicable; although, we plan to, or we proposed to make those generically applicable in the Code of Federal Regulations.

So, in addition to this, I would also mention that because of B- there's actually six potentially for rulemakings that also did address it as part of this rulemaking effort, and that's because those six petitions relied solely on the Near-Term Task Force report, and in each case those Near-Term Task Force recommendations are being addressed in this rulemaking, so it logically follows that this rulemaking will also address those petitions. So, it's quite a large effort that's scoped in, and I think it's important just to remind everybody of the scope of the rulemaking.

MEMBER STETKAR: Before you get to the B- into the language of the rule, I've got a few issues with the Statements of Considerations, because I hadn't read through those before. I'm not even sure we had them

before.

First comment is that there is a woefully misleading statement regarding ACRS, and it's in the Scope of Proposed SAMG Requirements. It happens to be on page B- it's in a footnote. It happens to be on page 28, at least in my copy. Just to read it on the record, the discussion says, "As part of the NRC's efforts to develop the backfitting justification for imposition of SAMG requirements, it sought to make use of any applicable quantified risk information that might help to inform the justification.

In this regarding, the NRC looked at its recent technical analysis work performed in support of the containment protection and release reduction CPRR Rulemaking Regulatory Basis." And there's a footnote, and the footnote says, "The technical" B- there's a word missing, "was presented to the ACRS Subcommittee on August 22nd, 2014," and there's an ADAMS reference, "And November 19th, 2014," and an ADAMS reference.

If I'm a member of the public reading this, the implication I get is that the ACRS endorsed that.

(A) The ACRS did not endorse it. It was presented to a Subcommittee. And (B) the Subcommittee had tremendous problems with that technical analysis. Please remove that footnote, period. I'm now speaking as the Chairman

of the ACRS, not a member. That is a completely misleading reference to ACRS.

MR. REED: Okay.

MEMBER STETKAR: I've got real problems with the way you refer to those technical analyses for the CPRR as evidence that SAMGs don't improve risk. You explicitly make those statements. Now, those analyses were done to look at the net risk-benefit to public health and safety of installing a filter on a hardened vent for boiling water reactors with Mark 1 and Mark 2 containments. They did not evaluate the effectiveness of SAMG actions. They only looked at the effectiveness of that filter; and, yet, you draw a conclusion that says based on that analysis, it looks like, you know, SAMGs won't really affect plant safety. But then you go on and say well, we have other qualitative reasons of doing this, and things like that.

I have no problems with the qualitative stuff, but to point to that limited, and in my opinion very flawed technical analysis to say that that B- the NRC can draw a conclusion that SAMGs in total for any plant in the country, for any set of accidents do not improve risk, is B- this is now my personal opinion, not as Chairman of the ACRS, misleading at best. Okay?

And the third place where you're misleading

is when you discuss the rationale for not including what you call firefighting procedures or firefighting strategies and procedures under the scope of the procedures that's included in this integration. And you're very careful to talk about these as firefighting strategies and procedures, and the rationale looks at fire brigade actions and things like that.

You say that this was discussed with the ACRS during the regulatory basis development. Indeed, it was discussed with us. We recommended that the fire response procedures, which are not firefighting procedures, they don't tell you how to put a fire out. They do tell you about things like oh, disconnecting power supplies to a large fraction of your plant, sending operators out to do local things in the plant that they wouldn't normally do, abandoning the main control room. Those operational aspects of those procedures are what our concerns were, not how one might go mobilize the fire brigade to go put water or gas on a fire.

Indeed, we have actual operating experience that shows people can get confused when they're in both the EOPs and the fire response procedures simultaneously. And, indeed, that confusion can cause them to overlook things that are important to

1	plant safety because they're focusing, perhaps, more on
2	the fire response procedure rather than on other
3	indications. So, I'd suggest that you may want to look
4	at the way that those procedures are characterized as
5	fire fighting procedures, and develop a better
6	rationale for why this procedure integration ought not
7	to include the fire response procedures, which are
8	different. I'm done. I don't know if you want to respond.
9	Those are the three things that I B-
10	MR. REED: Well, we'll certainly touched
11	upon the SAMG B-
12	MEMBER STETKAR: B- had reading through B-
13	MR. REED: B- stuff some more later. And we
14	can B- I'm sure we'll revisit that. I can give you the
15	thoughts, anyway.
16	MEMBER STETKAR: Yes.
17	MR. REED: And then we can talk about that,
18	and I don't know if you want to talk B- if anyone B-
19	MEMBER STETKAR: That's strictly from the
20	Statement of Discussions because, you know, you never
21	said that reflected B-
22	MR. REED: Yes, and that's B-
23	MEMBER STETKAR: B- the rule language.
24	That's why I wanted to B-
25	MR. REED: Well, we can address that

	17
1	throughout, or however you want to do it.
2	CHAIR SCHULTZ: No, I think we should wait
3	on that B-
4	MR. REED: Okay.
5	CHAIR SCHULTZ: B- because I think it's
6	worthy of further discussion B-
7	MR. REED: Absolutely.
8	CHAIR SCHULTZ: B- a broader discussion
9	than this.
10	MR. REED: Absolutely. Appreciate that. So,
11	can we go to the next slide where we actually get into
12	the substance of this?
13	MEMBER STETKAR: Yes.
14	MR. REED: All right, sir. Okay. So, the way
15	the rule is structured is first, in Paragraph A we have
16	an applicability paragraph there. Again, as the
17	Committee should be aware, this applies to power
18	reactors both operating, as well as new applications.
19	And, in fact, we actually have decommissioning
20	provisions in here, so we've built in that so it applies
21	to whether you're in decommissioning or at power, as
22	well as a new applicant. So, again, that's no change.
23	You'll see that we have, in fact, updated our
24	decommissioning provisions to reflect exactly what

we've been doing here recently, as you'll see in a

second.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

This Committee was B- we were provided B- I think November 21st is the right date for Subcommittee meeting. We did discuss new design features requirements at that Committee. Those have changed slightly. We have a slide on that, on Slide 7. And at that point, I think we'll wait B- we can wait, if you will. George Tartal in NRO can address that slide B- that issue on Slide 7, but I just simply note that in November we had an assessment feature, if you will, in those design feature requirements, and now it's simply, basically, about design features and building that into the design of your facility for new reactor designs such that you enhance scoping capability and lessen reliance on human action. So, again, that will be addressed. We have a slide on that, on Slide 7.

The decommissioning provisions actually just reflect what we've recently done for Oconee and San Onofre 2 and 3, Vermont Yankee, and Crystal River, so it looks like a lot, but it's actually completely status quo there, is what we've done. It reflects how we've been treating mitigation strategies when the licensee goes into decommissioning, how we're relieving those requirements. So, the idea here is simply B- it's good rulemaking practice. I'm trying to build into the

rule decommissioning provisions to helpfully facilitate that process of decommissioning. I'm sure this Committee is well aware, this is a issue of pretty high importance right now to the Commission, so this is really building that in. So, again, it's fairly similar, you know.

Once the fuel is removed from the reactor and goes to the spent fuel pool, obviously, it doesn't make sense to apply the mitigation strategies and quidelines that apply to the reactor source term, so what you do is remove anything doing with core cooling the reactor, of course, or primary reactor containment. And your focus goes to the spent fuel pool. And then whatever period of time is needed to basically conclude that your decay heat in your spent fuel pool is low enough that your boil off happened long enough giving you plenty of time to take out action. Then you basically the can now remove remaining Beyond-Design-Basis External-type mitigation strategies and it leaves you with the so called B5B or 50.54(hh)(2) mitigation strategies. And those are now, as you'll recall, they are now what would be proposed 155(b)(2). And that's because the nature of those events involve kinetic energy being added to the spent fuel pool, and that's why those stay in place until the fuel

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

is completely removed from the spent fuel pool.

Again, if you look through the SAMG considerations you'll see that discussion there. This is in alignment with what we've been recently doing. We're not carving any new territory here. This is trying to reflect that and do basically good rulemaking in terms of decommissioning.

CHAIR SCHULTZ: In that regard, Tim, in terms of the decay heat once it's sufficiently low in the spent fuel pool, in the section there's discussion related to one reactor, a specific reactor that has been shut down for a very long time. And it wasn't clear to me whether you were trying to incorporate into the rule provisions for that one particular reactor, or whether you were using that as an example.

MR. BOWMAN: What we're doing, Dr. Schultz, with that one B- this is Eric Bowman. I'm the Staff Lead for the B5B requirements, as well as the Special Advisor for Japan Lessons Learned Division. That particular facility is a decommissioned reactor. It's the only one with fuel remaining in the spent fuel pool.

In 2005, we looked at the risk that was presented by the spent fuel that's remaining in that pool and concluded that it was sufficiently low remaining decay heat that the B5B requirements would not

1	need to be imposed on that particular facility.
2	CHAIR SCHULTZ: That particular reactor.
3	MR. BOWMAN: Well, spent fuel pool to be
4	precise.
5	CHAIR SCHULTZ: Okay.
6	MR. BOWMAN: Not the reactor, but the pool.
7	CHAIR SCHULTZ: Right.
8	MR. BOWMAN: The reactor would have been out
9	of the question, anyway, because it had already
10	decommissioned. We haven't got any information to show
11	any change, any substantial safety benefit that would
12	be accrued by imposing requirements on that licensee.
13	The counter is true for the remaining
14	reactors that have entered decommissioning. They had as
15	operating licensees the requirements imposed upon them
16	to develop and implement the strategies for their spent
17	fuel pools, and we concluded in the Power Reactor
18	Security Rulemaking in 2009 that those requirements
19	should remain in place until the fuel is removed from
20	the pools. So, we've constructed the wording of the
21	decommissioning provisions to carry that forward as we
22	move the B5B provisions, if you will, the 50.54(hh)(2)
23	provisions from Section 50.54 to Section 50.155.
24	CHAIR SCHULTZ: That clarifies the
25	distinction for me. Thank you.

MR. REED: Is there any other questions before we move on with this? Okay. Then we come to Paragraph B which I kind of view as the central piece to this entire proposed rulemaking. And this goes to the integrated response capability that we would require, develop and implement, maintain integrated response capability. It's this and the next slide run through this paragraph the way it's structured in the proposed requirements therein.

They're again substantially the same. It starts off with, of course, the mitigation strategies for Beyond-Design-Basis external events, what's known in the industry as FLEX. That's the first set of quidelines there. The second set of quidelines as we just mentioned are the extensive B- what are most commonly called the Extensive Damage Mitigation Guidelines. Those would be there, obviously, as we move 50.54(hh)(2) in those rule. Again, this is a loss large area due to explosions and fires. Then we have the only paragraph this that are not requirements. These are the Severe Accident Management Guidelines. Those, of course, go into place when you have the onset of core damage.

Those, as the Committee is well aware, are currently voluntary industry initiatives. This

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

proposed requirement, we are proposing to the Commission that those would be requirements. They would be restricted to the guidelines. It's intentionally designed to be the least amount of requirements for this set of guidelines that we think is necessary.

So, those are three guideline sets. That integrated with the currently existing would be symptom-based EOPs. We've structured the rule B- that's on the next slide. Before I go to it, I'll hold for a second, but we've structured it intentionally such that we don't go back and revisit the work from the 1980s, so we say these are structured with the EOPs. The intention is to leave the EOP work in place and not touch that. So, what we're trying to do is take these strategies and quidelines that were developed over different times and different places for different events and basically work those into something that becomes a lot more seamless in terms of an integrated capability. And it looks B- really, I think it's going in place largely in place, I mean, so this is really B- if you think about it, the FLEX strategies are being implemented right now connected into the EOPs, the Station Blackout EOP. The Extensive Damage Mitigation Guidelines are in place.

The SAMGs are voluntary B- are in place,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	but voluntary, but there are links, and so this would
2	really formalize that and make sure it's done, and a
3	complete and thorough job. So, that's the idea of this
4	integrated response capability.
5	This is basically the same as we presented
6	back in 2014. We haven't made any substantive changes
7	here since that B-
8	CHAIR SCHULTZ: I wanted to just clarify
9	that for the record, Tim, that what you have on the
10	slide, revised or unchanged B-
11	MR. REED: Yes.
12	CHAIR SCHULTZ: B- that you're talking
13	about what the Committee has heard previously.
14	MR. REED: That's correct.
15	CHAIR SCHULTZ: Not what this rule is doing.
16	MR. REED: Yes, right.
17	CHAIR SCHULTZ: The proposed rule is doing.
18	So, as you've described here in detail these are, in
19	fact, all changes that are being proposed with the rule.
20	MR. REED: Oh, absolutely. Sorry, it's
21	B- yes, this is entirely focused on the Committee and
22	trying to get you B- hopefully, help you focus attention
23	on the new stuff.
24	CHAIR SCHULTZ: Right.
25	MR. REED: That was the intent.

MR. BOWMAN: The one thing I would suggest clarifying B- this is Eric Bowman, again. The 50.54(hh)(2) movement from its current location to this particular section isn't going to be a change in the strategies, the B5B strategies that have already been in place, licensed, and reviewed. So, that will not be a substantive change. Otherwise, the statement you made about what the meaning of the unchanged is exactly correct.

CHAIR SCHULTZ: The statement at the bottom, "No additional equipment requirements for SAMGs."

MR. REED: Yes. The structures, as we get into it we can talk about this, and I'm sure we will based on the comments so far. The way we've structured the SAMG requirement is in light of what I think are B- I think our Work Group thinks are very informative risk information. And based on, in light of that what we tried to do is address what we've B- with a problem that was identified.

The problem that was identified post-Fukushima from the TI that showed that there was a range of conditions out there. When we went out and looked at what licensees had in place for the SAMGs, between people who have updated and kept those SAMGs

basically up to date and were in great shape, to folks that put something in place in say 1998 and just basically did not do a whole heck of a lot with them since then, so there's a range there. So, the concern was hey, these things aren't necessarily being maintained. They don't necessarily reflect the generic work by the industry and updating SAMGs over time, certainly couldn't reflect the most recent work here. And wouldn't necessarily be in alignment with the configuration of the facility and wouldn't reflect the new capabilities going in place under the Mitigation Strategies Order. So, that's the problem, if you will, and so putting requirements on SAMGs, the way we've structured it would certainly solve that problem. And that was what we were going after.

Now, in terms of going further than that, you know, in terms of saying should the Staff review and approve SAMGs on a generic basis or on a plant-specific basis, we backed off of that. And I'm sure you've read that. And the idea is that we don't think that's necessary, and level of regulatory assurance for this thing B- for this area. We think we can do this with inspection. And it basically would be a high-level inspection to make sure licensees have SAMGs, that they're in place, they're in Configuration Management,

they reflect new equipment, they're updated in accordance with the generic Owners Groups program, and new EPRI basis documents, the great work that's been done here in the last couple of years, and so that's the intent.

Of course, when I talked about SAMG requirements, I think it's in the backfit analysis. You'll see there's a footnote, and what I'm really saying there is that all the regulatory assurance, that in fact goes to that. And that includes drills that extend into core damage, that includes the change control that would apply to SAMGs, that includes training for SAMGs, so it's not B- it is the guideline set, but it's all the assurance requirements that support the guideline set so that you have sufficient assurance that, in fact, SAMGs are in place, and there's reasonable expectation that they can be implemented. But that's what we thought B- our view was B- our view is what is appropriate given what we understand to be the risk benefit from that.

Now, obviously, we think they're beneficial from a qualitative standpoint. I think there are very strong defense-in-depth arguments. Okay? But in terms of what I've extracted, I know Dr. Stetkar disagrees on this, but B-

1	MEMBER STETKAR: What I would ask is, has
2	the Staff B- I mean, the thing you refer to B-
3	MR. REED: Yes.
4	MEMBER STETKAR: B- is not a valid study of
5	the effectiveness of SAMGs.
6	MR. REED: Yes, it wasn't B- that's
7	correct.
8	MEMBER STETKAR: Has the Staff actually
9	tried to look at the effectiveness of SAMGs B-
10	MR. REED: Yes, I think B-
11	MEMBER STETKAR: B- in a quantitative sense
12	across pressurized water reactors, different plant
13	designs?
14	MR. REED: Yes, I think B- I tried to B-
15	MEMBER STETKAR: Not, you know, early
16	fatalities and cancer risk just because you can't
17	quantify anything else?
18	MR. REED: Yes, I fully understand that
19	wasn't directed to SAMGs. That's absolutely the truth.
20	What I tried to do is be risk-informed by that
21	information, okay, the best I can. And what I'm trying
22	to B- what we're trying to do with that information is
23	understand what could be the benefit for SAMGs using
24	that, so it's certainly a stretch.
25	MEMBER STETKAR: Give you a different

perspective from B- and I've been cautioned about not doing this, but I'll try to do it once. I've worked on risk assessments in Europe that are full scope Level 2 risk assessments that, indeed, have shown substantial risk benefit from severe accident management guidance to save the containment. Can't tell you about them because they're, you know, proprietary work that I worked on, so I know there's quantifiable benefit.

I doubt that the NRC has looked at that because the NRC does not have models or quantitative ability to look at those deltas. You typically don't have SPAR models that have detailed Level 2, and you certainly have not quantified Level 2-type human reliability. You didn't even do it in the thing you referred to. I won't call it a risk assessment. So, developing a blanket B- saying I looked at that thing B- in Europe when we looked at, for example, benefits of filters versus non-filtered vents on a boiling water reactor 30 years ago, it was clear that the filter didn't buy you any improvement in terms of offsite health benefit, and people have known that for long time. But that's not SAMGs, that's not an inference that I can say having SAMGs or not having SAMGs will have an effect on reducing risk to the health and safety of the public. And that's my real problem with

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	referring to that particular study and saying well, we
2	gained all of these tremendous insights from that thing
3	to say well, SAMGs are likely not to have much benefit,
4	because I can show you a study B-I can't.
5	Unfortunately, I can't show you the studies, but studies
6	have been done to show that they do.
7	MR. REED: Well, I'm certainly not aware of
8	that.
9	MEMBER STETKAR: It leaves people the wrong
10	B- the problem is it leaves people the wrong impression
11	because it says well, the NRC did some sort of risk
12	assessment work, and the conclusion B- and it's recent.
13	It's not stuff that's 30 years old. And the conclusion
14	from that is oh, there's likely not much quantitative
15	benefit, but we can develop a lot of qualitative
16	arguments which, by the way, are all very good.
17	MR. REED: Appreciate, at least B-
18	MEMBER STETKAR: The qualitative arguments
19	are all very good, but to explicitly say that we don't
20	have any B- you may not have any quantitative evidence.
21	MR. REED: I mean, I was trying to
22	extrapolate that, and you can B- I stand accused.
23	CHAIR SCHULTZ: Well, let me pile on a
24	little bit.
25	MR. REED: Okay.

CHAIR SCHULTZ: Because I do believe that the discussions associated with the reasons why the SAMGs are of safety benefit, those discussion B- that discussion is very good. I do get stuck when I see that the rationale for moving forward with this portion of the proposed rule is that B- the rationale is that we're using qualitative factors, or qualitative rationale. I think it should be quantifiable. I think it's clear that if you have a facility of these types, and you have the need for Severe Accident Management Guidelines, and you instill them into the operation of the facility, that there is a quantitative benefit. Let me say it differently. The inability, perhaps, for us not to be able to quantify at this time does not mean that all you have left is qualitative. MR. REED: I quess B-CHAIR SCHULTZ: It's just a matter expression, but it de-emphasizes the advantage and the benefit of the SAMGs, and all of this integrated response capability, and its benefit and need to move forward with the rule. Otherwise, you begin to lose the argument B-MR. REED: I think B-CHAIR SCHULTZ: B- that this is an important B-

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 MR. REED: Part of the problem is I think in 2 backfit space, and not necessarily in showing a change in benefit. I'm showing either adequate protection, 3 4 which is a very large change, or a substantial B- you 5 know, so I think in purely backfit, so that may be part 6 of the problem. 7 MEMBER STETKAR: No. Yes, I understand. 8 CHAIR SCHULTZ: Yes. 9 MEMBER STETKAR: I understand that 10 constraint. And quantitatively in the context of U.S. 11 backfit numerics, it's been a while since I looked at 12 the study. I honestly don't know B-13 MR. REED: Yes, and I B-14 MEMBER STETKAR: B- whether you trip over 15 B- on the other hand, I am absolutely confident that you 16 can show more benefit than was shown from that CPRR 17 little study. 18 MR. REED: Yes, I would agree with that, 19 too. I think you could show more if you did something 20 explicitly for SAMGs. Okay? But I'm thinking in my mind, 21 and I didn't provide it in this one, but in the last 22 presentation B- and I didn't want to provide it here. 23 I didn't want to get into a lot B- because I knew B- I 24 think is some sensitivity some of this information

because I was at that briefing, Dr. Stetkar, but I was

thinking about the more bounding number there, that was a full magnitude below the QHOs, if you recall. And, to me, that's B- you know, when you're 10 times below at a bounding level for a very B- for a type design that is amenable to actions after core damage, and there's lots you can do with the Mark 1 and Mark 2 there. To me, that is pretty good information that tells me that what I believe is B- everybody kind of expects that B- severe accident risk is very low. It's low as a function of all our regulations that drive core damage down, and it's low as a result of EP moving people out of harm's way. I mean, that shouldn't be surprising, but what was surprising to me was it was that low. And that's why in the backfit space I'm thinking I don't B- even if you spent the time and money to do it, I don't think we can make the level, if you will, show we can impose by quantitative measures.

MEMBER STETKAR: Don't hang up, though, on that one particular plant design, and the one particular issue for that one particular plant design. How much benefit do you get from piping an alternate cooling water supply to the containment fan coolers from a non-safety grade source of water to save the containment? That's a SAMG. I've seen it done. How much do you get from piping fire water into the containment

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

spray system? That's a SAMG. I know plants that have hooked it up, and I've seen the credit that you can get for that.

They have it in pressurized water reactors and they are not focused on this particular one issue for a boiling water reactor with a Mark 1 or Mark 2 containment. And that's the broader context of SAMGs.

MR. REED: Yes, I hear you. I mean, I'm not sure if I'm communicating well, but in each case if I'm going to get a lot of benefit for the circumstances, I think you're going to find that there's a power reactor there with a lot of risk there. For whatever reason, internal, external, probably external risk that there's substantial risk such that when I do that SAMG, I get a big benefit. So, yes, there would be a range across the board of different B- every plant is going to have a different risk, but for there to be a substantial change in severe accident risk, I think, you know, there's got to be some risk there.

And the first thing I would ask the people is if, in fact, you get to the point where you show SAMGs, let's say whatever plant it is, you show SAMGs get a very big return, I'm going to say let's come to a full stop. How did you get to that sequence? Is it better to stop upstream and address the issue before it goes to core

1	damage, if you follow what I'm saying.
2	MEMBER STETKAR: It's a difference in
3	perspective. Will it drop below some magic absolute
4	number, or will it drop the risk by a factor of 100?
5	MR. REED: Yes.
6	MEMBER STETKAR: A factor of 100, not
7	necessarily less than, you know, 1E to the minus 5 large
8	release frequency.
9	MR. REED: Exactly.
10	MEMBER STETKAR: But gain a factor of 100 on
11	perhaps a lower value than that.
12	MR. REED: Yes.
13	MEMBER STETKAR: But a factor of 100, to me,
14	is kind of important from a risk perspective.
15	MEMBER BLEY: And the point you just made,
16	Tim, if we put B- for any given defined scenario, you
17	can prevent it. You can come up with something. I agree
18	with you. But putting all your eggs in the prevention
19	basket doesn't cover you for the case where you didn't
20	think of the scenario.
21	MR. REED: Yes, that's defense-in-depth,
22	and I like that argument B-
23	CHAIR SCHULTZ: And that's the qualitative
24	stuff brings out that point.
25	MR. REED: Yes, I agree 100 percent. There's

value to that, and if the Committee has ever looked through the SAMGs and looked at EPRI Technical Basis document, if you glance through that, there's enormous amount of great information in there. I think it's very valuable, so I do think there's a lot of value in it. Absolutely. MEMBER BLEY: And to that issue of what we've forgotten, when we had the floods a couple of years ago and started looking hard at the risk from floods, I think nobody had calculated it at the levels that you probably calculate it now. MR. REED: Yes, I agree with that, too. I think sometimes we think we know more than we really do. There's more uncertainty, perhaps. Yes, I agree with that, also. I think I had those thoughts in there, too, so I'm aligned with it qualitatively. I'm just trying to address Dr. Stetkar's issues on how I was informed, or our team was informed by the risk. We think we really were informed enough. MEMBER BLEY: Your argument about where the level of risk is compared to B- is one thing, but I really agree with John on the idea of extrapolating anything from that one study to apply across B-MR. REED: Yes, I know B-

MEMBER BLEY: B- the range of the SAMGs,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

just doesn't work.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. REED: I know. I was B- you know, I think it was Dr. Corradini, one of our previous meetings B-

MEMBER BLEY: He came up with it?

MR. REED: Well, he was the one, hey, how come you aren't doing risk B- I haven't heard B- and he's beating on me. And I said well, you know, I'm going to try to find risk information everywhere I can find it. And I thought the B- I think the folks in Research did a great job in that technical basis for CPRR. I'm sorry, I really do think they did a great job, and that's why I was looking at it. I think it is informative, and there's a lot B- it tells you a lot about doing things after core damage, and whether there's any risk benefit to be gained. Certainly, there's benefits, but are they at the level that you can backfit and impose it? I don't believe you're going to get there personally as a backfit B- from a backfit standard in the U.S. I do understand there would be benefits, I agree, but it's a tough standard to hit the backfit mark, in my personal opinion. Anyway.

CHAIR SCHULTZ: But here's another perspective. If you look at that evaluation and you see the difference between the goals and the risk shown, one way one might look at that would be to say I can

1 B- there's plenty of margin, and I can buy into that. 2 But I can buy into that only if I have an integrated response capability that falls along these lines, 3 4 because those are the elements that, in fact, are being 5 brought forward to the Mark 1s, Mark 2s with that overall 6 evaluation and approach. There's a lot of work that's being done, we'll hear about it tomorrow morning B-7 8 MR. REED: Yes. 9 CHAIR SCHULTZ: B- with regard to B-10 MR. REED: Absolutely. 11 CHAIR SCHULTZ: B- response to events. 12 MR. REED: Yes. CHAIR SCHULTZ: And the need for that in 13 14 order for the argument to hold, perhaps. And I don't mean 15 you B- everyone wouldn't need that for the argument, but 16 I would propose that this is extremely helpful to 17 demonstrate that were this in place, I can buy into it. 18 I can see that the delta is there, and it's very, very 19 beneficial to move in this direction. MR. REED: Also, I would be remiss if I 20 21 didn't mention that B- I do tend to forget this because 22 I think of it as no SAMGs and SAMGs, and that's the delta; 23 where, in fact, there are SAMGs. And the delta about this 24 requirement is simply updating those SAMGs. As I

mentioned, some folks they really update, others that

may be a switch, and so the delta in terms of that impact is fairly small, I believe. I think you could probably take somebody who has a 1998 SAMG that's been sitting on the shelf, and you probably wouldn't be too bad given their most recent experience with mitigation strategies and their understanding of how to do that. They have a much more mitigation strategy mind set, clearly, and if you take even something that was out of date, I believe they'd have a really good chance.

Now, I think it's much better the work the industry has recently done, it's great stuff, and I would like to see it updated, no doubt. And they're working that way, so I do think there's benefits. But we've got to keep in mind that these things are in place at every facility. They're just voluntary, and what we're trying to do is make them mandatory. So, that goes to this backfit again.

I'm a backfit mind set in rulemaking. That's the way I'm thinking, so that's why I thought B- I'm trying to inform the Commission. I'm trying to be as honest and objective across the board. I mean, the fact is, is that it's the Commission's decision here on how much weight you're going to give to qualitative factors. I mean, that's a recent SRM, and I understand that. For them to make that informed decision, I think

1	they have to have all the best information, again.
2	That's the spirit I'm trying to provide, so B-
3	MEMBER STETKAR: Tim, my point is that the
4	information that you throw in their face as quantitative
5	information is rather, in my opinion, bad information.
6	It's misleading.
7	MR. REED: I should probably characterize
8	it a little better. I think I B-
9	MEMBER STETKAR: And that's the danger of
10	spending B-
11	MR. REED: Yes.
12	MEMBER STETKAR: B- kind of a page focusing
13	them on this recent study that's been done, and look at
14	the insights that we can from it, and from quantitative
15	B-
16	MR. REED: Yes, I B-
17	MEMBER STETKAR: B- we can't make the case,
18	because it's not true.
19	MR. REED: It B-
20	MEMBER STETKAR: It's true that you can't
21	make the case B-
22	MR. REED: That's what I meant.
23	MEMBER STETKAR: B- but using that study as
24	evidence B-
25	(Simultaneous speech)

1 MEMBER STETKAR: B- you can't 2 quantitatively justify it. MR. REED: Certainly want to characterize 3 4 that information correctly, but I want to be informed 5 by it. So, I mean, to the extent you can help with that, I do appreciate it. I mean, so B- because I think it's 6 7 great information to try to use, but I understand we've 8 got to be careful how we do that. 9 STETKAR: Right. Ι think MEMBER very 10 careful with sensitivity. MR. REED: Yes, okay. 11 12 MEMBER STETKAR: Just to try to demonstrate 13 that there is quantitative evidence and that you've 14 relied on it to some extent. 15 MR. REED: Yes. 16 MEMBER STETKAR: And I think B-17 MEMBER CORRADINI: Can I ask a question? 18 CHAIR SCHULTZ: Yes. I was just informed 19 that you wanted to ask a question. Go right ahead. MEMBER CORRADINI: So, Tim said I 20 21 beating him up, so here's my chance. So, Tim, I don't 22 understand the last phrase in your viewgraph where no 23 additional equipment requirement. And that B- and I 24 want you to explain that, and also from the context that 25 the way you described the process, NRC Staff is going

1 to make sure there are SAMGs, that they're up to date, 2 that they're being trained on, but it's going to make no comment on the technical content of them, and review 3 4 them for, I don't know, the evolution of the technical 5 content. Am I misunderstanding? MEMBER REMPE: Could I even ask a little bit 6 7 differently, because you said they were going to review 8 them for the reasonableness, or adequacy for reasonable 9 implementation successfully. At least vou 10 something like that a few minutes ago. Right? And so how 11 would a Staffer do that without some sort of 12 quantitative analysis? I mean, what's your vision on how 13 you're going to implement this? 14 MR. REED: Well, first let me talk a little 15 bit to Dr. Corradini's, and I'll try to get to you both 16 at one time. 17 MEMBER BALLINGER: I've got one after that. 18 MR. REED: Okay, fine. 19 (Simultaneous speech) 20 MR. REED: Well, no, this is the central 21 question I think in this rulemaking, so this makes a lot 22 of sense. But, you know, if I B- if you follow where I'm 23 going with this, if I don't think there's a lot of 24 quantitative risk benefit, okay, there is benefit, but 25 not a lot. I do want the requirements in place to

4.3 1 basically make sure there things are in the 2 Configuration Management Program, and maintained up to date. That was the problem. 3 What I don't want to do is sink a lot of 4 5 attention and resources from the NRC into reviewing at 6 any level and then getting into exchanges back and 7 forth, and industry taking their resources and sinking 8 it at a generic level, or even a plant-specific level 9 because those resources would not be doing something 10 else that, in my view, would be much B-11 MEMBER BALLINGER: Looking at equipment? 12 MR. REED: No, I mean in terms of reviewing, 13 looking at strategies, looking at equipment for the 14 strategies, looking at the B- basically going through 15 and reviewing the SAMG information. I think that would 16 take an awful lot of focus and resources away from 17 activities that I think would be vastly more important 18 for plant safety. That's my concern. 19 MEMBER CORRADINI: So, let me ask it more 20 bluntly. So, you're saying that there's going to be a

frequency of a box check, but not any frequency of a content check.

MR. REED: I don't think that B- I think that's not too far off. I mean, basically, what B- I mean, I wouldn't, obviously, put it that way, but what

21

22

23

24

we're suggesting here, you could see the inspection
ideas that we have here, is to make sure that the
guideline set is in place, is within Configuration
Management, reflects the new set of equipment and quite
a bit of additional capability for mitigation that's
going in place because of the Mitigation Strategies
Order, and reflects the new generic industry efforts to
update the SAMGs. That's an awful lot of good stuff, and
if that happens, I think we have addressed the issues
that were identified in the TI. So, that's B- if that's
the box check, Dr. Corradini, that's what we are
intending to do. But not delve into the individual
strategies and reviewing them, or looking at whether the
primary means, alternate means, or uncertainties of
instruments, the range of instruments, or everything
else as you walk through all the different phenomenology
you could see in these different core damage sequences
are the appropriate way to do it. That's a large, giant
effort that you could go on for years, and that's B- I
don't want to take our resources, the licensee's
resources and go down that rabbit hole.
MEMBER CORRADINI: Okay. All right.
MR. REED: Is that B-
MEMBER CORRADINI: You've clarified it. I

may not agree with it, but you clarified it.

1	MR. REED: Okay, that's B- understand.
2	MEMBER REMPE: Then is it worthwhile having
3	that if they have these SAMGs, and they're trained to
4	rely on certain instruments, as you brought up, and the
5	instrument is not good for those conditions. I mean,
6	what's the benefit?
7	MR. REED: I probably don't have my SAMG
8	person here yet in the room. They'll be here shortly,
9	but basically, the SAMGs have that philosophy built into
10	them, you know, in terms of primary means to B- you know,
11	if you've looked at them B-
12	MEMBER REMPE: They're working on that to
13	even improve it at this time, too.
14	MR. REED: Yes, absolutely. Absolutely.
15	MEMBER REMPE: But if there's not any
16	regulatory exchange or review B-
17	MR. REED: That's right.
18	MEMBER REMPE: B- I'm not sure if it's going
19	to be a worthwhile endeavor.
20	MR. REED: No doubt I'm trusting the
21	industry experts, and I'm not going to B- and the NRC
22	is not going in and basically checking that work, at
23	least not officially.
24	MEMBER REMPE: Well, I B-
25	MR. REED: I would say I'm probably not

being fully fair to the efforts of the NRC because, you
know, back in the '90s, some of you folks might have been
around when the Staff did look at the SAMGs, and I had
quite a bit of interaction with the industry up until
1998 in establishing the voluntary initiative. And we
have, in fact B- we've had a public meeting, a two-day
public meeting back B- I'm thinking it was in March,
somewhere in 2014, maybe it was a little later month
where we've interacted with them. And, in fact, we've
got access through the e-Portal. We have been looking
at the SAMGs, so if it sounds like we don't have any idea,
that wouldn't be proper. But what I'm saying is, when
I say review, an official review where somebody sends
and ends in official review. And that's a different
animal, you know. What we've done, I wouldn't
characterize that as review. I think we've used works
like "look," and, you know, that's a soft word, but I
won't want to over sell what we've done, but we have
B- we're definitely familiar with it. We have
interacted with industry, we've interacted recently, so
that's the level at this point of what we've done.
MEMBER REMPER Historia 11 1 1 1 1 1

MEMBER REMPE: Historically, you did at the beginning and it was deemed a voluntary effort, and then after B-

MR. REED: That's right.

MEMBER REMPE: B- Fukushima you went back and said well, the voluntary effort didn't work so well, and here we are again. Well, we'll do a checkbox review to keep it from being something that's not really going to be useful in the end-run if you don't have more of an exchange, and an ongoing exchange at some level. I realize it's a severe accident and not deemed to be that frequent of an event, but it's just B- I'm wondering if something more concrete needs to be established.

MEMBER CORRADINI: So, can I try a different way of saying it, Tim? I understand where NRC can only interact with the owner-operators, the licensees in a formal manner, but I think in this regard, if you have a no- good, very bad day, you want to be ready for it by having the regulator in conversation with the licensee so that they're on the same page as to what the content is of these. So, to the extent that the Agency has people in conversation with the licensees on this on an ongoing basis, I think it can only be beneficial. And I think these B- as John started off the conversation, on a relative basis, these are quite beneficial.

CHAIR SCHULTZ: Thank you, Mike. Charlie, you're next in queue.

MEMBER BROWN: Okay. Equipment. On B- I

guess at an ANS meeting recently, one of your staff presented a B- some conclusions where it demonstrated for accidents monitoring instrumentation, that that was needed to further hardened reactor and containment, and spent fuel pool monitoring to better withstand severe accident conditions. That was presented B- one of your staff members did that.

So, I said okay, that's consistent with some of our past discussions and the meetings relative to severe accident monitoring. Then I looked at the FRN and said, okay, the NRC proposes to have requirements for licensee B- this is on page 67, for licensee equipment, including instrumentation that is relied upon for use in the proposed mitigation strategies and guidelines.

You page down to page 69, when you finish all your discussion, it says, "As a result, we determined that conditions to which the instrumentation would be relied on would be exposed, do not include the progression of sequence of events to damage the fuel." You've determined that it should not be necessary for the instrumentation to be designed for use in the mitigating strategies and guidelines conditions, in the first paragraph. But, instead, it would be necessary that the design and associated function requirements

B- functional performance be sufficient to meet the demands of those strategies. Well, that was a little loose, couldn't figure out what that said.

Then I looked at your other document that you provided us that said -- that's the being supported -- to support the meeting with ACRS today and not to solicit external feedback, where said, "The proposed SAMGs would not include new instrumentation requirements." You go through a discussion and then you conclude that, "The Staff concludes the NRC and licensee requirements efforts and resources are focusing on designing severe accident instrumentation. Attention could be significantly diverted from more important safety issues."

I'm trying to figure out where you're going with this. Is it the conclusion -- there have been a number of past meetings where we've discussed and it has been kind of understood that you would look at or assess it, and it seems to me what you've said is no, there's no severe B- other than the fuel pool B- the spent fuel pool level instrumentation, that looks like everything else is off the board and everybody would just be relying on the standard built in equipment, so I'm not quite sure where you're going with these statements from one to the other. First a little bit of an endorsement, then the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

presentation to the ANS, then diverting attention from other more important safety issues is such that no instrumentation is required.

MR. REED: I guess all I can B- and, Eric, I think some levels on mitigation strategy stuff, but I can give you the perspective on SAMGs. The SAMGs approach is basically in terms of equipment and instrumentation. It's going to be, I'll tell you, the status quo. In other words, you make use of everything you have in the facility, wherever the pedigree of that is. It's Reg Guide 1.197.

(Off microphone comment)

MR. REED: Yes, I probably did. And what you do is, given that you're basically looking, and you recognize that's going to only last for so long, and then no matter what it is you do, whether you get the super duper instrument or whatever, depending on where that is, it's going to fail. And what you're really looking at now is hey, what's my primary means, what's my backup means, what my alternative means are, what are my calculational methods for determining it, and that's what the SAMGs do.

So, the question I would have is, given that's the philosophy the SAMGs are built on, what would be the difference if you changed out an instrument to

make it more capable of say severe accident conditions beyond what it would be for Reg Guide 197, whatever, I think Rev. 3, whatever it is that people have actually monitoring instrumentation for. How much better would it be? And would it extend you look into a severe accident by minutes, hours, anything at all? Would that, in fact, then end up changing any of the actions that are taken in terms of mitigation? Would it still be add water, add water, add water, or would it, in fact, be a real change in what can we do in mitigation?

And then you roll that back up to finally why I started. How important are SAMGs in their entirety for public health and safety? I don't think in terms of backfit space and absolute change they're a very large change. They are beneficial. You know, obviously, you've seen my arguments. Okay? And when I look at how the overall changes in terms of safety, and then I drive it down and I look at okay, I'm going to start thinking about equipment, enrichments, and different strategies, and maybe making it better, how much better am I making it? And how much does that matter B-

MEMBER BROWN: How do I know if I'm adding water that I'm doing any good? I mean, not if you're going out a hole that you're not aware of, it's never getting to where you want it to go, and the temperatures

	32
1	just keep going up.
2	MR. REED: How will you know with better
3	instruments?
4	MEMBER BROWN: You'll know the temperature
5	keeps going up until you've exceeded B-
6	(Simultaneous speech)
7	MEMBER BROWN: B- up to 2,000 degrees.
8	Well, then you know you've got a bigger problem.
9	MEMBER REMPE: And it's real important to
10	know where it fails.
11	MR. REED: So, you extended the time in a
12	sequence.
13	MEMBER BROWN: Well, no, you've extended
14	the information you have relative to how severe the
15	problem is now because you know the water is not getting
16	there. I mean, I just have a little bit of qualms with
17	that thought B- pressure B- let me see, temperature,
18	pretty important. Okay? And you can put pretty hardened
19	sensors in place, and you can get that information out,
20	okay, under pretty nasty getting them out of the plant
21	where you can read them. You can also get some types of
22	level out if you work out B-depending on the reactor type
23	we're talking about that is pretty blacksmith
24	technology approach to doing business, and maybe the

temperature is the best one. But if you don't know

1	whether the water is doing anything or not, what the hell
2	good is it to put the water in? You pump the whole
3	Atlantic Ocean or the Pacific, whatever it is, it's not
4	cooling anything, doesn't do any good.
5	MR. REED: You're going to B- the Committee
6	is going to hear this a lot because I do this B- I always
7	say bring your backfit justification. I'm thinking in
8	backfit space, so when you say you want to do something
9	different with equipment or instrumentation, then I say
10	okay, show me the benefit for that, and let's see if you
11	could show substantial additional protection or
12	adequate protection. I don't think you can. And if you
13	can, then we'll talk about the costs both direct and
14	indirect that justify B-
15	MEMBER BROWN: I would argue that it brings
16	in the thought or the concept of alternate B- if you know
17	your water is not doing any good, I better do something
18	else.
19	MR. REED: Okay.
20	MEMBER BROWN: You know you have to go do
21	something else.
22	MR. REED: Right.
23	MEMBER BROWN: You may not exactly know, but
24	what's the knowledge worth?
25	MR. REED: That's B-

1	MEMBER BROWN: Do you want to continue to
2	have the whole thing melting down like a little volcano
3	and lava flowing out the side B-
4	MEMBER BLEY: Not much today, but today you
5	have an accident it'll be really B-
6	MEMBER BROWN: Right. I've got a
7	fundamental disagreement on some very basic. And I'm not
8	talking about extensive B-
9	MR. REED: I understand what you're saying.
10	MEMBER BROWN: B- high-level digital, you
11	have flat screen displays, you know, the hardened
12	B- that's baloney.
13	MR. REED: I understand the spirit of what
14	you're saying.
15	MEMBER BROWN: Look at a temperature sensor
16	with hard wire coming out and a guy reads with a meter
17	somewhere 200 feet away.
18	MEMBER POWERS: The trouble, Charlie, is
19	that if you've got conditions that will damage a ceramic
20	fuel then you've got conditions that will destroy any
21	thermocouple known to man.
22	MEMBER BROWN: I don't B- once you B- I
23	don't know. If your fuel is already broken and stuff is
24	coming out of it, you've got heat. It can get pretty hot.
25	MEMBER REMPE: So put your thermocouple on

1	the bottom of the vessel and you'll know it's heating
2	up, and that something real hot is on the inner surface
3	of the vessel, and you might think of an alternate
4	strategy.
5	MEMBER BROWN: I just think it B-
6	MEMBER REMPE: It's where you put that
7	thermocouple.
8	MEMBER POWERS: If you're going to talk
9	about thermocouples located away from the fuel, we've
10	got lots of them.
11	MEMBER REMPE: But what's their operating
12	envelope, 350 C?
13	MEMBER POWERS: You can make them anything
14	you want to.
15	MEMBER REMPE: Well, that's the issue, is
16	think about where you B-
17	MEMBER BROWN: The ones today are using
18	conventional B- getting the information out to B-
19	(Simultaneous speech)
20	MEMBER POWERS: B- things like that.
21	MEMBER BROWN: I mean, nobody is putting any
22	thought into the way you would do this in order to have
23	a better idea of what the temperatures are on the inside
24	of the reactor vessel.
25	MEMBER POWERS: And you're simply never

1	going to get there. If you're talking about temperatures
2	that are away from the reactor, the inverse calculation
3	is ill-posed, and it's more likely to mislead you than
4	anything I can think of. The answer is always water,
5	water, and water.
6	MEMBER BROWN: If you don't know whether the
7	water is doing you any good, then what good is it?
8	MEMBER POWERS: It is extremely difficult
9	to come up with a way that the water isn't any good.
LO	MEMBER BROWN: I don't know, but there seem
L1	to be a lot of questions floating around at the beginning
L2	В-
L3	MEMBER POWERS: Yes, you could hypothesize
L4	all kinds of strange conditions B-
L5	MEMBER BROWN: That doesn't seem like it's
L6	an unknown unknown type of operation B-
L7	MEMBER POWERS: The answer at Fukushima was
L8	add water.
L9	MEMBER BROWN: And we still don't know
20	whether any good initially.
21	MEMBER POWERS: The answer was B- yes, we
22	know that not adding water was really bad. We know that
23	one for an absolute for sure fact.
24	MEMBER BROWN: Well, this back and forth is
25	not going to resolve this particular issue, but I did

1 want to bring it out that this B- I personally do not 2 agree, even though my compatriot B-MR. BOWMAN: To answer the first part of 3 4 your question, though, the discussion in the Statement 5 of Considerations on the limitations of the equipment, including instrumentation is limited to the discussion 6 in the proposed Section 50.155(b)(1) for equipment 7 8 supporting the mitigating strategies portion. 9 (c)(1)for the equipment supporting sorry, 10 mitigating strategies portion of (b)(1) which 11 limited to pre-core damage. So, for its use to meet the 12 functional requirements before core damage there is no 13 need for the equipment or the instrumentation to be 14 capable of surviving post-core damage. 15 MEMBER BROWN: Where does the severe 16 accident monitoring thought process get factored? I 17 quess I missed that when I was reading this. MR. BOWMAN: There's an exclusion of a 18 19 separate equipment requirement for post-core damage, 20 and that's discussed, in part, in the draft SECY paper 21 where we made the statement. That's that separate page. 22 MEMBER CORRADINI: So, can I ask a question? 23 MEMBER BROWN: To the Commission B- for the 24 Commission. 25 MEMBER BROWN: Hold on, Mike.

1	MEMBER CORRADINI: Sorry, Charlie.
2	MEMBER BROWN: Well, that's where you do
3	state B- you do talk about severe accident monitoring.
4	MR. BOWMAN: Yes. There was B-
5	(Simultaneous speech)
6	MEMBER BROWN: B- not going to do anything.
7	MR. BOWMAN: We are not doing anything in
8	this context in this rulemaking. There remains a Tier
9	3 action item post-Fukushima to look at the value that
10	post-severe accident monitoring equipment would
11	provide and come to a conclusion as to whether or not
12	that would provide a substantial safety benefit. I think
13	part of B-
14	MEMBER BROWN: The patient could be dead by
15	the time we get to that one.
16	MR. BOWMAN: B- the problem that we've got,
17	and we may not have communicated it well enough, it's
18	not that we are pointing to the quantified results of
19	the CPRR information and saying it doesn't meet it. What
20	we're saying is we don't have quantified information
21	that meets the substantial safety benefit criteria at
22	this point.
23	MEMBER BROWN: I guess B- I understand what
24	you're saying. I just B- I have a little bit of
25	difficulty because I can't stick a quantitative, highly

1 quantitative in this very unknown type situation that 2 I'm just effectively going to B- I don't want to use the word "ignore," reject, not consider it at this time, 3 4 maybe forever. 5 MR. BOWMAN: We have to consider the value it would add to have the severe accident capable 6 instrumentation in the context of the existence of other 7 8 things like computational aids that can give us information that would influence our decisions on what 9 10 courses of actions we've got to be taking. 11 MEMBER CORRADINI: So, you really don't 12 want to rely on a computer when I could measure 13 something. You're not saying that, are you? 14 MEMBER BROWN: That is exactly what he said. 15 MR. BOWMAN: You would measure it. If you 16 can't measure something, you would use whatever means 17 you have available to aid you in B-18 MEMBER REMPE: I'm aware that industry has 19 these calculational aids, but what I was B- I haven't 20 B- I thought heard you say is we're just going to check 21 the box, but now it almost sounds like well, yes, we are 22 going to look at what they are proposing. And if the 23 first sensor goes and we B- you know, they should define 24 boundaries for when that sensor goes and what the 25 alternative methods are at that time. Are you going to have some interaction with the regulator reviewing what industry is proposing? Are you just going to say yes, they've got B- they say they have calculational aids, they have alternate sensors, and we check the box and go on. How much B- that's what I'm wondering, are you going to get into the details, or are you just going to let them do whatever?

MR. REED: Well, first of all, presuming the Commission does agree with the qualitative arguments and thinks that SAMGs should be imposed. I don't know if that's a given at all.

MEMBER REMPE: Right.

MR. REED: Then I think then it depends on, of course, their direction to us. Now, we are B- obviously, we're familiar with the SAMGs, and that's different than being reviewed, as I mentioned, so we are familiar. You do understand that, but I don't think we would B- if it's me, I'm speculating now, but those special requirements are pretty high-level, and unless I saw something that was egregious, I mean, in terms of some licensee's SAMGs were, you know, on the face of it not even potentially executable. Okay? I mean, it would have to be something where it doesn't make the black-letter of the B- you know, what our rule says, you know, in terms of what SAMGs do. It's a pretty tough B- a

pretty high standard. So, I wouldn't be going B- at least the way I see it right now, I wouldn't be going into individual sequences and looking at the different means of instruments and what have you. I wouldn't be going down to that level.

I think to go down to that level, in other words, to check the work that industry has done over the last 20 plus years would, obviously, have a lot of NRC resources and back and forth. So, right now it's saying yes, we've looked at it. We know it's there, but we're not reviewing and approving.

MR. BOWMAN: I think one potential example is something that would be plainly wrong with an implementation of a severe accident management guideline set for a licensee if their SAMGs did not reflect the plant as built, and as maintained, or the equipment that was available and that they should be proposing to rely on. Then we would say there is a problem, an issue of concern, and we would process it through our normal inspection processes in the Reactor Oversight Process for dispositioning.

MR. REED: Because I think if you read through that, one of the things I think it B- I think it was in this package, could have been in a previous version about the qualitative arguments, SAMGs, I

1 think, are very valuable and they became a lot more valuable because of the much increased mitigation 2 capabilities that are going into place now. 3 4 Now, those are designed to be pre-core 5 damage, but let's face it, this stuff would B- you use 6 everything and anything you can post-core damage, and 7 it's likely they would be very useful post-core damage. 8 So, for example, if a licensee didn't reflect that in 9 their SAMGs, that to me would be a clear case where no, 10 this is not making it. 11 MEMBER CORRADINI: May I ask a question at 12 this point, Steve? 13 CHAIR SCHULTZ: Yes, go ahead, Mike. 14 MEMBER CORRADINI: So, maybe we should wait 15 until industry comes up and ask them the question of 16 content, and the questions might be what is the minimum 17 set of instrumentation although outside of their EQ 18 range, that they look at so that they get a feeling for 19 how, God forbid, an event like this occurs, how it's 20 progressing in terms of water addition, or where I might 21 retreat to put the water? 22 Also, the next question for industry is, 23 what is the frequency in which they do training so they 24 do it appropriately, but not overwhelm the operators 25 with training that is of low probability compared to

other things need to train? I assume the industry has answers to these things.

CHAIR SCHULTZ: I agree, Mike. That would be a good approach to take, especially with regard to this afternoon, and we'll give the industry some time to think about that before they come up. But that is a way in which what we've just discussed, I think what Eric was getting to with regard to measurement versus calculation. Those are the elements that had gone into the development of the SAMGs.

DR. SHACK: Just thinking about it, I mean, it seems to me one of the problems with the SAMGs has not been so much that the guidelines have been poor o badly thought out. The question is whether they've really been implemented, people have been trained on them.

In your view, would the inspection under the ROP go some ways towards solving that problem that we're sure that people B- are they being implemented and people are being trained?

MR. BOWMAN: Well, the things we saw in the temporary instruction inspection, I think it was 184, I don't remember exactly what the number was, that was done post-Fukushima, was some licensees did not include the SAMGs in their Configuration Management Programs,

1 so there were some issues that were found with the 2 currently B- the then existing SAMGs reflecting B-3 SHACK: No, Ι realize there 4 problems found. The question is, is your proposal going 5 to fix that? It should. MR. REED: That's exactly what it's going 6 7 towards. In other words, it would B- sure, you update 8 them, you maintain them updated over time, that you've 9 done the sufficient training that, you know, you can expect that they could actually implement them. Those 10 11 are the kind of issues that were found in the TI, and 12 so that's what we're trying to do. That would address that. That's the level we're going to to solve the 13 14 problem. That's how we tried to construct it. 15 CHAIR SCHULTZ: I would hope so, otherwise, 16 there's no reason to move forward and make them mandatory, not voluntary. 17 18 MR. BOWMAN: Absolutely. SCHULTZ: That, 19 CHAIR in fact, this 20 approach would fix the problems that have 21 identified from 1998 until now, whenever they occur. 22 MR. BOWMAN: The other B-23 CHAIR SCHULTZ: I'm not saying there are 24 lots of problems out there, but there are certainly 25 some.

1	MR. BOWMAN: The other thing I would point
2	out to be completely open is that the content of the
3	SAMGs has changed since they were first implemented. One
4	of the major changes was the inclusion of damage to fuel
5	in a spent fuel pool. That wasn't covered under the prior
6	version of the SAMGs before the Fukushima event.
7	MR. REED: In fact, I think there are five
8	candidate high-level accidents. I don't see Ed in the
9	room, Ed Fuller did look at the Technical Basis Document
10	in detail and those are all lessons learned from
11	Fukushima, like hydrogen build-up mitigation, the use
12	of raw water. There's a few others, too.
13	CHAIR SCHULTZ: Well, this is something we
14	can hear in the industry presentation later today.
15	MR. REED: Any more questions on this slide?
16	DR. SHACK: One further comment. I mean, in
17	terms of the fence B- I agree that you probably can't
18	do this under a backfit. You know, that B- I haven't done
19	the calc but I'd be very surprised. But as a
20	defense-in-depth measure, I certainly don't see the
21	difference between the EDMGs and the SAMGs. And the
22	defense-in-depth capability I get from one to the other,
23	seems to me an inconsistent treatment. I would, you know
24	B-
25	MR. BOWMAN: All I can say in response to

1	that is that the requirement for the EDMGs was proposed
2	B-
3	DR. SHACK: Was under a different B-
4	MR. BOWMAN: B- as the adequate protection
5	exemption for exception from the Backfit Rule. So, it
6	did go through the backfit process. It was a policy
7	decision that was made. It's been carried forward B-
8	DR. SHACK: It seemed to me on a qualitative
9	basis if you're looking for defense-in-depth, I can at
10	least make a strong case for SAMGs as a contribution to
11	the defense-in-depth as I can EDMGs.
12	MR. REED: I would personally agree with
13	you, Dr. Shack. I think there's a stronger case for
14	SAMGs, but that's just my personal opinion. So, I do
15	think there's a lot of value, too, but Eric is absolutely
16	right that the EDMGs stem from B5B B-
17	DR. SHACK: It's a different world, yes, I
18	agree. But, again, I do want to think that B- you know,
19	it's important to solve the problem that we're really
20	seeing with the SAMGs, which is implementation and
21	training, not so much the proposing things that are
22	technically unsatisfactory.
23	CHAIR SCHULTZ: But you're proposing to
24	move it forward in that way.
25	MR. REED: Yes.

1 CHAIR SCHULTZ: The defense-in-depth 2 argument. MR. REED: Yes, absolutely. 3 4 MR. BOWMAN: Well, a defense-in-depth 5 argument that uses the cost justified substantial safety benefit exception to the Backfit Rule based on 6 7 qualitative factors, presenting the qualitative 8 factors to the Commission so that they can make the 9 decision on whether or not they believe it is, indeed, 10 cost justified substantial safety benefit. 11 MR. REED: And I do B- and when I say that, 12 I do say I understand that the work does not reflect 13 specific all the benefits for SAMGs in risk space, so 14 I understand that. I know that's not exactly what B- scratch Dr. Stetkar's itch here, but I do understand 15 16 that, that there's more benefit. And I'm suggesting that 17 there's enough that we could make the substantial list 18 from that standpoint. So, yes, sir, we are proposing to 19 the Commission to B- for them to go forth with this as 20 a requirement. 21 MR. BOWMAN: At least as a proposed B-22 MR. REED: Yes, a proposed requirement. 23 MR. BOWMAN: So we can fully inform and 24 develop a final recommendation. 25 CHAIR SCHULTZ: Yes, it's a Commission

decision.

1

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

2 MR. BOWMAN: Yes.

MR. REED: Is there anything else on Slide 4? We won't have to do the later slide on SAMGs by the time I get there.

(Off the record comments)

MR. REED: So, Slide 5 is just a continuation of Paragraph B. And I had mentioned that the three different guideline says they're integrated with EOPs and it's structured intentionally that way to leave in place the work from the 1980s that put in place the symptom-based EOPs after TMI. We're not going to revisit that. That work is fully acceptable.

And then given you have this integrated capability. Of course, you need to support that with sufficient command and control, and staffing. And this stems from the fact that, you know, at least one of these quideline the mitigation strategies for sets Beyond-Design-Basis External Events, FLEX is, in fact, for a site-wide Beyond-Design-Basis Event. That's a severe challenge to the site. Obviously, it's a command and control challenge. It also involves all site assistance, so for an indefinite capability maintaining core cooling, spent fuel pool cooling and containment capability, so that's the demand, ultimate demand that's placed on this integrated capability. And, obviously, that places demands on your command and control, your staffing, and your communications. You'll see the Paragraph B-4 and 5 there, I believe is the references. Again, that hasn't changed. That's been substantially the same as it was in November.

Slide 6. I was thinking that we were going to get to Slide 6 before we got into any real interaction, so that shows how much I know. But Slide 6 are the equipment requirements, and these have changed. And, namely B- and I have the exact requirements up there on the slide. The part of it that changed, of course, was the reasonable protection of the mitigation strategies equipment under proposed 155(c)(2).

Of course, just before we get to that, these are the parts of the rule, the equipment requirements we're calling them, that would make generically applicable the equipment requirements from EA-12-049, and that's in (c)(1), (2), and (3). And then the requirements for the level instrumentation from the spent fuel pool in Order EA-12-051 as 155(c)(4).

And there you see basic B- this was, obviously, you will recall back in November a lot of discussion. It was on COMSECY 14-0037, and we are still

awaiting the Commission's direction on this. And, of course, we'll be aligned with that direction. It goes without saying.

We think this is B- what we've seen so far, this is in alignment. I'll be very frank, there's some B- I mean, as we're going through this concurrence process, I think we've mentioned it in the beginning. This is a lot happening in parallel, and you're getting B- you're becoming part of the rulemaking concurrence process. Welcome to the party. But, you know, in this case we're getting feedback, and the concern is, is that can we actually implement that provision by effective date of the rule? There's a lot of moving parts there on what the licensee can do. They may, in fact, be getting information from another entity, and then giving it to us, us doing our assessment, so we're looking at that, and maybe we'll probably ask for some stakeholder feedback on that. We're thinking about any question to that, and maybe building in flexibility as part of our CR process to make sure that implementation can be done appropriately.

Again, we've got to B- we inform that by the Commission direction, so the Commission direction in the SRM will rule the day, and we need to comply with that. But, nonetheless, that's an ongoing issue. That

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

is different. You see that provision up there. I'll come to a full stop if the Committee wants to comment on that aspect of the change in the language. Okay. So, I that's where I thought the discussion was, and there's none.

(Off the record comment)

MR. REED: The training requirements, those are unchanged. In fact, it's actually B- Dr. Corradini kind of mentioned a little bit earlier, kind of our concept here. What we're trying to do is salvage training requirements that enable a licensee to make use of everything they have available to them right now that's usable, and there's quite a bit of training that's in place that would work for this integrated response capability. Training that goes to from the EOPs, from mitigation strategies order, anv training. There's a lot of B- even fire protection training could be applicable. All that training can be used. We're trying to B- you've read the Statement of Considerations there. We're trying to enable licensees to make maximal use of what they have. But to the extent they don't have any training, then we're talking about, you know, a systems approach to training there. So, we've written the Statement of Considerations to try to get that thought across. Hopefully, that makes sense.

clearly designed to,

It's

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

basically,

establish a minimum training requirement to not focus too much attention on SAMGs to the exclusion of say EOPs or other training, for example, so it's with that kind of mind set.

Again, that is basically the same training

Again, that is basically the same training requirements that were in place. There's no change. You've got the Statement of Considerations there with you so, hopefully, that makes sense of that requirement. Yes, sir?

MEMBER BLEY: For the plants that have chosen, should they enter the SAMGs to transfer control of the plant to the TSC, will there be anything specifically addressing any kind of training that would apply to whoever is in charge of the TSC?

MR. REED: I think exact B- that would be, I think, the most substantive part of the training. In other words, the TSC personnel, their understanding of the content of the SAMGs, that switch over from the control room to the TSC. I think that is where most of the training would be focused. Certainly, they're probably very B- in some cases, very familiar, perhaps not. We mentioned the TI results, so that's where I think most of the training would go.

Now, you should also understand, although we have drills, in my view, drills and training are very

similar, there's a lot of overlap, so we have also drills in this rule that would be a test, you know, a demonstration of whether you can do these transitions, so that's another check on it. But, yes, I do think that's where the SAMGs training would be focused, at least in my view. I don't know if I B-

MR. BOWMAN: What I would add is that the training requirement is written as a broad high-level requirement. It's in 155, Subparagraph E, and in the draft guidance, I believe it's in NEI 13-06 that we're looking at B- we're considering endorsing, is sets of guidance for training for the ultimate decision maker or the Emergency Director, whatever the chosen name for that person is, whether or not that person is within the control room or in the TSC, or wherever they'd be located.

MEMBER BLEY: I guess that always B- I hang up on this idea of transferring the control, it's B- even if you're very senior and experienced, if you're not licensed and refreshing routinely, you don't know the guts of the plant on the way B- in the way that licensed folks do. And I guess we'll have to wait and see how this would be implemented to make sure that we're covered in that regard.

MR. BOWMAN: Well, in any case, if you view

command and control as a bundle of rights and functions, in order to implement direction on what would be going on in the plant, if they transfer command and control to the TSC, what would happen is the TSC would provide direction to the main control room, and from there the licensed operators would direct what happens in the plant.

MEMBER BLEY: I guess that's kind of B-

MR. BOWMAN: So, there is a real functionC-

MEMBER BLEY: B- of the model I've always thought of, and that it would be advice. We hear more and more that no, in fact, they'll be driving the plant from the TSC, at some plants. And it's another venue, not commercial nuclear plants, I recall reading many incident reports in facilities that have a similar structure, and quite often you'd see the senior guy come in and say this is going bad, I'm taking over, without being fully informed of the details of what was going on right now in the plant. And the first couple of decisions would if not wreck the plant, put it in a lot worse situation than it was in. And that's the thing I keep worrying about with this concept.

The way you described it, I have no worry, send them recommendations and the guys who really are aware would say wait a minute, you might not want us to

1 do that for these reasons. Keep it at that and just watch 2 how this progresses. MR. REED: Okay, so we're on Slide 7. George 3 4 Tartal from NRO will present Slide 7. 5 MR. TARTAL: Good afternoon. Thanks, Tim. I'm George Tartal with the Office of New Reactors. I'm 6 7 going to talk to Slide 7 here on the new reactor design 8 requirements. 9 CHAIR SCHULTZ: George, just move up to the 10 microphone a little more. Thank you. 11 MR. TARTAL: Is that better? 12 CHAIR SCHULTZ: Yes. 13 MR. TARTAL: Okay, good. Again, this is 14 Slide 7, the new reactor about 15 requirements. We briefed the Committee on this in 16 November. The concept is not substantially changed from 17 what we briefed the Committee on last time. 18 Again, the applicability statements that 19 this feature, or sorry, this provision would apply to 20 applicants for new reactors and the key here is 21 applicants, that this being a forward fit requirement. 22 That's the way that we discussed with the Committee last 23 time, it being forward fit. It applies when the key 24 safety functions, that is core cooling, containment,

and spent fuel pool cooling capabilities are being

proposed to the NRC for review and approval, and we want this requirement to apply as early as possible in the design process.

It still applies to applicants for designs for construction permits, operating licenses, design certifications, standard design approvals, combined licenses, and manufacturing licenses. That concept hasn't changed.

What has changed on this particular provisions is, as we went through the backfit analysis, we found two situations that would either be a backfit or inconsistent with issue finality provisions in Part 52. The first of those is the requirement used to say that it applied to applicants that referenced a design with a previous approval. For example, a combined license applicant referencing a certified design. We removed that applicability statement from Paragraph A.4 because that would essentially be inconsistent with the issue finality given to the design certification.

And then the other situation that we revised in A.4 is applying to applicants for design certification renewals. Again, under the issue finality provisions of Part 52 that would have been a violation of the issue finality afforded to the design certification once it's certified, so we had to remove

1	that provision from A.4, as well.
2	MEMBER CORRADINI: So, can you give me an
3	example of each so it's clear?
4	MR. TARTAL: I did give you B-
5	MEMBER CORRADINI: Or clearer?
6	MR. TARTAL: Right, okay. So, let's give you
7	an example of a combined license applicant such as Levy
8	that's referenced in the AP1000 design. All right? This
9	rule provision would not apply to a plant like Levy
10	because they already have B- sorry, they're referencing
11	a certified design in their applications, so they would
12	not need to comply with the requirements of Paragraph
13	D in that situation.
14	Another example would be B- you wanted
15	another example on DC, so let's say the AP1000 design
16	that Westinghouse came in for a renewal. We would not
17	be able to impose this provision on Westinghouse in that
18	case because they're already afforded issue finality in
19	this area.
20	MEMBER CORRADINI: But they still conform
21	to the current plant rules.
22	MR. TARTAL: Yes. They're still subject to
23	the rules and regulations that were in effect at the time
24	the design was originally certified.
25	MEMBER CORRADINI: And all the associated

rules that we just spoke about.

MR. TARTAL: You're talking about the other provisions that the other Staff are talking about now in this meeting?

MEMBER CORRADINI: Yes.

MR. TARTAL: No, those provisions apply to B- oh, I'm sorry, yes, for the combined license applicant in the first situation, yes, those provisions would apply to the combined license applicant, not to the design certification renewal applicant.

MR. BOWMAN: As far as the applicability goes for the remainder of the requirements in Paragraphs B, C, E, F, and G, those are all applicable; being subject to Paragraph D as an applicant for a new reactor plant design would not result in an exemption from any of the other requirements of the section as a whole.

MEMBER CORRADINI: The reason I'm asking the question, just so I B- maybe I'm misunderstanding. So, just you can tell me to wait, but you're about to go to the second part of that slide where the bullet is, "Longer time constant, sufficient instrumentation."

I'm trying to understand what sufficient instrumentation means for a new plant that it isn't meant for in a current B- do you understand where I'm going?

MR. TARTAL: I'm not sure what that has to do with the applicability. Can you help me with that?

MEMBER CORRADINI: Well, I B- so, is there going to be an additional requirement of instrumentation on a new plant that is being required on a current plant? That's where I'm going.

MR. TARTAL: Yes, this is a forward fit requirement, so the idea of having the longer time constant, sufficient instrumentation; actually, you're reading from the Commission's Advanced Reactor Policy Statement, but specifically to the requirement in Paragraph D, that's the second sub-bullet under new reactor design requirements.

MEMBER CORRADINI: Right. So, my question is going B- I now am going to require additional instrumentation for these advanced plants under adverse conditions. So, what's the design basis for the adverse conditions? I'm struggling. On one hand, we're arguing that we don't know what they are, or there's not risk-significance to them. On the other hand, we're asking the new plants to design to something, and I don't understand what they're designing to.

MEMBER BROWN: I don't think that's B- I'm not sure I understand that question, but I thought I just heard that no B- there's no advanced instrumentation in

accident for anything, new 1 reactors, old 2 reactors B-MEMBER REMPE: Well, actually B-3 MEMBER BROWN: B- backfit reactors. 4 5 MEMBER REMPE: For the AP1000 there's not a 6 good B- maybe I'm misunderstanding, but I don't think 7 that there's a firm process in place. But for these new 8 plants that B- the AP1000 B-9 MEMBER BROWN: Do you mean the SMRs, or are 10 you B-11 MEMBER REMPE: No, the AP1000. They 12 actually did analysis that considered an some 13 scenarios, identified some sensors and said they had to 14 be surviving that for a certain time, and the staff, and 15 it was an agreement type of thing. It wasn't a fixed 16 process that they had to follow, but they said yes, 17 that's good. Is my B- am I correctly interpreting what 18 I read from it's like FSAR or something. 19 MR. McKIRGAN: So, if I could B- this is 20 John McKirgan from the New Reactor Staff. Under Part 52, 21 I think the analysis you're talking about is the severe 22 accident analysis where they look at the most likely 23 severe accident scenarios and describe features that 24 would address those scenarios, so that is part of

certified design.

1	MEMBER REMPE: Right. So, that's part
2	B- and the reason they do that is because of the
3	Commission's Advanced Reactor Policy Statement that
4	said they had to do that. The existing plants just look
5	at design basis events.
6	MR. McKIRGAN: At a very high level, I'll
7	agree with that.
8	MEMBER REMPE: Okay.
9	(Simultaneous speech)
LO	MR. McKIRGAN: But I think in concept,
L1	that's a fair statement. Dr. Corradini, could I ask you
L2	to rephrase your question for me a little bit?
L3	MEMBER CORRADINI: Well, I'm listening
L 4	because I'm probably misinterpreting, so your
L5	explanation is helping me. So, I'm trying to understand
L 6	the nuances of an AP1000 versus an APR1400.
L7	MR. McKIRGAN: Okay.
L8	MEMBER CORRADINI: So, let's say the
L 9	APR1400 which is going to come in under certification,
20	you're going to look at it, and somebody wants to build
21	one in the States. How is their B- since they're not
22	certified yet, how are they going to be treated, and any
23	different than the AP1000?
24	MR. McKIRGAN: So, let me see if I can say
25	that simply. We're looking for B-

MEMBER CORRADINI: Please do.

McKIRGAN: We're looking for design features so we want to address this rule to those applicants who have not yet finalized their designs. So, in the case of the AP1000 where there is a certified design and construction is going on, we feel those design B- that has achieved a level of design finality that we want to not become a backfit issue, so we're looking to forward fit these. So, we're only looking for have those applicants that not yet achieved certification. So, if the Commission were to proceed with this, then these provisions would apply to the APR1400 which was accepted for review.

MEMBER CORRADINI: Okay, and now that B- okay, so I B- then I did interpret it correctly. So, my next question is, what is the basis of the adverse conditions you would add instrumentation or improve the design of the instrumentation? I'm struggling with the words.

MR. BOWMAN: Right. If I could interject, this is Eric Bowman, Dr. Corradini. On the slide what you see at the bottom is a quote of two portions of the Advanced Reactor Policy Statement, and the first one includes the phrase "sufficient instrumentation," and goes on further about the instrumentation.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

There is no language that's being proposed
in 50.155 in the design features portion that addresses
instrumentation. The proposed guidance for new reactor
designers to use in meeting the Paragraph D requirements
or proposed requirements is contained in Appendix A of
Draft Guide 13-01, which a very preliminary copy has
been provided to the Committee. And there is no
additional instrumentation requirement contained
within that appendix, so I would say that the sufficient
instrumentation would be included in the design if it's
considered by an applicant to be a design feature that
enhances coping durations and minimizes the reliance on
human actions, or if it's required in order to follow
the Advanced Reactor Policy Statement. It wouldn't be
a B-
(Simultaneous speech)
MEMBER CORRADINI: So, what I'm hearing you
say is there really is no B- I did not read Appendix A,
but I am pulling it up now. But the guidance in Appendix
A is a bit qualitative.
MR. McKIRGAN: Yes, and I think we'll talk
about that more in a moment.
MEMBER CORRADINI: Okay, fine. Then I'll
wait.
MR. McKIRGAN: But, Dr. Corradini, if I

could also remind you, so there are no additional instrumentation requirements in this provision under this rule, but I would not want you to forget the other provisions in Part 52 and the severe accident analysis that goes into design certifications where they do consider the most likely severe accidents and talk about the features to mitigate those. So, the instrumentation B- there is a greater level of consideration in that area, and we can talk more about that perhaps at another meeting. But I think that's what Dr. Rempe had read, and that does apply to the design certification applicants independent of the rulemaking package that is before the Committee right now.

MEMBER CORRADINI: Okay, thank you very much. That helps. Thank you.

MEMBER STETKAR: Let me try something else to get away from the instruments and focus on the second sub-bullet under the intent there. "Simplified safety systems that where possible reduce required operator actions." And I won't mention any existing designs, but let's presume that we have a design, been certified where under a loss of all AC power the operators must de-energize everything in the control room and relocate to a remote shutdown area that has much less instrumentation and indications available. And that's

a certified design, that's already been accepted. And we have a new design that comes in, Design X for certification, that proposes that same strategy. Would that new design be held to a different standard because the determination could be made that that's not simplified and it doesn't reduce the need for operator actions? Is that part of this intent?

MR. McKIRGAN: You said a lot there, and I don't know that I caught it all.

MEMBER STETKAR: Okay.

MR. McKIRGAN: I mean, certainly the intent here is to B- for the new applicants to come in with these enhancements. Obviously, this provision does not apply to the certified designs.

MEMBER STETKAR: Right.

MR. McKIRGAN: So, I missed when you B-

MEMBER STETKAR: Well, but what I was asking, given the fact that we've accepted a design where it employs that strategy, de-energize everything in the control room to preserve battery life and relocate to some other place in the plant where you do things from that location. But if a new applicant came in now that proposed that same strategy for an extended loss of AC power, would that applicant be held to higher scrutiny because it could be judged that they are not

1	minimizing, in fact, they're increasing the need for
2	operator actions?
3	MR. McKIRGAN: And this B- so, yes, this is
4	where the guidance comes in, because as you can see, this
5	is a very high-level language in the requirement, in the
6	regulation. And then the guidance is what's providing
7	one acceptable means to meet that requirement. It's very
8	difficult when you start to get into speculation about
9	what B-
10	MEMBER STETKAR: I'm just trying to
11	understand, you know, what different philosophical
12	criteria are going to B- I tend to provide specific
13	examples, but to try to understand the different
14	philosophy that might be applied to a new design
15	certification applicant coming in tomorrow compared to
16	one that's already been accepted.
17	MR. McKIRGAN: And I think that is captured
18	in Appendix A to the Draft Guide.
19	MEMBER STETKAR: Okay.
20	MR. McKIRGAN: And I think if you haven't
21	had an opportunity B-
22	MEMBER STETKAR: I have not had an
23	opportunity to read that, so I will.
24	MR. McKIRGAN: So, that B- and, again,
25	that's a Reg Guide, that's not the requirement, but it

is one acceptable means. And, again, as Tim started the discussion, the major focus here is to get this out for stakeholder feedback, to have the dialogue.

MEMBER STETKAR: Okay, thanks.

MR. REED: Any further questions for George on Slide 7? All right.

Slide 8, then we'll go to Paragraph F and G of the proposed rule. And as I note there at the top, this is basic B- it is the same as what was presented back in November, so just to remind folks, those are provide the drills and/or exercise requirements and change control is Paragraph G. The drills, of course, include an initial drill that would show use and transitions between the various guideline sets. Then there's a follow-on periodicity of every eight years to show continued capability of that B- those transitions and use of the integrated capability of these multiple sets of guidelines.

It is rather complex. It's B- you know, in fact, you'll find if you go back into the questions, we actually have a question focusing on this issue in terms of the structure of the periodicity, if you will, of the drills, and to ask for stakeholder feedback as to whether that aligns well with the EP drills. They also have, essentially, an eight-year period type of

periodicity to them because the intent here is to enable flexibility to licensees to most efficiently address these kinds of drills and exercise requirements. And if necessary B- if they can in one fell swoop in terms of combining drills and exercises, so that was the intent.

So, this has been B- is basically unchanged since

unchanged. It is, in fact, entirely unchanged since November, but again we have an additional question there to understand from external stakeholders whether there's any need to change this, or improve it, and to align it better with other EP exercises.

MEMBER POWERS: Is the eight-year periodicity of the drill the product of deep thought?

MR. BOWMAN: The deep thought that went into it was an attempt to align with the existing periodicity for the EP exercise program, and the Appendix E inclusion of the drilling on the B5B strategies. One of the other things we're doing is removing the B5B strategy demonstration from the EP exercise program and moving it over to the requirements here for the Paragraph F drills or exercises in order to provide more flexibility to licensees on whether to do a separate drill for that, or include it in the emergency preparedness exercise.

MEMBER POWERS: It did not include anything

1	about the ability of human beings to retain experience?
2	I can think of nothing that happened eight years ago that
3	I can even recall, so B-
4	MR. BOWMAN: I have nights like that, too.
5	MEMBER POWERS: My entire life is like that.
6	MR. REED: Actually, Dave Desaulniers is
7	C-I think he's got perhaps something to say.
8	MR. DESAULNIERS: Okay. As a member of the
9	working group, just to add B-
10	CHAIR SCHULTZ: Go ahead.
11	MR. DESAULNIERS: B- that you raise a good
12	question.
13	CHAIR SCHULTZ: For the record, just please
14	announce yourself.
15	MR. DESAULNIERS: David Desaulniers.
16	CHAIR SCHULTZ: Thank you.
17	MR. DESAULNIERS: Just keep in mind that the
18	eight-year periodicity is for drills, and while you can
19	look at those as training opportunities, you heard
20	earlier training is implemented in accordance with a
21	systems approach to training. Part of that system is to
22	look at the periodicity of the training, insuring that
23	it's sufficient. So, there shouldn't be training
24	ongoing outside the drill periodicity.
25	MEMBER BLEY: Are these drills that the

1 Staff would track closely, or is this just that they need 2 to do these drills, and perhaps could meet 3 requirement by other drill requirements that they 4 already have in place for other organizations that 5 observe them? MR. BOWMAN: The drills would be subject to 6 7 the Reactor Oversight process, viewing an ordinary 8 drill, as is done for the fire response drills, and all 9 other drills. 10 MEMBER BLEY: The resident might submit B-11 MR. BOWMAN: Exactly. That's the level of 12 oversight we would see for that. 13 CHAIR SCHULTZ: It's not a graded exercise. 14 BOWMAN: Unless they incorporate it 15 into doing it at the same time as an emergency 16 preparedness exercise. And then we wouldn't be strictly 17 looking at these aspects of it as parts of the graded 18 portion. The EP exercise is graded for meeting 19 requirements as an EP exercise. We wouldn't extend the grading to the SAMGs, for instance. 20 21 MR. REED: Okay. Let's go to the change 22 control portion on the bottom of this slide. That is 23 unchanged, too, and this is a B- as I think I spoke to 24 back in November, it's a very basic, nominal I'll call

it change control provision for Beyond-Design-Basis. We

recognize that the current change control provisions that are in place, whether it's 50.59, 50.54(g), or 50.54(p) fire protection, whatever it is, those each are B- I'll call these design-basis type change controls, they focus on a certain regulatory area, and we are fully B- we understood that in large measure I'll say those were "blind" to a Beyond-Design-Basis type situation, so the idea here is to have a change control that looks at the Beyond-Design-Basis aspects of this regulation and its implementation, and that a licensee would nominally have to look at changes to the facility, understand those changes, include that they continue to comply with the requirements and document that and maintain it, so that's the idea.

Then, of course, if you look in regulation you'll find that we also indicate that you need to apply your currently existing change control provisions because as I think the Committee is probably fully just from the discussions aware in place modifications went from the Mitigation Order, for Strategies it's very easy these modifications to touch on multiple areas. Touch and, in fact, impact safety-related systems, structures, and components, that clearly brings in 50.59. Brought fire protection equipment that will bring into play fire

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

protection change control. It can go into EP, it can go into security, so depending on what the change to the multiple is, it can affect regulatory areas, which each have their own change control provision. So, it is B- now, this is a very complex situation, and what we're trying to do is address the Beyond-Design-Basis, insure continue to do what they have to in the other change control provisions so they don't offset anything to do with the licensing basis there. So, that's the intent.

I do understand that in a previous life having to do change control and doing this kind of thing, there are lots of opportunities going back and forth where this can be very complex, and one change control provision could stop another or create some interface issues, and we probably need to sort that out. And, hopefully, we'll get great stakeholder input on any kind of disconnects like that. For example, if you're in Beyond-Design-Basis space and you want to go and take a B- say open a security door because that makes sense for mitigation, maybe your security 50.54(p) or something else stops you from doing that, or it may appear to stop you from doing that. So, those are the kind of interface issues we want to sort through and make sure that they're not stopping us from doing what we need

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

to do, and that we can implement these Beyond-Design-Basis requirements.

So, all that's kind of built into this, and I look forward to getting a good set of feedback on this. It does not, unlike any other change control provision in place, have a threshold criteria, and I'm talking about, if you're familiar with 50.59, there are eight such criteria. And, typically, the other ones have I'll call it a reduction of effectiveness criteria. There's no such criteria that says hey, if you cross this line, you come to NRC for prior review and approval. It simply indicates hey, you must continue to comply with the regulations. You must reach that conclusion, and you must basically maintain that documentation there so we can come and look at that later.

That's not a great deal of flexibility on the part to the licensee, and I understand that, so it's an area where we're seeking external stakeholder input. You can see that in one of our stakeholder questions to say whether there's a better way of doing it, or there's been an improved way to do it under what we're suggesting here. That's all exactly the same as it was previously.

CHAIR SCHULTZ: Tim, did you ask for stakeholder feedback on the frequency of the drills?

MR. REED: Yes, we did. We, actually B- we

just added B- I think we might have added it. I don't know if you have it, if we added it after it went to you or not. I can't keep track of the changes going on but, yes, it was looking at the frequency of these drills versus the frequency of your EP exercises. (A) How does that match up? Is there B- you know, does that work together, is there a way of doing it better? That's the kind of question that we're looking at, so we do have one on that, also.

CHAIR SCHULTZ: Thank you.

MR. REED: Any other questions on this slide? Appendix E, these also remain unchanged. As you'll recall, these are the B- what I refer to as the B- enhanced onsite onsite emergency response capability type requirements. They are located in Appendix E to 10 CFR Part 50 either directly in the current part, existing parts of Appendix E, or as a new the Section which contains staffing and communications capability requirements.

Then in addition, of course, we also have made basically what I view as a cleanup to the ERDS requirements in Appendix E that reflect what is already in place in terms of not referring to any kind of technology there. So, we're fixing that part of the regulation as part of this, also. But this goes to the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

B- what I call the multi-source-term requirements, and also the equipment to support those B- doing those assessments.

Right now, it would be B- if you go and look at this, would require licensees to be able to do multiple source-terms, even a single unit would have to be able to handle releases from the reactor and the spent fuel pool at the same time, and through multiple points.

Of course, multiple units, multi-units it's a more complex situation, so that's building this capability into Appendix E.

This is something that was being done post-Fukushima by the industry. We expect that as a result, though it is a backfit, is in fact done and should be of very little or no impact, so that's going into Appendix E. And the staffing and communications requirements here reflect the 50.54(f) request for information of March 12th, 2012 where we requested licensees to basically do an analysis of their staffing for a Beyond-Design-Basis type event that affects the entire site. They, in fact, are responding to that, so that's ongoing. Again, this would simply reflect that staff requirement, and also those communications capability part of that response or that RFI. And that, again, this reflects that request for information, so

that's building that into Appendix E.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

So, that's Appendix E. That is unchanged. The application requirements saying those are basically unchanged. I think there is some B- and this is what I call the content of applications. There's a lot of regulation if you go and look in there in Part 50 and Part 52 about if you want to come in with a new reactor application under either process, Part 50 and Part 52. So, there have been some changes George Tartal was mentioning before, we made some changes now about forward fitting basically design requirements. So, for example, 52.59 was a certification of a current B- renewal of a certification for a current certified design. That's not there, but that's now been changed to reflect what George just said earlier in terms of the new design requirements on new designs forward fitted. otherwise, those application B- content application requirements reflect exactly, I believe, unchanged from what was in what you saw in November.

The implementation now, if you go back to November and you look at that, we basically gave you kind of a high-level list of items that in our view would kind of drive the issue in terms of how much time do we have to give licensees to implement this once this regulation goes final, and you hit you effective date. How much time

are folks going to need? And we tried to list a couple of items, areas there where we think there would be kind of pacing, what would be the implementation period.

Now you'll see in there it's essentially a B- it's marked to two refueling outages, and we actually have a question on this because we recognize that it may not make sense to tie implementation of this rule to refueling outages, but the proposed rule as written right now would basically say you'd have to implement it two refueling outages following the effective date of the rule; basically, when you're coming from startup and withdrawing rods. So, it made sense to make that four years or something else, and we have the question, stakeholder question on that. And, of course, we'll pursue that as part of our CER process as we get to the final rule, we see where we are, we see what licensees have on their plates. We'll revisit this and see if we've got it right.

And I'll just reflect back to an earlier slide where I mention we may have some challenges with implementing 155(c)(2), that would be another aspect of this we have to be mindful of to see whether that implementation is appropriate. We may need to build some flexibility or some criteria into the implementation of that provision, again, mindful of the fact that we have

to get a Draft SRM from the Commission on COMSECY-14-0037. And we're obviously going to comply with that regardless, so that's a driver on that. So, implementation now you do see the language there as opposed to a high-level set of bullets that you saw in November. So, I'll come to full stop and see if folks have any questions on this.

Okay, backfit considerations. This will be the first time we've had a discussion on backfit today. Huh? That was supposed to be a joke. So, this is B- this slide was I think identical to what I provided before. And I don't think it's really worthwhile going through it with basically all the backfit discussion we've had today.

We've developed the proposed rule such that if the Commission, in fact, does not agree with the Staff and our qualitative basis for imposing SAMGs, that we can, in fact, adjust the regulation. And we definitely can do, and so we're ready to do that if that's the direction we get. So, that's the first thing. I've committed to the Commission back in B- was in SECY paper B- one of the updates to Fukushima from 2014, I think, that I would do that, so we can do that. And, if necessary, we will do that.

But in large measure, most of the

requirements in this rulemaking are going into place right now. In large measure, they're being imposed under orders, most of them. The vast majority are being imposed as a result of implementation of EA 12-049, the Mitigation Strategies Order. But we also reflect the spent fuel pool level, as EA-12-051 said. That's already in, those are in place, those are not backfits as a result because they've already been imposed.

The rest of this, you'll see some discussion of other areas where technically they would be backfits. I mentioned just now recently the multi-source-term requirement. That would be a backfit. It's a new requirement, but in fact licensees are implementing it voluntary, so that's a new requirement without impact, as far as we understand at this point.

SAMGs and everything that support SAMGs, as I mentioned earlier, are backfits. And, of course, we've had quite a bit of discussion on whether we have a good valid basis on that. And I have a next slide on that coming up, and we can B- if you want hold it, or we can have some more discussion this slide.

And we mentioned earlier that we have new reactor requirements, and that's in, of course, 155(d). And those are forward fitting, and that's why they're not an issue for us in backfit, you know, since it's

1 really about implementing a new reactor policy and 2 trying to implement the Commission's ideas there, what 3 the Staff believes those are, so we've got that 4 discussion. 5 And, in fact, additionally, what I view as simply cleaning up the ERDS requirements to reflect what 6 7 is in place now, and remove references. There's a 8 reference right now in there about NRC replacing a 9 modem. Nobody uses that any more, so it's an opportunity 10 to clean up the requirements for ERDS. I'll come to a 11 stop, and if you want to we can talk about backfit here, 12 or we can go to the next slide and talk about the backfit 13 again, if you want. 14 CHAIR SCHULTZ: Let's stop for a moment and ask if there's questions on this slide. 15 16 MR. REED: Okay. 17 MEMBER REMPE: A long time ago when they did 18 the Advanced Reactor Policy Statement, what was C-- it 19 was before I was on ACRS, and what was the Commission's 20 motivation for imposing more requirements for severe accident instrumentation on the new reactors versus the 21 existing fleet? 22 23 MR. McKIRGAN: If I could begin, this is 24 John McKirgan. The Policy Statement does not impose any 25 requirements, so it was intended to provide

1 opportunity for the vendors to voluntarily provide 2 these features, but it does not impose requirements. 3 MEMBER REMPE: Westinghouse did not have to 4 do that analysis, and that's why it's a fuzzy thing with 5 the Staff interacting with them on it. MR. McKIRGAN: Let me see if I can say it 6 7 correctly, and someone from the audience can correct me if I'm wrong. But I believe it's a concept of application 8 9 requirement, so there's a requirement that they have to 10 provide information in the application on those things. 11 And there is, of course, the Policy Statement from the 12 Commission, so the Staff in conducting our reviews looks 13 at those things and considers them. Of course, the 14 vendors first have been mindful of the Policy Statement 15 and the content of application requirements, and have 16 provided these features. So, it's a combination of the 17 voluntary input provided by the vendors and then the 18 quidance that's used by the Staff during the review that 19 gets us B-20 MEMBER REMPE: Never any discussion well, 21 the Commission decided, you know, we think this is just 22 needed for adequate protection, for example? 23 McKIRGAN: I don't MR. have that 24 background. I could not answer that. 25 MEMBER POWERS: I'm not sure what

1 question is, Joy? MEMBER REMPE: Well, it seems to be the new 2 reactors have gone ahead and looked at severe accidents 3 4 and the instrumentation survivability for whatever 5 reason, and I'm just wondering B-MEMBER POWERS: Required to because they're 6 7 required to have a PRA. They're required B-8 MEMBER REMPE: They have a PRA, yes. But 9 they look at instrumentation, too. 10 MR. MONNINGER: So, if you may allow, this 11 is John Monninger of the Staff. I'm the Director of 12 Division of Safety Systems and Risk Analysis from the 13 Office of New Reactors. You know, the first question was 14 with regard to the Advanced Reactor Policy Statement, 15 and the original timing of that was very closely aligned 16 also with the Severe Accident Policy Statement, which 17 came post-TMI, and the Commission's expectations for 18 new reactors, or advanced reactors to have high levels 19 of safety, and particularly higher levels of severe 20 accident safety performance. 21 We can talk about the AP1000, the AP600, the 22 ABWR, the System 80+. Back in 1990, the Staff proposed

various policy positions to the Commission. One of those policy positions was something called Equipment Survivability, and out of that policy position the Staff

23

24

did impose those requirements on applicants for both equipment and for instrumentation, for instrumentation post-severe accident, prior to severe accident and post, so we looked at various profiles. The Staff did MELCOR calculations, the applicants did a series of MAPP calculations to come up with quasi bounding profiles for the equipment, and we spec'd out, or the applicant spec'd out equipment within the design certifications for both the prevention and mitigation of severe accident, and also the instrumentation necessary for that. So, that's B-

MEMBER REMPE: Okay, that helps a whole lot.

And what I'm not hearing you say is why, was it deemed that's needed for adequate protection?

MR. MONNINGER: So, in those days we B- for the good or for the bad, we developed what we called Policy Positions. We didn't say whether they were for protection, they adequate weren't necessarily substantial safety enhancements. There was, you know, a lot of qualitative discussions in there, but there was no type of backfit discussion done at that time. It was the positions, there as probably, you know, 10, 15, 25 of them that were generated over five years or so, and intended the Commission's they were to meet expectations for the Severe Accident Policy Statement

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

for closure of severe accidents, and also the Commission's expectations within the Advanced Reactor Policy Statement, but wasn't an explicit analysis against the Backfit Rule in those times.

Subsequently, many of those provisions were codified within Part 52. You know, I don't have the exact accounting for which ones did roll up into Part 52, and which ones didn't, there were issues with direct containment heating, steam explosions, the equipment survivability, hydrogen control, all those types of issues. And that's where the instrumentation for new reactors or advanced reactors comes in.

MEMBER REMPE: Thank you very much.

MR. REED: I was just add, too B- you mentioned the Severe Accident Policy Statement. If you go to Appendix A of the Draft Reg Analysis you'll see I walk through a little bit of the history on SAMGs, and I do have some quotes out of the Severe Accident Policy Statement from 1985. And you'll see the Commission at that time concluded that severe accident risk was not an undue risk to public health and safety. Of course, then they hedged and said, of course, if you identify any kind of vulnerabilities we would address those under backfit, and as you folks probably are well aware, along later in the decade came 88-20 that was looking exactly

at those IP and IPEEE, those vulnerabilities. But, nonetheless, at that time they had to conclude no undue risk to health and safety of the public on the Severe Accident Policy Statement itself. So, these would be causing future reactors go beyond that and to be much safer. I think the risk results that they are, in fact, submitting would show that they have achieved significant levels of safety improvement for new reactors. So, just adding to what John just said.

MEMBER REMPE: Thanks.

CHAIR SCHULTZ: Go ahead.

MR. REED: All right. So, let's go to SAMGs where I sense there's -- the Committee is not in full agreement with the justification. We started this thing off talking about the quantitative analysis that IB- or it was informed by quantitative information, and also the qualitative basis I provided. It sounds like folks have B- do like the qualitative arguments that I provided there. I do B- you know, I boil this down to it's a very simple argument because I think it's very easy to relate SAMGs to the qualitative arguments in terms of defense-in-depth. They are, in fact, the B- I'll call it the command and control guideline set, if you will, once you go past core damage. They're informing the decisions that you make with containment,

or how you try to maintain containment under human control, and containment is clearly one of the most important defense-in-depth features in the facility in terms of fission product barriers. And they also do inform or can inform any decisions made by the onsite emergency response organization for protective actions either on site or off site, so that goes to EP. And that's another one of our fundamental foundational defense-in-depth parts of our regulations.

So, you saw those arguments. I think they're very good arguments from a qualitative standpoint, but I'm mindful of the Commission's SRM here recently, and unfortunately it came just a couple of weeks B- about a week and a half ago, the early part of this month on qualitative factors. So, I think, as I mentioned earlier, it's up to the Commission to decide the weight that they want to put on the qualitative factors given what I think is B- I personally think, I think the Working Group believes is really good risk information to inform our decision, recognizing B- and I think I've got to be a little more careful on how I characterize it, as Dr. Stetkar discussed, and we discussed earlier with the Committee. But I do think there's a lot of value in looking at the information coming out of the containment protection and release

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

reduction.

Again, as I mentioned earlier, I think that analysis demonstrates what I think what you should expect, and which I think is a great story for safety, that the 50 plus years of regulation and infrastructure the AC and the NRC have put in place, have in fact driven down severe accident risk to a very low level such that when you do look at it and you try to quantify it, and you try to show B- and you do show benefits. I mean, even that work shows benefits, too. Whether that meets our backfit criteria. I don't think it does, and I think it strongly enough to suggest you won't get there.

Now, we can disagree on that, whether we could go off and do a detailed look with a PRA or some sort of risk analysis that looks at SAMGs more fully and tries to get at their benefits quantitatively. I think B- I bet that that would come out pretty much around the same answer, and that's what I'm suggesting. So, again, that was an effort to provide a full complete story to the Commission, as I said, both sides of the equation, everything I know about risk, everything I know about the qualitative arguments that are very strong for defense-in-depth, and let the Commission make that decision.

I think personally, it's worth the

get the feedback from industry and external
stakeholders, but if the Commission wants to decide that
no, it's B- you know, based on the recent decision on
qualitative factors they want to B- of course, I can,
in fact, adjust this regulation. It might take B- it
actually would probably take a little bit of time, a
couple of weeks, but we definitely can do that and adjust
to remove SAMG requirements, if that's the direction.
But this was B- I did have last time if you recall a
little bit more detail about the CPRR work. I'm
sensitive, I was sensitive to some of the issues here
already. I tried to remove that. In fact, I removed the
figure. You won't see that in here. That was in the last
presentation that came right from the CPRR with the
bounding number, if you guys recall. So, that's B- I'll
come to full stop. Let me just stop talking and allow
you guys to start talking, so how's that?
MEMBER SKILLMAN: Tim, second carat under
the first bullet, "Decisions Concerning Containment."
In that context is containment a noun or a verb?
MR. REED: I'm thinking of it as a noun. In
other words, I'm thinking B- I'm trying to make any

Commission to put that out for stakeholder feedback and

decision to keep that barrier under human control. I

don't want to lose the physical integrity of that

1	boundary because then I'm done. Right? So, that's
2	exactly how I think about it.
3	MEMBER SKILLMAN: Okay, so in that context
4	it's containment integrity.
5	MR. REED: Yes, I think you could think of
6	that as B- and we B-
7	MEMBER SKILLMAN: Okay, let's B-
8	MR. REED: We've had that discussion.
9	MEMBER SKILLMAN: We're going to get into it
10	in 13-01 in a minute B-
11	MR. REED: Yes.
12	MEMBER SKILLMAN: B- because I want to
13	point out the inconsistencies throughout 13-01. So,
14	what I want to suggestion here is words matter, and
15	written words matter more.
16	MR. REED: Absolutely.
17	MEMBER SKILLMAN: And here, this is
18	containment integrity. I think somewhere in this
19	discussion you need to weave in containment integrity
20	and containment cooling, because while they are
21	considered one and the same, they are, in fact,
22	different. For example, containment integrity gets to
23	the liner, or the vessel, any vessel, whatever might be
24	used in the valve seals, what your last leak rate test

confirmed; whereas, containment cooling can get into

Τ	spray, boxear rais, other activities that you would
2	B- or other functions that you would use to cool. So,
3	I think there needs to be clarity around this term. And,
4	more importantly, as you did in 13-01, there are 12 or
5	13 different places where you used this term, and
6	sometimes you used the term containment integrity,
7	other times it's containment cooling, and it isn't
8	consistent. So, I want to just lob that now and we'll
9	talk about it a little more in 13-01.
10	MR. REED: We can certainly wait until
11	13-01, if you wish.
12	MEMBER SKILLMAN: 13-01 is fine. I think
13	that's the better place to talk about it.
14	MR. REED: Okay.
15	MEMBER SKILLMAN: But I think when you talk
16	about it, you better be specific as to containment
17	integrity, or containment cooling.
18	MR. REED: The good news is Eric is going to
19	present 13-01.
20	MEMBER SKILLMAN: Okay.
21	MR. BOWMAN: Well, I'm going to present that
22	we aren't really ready with 13-01 completely yet, as we
23	don't have a complete version of the underlying proposed
24	industry guidance. And we are also awaiting the decision
25	on the COMSECY-14-0037. I think we can talk about the

containment portions. The one thing I would suggest,
though, it's not just integrity or cooling, the words
that we used in the original Mitigating Strategies Order
and the words that we're using in the proposed rule are
containment capabilities. And that also encompasses for
Mark 3, and estimates of containments, the backup power
for the hydrogen igniters.
MR. REED: I think mass and energy. Yes,
there's a lot to it.
(Simultaneous speech)
MEMBER SKILLMAN: And there's one incident
in 13-01 where it is containment capabilities, so it
seems that there is an opportunity here for
clarification.
MR. REED: Oh, yes.
MEMBER SKILLMAN: Thank you.
MR. REED: No other problems with the SAMG
backfit?
CHAIR SCHULTZ: No. I guess, Tim, the only
comment I'd have is that going back and forth between
qualitative and quantitative, I would precede each of
the four bullets that you have there with the value of,
the way you did it at the bottom. I mean, each of those
has significant value.
MR. REED: Oh, yes. Sure.

1 CHAIR SCHULTZ: And the other piece of this, 2 although there's a great amount of detail associated with costs associated with performing this, imposing 3 4 the requirements, much has already been done. And I 5 didn't go through carefully and dissect that, but things 6 are moving B- things have moved forward, things are 7 moving forward, and so it's certainly B- well, I think 8 we're talking about codifying what is in place and 9 assuring that it stays in place, and it doesn't drift 10 the way some, only some have drifted in the past. 11 MR. REED: That's exactly what we're trying 12 to do. And when we did the analysis of cost, we tried to B- the costs have been, I'll call sunk costs to date 13 14 were not costing that's going forward, which I think is 15 a fair way of doing it, too. 16 CHAIR SCHULTZ: It is the right way of doing 17 it, certainly. 18 MR. REED: And I do agree there's value in 19 them. And I personally think the value is largely in 20 maintaining the containment under human control. And I 21 think I made those arguments pretty clear, because the 22 containment is there for one reason, it's to contain 23 fission products, and fission products, when you have fission products, you got core damage, and where are 24

you? You're in SAMG space, and so that to me is a direct

1 link, and I've said that many times before. So, it's a 2 pretty strong argument from the defense-in-depth standpoint. 3 4 CHAIR SCHULTZ: Any other comments before 5 we break? We have reached the time for a break, and after 6 the break we'll go into the discussions related to the 7 Draft Regulatory Guides. So that we go into that with 8 sufficient energy, I'll call a break until 3:35. 9 (Whereupon, the above-entitled matter went 10 off the record at 3:15 p.m., and resumed at 3:34 p.m.) 11 CHAIR SCHULTZ: I would like to bring the 12 meeting back in session and on the record. And we'll 13 proceed then with the discussion on the Draft Regulatory 14 Guidance. Eric Bowman, welcome. 15 MEMBER REMPE: Can I ask a question that's 16 kind of a holdover from earlier discussions this 17 afternoon? 18 CHAIR SCHULTZ: Go ahead, Joy. 19 MEMBER REMPE: We talked about the Severe 20 Accident Management Guidelines, and I know at one point, 21 Tim, you mentioned well, even if they use the old one 22 and properly trained on it, and implemented it, it would 23 be there. It's pretty good, but I read the Draft SECY. 24 It discusses that the BWR Owners Group and the PWR Owners 25

Group have new SAMGs, and it says the Staff will not be

reviewing them. And I guess I'd like to know have you looked at them, what's your thoughts, are they sufficient or deficient? I mean, this is kind of important. Again, why do this if you're not to have some sort of oversight?

MR. REED: Sure. I can tell you what we have done. And I tried B- I mentioned a little earlier we had I think it was a one or two-day public meeting where we interacted with the SAMG experts, some of which are here. We also were granted access to an e-Portal which we've looked at the SAMGs that are in existence in the e-Portal, so we're familiar with that. We actually had a member of our research staff, Ed Fuller, who is a SAMG expert from back in the day also, he also looked at the Technical Basis Document. I think I mentioned that the Technical Basis Document from EPRI, if not 2012 version update the 1992, added five candidate high-level actions of lessons learned. I believe it's five. I might be wrong, but I believe so. I'm checking my memory here. Lessons learned from Fukushima, so we've done all that work.

But that's different, and I want to make sure, I don't want to over B- but that's different than reviewing it. You know, that's having a lot of familiarity with it. I think we used looking at it, you

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

know. I'm not even sure we can say audit, you know. Each
of these words mean something to us, and if I'm going
to review that, then I need to have that submitted to
me. Then I need, I think, to have some sort of criteria
of what I would look and find acceptable. That works us
into a pretty structured format, and that's what I was,
you know, saying what we have not done to date, and
that's why we structured it admittedly with a light
regulatory footprint not to do that. You know, basically
that B- going back to this idea about hey, do you have
them? Are they in place? Are you keeping them up to date?
Not getting into the licensing up front review and
approval type process, so is that helpful?
MEMBER REMPE: Not totally, because B-
MR. REED: Okay.
MEMBER REMPE: B- you've B- I believe you
mentioned in your discussion, or someone did that well,
if it doesn't reflect the plant, we'll clearly say
that's not working. But what if you just don't think it
B- I mean, do you think they're adequate with what you
reviewed? I mean, the B-
MR. BOWMAN: What we're standing from is in
the 1990s we had a significant amount of interaction
with the EPRI and the parties that were developing the

basis for the Severe Accident Management Guidelines,

the Technical Basis Report, and looked at the Owners Groups guidelines, including modifications to it, and concluded that they were good enough for us to forego further regulatory action on the subject of the SAMGs, and leave them as a voluntary industry initiative. We would be building on that view of the Severe Accident Management Guidelines, and we also have an outstanding offer from the Owners Groups as a joint submittal from the BWR Owners Groups and the Pressurized Water Owners Group B- Pressurized Reactor Water B- Pressurized Water Reactor Owners Group to submit any changes on a future ongoing basis to the Severe Accident Guidelines so that we could keep up to date on them and maintain currency, and the assessment that they were adequate to meet the needs. It would not be a licensing-type review. That's where we are with it.

MEMBER REMPE: So, you do review them for adequacy? And you B-

MR. BOWMAN: We have not taken that offer up to date. It really depends on what happens with the rulemaking, the treatment. We haven't completely settled that. That will be further settled when we get feedback from stakeholders, and it'll depend on, of course, whether or not Severe Accident Management Guidelines, in fact, become requirements, or what the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 final disposition is. 2 MEMBER REMPE: Okay, so depending on the 3 outcome, you have an offer from industry that you can 4 B- I don't know B- review is a bad word, maybe, I don't 5 know, but review them for adequacy, and if there's some point of contention there can be follow-on discussions? 6 MR. BOWMAN: Yes. We have to remain mindful 7 8 that we cannot delegate to the Owners Groups the 9 authority to set what is acceptable legally to meet a 10 requirement. We can look at a public document such as the Technical Basis Report, and judge whether or not we 11 12 think that it provides sufficient basis to develop the 13 Accident Management Guidelines Severe 14 licensee-specific basis. Those are some hurdles that we 15 haven't crossed yet. 16 MEMBER REMPE: Okay, thank you. And that 17 you, Steve. 18 CHAIR SCHULTZ: Thank you. Okay, Eric. 19 MR. BOWMAN: Okay. Draft Regulatory 20 Guidance. We've provided as part of the Draft Proposed 21 Rule package three Draft Regulatory Guides that would 22 propose to endorse a number of documents that were 23 developed by industry to provide guidance. 24 Rather than going in the order that they are 25 listed on the slide here, I'll just start out with Draft

Guide 1317, which is on the wide range spent fuel pool level instrumentation, because I think that'll be the easiest one to cover with the Committee.

The proposed requirement in 155(c)(2) is to make the orders, EA-12-051 generically applicable. The way we've drafted that portion of the proposed rule is a high-level requirement that lacks a lot of the specificity that was in the order, itself. But we are carrying forward the guidance that was provided by industry for the order as endorsed by JLDISG 2012-02 with no changes. So, what you got for Draft Guide 1317 is really just that Interim Staff Guidance put into regulatory guide format.

The second one to discuss, Draft Guide 1301, is the guide on the mitigating strategies portion, the portion that would EA-12-049 generically applicable. It also includes an Appendix A that provides the guidance for new reactor designers to meet the Paragraph D portion of 50.155. And then the third one would be Draft Guide 1319, which deals with the other aspects of the proposed rule.

The state of development for Draft Guide 1301, it's a very preliminary draft right now. We've had several public meetings with industry and public stakeholders on the subject of the revision to NEI

12-06. Currently, we have Draft Version C of Revision

1. It's taking some feedback that we've provided and
it's B- the intention of the revision to NEI 12-06 is
to address lessons learned in the implementation of the
requirements of the Mitigating Strategies Order.

The other thing that is going to ultimately be dealt with in Revision 1 to NEI 12-06 is the reevaluated hazards under the 50.54(f) letter of March 12th, 2012. We're still awaiting the Commission's guidance in the SRM on COMSECY 14-0037 in order to proceed further on the development of guidance for how that should be dealt with.

You've seen in the presentation earlier and in the proposed rule language that we have proposed at least as a starting point for seeking stakeholder input on how the mitigating strategies should deal with the reevaluated hazards. Once we get the SRM on that COMSECY, we'll get further along with the discussions with stakeholders, including the Industry Working Group, on how to address the reevaluated hazards.

My understanding is that the Industry Working Group is going to propose an Appendix G to add to NEI 12-06 that will address the reevaluated flood hazards, and potentially an Appendix H for reevaluated seismic hazard.

So, what you've got is a B- you can think of it as a rough draft of what we would put out in Draft Guide 1301 to seek public comment on the regulatory guidance as it's developed to date. We intend to finalize the Draft Guide to include guidance on the reevaluated hazards, and clear up some of the typographic errors, if you will, that Dr. Skillman pointed out, so that we have a more complete product when the proposed rule package is published. Right now we're shooting for this summer as B- insuring that we get the Draft Guide more fully developed. And we are, of course, happy to come and interact with the Committee again when we're further along in that development process.

MEMBER SKILLMAN: Eric and I were off the record when we sat and spoke for several minutes during the break. I went through this Draft Guide very thoroughly and there are about 13 instances where the term core cooling containment and spent fuel cooling is used, but not all 13 instances are the same. Sometimes sometimes it's containment it's containment, integrity, sometimes it's containment function, sometimes it's containment cooling, so I pointed that to Eric that that phrase should be used consistently each time it's used in this guide for the record. Thank you.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 MR. BOWMAN: Thank you for that. Are there any other questions on the main body portion of Draft 2 Guide 1301? 3 4 MEMBER SKILLMAN: I do. I have one. It is on 5 page 3 of the Draft Guide. It is the second paragraph 6 from the bottom of the page, and this paragraph communicates that the Commission-issued memorandum 7 8 which included requirements for mitigation strategies 9 as a license condition for Virgil Summer Stations 3 and 10 3. And my question is about what Vogtle 3 and 4? 11 MR. BOWMAN: Vogtle 3 and 4 were subject to 12 the Mitigating Strategies Order EA-12-049 because it 13 was issued contemporaneous with the issuance of their 14 combined license. 15 MEMBER SKILLMAN: So, it's a chronology 16 issue. 17 MR. BOWMAN: Yes. It's just Summer's Units 18 2 and 3 didn't receive their combined licenses prior to 19 the issuance of the Mitigating Strategies Order, and 20 they were issued license conditions along with a 21 combined license. 22 MEMBER SKILLMAN: Thank you. 23 MR. BOWMAN: If there are no other 24 questions, I'll have Clint Ashley from the Office of New 25 Reactors to discuss the content of Appendix A for Draft

Guide 1301.

MR. ASHLEY: Thank you, Eric. Good afternoon. I'm Clint Ashley. I'm from the Office of New Reactors. I was a member of a team that was put together to put this preliminary Draft Guidance for Applicants for New Nuclear Power Plants, and there's other members in the audience that if your questions get more detailed, we can certainly draw on their expertise.

Draft Guide 1301, Appendix A contains guidance that provides applicants for new nuclear power plants with an acceptable method to meet the proposed rule. This slide highlights guidance related to coping duration and human actions, which are areas that are not covered in NEI 12-06 for meeting the proposed rule, as Eric just summarized.

So, to enhance coping durations, the design features should increase the amount of time that safety functions can be maintained early in an event before there's a need to augment the plant with onsite portable equipment, or possibly even transition from plant equipment to onsite portable equipment. And we believe that enhancing coping durations provides the operators with the time to plan and implement the onsite portable mitigation strategy for the longer term coping. So, with respect to the initial coping phase, enhanced coping

durations means coping with installed plant equipment for at least 24 hours.

And we looked at this, we looked at the existing designs, the AP1000, the ESBWR, and they had coping durations, initial coping durations out to 72 hours. We looked at the Advanced Boiling Water Reactor, it had initial coping duration out to 36 hours. We looked at operating plants in general, and we saw some initial coping durations that were on the order of five to eight hours. Eric, please correct me if that's B- it's a rough general idea about coping durations.

So, we also spoke with the Staff that had been involved with the Fukushima activities, read the Near-Term Task Force reports, and we came up with a judgment that we felt that 24 hours would provide an operator with ample time to implement the mitigation strategy, keeping in line with this rule requirement that says we need to have enhanced coping durations. That's for the initial response phase.

Now, as far as the concept of enhanced coping durations, we also applied that to the transition phase, which is where you would B- at the end of that transition phase you would bring in your offsite equipment. So, we viewed that B- again, we looked at the current certified designs and their capabilities, and

so we came up with a judgment that the coping for that transition phase if we want to bring in that offsite equipment, we expect that to be at 72 hours. And that's consistent with the current fleet of advanced reactor designs. Are there any questions on the B- how we came up with the 24 hours and 72 hours?

additionally, we also Now, have this feature for B- in the initial response phase, we permit use of an installed AC power engineered alternative, and we refer to that as supplemental AC. Again, that has to be protected from external hazards such as the flood and the seismic. The basis for the eight hours was to be consistent with the recommendations in the Near-Term Task Force report. And we believe that this coping duration will, again, provide ample time for operators to start in line the supplemental AC source. It would be permanently installed, normally disconnected from the electrical bus, designed such that only minimal operator action would be needed to put the system in service, and we would expect that it would be diverse and independent source from the emergency AC source.

With respect to human actions, you know, the requirement to minimize reliance on human actions we felt was consistent with the Advanced Reactor Policy Statement, and we modeled this after the Aircraft Impact

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

Assessment Rule. We believe that the benefit of being able to cope with an extended loss of AC power would reduce reliance on operator actions, was also recognized by the Near-Term Task Force report based on the results of insights from the Fukushima Daiichi accident.

So, greater reliance on design features that would include well thought out human-machine interfaces, would reduce reliance on and simplify manual actions necessary to restore key safety functions. So further reducing reliance on human actions would also reduce the potential for human failures during stressful adverse conditions.

So, for the initial response phase which is our focus with respect to design features, the guidance is we would expect minimal operator actions at limited and protected locations, and that all necessary actions to monitor and coordinate the control of the nuclear facility can be performed in the main control room. However, we also recognize that if there's an alternate station that contains equipment specifically designed for that purposes, that it could be also conducted from outside the control room.

MEMBER STETKAR: So, a design that requires that the operators completely de-energize the main

1 control room and shuffle off to another place that has 2 barely enough instrumentation available for them to 3 make sure they're adding some water is perfectly fine, 4 because that minimizes operator actions during a very 5 confusing situation. MR. ASHLEY: The guidance doesn't preclude 6 7 geographically where the operators do command and 8 control, but I recognize that certainly if you were to 9 have to de-energize the control room to extend battery 10 life, that would be a more complicated action, and an 11 applicant would have to do sufficient technical 12 justification and provide that to the Staff in order for 13 them to make a judgment on that. 14 MEMBER STETKAR: Okay. 15 MR. ASHLEY: That's all I had for Appendix 16 Α. 17 MR. BOWMAN: Okay, thanks, Clint. Draft 18 Guide 1319 is the final Draft Guide. In this guide we 19 consider three industry-developed guidance documents 20 majority of the remaining address the vast 21 requirements that would be in place for 50.155. 22 The first of the industry documents, NEI 23 1201 should be familiar. It was the guidance document 24 endorsed for meeting the B- providing that was 25 information in response to the RFI of March 12th, 2012

on the staffing assessment for response to a multi-unit event on site, and also providing the information for the communications assessments.

The other two guidance documents that we're looking at, the industry ones, NEI 1306 and NEI 1401, NEI 1306 deals with the multi-unit dose assessment, the types of training, drills, and exercises, and the necessary facilities for emergency preparedness for a multi-unit event.

NEI 1401 covers the command and control, the integration of the different procedure sets, what would be necessary to create an integrated response capability of all the elements that are in 50.155. And finally to provide some guidance on the development of Severe Accident Management Guidelines.

It points back to the EPRI Technical Basis
Report for the Severe Accident Management Guidelines,
and does make mention of the Owners Groups guidelines.
We do include the we aren't endorsing secondary
references within the NEI document, so this is not
intended to be an endorsement of the Owners Group Severe
Accident Management Guidelines.

I'm not sure if you've had enough time to look through the guidance documents, so we would, of course, be happy to come back and discuss them further

with you, as we'll have to do with Draft Guide 1301 once that's finalized.

MR. REED: And, again, we mentioned a little earlier the timing for the draft quidance is to try to get it B- our process is to issue with the proposed rule, so our estimate on that, of course, is that have to reflect the Commission's deliberation on this proposed rule. We have to take some guess at that, get the SRM, fix the package and get it to the Federal Register. And if you start working those numbers and you be reasonable about it, I think something like maybe July of next year, or this year, I quess, whatever year we're in, 2015, would be about the estimated time that the rule would probably be published, maybe even August. So, with regard to the Draft Guidance and filling in the holes, that would be the kind of time frame I think that we have to finish what we have, have complete Draft Guidance sufficient to get the stakeholder feedback on the Draft Guidance to get to the final guidance.

And then it's up to the Committee. I mean, you guys B- this is, obviously, a very important issue. You guys have engaged with us quite a bit but, you know, in other rules, as you well know, you don't engage on Reg Guides until the Final Rule, so it's up to the Committee whether you want to interact more with us

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	before that goes out, during the public comment period,
2	wait until the Final Rule. Your call. We're here to do
3	whatever it is that you wish in that regard, so that's
4	basically what Eric was suggesting. I think I actually
5	have that on the last slide, too.
6	MR. BOWMAN: I already switched to the last
7	slide.
8	MR. REED: You did, so recognize that that's
9	there. That's a hole right now, if you will, in the Draft
10	Guidance, and industry I think is probably waiting for
11	the Final SRM on COMSECY 14-0037. I know that some work
12	on some of these appendices are going on, so we'll have
13	to see how that sorts out.
14	CHAIR SCHULTZ: Are there any other pieces
15	with regard to 1301 where you're anticipating further
16	appendices, other elements that would, perhaps, be
17	included?
18	MR. BOWMAN: Those are the two major items.
19	The current version, the current draft version of NEI
20	12-06 includes an appendix on AP1000 design and how it
21	can meet the Mitigating Strategies requirements. There
22	had been an effort earlier to generalize that to new
23	reactor designs.
24	And the other caution I would have is that
25	we don't have a final clean version of NEI 12-06, so I

can't tell you with certainty exactly what it's going to look like, or whether or not we will have any further clarifications or exceptions that we need to add to 13-01 until I see a final version. The version that this was based on, this Version DG-1301 was based on was a version that included redline strikeouts and comments that still needed some cleaning up.

CHAIR SCHULTZ: That's helpful, thank you.

MR. BOWMAN: But I did want to give you a

sense of where we are currently with what we view as appropriate guidance, what the state of affairs is right

12 | now.

MR. REED: And that's part of my last slide, the Staff's last slide here on status and path forward. As I mentioned earlier, we are in office concurrence right now. It's ongoing. I'm getting feedback from offices. I'll certainly try to incorporate some of the feedback that we've heard today, too. We need to get this package after office concurrence up to the EDO on the 16th of April, and it needs to go and it will go to the Commission on April 30th. So, that's the schedule. We're on that schedule right now. We intend to meet it. As I mentioned, the Draft Guidance will go out with the Proposed Rule, and that I'm estimating in the summer. And we're certainly here to, if you so wish, we'll try

1 to interact with you, the Committee, as you wish on the 2 Draft Guidance. As you're well aware, the Full Committee 3 4 meeting is on April 9th on the proposed rule. That a much 5 shorter, one or two-hour meeting, but a lot of the 6 Committee Members, of course, are participating. And 7 then, of course, we'll meet with the Full Committee and 8 the Subcommittee, of course, during the final rule 9 process, so that's the path forward and the status. 10 CHAIR SCHULTZ: Other questions for the Staff from members of the Subcommittee? Hearing none, 11 12 I'll thank you now for the work that you've done in 13 preparation, and stay in the room in case there are more 14 questions. We're going to turn to the industry 15 presentation, and for the audience it's just going to 16 be a short break while we change chairs. We're not 17 leaving the record. 18 (Off the record comments) 19 CHAIR SCHULTZ: At this point, I'd like to 20 recognize David Young from NEI. 21 MR. YOUNG: Thank you. Good afternoon. My 22 name is David Young, and I'm the Senior Project Manager 23 in the Emergency Preparedness Department at NEI. With 24 me are Bryan Ford from Entergy, and Bill Webster from

Dominion. We appreciate the opportunity to provide

industry comments and observations on the draft proposed Mitigation of Beyond-Design-Basis Events Rule to this ACRS Subcommittee.

At this time, I'm going to turn it over now, and I'll turn it over to Bryan to go ahead and get started on delivering our comments in the presentation.

MR. FORD: Well, as David said, my name is Bryan Ford with Entergy, and I'm going to provide you some industry high-level comments on the rulemaking. We look forward to providing more during the rest of the process.

To start off with some overall positives, we think the right topics in general are in the rulemaking, and the rulemaking reflects the significant amount of work that has been done between the NRC and the industry since Fukushima. You know, it does work to codify the existing order requirements and commitments, and the responses to the 50.54(f) letter.

We appreciate the fact that the Staff intends to support the use of the previously developed and the still developing industry guidance. There is still additional work needed on that. Specifically, if the seismic moves into the rulemaking, we don't have guidance yet that supports that. And we do appreciate the changes that have been made based upon previous

industry comments in the process.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Some areas that we think could use some improvement. the You know, mitigation of Beyond-Design-Basis Event capabilities needs to address a spectrum of plant conditions that may be caused by the different initiating events and the resulting damage states. One thing that the current proposed does is it basically requires that you assume the ELAP condition and the loss of the heat sink even when you're assessing the revised hazard response. We think that in many of those cases you should be able to use a alternate or targeted hazard mitigation strategy that takes into account the actual state of the plant. If the flood or whatever the event is doesn't cause a loss of offsite power, then for that targeted hazard strategy you shouldn't need to assess the extended loss of AC power.

MEMBER SKILLMAN: Bryan, doesn't that take the teeth out of the tiger?

MR. FORD: Well, we're really thinking that, as we said before, that the current FLEX or 12-06 strategies were basically developed for an unknown set of events, so instead of a known damage state, you're basically taking I'm going to assume a damage state and develop strategies to address that damage state.

1	Once we move to the revised hazards, we
2	think that we have a better understanding of what the
3	effect has been on the plant of that event, and we think
4	taking that into account for building the strategy
5	specific for that event is the appropriate thing to do.
6	MR. YOUNG: For that reevaluated hazard.
7	MR. FORD: For that reevaluated hazard.
8	You'll see in a second, we still think we need to keep
9	the overall FLEX capabilities, whether it's for flood
10	or for whatever the hazards are, but when we're going
11	in and building a specific strategy for the reevaluated
12	hazard we think we should be able to consider what the
13	effects of that reevaluated hazard has been on the
14	plant.
15	MEMBER SKILLMAN: Well, supposing I say
16	okay, well, I really haven't lost all of the ultimate
17	heat sink, I've only lost 20 percent of it?
18	MR. FORD: You know, you would have to
19	evaluate how you can say that, and whether or not the
20	equipment is still available. You'd have to go through
21	the whole process to assure that the necessary equipment
22	is available for the hazard that you just evaluated.
23	MEMBER SKILLMAN: I didn't lose all my AC,
24	I only lost two of my three lines.
25	
25	MR. YOUNG: But I think when you would look

1 at the strategies for that particular condition, then 2 you'd factor that into how you would build your strategies. 3 4 MEMBER SKILLMAN: Now I have a custom 5 strategy. MR. FORD: Yes, and we think in many cases 6 7 or in some cases for the reevaluated hazards plants are 8 going to need to build a specific strategy to deal with 9 the reevaluated hazard. MR. YOUNG: There'll be information that we 10 will have now on the reevaluated hazard that would not 11 12 have been B- as Bryan said B- right, in this nebulous 13 damage state where everything is gone, that's the 14 underlying assumption, from the reevaluated hazards 15 you're going to have additional information that may 16 indicate that certain things are going to be available, 17 so you would have to have strategy sets that reflect the 18 availability of that equipment. In fact, an installed 19 power source, why wouldn't I use it? 20 MR. FORD: And on the other hand, it may also 21 say that other equipment isn't available that in your 22 primary FLEX strategy is, so you would need to take that 23 into account and deal with it for the targeted hazard. 24 MEMBER SKILLMAN: On the other hand, if I

just choose to not go through these permutations and

combinations and simply say I'm in ELAP, and I've lost access to my normal heat sink, doesn't the path forward become very, very clear; even though it's complicated, it's very clear?

MR. FORD: I'm not sure about that depending upon what the reevaluated hazard has done at your plant. You know, depending upon how you got into that ELAP state and, you know, we make certain assumptions under the 12-06 current strategies on the availability of equipment and what equipment is available and what equipment isn't, and in the reevaluated hazard that evaluated hazard may exceed those assumptions. And as a result, you know, the plant can be in a greatly different state potentially than we assumed for the base FLEX flood or whatever it may be event.

MEMBER SKILLMAN: I understand your explanation. It just seems to me that by asserting this might be the better way to go you have created what can be an unending series of evaluations to try to figure out where you should be. And it seems to me that that's not simplifying, that's complicating this issue.

MR. FORD: Well, hopefully, when we get to the next slide B- I don't see that it complicates it right yet, but we'll show you what our proposal is, and we'll see.

MEMBER SKILLMAN: Thank	you
------------------------	-----

MR. FORD: One thing we do think, though, is that the current proposal of including seismic into this is inconsistent with the current seismic path forward that we've been working on. Currently, the seismic path forward that's being used is a risk-based path where we're doing reviews of IPEEE information, we're doing SPRAs. The flooding path in FLEX is of a deterministic path forward. You know, you go and you build a specific strategy for that. So, we currently don't have any guidance that really goes towards incorporating the reevaluated seismic hazard into FLEX, and how you would do that. And we haven't started developing that yet.

MEMBER STETKAR: Why haven't you?

MR. FORD: Because right now the industry path is that we are doing this risk-based path of doing SPRAs, and using the IPEEEs for the plants that could.

MEMBER STETKAR: I guess I didn't understand that answer, but that's okay.

MEMBER POWERS: I mean, is the difficulty or the conundrum we have here that for seismic we have some sort of probabilistic record that goes back a few thousand years, but for floods, you know, maybe 100 years is all we have. Is that the conundrum?

MR. FORD: I think that is part of it. You

know, the stated current NRC position that I understand is that they can't really assign probability numbers to many of these flood events because of the amount of information we have available. On the other hand, there is numbers that are accepted for probability to seismic events, and we're right now consistent with the industry commitments for resolving the 50.54(f) letter. We're off with the Tier 1 plants doing SPRAs currently.

So, our suggestion is twofold. One, where in the proposed rulemaking the reevaluated hazard was added back in the equipment section, we don't think that's necessarily the right place to add it because where it was put really only applies to the portable FLEX equipment, and there's a lot to these strategies and making one of these strategies for one of the hazards than just the qualification of the portable equipment. So, we think the appropriate place would be to bring it up into the (b)(1) section where it says you have to build a strategy or quideline that supports that reevaluated hazard. And our view is that it doesn't necessarily have to be directly connected to the concurrent ELAP, but you need to do the current FLEX, and then if you have a hazard that exceeds your current FLEX, you also need to go evaluate that hazard for what the appropriate strategy would be. And our current view

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

is that you would limit that to the reevaluated flood hazard consistent with the industry commitments.

So along with that, we wouldn't put it back in the equipment section. We're not really sure the equipment section as a whole is really necessary for the rule. It's more stuff that should be controlled by quidance. There's always chances that when you try to take a large body of quidance and sum it up in a couple of sentences that you lose the subtleties of what makes that work. But as a minimum, we think that this would B- this section on incorporating the revised hazard would be best up in the "You must build your strategy to address it," and leaving up what is reasonable protection decide and how vou that reasonable protection robustness into the guidance.

On the new plant requirement that was discussed earlier, we don't necessarily think that those requirements are necessary to be added in for new plants. That, one, the new plants are designed to the higher review standards and design standards that are identifying the revised hazards, so we're not sure that those are necessary to be included in the rule.

Also, on SAMGs, we don't think using the qualitative factors is in accordance with the Commission direction given in the SECY, and so we think

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

that it would be more appropriate to achieve the regulatory footprint that the Commission would like in a different way. The industry has developed and is committed to SAMGs, and we understand the goal is to have a regulatory footprint to make sure we keep them in the future, but we don't think that it seems that the current method of justification is correct for including them in the regulations. MR. YOUNG: So, for example, if the basis here of qualitative factors wasn't sufficient to get it in the rules, then perhaps some sort of voluntary industry docketed commitment might be a way establishing a footprint on it in the future. That doesn't exist today. That may be one approach. MEMBER REMPE: So, we have a voluntary commitment. Isn't that what they had years ago, and then they inspected after Fukushima and the voluntary commitment wasn't kept up? So, what are you suggesting at this time? MR. YOUNG: Well, it would be a B- kind of the word we used yesterday in some of the discussions, more reinvigorated and more vigorous kind of commitment that carries more B-MEMBER REMPE: Unless it's a regulatory commitment, I don't B-

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

## (Simultaneous speech)

2	MR. YOUNG: If it was a licensing basis
3	commitment of that nature, and I don't want to go into
4	a whole lot of specifics here because we'd have to talk
5	it through with a lot of folks, but certainly more than
6	just sort of the voluntary initiative that was
7	characterized back when it was rolled out in the '90s.
8	MR. FORD: So, I guess our main point is that
9	we don't think that the current justification in the
10	rulemaking package using the qualitative factors is
11	sufficient to justify the imposition of the
12	requirements as a regulation. We do understand the
13	desire and need to have, you know, appropriately
14	maintained and controlled SAMGs, and we support that,
15	and we're willing to work on how the appropriate way is
16	to include it, but we don't think B-
17	MEMBER STETKAR: Bryan, let me ask, does the
18	industry have that broad-based quantitative
19	justification to show that there isn't any benefit from
20	the SAMGs? Do you have all of those Level 2 PRAs that
21	you can show me how much B- how little benefit you get
22	from the SAMGs?
23	MR. FORD: No.
24	MEMBER STETKAR: Okay. Thank you.
25	MR. FORD: But to be clear, and this is as

1	a licensee for a long time, it's the NRC B- you know,
2	as the NRC has said in the past, there's a job for the
3	NRC, and a job for licensee.
4	MEMBER STETKAR: So, you can't quant B- you
5	can't tell me quantitatively that they're not
6	justified. The NRC can't tell me quantitatively that
7	they're not justified. You're telling me qualitatively
8	that you don't think they're justified.
9	MR. YOUNG: Well, no, I don't think that's
10	what we're saying.
11	MEMBER STETKAR: That's all I hear.
12	MR. YOUNG: You know, what we're saying is,
13	is the basis as currently written in the FRN doesn't get
14	you there. We don't think it gets you there, so there
15	was B-
16	MEMBER STETKAR: I'm asking do you have a
17	basis to disprove that?
18	MR. YOUNG: The Staff B-
19	MEMBER STETKAR: Quantitative, we want the
20	quantitative basis B-
21	MR. YOUNG: The Staff itself said that
22	quantitatively they can't get there, so we're going to
23	use qualitative approach to make it over the hump, and
24	we're saying when you look at the SECY, it's like
25	B- we're not seeing the sufficient rationale there for

Т	using qualitative factors. So, the solution is either
2	come up with more B- better quantitative rationale,
3	take some kind of administrative exception to backfit,
4	get a docketed commitment. I mean, there's other
5	approaches, so B-
6	MEMBER BLEY: Can I ask a B- you were here
7	for the Staff's presentation, and you've talked with
8	them on it. The way they're proposing to have oversight
9	of the SAMGs, at least to me seems a not very intrusive
10	way to do it. Do you have objections to the way they've
11	described how they would have that oversight, or are you
12	just objecting to the basis that they provided for
13	getting to that?
14	MR. FORD: The basis.
15	MR. YOUNG: Yes.
16	MR. FORD: The basis is the B-
17	MR. YOUNG: As I said, I don't think the
18	industry is objecting to maintaining and, you know, we
19	just put out documents to upgrade the SAMGs.
20	MEMBER BLEY: Anything inspections?
21	MR. YOUNG: Yes, I mean, yes, I always
22	expected B-
23	MEMBER BLEY: So, on the practical level you
24	are not objecting to how they want to pursue the SAMGs.
25	MR. YOUNG: It is the process that they're

using to get there.

CHAIR SCHULTZ: Has the industry evaluated the costs that are provided for the implementation, the SAMG implementation, the costs that are in the evaluation? Are they reasonable?

MR. YOUNG: Yes. We've looked at some of the numbers in the Reg analysis and, quite frankly, aren't prepared to discuss those here today, but I think we want to go back and take a very good look at the numbers that are in the Reg analysis and maybe just do some independent scrubbing to see if we come up with something in the same ballpark. I just had some recent experience in the EP Rule back in 2011, and I think some of the numbers that were in that Reg analysis weren't borne out in the subsequent cost of implementation, so I would want to go back and take a pretty hard look this time around going in on the front end and see if we can look at those estimated costs, and do they really reflect all the B-

CHAIR SCHULTZ: Well, let me ask it differently. The scope of what's described and costed out, the scope of what is described there seems to be what you say the industry would commit to with respect to SAMGs, that portion of it, and then also an upgrade, and making sure the Owners Groups and making the

1 improvements that we've discussed, as well as assuring 2 that everyone is committed to, and performing, and doing, and sustaining, and exercising, excuse me, 3 demonstrating through drills. All of that is to be done, 4 5 is what you're saying, the industry sees value in that. 6 MR. YOUNG: We don't see any B- we don't 7 have any objection to the current proposed requirements that are in the FRN. 8 9 CHAIR SCHULTZ: Okay. 10 MR. YOUNG: So, having SAMGs, configuration 11 control, maintaining them up to date, drilling on them 12 periodically, that's all B-MEMBER BLEY: You want to not have it a rule? 13 14 having a little trouble seeing what you're 15 presenting to us. 16 YOUNG: I think B- again, MR. in 17 discussions, I quess, you know, the message B- you know, 18 the point here in this presentation is to B- we're not 19 objecting to the requirements. We just think the Staff 20 needs to go back and take a look at the basis provided 21 in the FRN, and look at its consistency with this SRM, 22 and if they can't get through it through anything other 23 than qualitative measures, we ask that they go back and 24 think about another approach for providing a basis for

imposing the requirement.

1	MEMBER BALLINGER: So, what you're
2	objecting to is basically the administrative process?
3	MR. YOUNG: The imposition B- how the
4	requirement is imposed.
5	MEMBER BALLINGER: What is the downside?
6	MR. YOUNG: Well, because if you start to
7	use qualitative factors and defense-in-depth, that
8	becomes a slippery slope very quickly for everybody's
9	great idea.
LO	MEMBER BALLINGER: Okay, so there's your
L1	objection.
L2	MR. YOUNG: You know, so everybody's got
L3	great ideas, and I'm sure they all add defense-in-depth
L 4	at some point but, you know, the Commission said yes,
L5	we want some kind of quantitative analysis. Right? I
L6	mean, that's the expectation, so that's the concern.
L7	CHAIR SCHULTZ: Do you have a way in which
L8	you would characterize the safety benefit of SAMGs, not
L9	only the SAMGs, but what has been proposed, which is that
20	B- and the industry is doing, assuring that there's
21	integration, operating procedures on up to response to
22	severe accidents.
23	MR. YOUNG: I think in our conversations,
24	you know, we've all along in our conversations,
25	interactions with the Staff, and the last time we were

in front of the Subcommittee, the industry has
acknowledged that, you know, we are prepared to support
having some kind of regulatory oversight of severe
accident management because they certainly do add some
additional level of mitigation capabilities, you know,
for accidents and protection of the public. So, you
know, quantifying the B- and I'm hedging a little bit
because of the way you kind of phrased it, which almost
goes more to, you know, have I looked at some of rigorous
analysis? No, I haven't. But, I mean, qualitatively,
that's kind of what we said, is we support it, we think
there's value to having it, and we think some kind of
oversight of it is appropriate. And we're just proposing
here, not to make light of what you said, but yes, it
is more of an administrative kind of thing because there
some other precedent issues that could come up.
CHAIR SCHULTZ: It's a policy matter.
MR. YOUNG: As a policy matter.
MEMBER REMPE: So what regulatory oversight

MEMBER REMPE: So what regulatory oversight
process could be invoked that gives assurance that the
voluntary effort wouldn't dissipate? I mean, you're

voluntary effort wouldn't dissipate? I mean, you're saying I don't mind doing it, I don't want it to be imposed this way, so give me an example of what you'd

suggest.

MR. YOUNG: Well, I'm certainly nowhere

1	near as knowledgeable as Mr. Reed but, you know, I don't
2	know what the ultimate mechanism might be to fit this.
3	All we're saying is that the basis currently in there
4	now just needs to be looked at, just go back and rethink
5	that. Is there some other basis that gets you there
6	without having to invoke qualitative requirements in
7	this instance because of the precedent issue, and how
8	this could get B-
9	MEMBER BLEY: And especially
10	defense-in-depth.
11	MR. YOUNG: And particularly B- I mean, is
12	there anything isn't defense-in-depth at some point. I
13	mean, you could almost make that argument for just many,
14	many things, so B-
15	MEMBER BALLINGER: So, your issue is the use
16	of qualitative arguments period, and that's to start the
17	slippery slope, is what you're saying.
18	MR. YOUNG: Yes. In so many words, yes.
19	MEMBER BLEY: So if they say, went back and
20	looked at say some of the PRAs and then addressed some
21	of the events that we've heard, maybe not just
22	Fukushima, and said gee, there's uncertainty in how
23	likely some of these are, and attacked that uncertainty
24	basis, and from that showed there was a possibility of

a higher risk that might meet the Backfit Rule, that

1 would be more palatable. MR. YOUNG: Well, clearly then you're in 2 accordance with the SECY. Right? Now, you've done a 3 4 quantitative set of analysis, and here's your results, 5 and this is what it shows, and you compare this B-MEMBER BLEY: Maybe substantial judgment 6 7 involved in it, but it's a quantitative B-8 MR. YOUNG: Well, it's a quantitative 9 assessment. Now, again, that's not to say that, you 10 know, we might have comments on that in public comment 11 period, and we could certainly talk about those at that 12 point, but certainly something like that would be more 13 of a path for getting a quantitative rationale. 14 MEMBER BLEY: From the way you've talked it 15 seems there's not an easy mechanism, or a previously 16 adopted mechanism to get these kind of requirements in 17 place other than a rule. Is that right? You suggested 18 something but it had no stuff there, no substance there. 19 MR. FORD: We would have to sit down and talk 20 to the Staff over what the appropriate mechanism is. The 21 previous voluntary industry initiative that put SAMGs 22 in, I mean, as the Site Licensing Manager, that is not 23 as near and dear to my heart as I wrote a letter that

had a regulatory commitment in it that I track to make

sure that it's done. So, there may be other mechanisms

24

we could use that raises the B- at least the perceived B-

MR. YOUNG: So, we could have some public engagement that hopefully we come up with the right, you know, the right form letter, for lack of a better term, that has the right words in it, and that's the commitment letters everybody sends in.

MEMBER BALLINGER: Well, let be clear again. The objection is the qualitative factors, the use of qualitative factors because you're concerned C-now maybe I'm putting words in your mouth, of the subjectivity that can creep into using qualitative factors, the definition of qualitative factors.

MR. YOUNG: It's the use of qualitative factors to B- as a substitute for not getting there quantitatively, because if you look at what the SECY said, right, it's quantitative factors, and you can inform the decision making with qualitative. But, you know, we expect some sort of quantitative basis for this information, and it's like well, they did the quantitative measure, it's like no, we didn't get there. Okay, so now we go over the hump by using qualitative measures, and that just doesn't seem to be the right B- I mean, so where does that stop? So, every time I don't get them from quantitative measures, I'm going to invoke

1	qualitative measures? I mean B-
2	MEMBER BLEY: If you look at Reg Guide 1.174
3	B-
4	MR. YOUNG: Which I haven't.
5	MEMBER BLEY: B- which is used in a
6	different way, but that has you do risk calculations,
7	but also has you go through an integrated decision
8	process where you can bring things that may be
9	responsible for extensive uncertainty, or lacks of
10	knowledge into that decision process to jointly come up
11	with a basis for considering the impact of changes. It's
12	not quite what's written into the Backfit Rule or that
13	sort of thing, but it is a kind of process that
14	integrates strictly quantitative with a consideration
15	of factors that are difficult to quantify. That sort of
16	approach would smell better, or maybe not.
17	MR. YOUNG: You know, I'm going to have to
18	plead ignorance. I have not read that.
19	MEMBER BLEY: Well, the other gentlemen
20	probably are not ignorant of B-
21	MR. WEBSTER: 1.174 is where we risk-inform
22	tech spec submittals.
23	MEMBER BLEY: Yes.
24	MR. WEBSTER: Again, as risk-informed the
25	quantitative numbers are B-

1	MEMBER BLEY: Are part of it, but also
2	there's an integrated B-
3	MR. WEBSTER: Right.
4	MEMBER BLEY: B- process to consider things
5	that you haven't yet figured out how to quantify
6	properly.
7	MR. FORD: And I don't know how well that
8	comports with the legal requirements, you know, in the
9	Backfit Rule for significant safety benefits. I haven't
10	thought of how that would connect to B-
11	MR. YOUNG: Yes. So, I mean, I don't think
12	necessarily we were going to solve the thing here, but
13	it was just to make this comment, and if we had to have
14	some subsequent engagement with the Staff to find out,
15	you know, hey, what is the best path forward for this,
16	happy to have that engagement and figure out what that
17	right solution is.
18	MEMBER BLEY: I assume this conversation
19	has been going on with the Staff.
20	MR. YOUNG: We've had some recent
21	conversations.
22	MEMBER BLEY: So, it's fairly recent.
23	MR. YOUNG: Well, we just saw this last
24	week. Right?
25	MEMBER BLEY: Yes, but you kind of knew what

was coming, but go ahead.

CHAIR SCHULTZ: Yes, as this is the
Fukushima Subcommittee, I throw out some B- another
thought for a B- a thought exercise, and that is at least
to me when Fukushima happened, and the response in the
days just thereafter by the NRC, and by the industry,
and the United States seemed to at least rely partly on
the fact that our reactors were safe, and some of that
depended upon, I believe, the fact that we have Severe
Accident Management Guidelines, we have things in
place. We had a lot of work that we had done in terms
of safety, operator performance beyond just operating
the facilities, but going into elements associated with
severe accident response, and leading up to there. So,
that just tells me that, as you've said, this is an
important feature, and it does concern me that we can't
quantifiably demonstrate that this is an important part
of what we do. We want to do it, and with some reasonable
oversight by the Staff, we're willing to proceed. I hope
we can find a way soon to make this happen.

I understand your point in terms of policy, the slippery slope discussion.

(Simultaneous speech)

MR. YOUNG: Yes, I just want to stress again, this isn't a question of pushing back on the right

regulatory footprint. That's not what B-2 CHAIR SCHULTZ: In terms of decision 3 making, it seems as if we ought to be there but we're 4 not, decision making to move forward and figure a way 5 to set up the process. MEMBER BLEY: I mean, the reason we all 6 7 think it's important, I think, is because despite what 8 we calculate events crop up every once in a while, maybe 9 every 20 years or further than that, that puts us into 10 a spot, but these would be really good to have. Then we say well, our calculations are still okay because we've 11 12 done a better job on some of this than somebody else has. 13 But there are a few areas of uncertainty that could 14 affect this. MR. YOUNG: Take the flip side though, too, 15 is that now we have FLEX in place, right, which we didn't 16 have before, so there's that whole other barrier that's 17 18 in place now. I think that's obviously something to 19 reflect on when you start thinking about SAMGs. 20 BLEY: Absolutely. MEMBER And the 21 procedures for FLEX need to get integrated with all this 22 stuff. 23 MR. YOUNG: That's right. 24 DR. SHACK: Just going back for a second to 25 your reevaluated hazards, I mean, the orders were put

in place to deal with Beyond-Design-Basis accidents and external events, and you've just stripped seismic out of it. It just seems a little peculiar.

MR. FORD: Well, the orders had you build a set of capabilities for Beyond-Design-Basis Events, and within those there was constraints put upon how you made the assumptions for designing those systems. You know, in most cases something that was robust for your current hazard was considered robust sufficiently to use for the FLEX hazard. So, it was just one of those constraints; otherwise, what would you have picked, you know, something X, Y, or Z? So our current FLEX designs have been built there.

Now, we did a B- I always forget the acronym, ESEP evaluation for plants whose GRMS was exceeding it in certain requirements to provide a level of confidence that FLEX could perform it beyond the current design basis. You know, what we are really pointing out is not that in the long run whether we make FLEX support a reevaluated seismic hazard or not, at least my way of looking at it, my real point was, one, that's not what we're doing right now. We're off spending millions of dollars doing SPRAs because that was the path decided, and if you B- if we want to change track, so far the industry has not committed to do this

2 impose it, but then you need to evaluate that revised track under the Backfit analysis. 3 4 MR. YOUNG: And have the guidance. 5 MR. FORD: And have the documents, and we 6 haven't yet put together the quidance on how to do that. 7 You know, as we found with flooding, it's not as simple as, you know, just saying go use these new numbers and 8 9 make it work. So, what we're really pointing out is that 10 right now what's in this B- what's in the proposed 11 rulemaking for the area of the seismic reevaluated 12 hazard is not consistent with the current industry 13 commitments for resolving the 50.54(f) letter. And if 14 it's going to stay inconsistent with our commitments, 15 then it needs to be appropriately evaluated under 16 Backfit and the appropriate quidance put together. 17 RICCARDELLA: This MEMBER is Pete Riccardella. Could I make a comment? 18 19 CHAIR SCHULTZ: Yes, Pete, go ahead. 20 MEMBER RICCARDELLA: Yes. You know, I think 21 regarding the seismic assessment, I mean, it's one thing 22 when you have a bunch of existing equipment out there 23 that's been there for years and years, and now you've got a new ground motion response spectra, and the 24 25 appropriate road to go is a seismic risk assessment, but

other track for the revised seismic hazard, and you can

we're talking about new equipment that we're putting in, or that's been put in very recently when you had a pretty good idea what the new seismic criteria were going to be. I can't understand why it wouldn't be designed to the new seismic ground response spectra.

MR. WEBSTER: Well, one thing just B- you know, the FLEX order was implemented before the GMRS data was available to all sites, so it was B- we did it. We started implementing the FLEX before that information was available.

MR. YOUNG: Well, one thing, too B- let me just throw out a lifeline here. So, we've got Andrew Maller here from NEI who is heading up our interface on the seismic stuff, so let Andrew speak here for a minute on what he can share with this.

MR. MALLER: Thanks, David. So, I did just want to mention that we do have a number of activities going on in response to the 50.54(f) letter. In large part, a number of the plants are doing SPRAs that take out to 2020 under the current schedule, so that's the first phase of the 50.54(f) response. Phase 2 is where the NRC will look at any potential design-basis changes after that. So, what's unclear right now is where this rulemaking fits into the overall schedule for closure there.

We're trying to work that out. We don't have
the answers right now. It's not been at the top of our
list. We've had a number of Near-Term actions that we've
been working on that are also a part of the 50.54(f)
response, including figuring out the scope for
high-frequency limit evaluations, about fuel pool
evaluations, finishing up the expedited approach that
Bryan mentioned, so there's a number of things going on.
We're trying to figure out how the overall strategy for
closure on 2.1 seismic relates to this rulemaking, so
the idea is, like we said, we're not trying to say we
don't think this ought to be a part of this rulemaking.
What we're saying is that it needs to be a part of this
rulemaking once we get the guidance put together to
support this, and we're not there yet. So, one
B- obviously, one possibility is to just put a pause on
the rulemaking and wait for us to come up with the
guidance for seismic. Or the other concept would be to
pull out this part for now until we come up with that
working with the Staff, and then find the time to work
that in.
MR. YOUNG: So, your second option, you're
talking about like a placeholder, move forward with this
and then fill it in later. Is that B-
MR. MALLER: Yes, I think there's different

regulatory options in order to do that. Our point was not that the rulemaking should not include seismic as an external hazard, but the way it's set up right now, it doesn't quite reflect the path that we're on, and we don't have the guidance yet to support where we're going to end up relative to mitigation strategies in terms of seismic.

MEMBER STETKAR: Well, I thought the order was a way to proceed ahead on the seismic event in a restricted sense where you looked at the consequences as being an ELAP and a loss of ultimate heat sink. I would look at the seismic PRA as something above that, that if we get new insights out of that, it could lead to regulatory action above and beyond that. But this was already considered as an adequate protection event for the seismic in a broad kind of sense that you really weren't quite sure what the consequences were, but you took a base case. And I don't see that that has to in any way conflict with what's going on under 2.1. To me, they're separate tracks, and you can proceed ahead with this rule, which essentially just embodies the orders. It's not really from that point of view, as the Staff made the argument before, it's not imposing any new requirements beyond what the orders did.

MR. FORD: And from our point of view, the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

orders did have us build mitigating capabilities for a seismic event, and instead of developing a new seismic spectrum or GRMS to evaluate against, you use the current design base B-

MEMBER STETKAR: Here's the problem, and this will help Pete also. There are plants out there who are taking installed equipment and taking credit for it as part of their FLEX strategy and enhancing, because it's not qualified right now to the existing seismic earthquake, enhancing that equipment so it meets the current seismic design basis. Those plants know fully well that their reevaluated seismic hazard will be far above their existing design basis. The strategy is you build it, you enhance it to the existing design basis, and then you say you can't justify further enhancing it under a Backfit Rule. That's why we're having this discussion.

MEMBER RICCARDELLA: It seems to me that the worst case would be that you've got this equipment put into your original SSE, you've got the new GRMS. The minimum you should have to do is a seismic risk assessment, or seismic margins analysis of that new equipment at least to show, you know, that it can withstand the new hazard. Maybe you didn't design it, just like you didn't design the original stuff, but

2 showing that you have sufficient margin. MR. FORD: And we have done the ESEP that 3 4 evaluated installed equipment. It was a subset of 5 equipment to a higher seismic standard for those plants 6 it was applicable to show that they were robust beyond their current design basis. But just one point of 7 8 clarification, every plant is using for their FLEX 9 strategies a fair amount of installed equipment. I mean, 10 if you're going to have a portable pump and inject, you 11 have to inject it into something, or you have to have 12 tank that it's getting water out of, so everybody is 13 using a fair amount of installed equipment in these 14 strategies, and you have to. So, our point was right now for the 50.54(f) 15 16 letter is out path for resolving, you know, any safety 17 concerns associated with the revised spectra has been 18 depending upon your spectra, and whether you had IPEEE 19 that covered it, and all these other things, has been 20 a probabilistic approach in many cases. We have not B-21 MEMBER RICCARDELLA: So, as a minimum you 22 would do that on the newly installed FLEX equipment, as 23 well. Right? 24 MR. FORD: On the newly installed B- you 25 know, the B-

that's what your seismic risk assessment is doing, is

1 MEMBER STETKAR: Pete, it's not newly 2 installed equipment. It's stuff that is there B-3 MEMBER RICCARDELLA: Well, somebody B-4 MEMBER STETKAR: No, wait. The stuff of 5 concern is the existing pumps, and valves, and piping, and tanks, and you know, that's already there in the 6 7 plant. 8 MEMBER RICCARDELLA: I understand that, and 9 the plan is to do a seismic risk assessment or a margins 10 assessment of that. But then there's additional new 11 stuff that they're putting in, and if they didn't do that 12 to the new ground motion, I'm assuming that they will do a sort of risk assessment on that. 13 14 MR. FORD: Well, it would be included, as 15 necessary, into the SPRA risk assessment. I mean, if you 16 needing to credit that equipment up 17 appropriately characterize the risk for your plant, 18 then you would, but if it wasn't, you know, part of what 19 you needed to look at to appropriately bound the risk, 20 then you may not. 21 MR. YOUNG: Andrew, is there any other 22 clarity you can offer on that? 23 MR. MALLER: Well, I was just going to say, 24 mean, obviously we did the expedited seismic 25 evaluation process where we looked at a subset of

equipment related to FLEX for an increased seismic hazard beyond the design-basis and, you know, across the fleet the results of that have been very positive with very B- with the number of plants without any modifications identified as a result of that. So, we've demonstrated the seismic margin within the fleet.

There are some questions here popping up, and I think that really gets to the point of why we don't think we're ready to move forward with this in the rulemaking, and we need to figure out what the guidance looks like. So, I think it's this sort of dialogue that really contributes to that point. We're just not there yet. That's all the message is, is we're just not there yet, and we need to work with the Staff to put it together.

MR. WEBSTER: Yes. And we definitely are not saying that we don't think seismic should be considered. We just think it's, like you said, we've just go some more evaluations to do to determine what the right safety improvement is, and what right evaluations need to be done.

MEMBER REMPE: Before you leave this B- I'm back on the Severe Accident Management Guidance, and I think I heard you say we aren't opposed to regulatory footprint, just the way that you've B- or the basis for

1	it. And there were specific items mentioned about having
2	configuration control, drilling them, et cetera. For
3	the et cetera, during the earlier discussion, the Staff
4	mentioned that industry had offered that we B- they
5	could do some sort of collaborative review or something
6	and, you know, to say well, did you think of this, and
7	you need to include this, and is that your perception,
8	too, that you don't mind having B- they're not going to
9	do a detailed review. We heard the Staff say that, and
10	also put it in several documents, but what about
11	interactions and some sort of not a detailed official
12	review, but some sort of interchange and oversight that
13	way?
14	MR. YOUNG: Right. So, what you're asking
15	that really involves the Owners Groups, and so I'm not
16	an Owners Group representative, but let me if I can,
17	again, reach out to my lifeline here. So, Jack
18	Stringfellow, are you on?
19	CHAIR SCHULTZ: No, he would not be able to
20	talk. We can open the line.
21	MR. YOUNG: Okay. Just give me one moment
22	here. I just want to see if he's able to hop on. Jack
23	is the Chairman of the PWR OG, and was instrumental in
24	coming up with the proposal that Tim referred to earlier

with respect to how this material could be looked at by

1	the Staff on a periodic basis.
2	MEMBER REMPE: Oh, so there's some sort of
3	written proposal that has B-
4	MR. YOUNG: There is a joint letter that the
5	Owners Group sent in, the PWR/BWR Owners Group sent a
6	joint letter offering a process by which the Staff could
7	periodically look at updates to SAMG material. There
8	was, I want to call a comment period in line with what
9	Tim said earlier about it's not really a review, but
10	there's a period in which the Staff can review this,
11	provide some comments and feedback back if there's open
12	questions, have some dialogue, make sure there's a clear
13	understanding before it would go out to the industry.
14	MEMBER REMPE: That would be actually good
15	if we could see that letter, and then if he has some
16	comments about it.
17	CHAIR SCHULTZ: The line is open, we
18	believe, so just ask and see if he's available.
19	MR. YOUNG: Okay, thank you. Hey, Jack
20	Stringfellow, are you on the line? Anybody from the
21	PWROG?
22	CHAIR SCHULTZ: Not hearing any, we'll
23	close the line. He may be out there, we just don't know.
24	MR. YOUNG: That's right. Okay. I do feel,
25	again, I'm not B- I can't speak B-

1	CHAIR SCHULTZ: But B-
2	MR. YOUNG: I'm sorry, go ahead.
3	CHAIR SCHULTZ: But let's see what
4	information you might be able to provide to us.
5	MR. YOUNG: Well, again, that was a summary.
6	I don't want to get too much more into that because I
7	think that starts to get directly into their business.
8	But I have seen the letter, I do know the letter was sent
9	it, and again was jointly signed by both the
10	Chairpersons of their organizations, and it did offer
11	B- I believe that the term that was used in the letter,
12	in the offer letter was audit, is what they called it.
13	CHAIR SCHULTZ: If it happens to be
14	internal, we'll get it here.
15	MEMBER STETKAR: It was sent to the Staff?
16	MR. YOUNG: Absolutely, yes, yes. Yes, they
17	have it. And, in fact, the Owners Groups were attempting
18	to be responsive to a request that came up in the meeting
19	that Tim referred to back in May when we had that two-day
20	workshop on SAMGs. This was one of the questions that
21	the Staff asked for, and the Owners Groups were
22	responsive to it. So, it is a process where, you know,
23	I think the term they used in the letter was an audit.
24	But, again, providing this material in advance on an

electronic portal because it is, of course, you know,

1	proprietary information, but giving B- I believe from
2	memory, I think it was a 60-day review period to give
3	the Staff plenty of time to review it and take a look
4	at it, provide some comments or suggestions, or
5	questions, and then get those resolved before it was
6	sent out.
7	MEMBER REMPE: But getting those resolved
8	sounds like a nice phrase that I'd like to see that
9	letter.
10	MR. YOUNG: Yes, and I believe that's
11	clearly the intent. I mean, obviously, now if we thought
12	something was going to B- and here I am speaking for
13	them. I believe their intent was if it was something that
14	was going to drag on for quite a period of time, there
15	was all kinds of other goods in the update package, then
16	what they would probably do is maybe take that one
17	element out, let's get all the other good stuff out
18	there, and then we would B-
19	MEMBER REMPE: That's a good letter to see,
20	so thank you.
21	MR. YOUNG: Okay.
22	CHAIR SCHULTZ: All right. We're ready for
23	Slide 7.
24	MR. FORD: Okay. Just a few other comments.
25	The new staffing and communication requirements that

were put into Appendix E, we don't think that they should go in Appendix E. We think they should come up into this new Part 50.155. We're concerned that putting these back into Appendix E will cause some confusion of the appropriate change controls, whether or not they're part of the e-plans, and you apply the e-plan change controls to them versus the change controls of the section.

MR. YOUNG: And we appreciate the fact that there's some language in there now to that extent, but we just think that just the cleaner approach is just to keep it with the rest of the rule. So, we just suggest that everything be in 50.155. We think it's where it belongs.

MR. FORD: We also think on the change control that there needs to be some more discussion, maybe potentially some changes in the other sections. We're concerned about the going forward interaction between the normal design-base change controls and the change controls in this section. You know, we agree that you have to evaluate that in the appropriate areas it's just making sure that the lines are clear for when you just evaluate it against these Beyond-Design-Base requirements versus you evaluate it against your fire protection program requirements, or your security plan,

or whatever those normal design-base requirements are.

MR. YOUNG: So, this was Tim's example earlier in his presentation. So, if clearly in design-basis space, you know, propping open security doors, you know, not a thing you can do, but if I'm evaluating a BDBE event, and it's clearly a BDBE event, and that's the only time it's ever going to get used, and the change control processes just somehow recognize the acceptability of that propping that security door open is okay in these conditions.

A couple of comments on the implementation period. We would suggest using four years versus the two outage item. You know, what happens with the two outage item all depending upon timing, some plants end up getting a very short window, potentially, and if four years is acceptable, then we think it would be appropriate just to put that in so they'd have time to implement.

And the last one is that we would request that we be given a fair amount of time to comment on this when it does come out. If we can get 120 days or that time frame, we think that would make it much easier for us to provide good comments, and would keep down the need for us to submit a request for an extension. And I think that is the end of the industry comments.

CHAIR SCHULTZ: All right. Any further
questions from the Committee to the industry with regard
to the presentation? Hearing none, the next segment of
the agenda is to ask for public comments, so we'll go
ahead and open the phone line. And while the phone line
is being opened, I'll ask if there are any comments from
individuals in the room, comments that would be like to
be made to the Committee? We're seeing none here, so I'll
wait for a moment to get the signal that the line is open.
The line is open as far as we know, but for us to assure
that we need someone to say hello.
MR. LYMAN: Hello, this is Ed Lyman from
UCS. Can you hear me?
CHAIR SCHULTZ: Yes, we can hear you, Ed.
MR. LYMAN: Okay, great.
CHAIR SCHULTZ: Please make a comment, if
you'd like to.
MR. LYMAN: Yes, I would. Thank you. I'm
sorry I can't be there in person today.
I have two comments. One is in response to
what we just heard from the industry. And I was actually
quite surprised to hear that they have a proposal which
is very similar to what UCS proposed back in 2012 when
the first Notice of Proposed Rulemaking for a Prolonged
SBO rule was put out.

	171
1	CHAIR SCHULTZ: Ed, just a moment. You're
2	breaking up on this end, and it may be the system.
3	MR. LYMAN: Okay.
4	CHAIR SCHULTZ: But are you on a speaker
5	phone?
6	MR. LYMAN: Yes. Well, I'll try the handset.
7	CHAIR SCHULTZ: Thank you very much.
8	MR. LYMAN: Is that better?
9	CHAIR SCHULTZ: We'll find out in a moment.
10	Thank you. Go ahead.
11	MR. LYMAN: Okay. So, we submitted comments
12	back in July 2012 where we proposed that the success path
13	approach should be taken where you define the series of
14	external event scenarios and you carry them through to
15	their conclusion, and you determine how the plant and
16	the auxiliary or emergency equipment and the personnel
17	will respond. And then you carry that through
18	consistently. So that sounds like it's not too far from
19	the approach that the industry was just proposing, which
20	is a lot different from B- their argument was always we
21	just want to consider this artificial boundary
22	condition, some mysterious event causing an ELAP and a
23	loss of access to the ultimate heat sink, and we don't

know how that happened, and we're not going to think

about the ways in which it happened. We're just going

24

1	to focus on that. And we always thought that seemed to
2	be an artificial and unrealistic approach. So, to the
3	extent that approach can be integrated again into this
4	process, we'd welcome it, but we also point out, as the
5	industry did, that the B- what's sauce for the goose
6	might be sauce for the gander, and the implications of
7	that may go in a different direction for some scenarios
8	than what the industry was anticipating, which was that
9	things might be worse than that artificial ELAP
10	scenario. So, I think that's encouraging.
11	CHAIR SCHULTZ: Ed, was that a letter from
12	UCS to the Commission?
13	MR. LYMAN: Yes, it was a comment on the
14	Advanced Notice of Proposed Rulemaking.
15	CHAIR SCHULTZ: Yes.
16	MR. LYMAN: It was May 7th, 2012.
17	CHAIR SCHULTZ: Thank you.
18	MR. LYMAN: Now, on the question of SAMGs
19	and qualitative factors, first of all, I think there
20	B- I think the industry is misreading the SRM, because
21	the way I read it B- well, the way it B- what it says
22	is that you use quantitative methods to the extent
23	possible, but where they're not appropriate or
24	possible, then you can use qualitative measures. It's

not saying you can throw anything at the problem and say

it's defense-in-depth. I think in the case of SAMGs there seems to be a large consensus from the Near-Term Task Force to what I heard from the members of the Committee that increasing the regulatory rigor of the SAMGs would be a positive development, and a significant increase in defense-in-depth, and that it's not just, you know, throwing some arbitrary measure at it and saying this is going to give us more defense-in-depth. That seems to be singled out as a very significant policy shift, and to the extent we think that should give considerable weight to going forward with what the Task Force recommended, and that's making SAMGs a rigorous, regulatory requirement that would entail significant review of not just checking the boxes, but insuring that it's actually a meaningful and workable plan.

So, if you're not going to review the details of the plan that thoroughly, then that's a more performance-based approach, and then you need to reflect that in enhanced exercises. And I don't know if the exercise, the drill and exercise provisions in this draft would be adequate to fully demonstrate that. So, I don't think you can have B- you need one or the other. Either you do a comprehensive sanity check on the SAMGs, or you require the licensees to demonstrate through performance testing that they'll work. So, I think that

1	is going to need to be beefed up. So, I think that's all
2	I have.
3	CHAIR SCHULTZ: Ed, this is Steve.
4	MR. LYMAN: Yes.
5	CHAIR SCHULTZ: Thank you very much for your
6	comments, and they did come through very clearly, so
7	thank you very much.
8	MR. LYMAN: I appreciate it.
9	CHAIR SCHULTZ: Are there others on the
LO	phone line that would like to make a comment? If so,
L1	please identify yourself, and make your comment.
L2	MR. WILLIAMSON: This is Bill Williamson
L3	from TVA. I'm representing the BWROG and the PWROG.
L 4	CHAIR SCHULTZ: Yes, Bill.
L5	MR. WILLIAMSON: Can you hear me?
L6	CHAIR SCHULTZ: Yes. Please go ahead with a
L7	comment. Thank you.
L8	MR. WILLIAMSON: My only comment is that
L9	both the Boiling Water Reactor Owners Group and the PWR
20	Owners Group are validating their SAMGs. We're doing it
21	with every means we have possible right now. For
22	example, the PWRs has scheduled a time to go to the three
23	different vendor's simulators and try them out and see
24	how they work. The BWROG is going through the actual
25	events that occurred at Fukushima Daiichi Units 1, 2,

1 and 3 and looking to see how the SAMGs and supporting 2 documents, TSGs would work through this. The Boilers and 3 the PWRs are communicating with each other on what our 4 findings are, and we expect to share this information 5 with one another. And I think we will find some way to 6 share it with the Staff, also. 7 MR. YOUNG: Bill, this is David Young. I 8 mean, clearly, you guys have already done a significant 9 amount of work already, the stuff that Tim referred to 10 earlier. Right? So, these are just ongoing work 11 activities to further enhance or improve the SAMG 12 quidance. Is that a fair characterization? 13 MR. WILLIAMSON: David, that is a fair 14 characterization. That is correct. 15 MEMBER BLEY: Any other comments, Bill? 16 MR. WILLIAMSON: I guess I would just add 17 that one of the main focuses of what we're doing is to 18 look at instrument readings and figure out how to 19 validate them whether they're giving us 20 indication, or where they're indicating error. And 21 that's where a lot of our efforts have gone on, and are 22 going on currently, also. 23 CHAIR SCHULTZ: Thank you. Are there other 24 members of the public who like to make a comment for the

record? Please state your name and make a comment.

1	Hearing none, we'll B-
2	MEMBER REMPE: Before you do that, if Bill
3	is B-
4	CHAIR SCHULTZ: No. It is a public comment
5	period at this point. That's how we've announced it.
6	We'll go ahead and close the phone line.
7	MR. YOUNG: Thank you, Bill.
8	MR. WILLIAMSON: You're welcome.
9	CHAIR SCHULTZ: All right. At this point
10	then, like to have comments by members of the Committee,
11	the Subcommittee. Joy, any closing comments?
12	MEMBER REMPE: Okay. I appreciated the
13	presentations from the Staff and their efforts, as well
14	as from industry today. The Staff during their
15	presentation did mention about the B- their willingness
16	to come back and communicate with us about the Draft
17	Guides in upcoming months, and I would like to have put
18	my vote in that I'd like to see that interaction occur.
19	With respect to what industry presented,
20	definitely as I mentioned during the discussion, I'd
21	like to see this letter from the BWR and PWR Owners
22	Group. And then with respect to what Bill Williamson
23	said on the line, I would like to, again B- and I've
24	mentioned this to the Staff about B- or with the

industry about the interactions with the Staff and the

1 results of his audits. And he said well, we'd like to 2 find a way to communicate to the regulator. And, again, those kind of details would I think provide more 3 4 confidence with respect to me on what was occurring. 5 Also, I really had wanted to ask but we're 6 not allowed to interact with the public commentors about 7 what B- I mean, I think Bill mentioned that they were 8 just doing the Fukushima Daiichi event, but what events 9 in the PWR Owners Group evaluating just one event for 10 the instrumentation B-11 MR. YOUNG: No, the Ownerships look at a 12 range of different events. I think Bill was just trying 13 to B- what he thought was the interest of this crowd 14 because of the nature of the mitigating design-basis 15 events rule of Fukushima, but I mean they regularly look 16 at OEs from a variety of different B-17 MEMBER REMPE: But for the Severe Accident 18 Guidelines, validate the Management and to 19 instrumentation performance, are they looking at a 20 range of events? 21 YOUNG: They look at а range 22 conditions in the guidance for which alternate 23 indications, confirming indications, calculation aids, trends. If you don't get an accurate reading, what's the 24

trend? Those kinds of tools are all talked about in the

Severe Accident Management Guidance from both Owners Groups.

MEMBER REMPE: They are talked about but to validate that they would survive, that's not in what I've seen for Severe Accident Management Guidance. And when they B- and feeling, knowing exactly when you can and can't trust. And I believe there are some activities to do that. I wasn't sure of the B- I wanted it on the record, so I'm glad you said although they're looking at a range of events.

MR. YOUNG: Am I on the record?

MEMBER REMPE: Right, I'm glad to hear that, but I'd like, again, if there were that exchange in having that with some sort of discussion with the regulator, it would make me feel better.

MR. YOUNG: So, let me say this, and maybe this will help. What Tim referred to a little while back was in May we had a two-day workshop, and I think everybody B- it seemed like everybody and their mother from the Staff was in this workshop. And day one was the PWRs, and day two was the BWRs. And it was a full day of going through soup to nuts, everything, all the guidance, the calc aids, the tech support guidelines, some of the basis information, and answering all those questions. And the idea of this two-day workshop was,

<u> </u>	I you will, try to baseline the Stail's knowledge on
wł	here are we right now? What are all the improvements
tł	hat we've made since Fukushima, I should say the Owners
Gı	roups, the Owners Groups have made there. And try to
ge	et that information out there, and that understanding
01	ut there. And then with the idea being that kind of once
W€	e've baselined that, I believe their intent then is
B-	- with this letter is to provide this ongoing look
ре	eriodically as other changes are made so that the Staff
is	s kept up to speed over time as to what the SAMGs are
do	oing, what they're trying to solve, you know, that kind
of	f thing. So, I believe that's the philosophy.
	MEMBER REMPE: Okay. I think B- that's all
I	have. Thank you.
	CHAIR SCHULTZ: Okay. Charlie?
	MEMBER BROWN: Nothing more.
	MEMBER BALLINGER: Nothing more.
	MEMBER RYAN: Thank you for the
pı	resentations today. They were very informative. Thank
УС	ou very much.
	MEMBER BLEY: Nothing more, thanks.
	CHAIR SCHULTZ: Dana?
	MEMBER POWERS: I continue to feel like we
aı	re abandoning or degrading, at least, a drive to use
ri	isk-information to structure the regulatory system.

And I'm getting the impression that we're doing things
in a fairly chaotic fashion through running the risk of
imposing inconsistent and divergent burdens on industry
here. And I think that's something we've got to make sure
does not happen. I think we have to work scrupulously
to make sure that does not happen, that in a rush to show
that we've done something, we don't end up with
something that is burdensome and, ultimately, degrades
safety by the introduction of complexity on the site,
congestion on the site. And I get very concerned about
our operating force being diverted into a focus, an
unmerited focus on low- probability events at the
expense of things that will happen on the plant. And the
current set of presentations just reinforced my
concerns in this area.
CHAIR SCHULTZ: Dick?
MEMBER SKILLMAN: Thank you for the
information you've provided today. And I, too, as Dr.
Rempe mentioned, I would like to see these Draft Guides
another time. I think they will contain some meat that
is important to us. Thank you.
CHAIR SCHULTZ: Bill?
DR. SHACK: No, I think I've commented
enough.
CHAIR SCHULTZ: Members on the phone line,

1	Pete?
2	MEMBER RICCARDELLA: Yes, this is Pete. I
3	think personally the Committee needs to understand
4	better how the updated seismic hazards are going to be
5	addressed just by either through time or through a
6	risk-based B-
7	(Telephonic interference)
8	MEMBER RICCARDELLA: That either would
9	work, we just need to understand it a little better. I
10	think it doesn't make any sense to put in a requirement
11	that would be highly vulnerable to theseC-
12	CHAIR SCHULTZ: Pete, you're breaking up,
13	if you're on a speaker. Are you?
14	MEMBER RICCARDELLA: Just hang on, I'll get
15	off it.
16	CHAIR SCHULTZ: Thank you.
17	MEMBER RICCARDELLA: Hello, is that better?
18	CHAIR SCHULTZ: Much better.
19	MEMBER RICCARDELLA: Okay.
20	CHAIR SCHULTZ: Lesson learned.
21	MEMBER RICCARDELLA: Yes. I think the
22	Committee needs to understand how these updated seismic
23	hazards are going to be addressed with the FLEX
24	equipment.
25	CHAIR SCHULTZ: Okay. Is Mike Corradini on

1 the line, by any chance? 2 MEMBER CORRADINI: Yes, sir. CHAIR SCHULTZ: Okay, Mike, would you like 3 4 to make a comment in closing? 5 MEMBER CORRADINI: Well, I think most 6 things have been said by the other members. To the 7 extent, Steve, you've kind of captured all of this, I' 8 quess I'll just thank the Staff for bearing with us for 9 a long day of questions. I do think we should look at 10 the quidance so that it's very clear. I understand 11 Dana's concerns, so it strikes me that without looking 12 at the guidance to make sure it's consistent, and it's 13 understandable, some of Dana's concerns could occur. 14 And beyond the guidance, I think Pete's 15 point, and I think John made it, also, is how an upgraded 16 seismic hazard is going to be figured into dealing with 17 the equipment that has to be used either partially or 18 totally within the FLEX implementation. But that's it, 19 thank you. CHAIR SCHULTZ: Thank you, Mike. I'd also 20 21 like to express my appreciation to the industry for the 22 presentation this afternoon for having brought a lot to 23 the table. And also to the Staff for their discussions 24 earlier. It was very helpful to the Subcommittee to hear

all of the presentations and hear responses to our

25

	183
1	questions. It's been a very fruitful afternoon.
2	So, I would close the formal meeting with
3	that. I do have an informal announcement because the
4	Fukushima Subcommittee does have a meeting tomorrow
5	morning. Yes, let me close the record.
6	(Whereupon, the above-entitled matter went
7	off the record at 5:09 p.m.)
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	



# Mitigation of Beyond-Design-Basis Events (MBDBE) Proposed Rulemaking

Advisory Committee on Reactor Safeguards
Fukushima Subcommittee

March 19, 2015

# **Background**



- Efficiency gains through consolidation
- Scope of proposed rulemaking as it relates to originating Near-Term Task Force (NTTF) recommendations:
  - All of recommendations 4, 7, and 8
  - All of 9.1, 9.2. and 9.3 except long term Emergency Response Data System (ERDS)
  - 10.2 (command and control/decision maker qualifications) and 11.1 (delivery of equipment to site phase 3 portion of Order EA-12-049)
  - Includes NTTF 9.4 (ERDS modernization)
- In terms of post-Fukushima regulatory actions already underway:
  - Makes generically-applicable Order EA-12-049 and Order EA-12-051
  - Addresses staffing and communications from NTTF 9.3 (10 CFR 50.54(f) request)
  - Addresses re-evaluated hazards from NTTF 2.1 (10 CFR 50.54(f) request)

Paragraph (a) - Applicability



- Applicability
  - Current operating reactors
  - New reactors
  - Decommissioning reactors
- Requirements apply to both current and new reactor licensees and applicants
  - Design features requirements in proposed § 50.155(d) are for new reactor plant designs, and are in addition to the remainder of the requirements (revised)
- Decommissioning provisions: (revised)
  - Once fuel is permanently removed from the reactor no reactor or primary containment requirements
  - Once decay heat is sufficiently low versus SFP heat up/boil off to provide ample time: then only remaining mitigation is § 50.155(b)(2)
  - Once irradiated fuel is removed from the spent fuel pool all requirements cease

#### Paragraph (b) – Integrated Response



- Integrated Response Capability (unchanged)
  - Beyond-design-basis external event mitigation
    - Would make Order EA-12-049 generically applicable
    - Formerly referred to as SBOMS (industry's "FLEX" program)
  - Extensive Damage Mitigation Guidelines (EDMGs)
    - Would move § 50.54(hh)(2) requirements to this rule
    - No substantive changes to requirements
  - Severe Accident Management Guidelines (SAMGs)
    - Currently voluntary industry initiative
    - Regulation would require SAMGs
      - Inspection under ROP only no licensing review.
    - No additional equipment requirements

Paragraph (b) - Integrated Response



- Integrate with Emergency Operating Procedures (EOPs)
  - Structured to not impact previous regulatory efforts on EOPs
- Supporting staffing and command and control
  - Both staffing and command and control should be in place after Order EA-12-049 implementation
  - Recognizes challenge of a site-wide event that could lead to core damage and involve offsite assistance

#### Paragraph (c) – Equipment Requirements Paragraph (e) – Training Requirements



- Equipment Requirements (revised)
  - Would make Order EA-12-049 equipment requirements generically applicable
  - Would make Order EA-12-051 spent fuel pool level instrumentation requirements generically applicable
  - § 50.155 (c)(2) revised to reflect COMSECY-14-0037:
    - Mitigation strategies equipment required by paragraph (b)(1) must be reasonably protected from
      the effects of natural phenomena that are the more severe of: (1) the design basis of the facility;
      or (2) the licensee's reevaluated hazards, stemming from the March 12, 2012, NRC letter issued
      under § 50.54(f), as verified by the NRC's assessment issued by [EFFECTIVE DATE OF THE
      RULE].
- Training (unchanged)
  - Training of personnel for activities not already addressed
  - Systems approach to training
  - Expect most training already addressed as part of EOPs and Order EA-12-049 implementation
  - New training should be in the SAMG area





- New reactor design requirements (revised):
  - Only applies to applicants listed in paragraph § 50.155(a)(4)
  - Would require that design features be incorporated into new reactor plant designs that enhance coping durations and minimize reliance on human actions for an extended loss of all ac power concurrent with a loss of normal access to the ultimate heat sink

#### Intent:

- Require certain elements of the Commission's advanced reactor policy statement for new reactor designs during ELAP/LUHS
  - "...longer time constants and sufficient instrumentation to allow for more diagnosis and management before reaching safety systems challenge or exposure of vital equipment to adverse conditions."
  - · "simplified safety systems that, where possible, reduce required operator actions"
- Applicants would consider the effects of an ELAP/LUHS early in the design process and incorporate design features that provide enhanced capabilities to address these events

United States Nuclear Regulatory Commission

Protecting People and the Environment

Paragraph (f) Drills and Exercises (Unchanged)
Paragraph (g) – Change Control (Unchanged)

- Drills provide assurance that guideline sets are integrated and can be used
  - Initial drill(s) to show use and transitions
  - Follow-on drill(s) to provide assurance of continuing capability
  - Complex drill schedule: Initial drill within 2 refueling outages (RFs) and follow-on in 8 calendar years
  - Current operating licensees/holder of combined license (COL) after 52.103(g) finding:
    - 1st drill within 2 RFs after that 8 year period
  - Applicants for a part 50 operating license (OL) or holder of COL before 52.103(g) finding:
    - Demonstrate use and transitions initial drill(s)
    - · Subsequent drills 8 year period
- MBDBE Change Control
  - Facility changes can impact multiple regulatory areas; all change controls must be applied
  - No threshold criterion; must comply with requirements

Appendix E, Application, Implementation



- New Appendix E requirements (Unchanged)
  - Multi-source term requirements are incorporated directly into current Appendix E
  - New Section VII requirement for staffing and communications
  - Technology-neutral ERDS
- Application requirements (Unchanged)
  - Applications for new reactors
- Implementation: Will use the Cumulative Effects of Regulation (CER) process (Unchanged)

#### **Backfit Considerations**

# United States Nuclear Regulatory Commission Protecting People and the Environment

#### (Unchanged)

- The MBDBE rule has different supporting backfit bases:
  - Proposed rule requirements are severable
  - Order EA-12-049 and Order EA-12-051 requirements are <u>not</u> backfits (i.e., already imposed by orders)
  - All other requirements need justification under Part 50 backfitting provisions (operating reactors) and Part 52 issue finality provisions (new reactors):
    - Items supporting Order EA-12-049 are technically backfits without impact
    - SAMGs and supporting requirements (drills and training that involve SAMGs)
    - Multi-source dose assessment (voluntarily implemented): Is a backfit but should not cause additional impact
    - New reactors requirements are designed to be "forward fitted"
    - Technology-neutral Emergency Response Data System (ERDS) remove technology reference, aligns with current practice, not a backfit

# SAMGs Backfit (Unchanged)



- Qualitative basis for imposing SAMG requirements
  - Guideline set used by operators and decision-makers following onset of core damage
  - SAMGs support making optimal decisions concerning containment
  - SAMGs support informing the emergency response organization with regard to protective actions (e.g., fission product barrier integrity)
  - The value of SAMGs, pre-planned guidelines for best use of all available resources to mitigate the accident

 Quantitative basis informed by Containment Protection and Release Reduction effort

# **Draft Regulatory Guidance**



- DG-1301 "Flexible Mitigation Strategies for Beyond-Design-Basis Events"
  - Current draft guidance would endorse NEI 12-06 rev. 1 with clarifications
  - NEI is revising NEI 12-06 rev. 0 (to produce rev. 1):
    - To reflect lessons-learned from implementation of Order EA-12-049
    - To address re-evaluated hazards
  - Includes guidance for new reactor designs to meet proposed § 50.155(d)
- DG-1317 "Wide-Range Spent Fuel Pool Level Instrumentation"
  - Would endorse NEI 12-02 (Previously endorsed for Order EA-12-051)
- DG-1319 "Integrated Response Capabilities for Beyond-Design-Basis Events"
  - Would endorse NEI 12-01 (Previously endorsed for RFI),
     NEI 13-06, and NEI 14-01

#### **DG-1301**



- Preliminary Draft
- NEI 12-06, Diverse and Flexible Coping Strategies (FLEX)
   Implementation Guide, Revision 1, Draft C, is basis
- Incorporates lessons learned in Order EA-12-049 implementation (alternative approaches, generic items, etc.)
- Work remaining includes:
  - Receipt of SRM-COMSECY-14-0037 to support development of NEI 12-06 Appendices for Seismic and Flooding Re-evaluations

# **DG-1301 Appendix A** (For New Reactor Designs)



- Enhance coping durations
  - Initially cope with installed SSCs at least 24 hours
    - After 8 hours, use of supplemental ac permissible
  - Then, cope at least 72 hours, using on-site equipment, before off-site resources are obtained
- Minimize reliance on human actions
  - Initially, minimal actions at limited and protected locations; monitoring, control, and coordination from the MCR or designed in location
  - Following the early phase, actions should be reasonable considering anticipated site conditions following the event

#### **DG-1319**



- NEI 12-01, "Guidelines for Assessing Beyond Design Basis Accident Response Staffing and Communications Capabilities"
  - Accident response staffing
  - Communications systems
- NEI 13-06, "Enhancement to Emergency Response Capabilities for Beyond Design Basis Events and Severe Accidents"
  - Multi-unit dose assessment
  - Training
  - Drills and exercises
  - EP facilities and equipment
- NEI 14-01, "Emergency Response Procedures and Guidelines for Beyond Design Basis Events and Severe Accidents"
  - SAMGs No detailed review of Owners Group or plant-specific SAMGs
  - Command and control
  - Procedure integration

#### **Status and Path Forward**



- Proposed rule package is in concurrence:
  - Due to EDO on April 16, 2015 and Commission on April 30, 2015
  - Draft guidance should be issued with proposed rule in summer 2015
  - Recognize the ongoing work on DG-1301 and can meet with the ACRS prior to July or during public comment period if the Committee desires.
- Future ACRS interactions
  - Full committee April 9, 2015 (proposed rule)
  - Full committee TBD (final rule)

# Industry Perspective on Draft Mitigating Beyond Design Basis (BDB) Events Rule

Bryan Ford
Senior Manager - Regulatory Assurance
Entergy Nuclear
March 19, 2015 • ACRS Meeting



#### **MBDBE Rule - Positives**

- Right topics addressed with "high-level" language
- Reflects the significant amount of industry work since Fukushima
  - Existing Order requirements and commitments
  - Responses to 50.54(f) letter of 3/12/12
- Staff intends to support use of industrydeveloped guidance – additional work needed
- Changes have been made based on previous industry comments



# **MBDBE** Rule – Areas for Improvement

- Reevaluated Hazards
  - MBDBE capabilities need to address a spectrum of plant conditions caused by different initiating events (hazards) and resulting damage states
    - In some reevaluated hazard cases, AC power and/or ultimate heat sink may be available
  - Rule wording should accommodate
     Alternate/Targeted Hazard mitigation strategies
    - Affects "reasonable protection" and "containment"
  - Inconsistent with current seismic path forward



# Reevaluated Hazards – (b)(1)

- Strategies and guidelines to mitigate beyonddesign-basis external events from:
  - Natural phenomena that result in an extended loss of all ac power concurrent with a loss of normal access to the ultimate heat sink
  - The licensee's reevaluated flood hazards, stemming from the March 12, 2012, NRC letter issued under § 50.54(f), as verified by the NRC's assessment issued by [EFFECTIVE DATE OF THE RULE].



# Reevaluated Hazards – (c)(2)

 The equipment relied on for the mitigation strategies required by paragraph (b)(1) of this section must be reasonably protected from the effects of natural phenomena. that are the more severe of: (1) the design basis of the facility; or (2) the licensee's reevaluated hazards, stemming from the March 12, 2012, NRC letter issued under § 50.54(f), as verified by the NRC's assessment issued by [EFFECTIVE DATE OF THE RULE].



# **MBDBE** Rule – Areas for Improvement

- Proposed § 52.79 and § 52.80
  - We do not believe that these requirements are necessary for new plants
  - Adequately addressed in current design review requirements (designed to higher standards)
- Use of qualitative factors to justify imposing SAMG requirements is not in accordance with Commission direction (SRM-SECY-14-0087)



# MBDBE Rule – Areas for Improvement

- Emergency Response
  - Relocate the new staffing and communications requirements from Appendix E to new Part 50.155
- Change control
  - Other change processes should recognize the differences between design/licensing basis and BDB external events
    - What is not acceptable in one instance (design basis) may be acceptable in the other (BDB)



#### **Other Comments**

- Implementation should be specified in "years," not 2<sup>nd</sup> outage restart
  - Recommend 4 years to minimize CER
- Given the scope and complexity of the proposed rule, the industry requests that the public comment period be initially established at the maximum possible duration
  - Obviate the need to request/process an extension

