



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 18, 2015

Mr. C. R. Pierce
Regulatory Affairs Director
Southern Nuclear Operating Company, Inc.
Post Office Box 1295, Bin - 038
Birmingham, AL 35201-1295

SUBJECT: VOGTLE ELECTRIC GENERATING PLANT, UNIT 1 - REGARDING THE 2014
STEAM GENERATOR TUBE INSPECTIONS (TAC NO. MF4987)

Dear Mr. Pierce:

By letter dated October 3, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14276A430), Southern Nuclear Operating Company (the licensee) submitted information summarizing the results of the spring 2014 steam generator tube inspections performed at Vogtle Electric Generating Plant, Unit 1. These inspections were performed during refueling outage 18. In a letter dated April 2, 2015 (ADAMS Accession No. ML15092A831), the licensee provided additional information concerning these inspections. The U.S. Nuclear Regulatory Commission (NRC) staff has completed its review of the reports and concludes that the licensee provided the information required by their technical specifications and that no additional follow-up is required at this time. The NRC staff's review of the reports is enclosed.

Sincerely,

A handwritten signature in black ink that reads "Bob Martin".

Bob Martin, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-424

Enclosure: Review of Report

cc w/encl: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

UNITED STATES NUCLEAR REGULATORY COMMISSION

OFFICE OF NUCLEAR REACTOR REGULATION

REVIEW OF THE SPRING 2014 STEAM GENERATOR TUBE INSPECTION REPORT

VOGTLE ELECTRIC GENERATING PLANT, UNIT 1

DOCKET NO. 50-424

By letter dated October 3, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14276A430), Southern Nuclear Operating Company (the licensee) submitted information summarizing the results of the spring 2014 steam generator (SG) tube inspections performed at Vogtle Electric Generating Plant, Unit 1. These inspections were performed during refueling outage 18. In a letter dated April 2, 2015 (ADAMS Accession No. ML15092A831), the licensee provided additional information concerning these inspections. Vogtle Electric Generating Plant, Unit 1, has four Westinghouse Model F SGs, each of which contains 5,626 U-bend thermally treated Alloy 600 tubes. Each tube has a nominal outside diameter of 0.688 inches and a nominal wall thickness of 0.040 inches. During SG fabrication, the tubes were hydraulically expanded, at both ends, over the full depth of the tubesheet. The vertical sections of the tubes are supported by Type 405 stainless steel support plates, which have broached quatrefoil holes. The U-bend sections of the tubes are supported by Type 405 stainless steel anti-vibration bars.

The licensee provided the scope, extent, methods, and results of their SG tube inspections in the documents referenced above. In addition, the licensee described corrective actions (i.e., tube plugging) taken in response to the inspection findings. After reviewing the information provided by the licensee, the U.S. Nuclear Regulatory Commission (NRC) staff has the following comments/observations:

Cracking was identified at the expansion transition region on the hot-leg side of SG 4 and in a bulge in the tubesheet on the hot-leg side of SG 4.

Based on a review of the information provided, the NRC staff concludes that the licensee provided the information required by their technical specifications. In addition, the NRC staff concludes that there are no technical issues that warrant follow-up action at this time since the inspections appear to be consistent with the objective of detecting potential tube degradation and the inspection results appear to be consistent with industry operating experience at similarly designed and operated units.

Principal Contributor: A. Johnson

Date: May 18, 2015

Enclosure

May 18, 2015

Mr. C. R. Pierce
Regulatory Affairs Director
Southern Nuclear Operating Company, Inc.
Post Office Box 1295, Bin - 038
Birmingham, AL 35201-1295

SUBJECT: VOGTLE ELECTRIC GENERATING PLANT, UNIT 1 - REGARDING THE 2014
STEAM GENERATOR TUBE INSPECTIONS (TAC NO. MF4987)

Dear Mr. Pierce:

By letter dated October 3, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14276A430), Southern Nuclear Operating Company (the licensee) submitted information summarizing the results of the spring 2014 steam generator tube inspections performed at Vogtle Electric Generating Plant, Unit 1. These inspections were performed during refueling outage 18. In a letter dated April 2, 2015 (ADAMS Accession No. ML15092A831), the licensee provided additional information concerning these inspections. The U.S. Nuclear Regulatory Commission (NRC) staff has completed its review of the reports and concludes that the licensee provided the information required by their technical specifications and that no additional follow-up is required at this time. The NRC staff's review of the reports is enclosed.

Sincerely,
/RA/

Bob Martin, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-424

Enclosure: Review of Report

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPL2-1R/F RidsAcrsAcnw_MailCTR Resource GKulesa, NRR
RidsNrrPMVogtle Resource RidsNrrDoriDpr Resource KKarwoski, NRR
RidsNrrDoriLpl2-1 Resource RidsRgn2MailCenter Resource AJohnson, NRR
RidsNrrLASFiguroa Resource AHuynh, NRR

ADAMS Accession No.: ML15134A326

***By memo dated May 6, 2015**

OFFICE	DORL/LPL2-1/PM	DORL/LPL2-1/LA	NRR/DE/ESGB*	DORL/LPL2-1/BC	DORL/LPL2-1/PM
NAME	BMartin	SFiguroa	GKulesa	RPascarelli	BMartin
DATE	05/15/15	05/15/15	05/06/15	05/18/15	05/18/15

OFFICIAL RECORD COPY