

From: [Foyto, Leslie P.](#)
To: [Wertz, Geoffrey](#)
Cc: [Adams, Alexander](#); [Butler, Ralph](#)
Subject: I-131 Processing Hot Cells
Date: Thursday, May 28, 2015 1:32:34 PM

Geoffrey,

As a follow-up to our discussion this morning, MURR will limit operation of the iodine processing hot cells to material quantities of less than the limits provided in MURR Technical Specification Limit 3.7 and 10 CFR 20, Appendix B. This assumes that no filtration is in place (unmitigated) if any processing were to occur. Please let me know if you have any questions.

Thanks,

Les Foyto

Associate Director, Reactor and Facility Operations

University of Missouri-Columbia Research Reactor

1513 Research Park Drive

Columbia, Missouri, 65211

(573) 882-5276 office phone

(573) 882-6360 fax

Website: <http://www.murr.missouri.edu/>

