

NRR-PMDAPEm Resource

From: Ptasznik, Elizabeth M [EPtasznik@ameren.com]
Sent: Wednesday, June 03, 2015 6:53 PM
To: Wyman, Stephen
Subject: RE: Callaway ESEP Clarifications Questions

Stephen,

A response to each of your questions are provided for the Callaway Plant below. We are asking for an extension on our response to Question 2.c until 06/25/2015.

1. The components in question were not included on the ESEL because of the exemption "NSSS Components" contained in the Augmented Approach Guidelines (Reference 1, Section 3.2). Without further definition provided, those components considered to be part of the Nuclear Steam Supply System (NSSS) were designated as the Reactor Coolant System (RCS) and connected systems up to the main steam isolation valves (MSIVs). Therefore, the components questioned, steam generator atmospheric relief valves (ARVs), accumulators, accumulator isolation valves, and reactor head vent and pressurizer PORV were not included on the Callaway Expedited Seismic Evaluation List (ESEL). (Reference 1: EPRI Report, "Seismic Evaluation Guidance Augmented Approach for the Resolution of Fukushima Near-Term Task Force Recommendation 2.1 – Seismic")
2. Steam generator water level, steam generator pressure, RCS pressure and RCS temperature were not included on the ESEL because of the exemption "NSSS Components" contained in the Augmented Approach Guidelines (Reference 1, Section 3.2). Without further definition provided, those components considered to be part of the Nuclear Steam Supply System (NSSS) were designated as the Reactor Coolant System (RCS) and connected systems up to the main steam isolation valves (MSIVs). Therefore, steam generator water level, steam generator pressure, RCS pressure and RCS temperature were not included on the Callaway Expedited Seismic Evaluation List (ESEL). Containment pressure instrumentation was not included at the time of the ESEP as the containment function was not expected to be challenged per the OIP. Further investigation of the need for inclusion of containment pressure instrumentation on the ESEL is needed. (Reference 1: EPRI Report, "Seismic Evaluation Guidance Augmented Approach for the Resolution of Fukushima Near-Term Task Force Recommendation 2.1 – Seismic")
3. The new flow path will rely on the HCST. For surface-mounted structures, systems and components (SSC), directly applying the GMRS for HCLPF determination is acceptable. Thus the RLGM for the HCST is the GMRS. The HCST, when constructed, will achieve a HCLPF capacity at the level of the RLGM. Connected piping and pipe supports screen out of ESEP and will be designed to SSE. Per the current design, a new fail-open AOV will be installed between the HCST and the existing AFW system. This valve will be seismically analyzed to meet ESEP requirements.
4. The walkdowns were performed by structural engineers that were designated as Seismic Capability Engineers (SCE). Required for that designation, they have all completed the EPRI 5-day SQUG training. These engineers were also the same engineers that performed the NTF 2.3 Seismic Walkdowns for this plant (their certificates were included in the 2.3 NRC submittals.)

If there is a need for further discussion, please contact me, and we can arrange a phone call with Callaway's project team.

Liz

.....

ELIZABETH PTASZNIK

Engineer

Regulatory Affairs - Licensing

E eptasznik@ameren.com

Please consider the environment before printing this e-mail.

From: Wyman, Stephen [<mailto:Stephen.Wyman@nrc.gov>]

Sent: Tuesday, May 19, 2015 3:30 PM

To: Elwood, Thomas B; Ptasznik, Elizabeth M

Cc: Maglio, Scott A; Devlin-Gill, Stephanie

Subject: Callaway ESEP Clarifications Questions

Mr. Elwood,

In follow-up to our phone conversation today, as part of the NRC review of the Callaway ESEP report, the staff would appreciate clarification on the following technical items:

The following clarification questions are raised in the context of the NRC evaluation of the ESEP submittals only and licensees' responses will be reviewed by NRC staff only to the extent the use of this information affects the elements and outcomes of the ESEP evaluation. As many licensees have used information from their ongoing SPRA analyses, the current review will not evaluate methods or results as they pertain to the SPRA. They will be reviewed later at the time of SPRA review.

- 1) The following SSCs appear to meet the ESEP guidance, but were not included on the ESEL: steam generator atmospheric relief valves (ARVs), accumulators, accumulator isolation valves, and reactor head vent or pressurizer PORV. Please add these components to the ESEL with any associated support equipment and provide results per ESEP guidance (e.g., HCLPF analysis results) or provide a justification why they are not included on the ESEL.
- 2) All necessary instrumentation does not appear to be included on the ESEL. Clarify which SSCs are necessary to achieve the following indications and confirm they are included in or added to the ESEL.
 - a. Steam generator water level
 - b. Steam generator pressure
 - c. Containment pressure
 - d. RCS pressure
 - e. RCS Temperature
- 3) The hardened CST (HCST) was not included in the ESEL. Confirm whether the new flow path will rely on the HCST and if so, whether the HCST when constructed will achieve a HCLPF capacity at the level of the RLGM. If the new flow path will rely on support equipment which falls within the scope of the ESEP, such as permanently installed equipment or FLEX connection points, confirm that these SSCs will achieve a HCLPF capacity at the level of the RLGM.
- 4) The licensee did not state whether the walkdown personnel were trained in seismic walkdown. Please confirm that the walkdowns were conducted by trained personnel that successfully completed training specific for seismic, such as the Seismic Qualification Utility Group (SQUG) Walkdown Screening and Seismic Evaluation Training Course.

An email response will likely be sufficient to support the ESEP report review, however, please be aware that your email response will be made publicly available in ADAMS. A response around June 3rd, if practicable, would be greatly appreciated to support the planned review schedule.

Please let me or Nick DiFrancesco (at 301-415-1115) know if you would like to schedule a clarification call or have any questions and concerns.

Thanks,
Steve

Stephen M. Wyman
USNRC/NRR/JLD/HMB
Office: O-13G9 MS: O-13C5
301-415-3041 (Voice)
301-415-8333 (Fax)
Stephen.Wyman@nrc.gov

The information contained in this message may be privileged and/or confidential and protected from disclosure. If the reader of this message is not the intended recipient, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. Note that any views or opinions presented in this message are solely those of the author and do not necessarily represent those of Ameren. All e-mails are subject to monitoring and archival. Finally, the recipient should check this message and any attachments for the presence of viruses. Ameren accepts no liability for any damage caused by any virus transmitted by this e-mail. If you have received this in error, please notify the sender immediately by replying to the message and deleting the material from any computer. Ameren Corporation

Hearing Identifier: NRR_PMDA
Email Number: 2134

Mail Envelope Properties (BE753406A3C6734B92286A3A848D9A3606C61139A1)

Subject: RE: Callaway ESEP Clarifications Questions
Sent Date: 6/3/2015 6:52:53 PM
Received Date: 6/3/2015 6:53:06 PM
From: Ptasznik, Elizabeth M

Created By: EPtasznik@ameren.com

Recipients:
"Wyman, Stephen" <Stephen.Wyman@nrc.gov>
Tracking Status: None

Post Office: exchcal1.corp.dir.ameren.com

Files	Size	Date & Time
MESSAGE	7637	6/3/2015 6:53:06 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: