

MRP-227-A Plant-Specific Inspection Plan Review and Action Item Update

Jeff Poehler
Annual Industry-NRC Materials Meeting
Rockville, MD
June 3, 2015

Status of NRC Reviews of Plant-Specific Inspection Plans



- NRC issued Safety Assessments for five plant-specific inspection plans (8 reactors), allowing closure of license renewal commitments, since June 2014
 - Palisades (12/11/14)
 - TMI-1 (12/19/14)
 - Palo Verde, Units 1, 2 and 3 (3/27/15)
 - Point Beach, Units 1 & 2 (3/30/15)
 - Millstone, Unit 2 (5/29/15)
- NRC issued License Renewal Safety Evaluation Report Supplement approving RVI Aging Management Program and Inspection Plan for Indian Point, Units 2 & 3 (11/6/14)
- Inspection Plans for 18 more reactors are under review (DE-10, DLR-8)
- Expect to issue more safety assessments in 2015.

Action Item 1- Plant-Specific Applicability



- Licensees continuing to resolve Action Item 1 using MRP 2013-025 guidance
- Long lead time to respond to question on cold work is an ongoing issue.



Action Item 7 - Plant-Specific Evaluation of CASS



- Successfully resolved for some plants using either:
 - Screening plus primary link modifications
 - Functionality analysis
- Staff reviewing generic functionality analysis for Westinghouse lower support columns
 - Need to identify applicability verification criteria
 - Separate meeting to discuss staff questions



CASS Screening Criteria



- MRP/BWRVIP submitted proposed PWR/BWR CASS screening criteria technical basis on March 9, 2015 via MRP Letter 2015-025
- Staff reviewing MRP letter and preparing a formal revision to previous guidance in LRA Issue 98-0030 (Grimes Letter)
- Under management review
- Likely will issue as Interim Staff Guidance (ISG)

