

Thomas D. Gatlin
Vice President, Nuclear Operations
803.345.4342



June 1, 2015

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Dear Sir / Madam:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (UNIT 1)
DOCKET NO. 50-395
OPERATING LICENSE NO. NPF-12
CYCLE 22 CORE OPERATING LIMITS REPORT (COLR) REVISION 2

In accordance with Section 6.9.1.11 of the Virgil C. Summer Nuclear Station Technical Specifications, South Carolina Electric & Gas Company, acting for itself and as an agent for South Carolina Public Service Authority, hereby submits Revision 2 of the Core Operating Limits Report for Cycle 22. This revision corrects an error in the macroscopic cross section for neutron absorption (SIG-P) variable affecting analyzed shutdown margin. This report supersedes letter dated May 27th, 2014 (RC-14-0080, ML14149A388).

Should you have any questions, please call Bruce Thompson at (803) 931-5042.

Very truly yours,

Thomas D. Gatlin

BJH/TDG/rp

Attachment: V. C. Summer Unit 1 Cycle 22 Core Operation Limits Report Revision 2
c: Without Attachment unless noted

K. B. Marsh
S. A. Byrne
J. B. Archie
N. S. Carns
J. H. Hamilton
J. W. Williams
W. M. Cherry
K. M. Sutton

V. M. McCree (w/attachment)
S. A. Williams (w/attachment)
S. E. Jenkins
NRC Resident Inspector (w/attachment)
NSRC
RTS (LTD 320, CR-15-01928)
File (RR 5000)
DMS (RC-15-0086)

A001
NRR

SOUTH CAROLINA ELECTRIC & GAS COMPANY
VIRGIL C. SUMMER NUCLEAR STATION
UNIT 1

CORE OPERATING LIMITS REPORT
FOR
CYCLE 22

REVISION 2

MAY 2015

LIST OF EFFECTIVE PAGES

| <u>PAGE</u> | <u>REVISION</u> |
|--------------------|------------------------|
| i | 2 |
| ii | 2 |
| iii | 2 |
| 1 | 2 |
| 2 | 2 |
| 3 | 2 |
| 4 | 2 |
| 5 | 2 |
| 6 | 2 |
| 7 | 2 |
| 8 | 2 |
| 9 | 2 |
| 10 | 2 |
| 11 | 2 |
| 12 | 2 |
| 13 | 2 |
| 14 | 2 |
| 15 | 2 |
| 16 | 2 |
| 17 | 2 |
| 18 | 2 |
| 19 | 2 |
| 20 | 2 |
| 21 | 2 |
| 22 | 2 |
| 23 | 2 |
| 24 | 2 |
| 25 | 2 |
| 26 | 2 |
| 27 | 2 |

Table of Contents

| <u>Section</u> | <u>Page</u> |
|--|-------------|
| 1.0 Core Operating Limits Report | 1 |
| 2.0 Operating Limits | 2 |
| 2.1 Moderator Temperature Coefficient (Specification 3.1.1.3) | 2 |
| 2.2 Shutdown Rod Insertion Limits (Specification 3.1.3.5) | 2 |
| 2.3 Control Rod Insertion Limits (Specification 3.1.3.6) | 3 |
| 2.4 Axial Flux Difference (Specification 3.2.1) | 3 |
| 2.5 Heat Flux Hot Channel Factor - $F_Q(z)$ (Specification 3.2.2) | 3 |
| 2.6 RCS Flow Rate and Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}^N$ (Specification 3.2.3) | 4 |
| 2.7 Power Distribution Measurement Uncertainty (Specifications 3.2.2 and 3.2.3) | 4 |
| 3.0 References | 6 |

List of Tables

| <u>Table</u> | | <u>Page</u> |
|--------------|---|-------------|
| Table 1. | RAOC W(z) at 150 MWD/MTU V. C. Summer – Cycle 22 | 11 |
| Table 2. | RAOC W(z) at 3000 MWD/MTU V. C. Summer – Cycle 22 | 12 |
| Table 3. | RAOC W(z) at 5000 MWD/MTU V. C. Summer – Cycle 22 | 13 |
| Table 4. | RAOC W(z) at 8000 MWD/MTU V. C. Summer – Cycle 22 | 14 |
| Table 5. | RAOC W(z) at 10000 MWD/MTU V. C. Summer – Cycle 22 | 15 |
| Table 6. | RAOC W(z) at 14000 MWD/MTU V. C. Summer – Cycle 22 | 16 |
| Table 7. | RAOC W(z) at 20000 MWD/MTU V. C. Summer – Cycle 22 | 17 |
| Table 8. | RAOC F_Q Margin Decreases in Excess of 2% Per 31 EFPD – Cycle 22 | 18 |
| Table 9. | Baseload W(z) at 150 MWD/MTU V. C. Summer – Cycle 22 | 19 |
| Table 10. | Baseload W(z) at 3000 MWD/MTU V. C. Summer – Cycle 22 | 20 |
| Table 11. | Baseload W(z) at 5000 MWD/MTU V. C. Summer – Cycle 22 | 21 |
| Table 12. | Baseload W(z) at 8000 MWD/MTU V. C. Summer – Cycle 22 | 22 |
| Table 13. | Baseload W(z) at 10000 MWD/MTU V. C. Summer – Cycle 22 | 23 |
| Table 14. | Baseload W(z) at 14000 MWD/MTU V. C. Summer – Cycle 22 | 24 |
| Table 15. | Baseload W(z) at 20000 MWD/MTU V. C. Summer – Cycle 22 | 25 |
| Table 16. | Baseload F_Q Margin Decreases in Excess of 2% Per 31 EFPD – Cycle 22 | 26 |

List of Figures

| <u>Figure</u> | | <u>Page</u> |
|---------------|---|-------------|
| Figure 1. | Moderator Temperature Coefficient Versus Power Level V. C. Summer – Cycle 22 | 7 |
| Figure 2. | Rod Group Insertion Limits Versus Thermal Power for Three Loop Operation V. C. Summer – Cycle 22 | 8 |
| Figure 3. | Axial Flux Difference Limits as a Function of Rated Thermal Power V. C. Summer – Cycle 22 | 9 |
| Figure 4. | $K(z)$ - Normalized $F_Q(z)$ as a Function of Core Height V. C. Summer – Cycle 22 | 10 |
| Figure 5. | RCS Total Flowrate vs. R for Three Loop Operation V. C. Summer – Cycle 22 | 27 |

1.0 Core Operating Limits Report

This Core Operating Limits Report (COLR) for V. C. Summer Station Cycle 22 has been prepared in accordance with the requirements of Technical Specification 6.9.1.11.

The Technical Specifications affected by this report are listed below:

- 3.1.1.3 Moderator Temperature Coefficient
- 3.1.3.5 Shutdown Rod Insertion Limits
- 3.1.3.6 Control Rod Insertion Limits
- 3.2.1 Axial Flux Difference (AFD)
- 3.2.2 Heat Flux Hot Channel Factor
- 3.2.3 RCS Flow Rate and Nuclear Enthalpy Rise Hot Channel Factor
- 3.3.3.11 Power Distribution Measurement Uncertainty

2.0 Operating Limits

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the subsections which follow. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.9.1.11.

2.1 Moderator Temperature Coefficient (Specification 3.1.1.3):

2.1.1 The Moderator Temperature Coefficient (MTC) limits are:

The BOL/ARO-MTC shall be less positive than the limits shown in Figure 1.

The EOL/ARO/RTP-MTC shall be less negative than $-4.8 \times 10^{-4} \Delta k/k/^{\circ}F$ (-48 pcm/ $^{\circ}F$).

where: BOL stands for Beginning of Cycle Life

ARO stands for All Rods Out

RTP stands for RATED THERMAL POWER

EOL stands for End of Cycle Life

2.1.2 The MTC Surveillance limit is:

The 300 ppm/ARO/RTP-MTC should be less negative than or equal to $-4.1 \times 10^{-4} \Delta k/k/^{\circ}F$ (-41 pcm/ $^{\circ}F$).

2.1.3 The Revised Predicted near-EOL 300 ppm MTC shall be calculated using the following algorithm from Reference 2:

Revised Predicted MTC = Predicted MTC + AFD Correction*+ Predictive Correction**

*AFD Correction is 0.05 pcm/ $^{\circ}F$ / % Δ AFD.

**Predictive Correction is -3 pcm/ $^{\circ}F$.

If the Revised Predicted MTC is less negative than the SR 4.1.1.3b limit of

$-4.1 \times 10^{-4} \Delta k/k/^{\circ}F$, and all of the benchmark data contained in the surveillance procedure are met, then an MTC measurement in accordance with SR 4.1.1.3b is not required.

2.2 Shutdown Rod Insertion Limits (Specification 3.1.3.5):

The shutdown rods shall be withdrawn to at least 230 steps.

2.3 Control Rod Insertion Limits (Specification 3.1.3.6):

Control Bank A and B rods shall be withdrawn to at least 230 steps. Control Bank C and D Rod Insertion Limits are specified by Figure 2. Control rod overlap is 102 steps.

2.4 Axial Flux Difference (Specification 3.2.1):

2.4.1 The Axial Flux Difference (AFD) Limits for Relaxed Axial Offset Control (RAOC) operation for Cycle 22 are shown in Figure 3.

2.4.2 The Axial Flux Difference (AFD) target band during base load operations for Cycle 22 is: BOL - EOL (0 – 23,000 MWD/MTU): $\pm 5\%$ about a measured target value.

2.4.3 The minimum allowable power level for base load operation, APL^{ND} , is 75% of RATED THERMAL POWER.

2.5 Heat Flux Hot Channel Factor - $F_Q(z)$ (Specification 3.2.2):

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{P} \times K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5} \times K(Z) \quad \text{for } P \leq 0.5 \quad \text{where: } P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

2.5.1 $F_Q^{RTP} = 2.45$

2.5.2 $K(z)$ is provided in Figure 4.

2.5.3 Elevation dependent $W(z)$ values for RAOC operation at 150, 3000, 5000, 8000, 10000, 14000, and 20000 MWD/MTU are shown in Tables 1 through 7, respectively. This information is sufficient to determine $W(z)$ versus core height in the range of 0 MWD/MTU to EOL burnup through the use of three point interpolation. A 2% penalty factor shall be used for RAOC operation to increase $F_Q^M(z)$ as per Surveillance Requirement 4.2.2.4e. A 2% penalty factor shall be used at all burnups.

2.5.4 Elevation dependent $W(z)_{BL}$ values for Baseload operation between 75 and 100% of rated thermal power with the item 2.4.2 specified target band about a measured target value at 150, 3000, 5000, 8000, 10000, 14000, and 20000 MWD/MTU are shown in Tables 8 through 14, respectively. This information is sufficient to determine $W(z)_{BL}$ versus core height for burnups in the range of 0 MWD/MTU to EOL burnup through the use of three point interpolation. Table 15 shows FQ margin decreases for base load operation that are greater than 2% per 31 Effective Full Power Days (EFPD). These values shall be used to increase $F_Q^M(z)$ as per Surveillance.

2.6 RCS Flow Rate and Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}^N$ (Specification 3.2.3):

$$R = \frac{F_{\Delta H}^N}{F_{\Delta H}^{RTP} \times (1 + PF_{\Delta H}^N \times (1 - P))} \text{ where: } P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

2.6.1 $F_{\Delta H}^{RTP} = 1.62$

2.6.2 $PF_{\Delta H} = 0.3$

2.6.3 The Acceptable Operation Region from the combination of Reactor Coolant System total flow and R is provided in Figure 5.

2.7 Power Distribution Measurement Uncertainty (Specifications 3.2.2 and 3.2.3):

If the Power Distribution Monitoring System is OPERABLE, as defined in Technical Specification 3.3.3.11, the uncertainty, $U_{F_{\Delta H}}$, to be applied to the Nuclear Enthalpy Rise Hot Channel Factor $F_{\Delta H}^N$ shall be calculated by the following formula:

$$U_{F_{\Delta H}} = 1.0 + \frac{U_{\Delta H}}{100.0}$$

where: $U_{\Delta H}$ = Uncertainty for enthalpy rise as defined in equation (5-19) in Reference 1 or 4.0, whichever is larger.

If the Power Distribution Monitoring System is OPERABLE, as defined in Technical Specification 3.3.3.11, the uncertainty, U_{FQ} , to be applied to the Heat Flux Hot Channel Factor $F_Q(z)$ shall be calculated by the following formula:

$$U_{FQ} = \left(1.0 + \frac{U_Q}{100.0} \right) \cdot U_e$$

where: U_Q = Uncertainty for $F_Q(z) = 5.0$ when confirming $F_Q(z)$ for RAOC or Base Load operation, or as defined in equation (5-19) in Reference 1 for all other purposes.

$$\begin{aligned} U_e &= \text{Engineering uncertainty factor.} \\ &= 1.03 \end{aligned}$$

If the Power Distribution Monitoring System is INOPERABLE, as defined in Technical Specification 3.3.3.11, the uncertainty, $U_{F\Delta H}$, to be applied to the Nuclear Enthalpy Rise Hot Channel Factor $F_{\Delta H}^N$ shall be calculated by the following formula:

$$U_{F\Delta H} = U_{F\Delta Hm}$$

where: $U_{F\Delta Hm}$ = Base $F_{\Delta H}$ measurement uncertainty.
= 1.04

If the Power Distribution Monitoring System is INOPERABLE, as defined in Technical Specification 3.3.3.11, the uncertainty, U_{FQ} , to be applied to the Heat Flux Hot Channel Factor $F_Q(z)$ shall be calculated by the following formula:

$$U_{FQ} = U_{qu} \cdot U_e$$


where: U_{qu} = Base F_Q measurement uncertainty.
= 1.05
 U_e = Engineering uncertainty factor.
= 1.03

3.0 References


- 1) WCAP-12472-P-A, "BEACON Core Monitoring and Operations Support System," August, 1994, (W Proprietary)
WCAP-12472-P-A, Addendum 1-A, "BEACON Core Monitoring and Operations Support System," January 2000, (W Proprietary).

- 2) WCAP-13749-P-A, "Safety Evaluation Supporting the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient," March 1997, (W Proprietary).


**Figure 1. Moderator Temperature Coefficient Versus Power Level
V.C. Summer – Cycle 22**




**Figure 2. Rod Group Insertion Limits Versus Thermal Power for Three Loop Operation
V. C. Summer - Cycle 22**



**Figure 3. Axial Flux Difference Limits as a Function of Rated Thermal Power
V. C. Summer – Cycle 22**



**Figure 4. $K(z)$ - Normalized $F_Q(z)$ as a Function of Core Height
V. C. Summer - Cycle 22**



**Table 1. RAOC W(z) at 150 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.245 | 6.140 | 1.135 |
| 0.140 | 1.244 | 6.279 | 1.141 |
| 0.279 | 1.249 | 6.419 | 1.146 |
| 0.419 | 1.261 | 6.558 | 1.151 |
| 0.558 | 1.276 | 6.698 | 1.155 |
| 0.698 | 1.282 | 6.837 | 1.158 |
| 0.837 | 1.279 | 6.977 | 1.161 |
| 0.977 | 1.274 | 7.116 | 1.164 |
| 1.116 | 1.269 | 7.256 | 1.165 |
| 1.256 | 1.262 | 7.395 | 1.167 |
| 1.395 | 1.253 | 7.535 | 1.167 |
| 1.535 | 1.243 | 7.674 | 1.167 |
| 1.674 | 1.232 | 7.814 | 1.166 |
| 1.814 | 1.221 | 7.953 | 1.164 |
| 1.953 | 1.210 | 8.093 | 1.162 |
| 2.093 | 1.199 | 8.233 | 1.159 |
| 2.233 | 1.189 | 8.372 | 1.155 |
| 2.372 | 1.181 | 8.512 | 1.150 |
| 2.512 | 1.172 | 8.651 | 1.144 |
| 2.651 | 1.163 | 8.791 | 1.138 |
| 2.791 | 1.154 | 8.930 | 1.135 |
| 2.930 | 1.146 | 9.070 | 1.135 |
| 3.070 | 1.139 | 9.209 | 1.136 |
| 3.209 | 1.134 | 9.349 | 1.139 |
| 3.349 | 1.132 | 9.488 | 1.143 |
| 3.488 | 1.131 | 9.628 | 1.146 |
| 3.628 | 1.130 | 9.767 | 1.147 |
| 3.767 | 1.128 | 9.907 | 1.149 |
| 3.907 | 1.126 | 10.046 | 1.153 |
| 4.046 | 1.123 | 10.186 | 1.159 |
| 4.186 | 1.121 | 10.326 | 1.163 |
| 4.326 | 1.117 | 10.465 | 1.167 |
| 4.465 | 1.114 | 10.605 | 1.170 |
| 4.605 | 1.110 | 10.744 | 1.174 |
| 4.744 | 1.108 | 10.884 | 1.177 |
| 4.884 | 1.108 | 11.023 | 1.176 |
| 5.023 | 1.107 | 11.163 | 1.183 |
| 5.163 | 1.107 | 11.302 | 1.205 |
| 5.302 | 1.108 | 11.442 | 1.202 |
| 5.442 | 1.110 | 11.581 | 1.189 |
| 5.581 | 1.113 | 11.721 | 1.159 |
| 5.721 | 1.118 | 11.860 | 1.122 |
| 5.860 | 1.123 | 12.000 | 1.084 |
| 6.000 | 1.129 | | |

**Table 2. RAOC W(z) at 3000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.408 | 6.140 | 1.112 |
| 0.140 | 1.407 | 6.279 | 1.120 |
| 0.279 | 1.410 | 6.419 | 1.125 |
| 0.419 | 1.417 | 6.558 | 1.131 |
| 0.558 | 1.427 | 6.698 | 1.135 |
| 0.698 | 1.428 | 6.837 | 1.140 |
| 0.837 | 1.421 | 6.977 | 1.144 |
| 0.977 | 1.411 | 7.116 | 1.147 |
| 1.116 | 1.401 | 7.256 | 1.150 |
| 1.256 | 1.388 | 7.395 | 1.152 |
| 1.395 | 1.373 | 7.535 | 1.154 |
| 1.535 | 1.356 | 7.674 | 1.155 |
| 1.674 | 1.339 | 7.814 | 1.155 |
| 1.814 | 1.321 | 7.953 | 1.155 |
| 1.953 | 1.302 | 8.093 | 1.154 |
| 2.093 | 1.282 | 8.233 | 1.153 |
| 2.233 | 1.262 | 8.372 | 1.150 |
| 2.372 | 1.242 | 8.512 | 1.147 |
| 2.512 | 1.223 | 8.651 | 1.142 |
| 2.651 | 1.203 | 8.791 | 1.138 |
| 2.791 | 1.182 | 8.930 | 1.139 |
| 2.930 | 1.165 | 9.070 | 1.146 |
| 3.070 | 1.154 | 9.209 | 1.153 |
| 3.209 | 1.148 | 9.349 | 1.159 |
| 3.349 | 1.145 | 9.488 | 1.164 |
| 3.488 | 1.143 | 9.628 | 1.169 |
| 3.628 | 1.142 | 9.767 | 1.171 |
| 3.767 | 1.140 | 9.907 | 1.173 |
| 3.907 | 1.138 | 10.046 | 1.176 |
| 4.046 | 1.136 | 10.186 | 1.181 |
| 4.186 | 1.134 | 10.326 | 1.188 |
| 4.326 | 1.131 | 10.465 | 1.195 |
| 4.465 | 1.129 | 10.605 | 1.200 |
| 4.605 | 1.127 | 10.744 | 1.205 |
| 4.744 | 1.124 | 10.884 | 1.209 |
| 4.884 | 1.122 | 11.023 | 1.211 |
| 5.023 | 1.119 | 11.163 | 1.213 |
| 5.163 | 1.115 | 11.302 | 1.212 |
| 5.302 | 1.112 | 11.442 | 1.209 |
| 5.442 | 1.108 | 11.581 | 1.196 |
| 5.581 | 1.104 | 11.721 | 1.179 |
| 5.721 | 1.100 | 11.860 | 1.160 |
| 5.860 | 1.100 | 12.000 | 1.137 |
| 6.000 | 1.105 | | |

**Table 3. RAOC W(z) at 5000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.330 | 6.140 | 1.111 |
| 0.140 | 1.328 | 6.279 | 1.118 |
| 0.279 | 1.331 | 6.419 | 1.125 |
| 0.419 | 1.339 | 6.558 | 1.132 |
| 0.558 | 1.349 | 6.698 | 1.138 |
| 0.698 | 1.350 | 6.837 | 1.144 |
| 0.837 | 1.344 | 6.977 | 1.149 |
| 0.977 | 1.335 | 7.116 | 1.153 |
| 1.116 | 1.327 | 7.256 | 1.157 |
| 1.256 | 1.315 | 7.395 | 1.161 |
| 1.395 | 1.302 | 7.535 | 1.163 |
| 1.535 | 1.288 | 7.674 | 1.165 |
| 1.674 | 1.272 | 7.814 | 1.167 |
| 1.814 | 1.256 | 7.953 | 1.167 |
| 1.953 | 1.239 | 8.093 | 1.168 |
| 2.093 | 1.222 | 8.233 | 1.167 |
| 2.233 | 1.205 | 8.372 | 1.166 |
| 2.372 | 1.188 | 8.512 | 1.163 |
| 2.512 | 1.169 | 8.651 | 1.159 |
| 2.651 | 1.153 | 8.791 | 1.158 |
| 2.791 | 1.143 | 8.930 | 1.158 |
| 2.930 | 1.134 | 9.070 | 1.165 |
| 3.070 | 1.125 | 9.209 | 1.174 |
| 3.209 | 1.119 | 9.349 | 1.183 |
| 3.349 | 1.116 | 9.488 | 1.192 |
| 3.488 | 1.115 | 9.628 | 1.200 |
| 3.628 | 1.114 | 9.767 | 1.208 |
| 3.767 | 1.113 | 9.907 | 1.214 |
| 3.907 | 1.110 | 10.046 | 1.219 |
| 4.046 | 1.108 | 10.186 | 1.222 |
| 4.186 | 1.105 | 10.326 | 1.223 |
| 4.326 | 1.102 | 10.465 | 1.225 |
| 4.465 | 1.099 | 10.605 | 1.231 |
| 4.605 | 1.096 | 10.744 | 1.237 |
| 4.744 | 1.093 | 10.884 | 1.241 |
| 4.884 | 1.090 | 11.023 | 1.244 |
| 5.023 | 1.087 | 11.163 | 1.246 |
| 5.163 | 1.087 | 11.302 | 1.246 |
| 5.302 | 1.087 | 11.442 | 1.243 |
| 5.442 | 1.088 | 11.581 | 1.231 |
| 5.581 | 1.089 | 11.721 | 1.215 |
| 5.721 | 1.092 | 11.860 | 1.196 |
| 5.860 | 1.096 | 12.000 | 1.172 |
| 6.000 | 1.103 | | |

**Table 4. RAOC $W(z)$ at 8000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | $W(z)$ | Core Height (ft) | $W(z)$ |
|------------------|--------|------------------|--------|
| 0.000 | 1.245 | 6.140 | 1.113 |
| 0.140 | 1.243 | 6.279 | 1.122 |
| 0.279 | 1.247 | 6.419 | 1.131 |
| 0.419 | 1.254 | 6.558 | 1.139 |
| 0.558 | 1.265 | 6.698 | 1.148 |
| 0.698 | 1.268 | 6.837 | 1.156 |
| 0.837 | 1.263 | 6.977 | 1.164 |
| 0.977 | 1.257 | 7.116 | 1.171 |
| 1.116 | 1.250 | 7.256 | 1.177 |
| 1.256 | 1.241 | 7.395 | 1.183 |
| 1.395 | 1.230 | 7.535 | 1.188 |
| 1.535 | 1.218 | 7.674 | 1.193 |
| 1.674 | 1.206 | 7.814 | 1.197 |
| 1.814 | 1.192 | 7.953 | 1.200 |
| 1.953 | 1.178 | 8.093 | 1.202 |
| 2.093 | 1.164 | 8.233 | 1.203 |
| 2.233 | 1.149 | 8.372 | 1.204 |
| 2.372 | 1.135 | 8.512 | 1.203 |
| 2.512 | 1.122 | 8.651 | 1.203 |
| 2.651 | 1.112 | 8.791 | 1.201 |
| 2.791 | 1.104 | 8.930 | 1.197 |
| 2.930 | 1.098 | 9.070 | 1.192 |
| 3.070 | 1.092 | 9.209 | 1.190 |
| 3.209 | 1.088 | 9.349 | 1.194 |
| 3.349 | 1.086 | 9.488 | 1.201 |
| 3.488 | 1.086 | 9.628 | 1.211 |
| 3.628 | 1.086 | 9.767 | 1.221 |
| 3.767 | 1.085 | 9.907 | 1.230 |
| 3.907 | 1.084 | 10.046 | 1.238 |
| 4.046 | 1.082 | 10.186 | 1.246 |
| 4.186 | 1.080 | 10.326 | 1.254 |
| 4.326 | 1.079 | 10.465 | 1.260 |
| 4.465 | 1.079 | 10.605 | 1.266 |
| 4.605 | 1.081 | 10.744 | 1.271 |
| 4.744 | 1.082 | 10.884 | 1.274 |
| 4.884 | 1.084 | 11.023 | 1.276 |
| 5.023 | 1.085 | 11.163 | 1.277 |
| 5.163 | 1.086 | 11.302 | 1.276 |
| 5.302 | 1.087 | 11.442 | 1.273 |
| 5.442 | 1.088 | 11.581 | 1.260 |
| 5.581 | 1.090 | 11.721 | 1.243 |
| 5.721 | 1.092 | 11.860 | 1.223 |
| 5.860 | 1.097 | 12.000 | 1.198 |
| 6.000 | 1.104 | | |

**Table 5. RAOC W(z) at 10000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.255 | 6.140 | 1.125 |
| 0.140 | 1.253 | 6.279 | 1.135 |
| 0.279 | 1.257 | 6.419 | 1.143 |
| 0.419 | 1.265 | 6.558 | 1.152 |
| 0.558 | 1.276 | 6.698 | 1.159 |
| 0.698 | 1.278 | 6.837 | 1.166 |
| 0.837 | 1.274 | 6.977 | 1.173 |
| 0.977 | 1.268 | 7.116 | 1.179 |
| 1.116 | 1.261 | 7.256 | 1.184 |
| 1.256 | 1.252 | 7.395 | 1.188 |
| 1.395 | 1.241 | 7.535 | 1.192 |
| 1.535 | 1.228 | 7.674 | 1.194 |
| 1.674 | 1.215 | 7.814 | 1.196 |
| 1.814 | 1.201 | 7.953 | 1.198 |
| 1.953 | 1.187 | 8.093 | 1.198 |
| 2.093 | 1.172 | 8.233 | 1.198 |
| 2.233 | 1.157 | 8.372 | 1.197 |
| 2.372 | 1.142 | 8.512 | 1.194 |
| 2.512 | 1.127 | 8.651 | 1.189 |
| 2.651 | 1.112 | 8.791 | 1.185 |
| 2.791 | 1.097 | 8.930 | 1.185 |
| 2.930 | 1.084 | 9.070 | 1.190 |
| 3.070 | 1.076 | 9.209 | 1.197 |
| 3.209 | 1.071 | 9.349 | 1.204 |
| 3.349 | 1.071 | 9.488 | 1.210 |
| 3.488 | 1.070 | 9.628 | 1.216 |
| 3.628 | 1.070 | 9.767 | 1.221 |
| 3.767 | 1.069 | 9.907 | 1.225 |
| 3.907 | 1.068 | 10.046 | 1.229 |
| 4.046 | 1.069 | 10.186 | 1.235 |
| 4.186 | 1.070 | 10.326 | 1.242 |
| 4.326 | 1.070 | 10.465 | 1.249 |
| 4.465 | 1.073 | 10.605 | 1.255 |
| 4.605 | 1.075 | 10.744 | 1.260 |
| 4.744 | 1.078 | 10.884 | 1.264 |
| 4.884 | 1.081 | 11.023 | 1.266 |
| 5.023 | 1.083 | 11.163 | 1.267 |
| 5.163 | 1.085 | 11.302 | 1.266 |
| 5.302 | 1.087 | 11.442 | 1.263 |
| 5.442 | 1.089 | 11.581 | 1.250 |
| 5.581 | 1.093 | 11.721 | 1.233 |
| 5.721 | 1.098 | 11.860 | 1.213 |
| 5.860 | 1.106 | 12.000 | 1.189 |
| 6.000 | 1.115 | | |

**Table 6. RAOC W(z) at 14000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.189 | 6.140 | 1.151 |
| 0.140 | 1.188 | 6.279 | 1.153 |
| 0.279 | 1.192 | 6.419 | 1.162 |
| 0.419 | 1.202 | 6.558 | 1.171 |
| 0.558 | 1.215 | 6.698 | 1.180 |
| 0.698 | 1.220 | 6.837 | 1.188 |
| 0.837 | 1.218 | 6.977 | 1.194 |
| 0.977 | 1.215 | 7.116 | 1.200 |
| 1.116 | 1.210 | 7.256 | 1.205 |
| 1.256 | 1.203 | 7.395 | 1.209 |
| 1.395 | 1.194 | 7.535 | 1.213 |
| 1.535 | 1.185 | 7.674 | 1.215 |
| 1.674 | 1.175 | 7.814 | 1.217 |
| 1.814 | 1.164 | 7.953 | 1.218 |
| 1.953 | 1.153 | 8.093 | 1.217 |
| 2.093 | 1.141 | 8.233 | 1.216 |
| 2.233 | 1.129 | 8.372 | 1.214 |
| 2.372 | 1.117 | 8.512 | 1.211 |
| 2.512 | 1.107 | 8.651 | 1.208 |
| 2.651 | 1.099 | 8.791 | 1.204 |
| 2.791 | 1.092 | 8.930 | 1.204 |
| 2.930 | 1.087 | 9.070 | 1.207 |
| 3.070 | 1.083 | 9.209 | 1.210 |
| 3.209 | 1.080 | 9.349 | 1.211 |
| 3.349 | 1.082 | 9.488 | 1.211 |
| 3.488 | 1.083 | 9.628 | 1.210 |
| 3.628 | 1.084 | 9.767 | 1.210 |
| 3.767 | 1.085 | 9.907 | 1.212 |
| 3.907 | 1.087 | 10.046 | 1.216 |
| 4.046 | 1.091 | 10.186 | 1.221 |
| 4.186 | 1.098 | 10.326 | 1.225 |
| 4.326 | 1.106 | 10.465 | 1.228 |
| 4.465 | 1.113 | 10.605 | 1.230 |
| 4.605 | 1.118 | 10.744 | 1.230 |
| 4.744 | 1.124 | 10.884 | 1.228 |
| 4.884 | 1.129 | 11.023 | 1.228 |
| 5.023 | 1.133 | 11.163 | 1.225 |
| 5.163 | 1.138 | 11.302 | 1.236 |
| 5.302 | 1.141 | 11.442 | 1.220 |
| 5.442 | 1.144 | 11.581 | 1.203 |
| 5.581 | 1.147 | 11.721 | 1.186 |
| 5.721 | 1.149 | 11.860 | 1.165 |
| 5.860 | 1.150 | 12.000 | 1.141 |
| 6.000 | 1.151 | | |

**Table 7. RAOC W(z) at 20000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.144 | 6.140 | 1.203 |
| 0.140 | 1.142 | 6.279 | 1.213 |
| 0.279 | 1.146 | 6.419 | 1.223 |
| 0.419 | 1.157 | 6.558 | 1.231 |
| 0.558 | 1.172 | 6.698 | 1.238 |
| 0.698 | 1.179 | 6.837 | 1.244 |
| 0.837 | 1.179 | 6.977 | 1.249 |
| 0.977 | 1.178 | 7.116 | 1.253 |
| 1.116 | 1.174 | 7.256 | 1.256 |
| 1.256 | 1.169 | 7.395 | 1.258 |
| 1.395 | 1.162 | 7.535 | 1.258 |
| 1.535 | 1.154 | 7.674 | 1.258 |
| 1.674 | 1.146 | 7.814 | 1.256 |
| 1.814 | 1.137 | 7.953 | 1.253 |
| 1.953 | 1.128 | 8.093 | 1.249 |
| 2.093 | 1.119 | 8.233 | 1.244 |
| 2.233 | 1.109 | 8.372 | 1.238 |
| 2.372 | 1.099 | 8.512 | 1.231 |
| 2.512 | 1.089 | 8.651 | 1.225 |
| 2.651 | 1.080 | 8.791 | 1.218 |
| 2.791 | 1.073 | 8.930 | 1.209 |
| 2.930 | 1.067 | 9.070 | 1.198 |
| 3.070 | 1.061 | 9.209 | 1.193 |
| 3.209 | 1.060 | 9.349 | 1.196 |
| 3.349 | 1.064 | 9.488 | 1.201 |
| 3.488 | 1.071 | 9.628 | 1.209 |
| 3.628 | 1.079 | 9.767 | 1.216 |
| 3.767 | 1.087 | 9.907 | 1.223 |
| 3.907 | 1.095 | 10.046 | 1.229 |
| 4.046 | 1.102 | 10.186 | 1.234 |
| 4.186 | 1.110 | 10.326 | 1.239 |
| 4.326 | 1.117 | 10.465 | 1.244 |
| 4.465 | 1.124 | 10.605 | 1.247 |
| 4.605 | 1.130 | 10.744 | 1.250 |
| 4.744 | 1.136 | 10.884 | 1.252 |
| 4.884 | 1.141 | 11.023 | 1.252 |
| 5.023 | 1.146 | 11.163 | 1.251 |
| 5.163 | 1.150 | 11.302 | 1.248 |
| 5.302 | 1.153 | 11.442 | 1.241 |
| 5.442 | 1.156 | 11.581 | 1.224 |
| 5.581 | 1.163 | 11.721 | 1.204 |
| 5.721 | 1.171 | 11.860 | 1.182 |
| 5.860 | 1.181 | 12.000 | 1.157 |
| 6.000 | 1.192 | | |

Table 8. RAOC FQ Margin Decreases in Excess of 2% Per 31 EFPD – Cycle 22

| Cycle Burnup (MWD/MTU) | Maximum Decrease in FQ Margin |
|-----------------------------------|--|
| 665 | 1.0200 |
| 6155 | 1.0200 |
| 6326 | 1.0200 |
| 6498 | 1.0200 |
| 6669 | 1.0200 |
| 6841 | 1.0200 |
| 7012 | 1.0200 |
| 7184 | 1.0200 |
| 7356 | 1.0200 |
| 7527 | 1.0200 |
| 7699 | 1.0200 |
| 7870 | 1.0200 |
| 8042 | 1.0200 |
| 8213 | 1.0222 |
| 8385 | 1.0270 |
| 8556 | 1.0306 |
| 8728 | 1.0302 |
| 8900 | 1.0287 |
| 9071 | 1.0269 |
| 9243 | 1.0248 |
| 9414 | 1.0224 |
| 9586 | 1.0200 |
| 9757 | 1.0200 |
| 9929 | 1.0200 |

Note: All cycle burnups outside the range of this table shall use a 1.020 decrease in margin for compliance with Specification 4.2.2.2e. Linear interpolation is adequate for intermediate cycle burnups.

**Table 9. BASELOAD $W(z)$ at 150 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | $W(z)$ | Core Height (ft) | $W(z)$ |
|------------------|--------|------------------|--------|
| 0.000 | 1.113 | 6.140 | 1.063 |
| 0.140 | 1.114 | 6.279 | 1.061 |
| 0.279 | 1.115 | 6.419 | 1.059 |
| 0.419 | 1.116 | 6.558 | 1.057 |
| 0.558 | 1.118 | 6.698 | 1.055 |
| 0.698 | 1.118 | 6.837 | 1.054 |
| 0.837 | 1.118 | 6.977 | 1.054 |
| 0.977 | 1.118 | 7.116 | 1.055 |
| 1.116 | 1.117 | 7.256 | 1.058 |
| 1.256 | 1.117 | 7.395 | 1.060 |
| 1.395 | 1.116 | 7.535 | 1.062 |
| 1.535 | 1.114 | 7.674 | 1.063 |
| 1.674 | 1.113 | 7.814 | 1.065 |
| 1.814 | 1.112 | 7.953 | 1.067 |
| 1.953 | 1.110 | 8.093 | 1.068 |
| 2.093 | 1.108 | 8.233 | 1.070 |
| 2.233 | 1.106 | 8.372 | 1.071 |
| 2.372 | 1.104 | 8.512 | 1.073 |
| 2.512 | 1.102 | 8.651 | 1.074 |
| 2.651 | 1.099 | 8.791 | 1.075 |
| 2.791 | 1.096 | 8.930 | 1.076 |
| 2.930 | 1.094 | 9.070 | 1.077 |
| 3.070 | 1.091 | 9.209 | 1.078 |
| 3.209 | 1.088 | 9.349 | 1.080 |
| 3.349 | 1.085 | 9.488 | 1.080 |
| 3.488 | 1.083 | 9.628 | 1.081 |
| 3.628 | 1.082 | 9.767 | 1.082 |
| 3.767 | 1.080 | 9.907 | 1.083 |
| 3.907 | 1.079 | 10.046 | 1.084 |
| 4.046 | 1.078 | 10.186 | 1.085 |
| 4.186 | 1.077 | 10.326 | 1.085 |
| 4.326 | 1.076 | 10.465 | 1.086 |
| 4.465 | 1.076 | 10.605 | 1.087 |
| 4.605 | 1.075 | 10.744 | 1.088 |
| 4.744 | 1.074 | 10.884 | 1.088 |
| 4.884 | 1.074 | 11.023 | 1.089 |
| 5.023 | 1.073 | 11.163 | 1.089 |
| 5.163 | 1.072 | 11.302 | 1.090 |
| 5.302 | 1.071 | 11.442 | 1.090 |
| 5.442 | 1.070 | 11.581 | 1.090 |
| 5.581 | 1.069 | 11.721 | 1.089 |
| 5.721 | 1.067 | 11.860 | 1.089 |
| 5.860 | 1.066 | 12.000 | 1.089 |
| 6.000 | 1.064 | | |

**Table 10. BASELOAD $W(z)$ at 3000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | $W(z)$ | Core Height (ft) | $W(z)$ |
|------------------|--------|------------------|--------|
| 0.000 | 1.098 | 6.140 | 1.058 |
| 0.140 | 1.097 | 6.279 | 1.057 |
| 0.279 | 1.098 | 6.419 | 1.056 |
| 0.419 | 1.099 | 6.558 | 1.054 |
| 0.558 | 1.101 | 6.698 | 1.052 |
| 0.698 | 1.102 | 6.837 | 1.050 |
| 0.837 | 1.103 | 6.977 | 1.048 |
| 0.977 | 1.103 | 7.116 | 1.049 |
| 1.116 | 1.103 | 7.256 | 1.049 |
| 1.256 | 1.104 | 7.395 | 1.050 |
| 1.395 | 1.104 | 7.535 | 1.052 |
| 1.535 | 1.103 | 7.674 | 1.054 |
| 1.674 | 1.103 | 7.814 | 1.056 |
| 1.814 | 1.103 | 7.953 | 1.058 |
| 1.953 | 1.102 | 8.093 | 1.060 |
| 2.093 | 1.102 | 8.233 | 1.062 |
| 2.233 | 1.101 | 8.372 | 1.064 |
| 2.372 | 1.100 | 8.512 | 1.066 |
| 2.512 | 1.099 | 8.651 | 1.067 |
| 2.651 | 1.097 | 8.791 | 1.069 |
| 2.791 | 1.096 | 8.930 | 1.071 |
| 2.930 | 1.095 | 9.070 | 1.072 |
| 3.070 | 1.093 | 9.209 | 1.074 |
| 3.209 | 1.091 | 9.349 | 1.075 |
| 3.349 | 1.089 | 9.488 | 1.077 |
| 3.488 | 1.087 | 9.628 | 1.078 |
| 3.628 | 1.085 | 9.767 | 1.080 |
| 3.767 | 1.084 | 9.907 | 1.081 |
| 3.907 | 1.082 | 10.046 | 1.082 |
| 4.046 | 1.081 | 10.186 | 1.083 |
| 4.186 | 1.080 | 10.326 | 1.084 |
| 4.326 | 1.078 | 10.465 | 1.086 |
| 4.465 | 1.077 | 10.605 | 1.087 |
| 4.605 | 1.076 | 10.744 | 1.088 |
| 4.744 | 1.074 | 10.884 | 1.089 |
| 4.884 | 1.073 | 11.023 | 1.090 |
| 5.023 | 1.071 | 11.163 | 1.090 |
| 5.163 | 1.069 | 11.302 | 1.091 |
| 5.302 | 1.067 | 11.442 | 1.092 |
| 5.442 | 1.065 | 11.581 | 1.092 |
| 5.581 | 1.064 | 11.721 | 1.092 |
| 5.721 | 1.062 | 11.860 | 1.092 |
| 5.860 | 1.061 | 12.000 | 1.092 |
| 6.000 | 1.060 | | |

**Table 11. BASELOAD W(z) at 5000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|------------------|-------|------------------|-------|
| 0.000 | 1.097 | 6.140 | 1.057 |
| 0.140 | 1.097 | 6.279 | 1.056 |
| 0.279 | 1.097 | 6.419 | 1.055 |
| 0.419 | 1.099 | 6.558 | 1.053 |
| 0.558 | 1.100 | 6.698 | 1.051 |
| 0.698 | 1.102 | 6.837 | 1.048 |
| 0.837 | 1.102 | 6.977 | 1.047 |
| 0.977 | 1.102 | 7.116 | 1.047 |
| 1.116 | 1.103 | 7.256 | 1.049 |
| 1.256 | 1.103 | 7.395 | 1.051 |
| 1.395 | 1.103 | 7.535 | 1.053 |
| 1.535 | 1.103 | 7.674 | 1.055 |
| 1.674 | 1.103 | 7.814 | 1.057 |
| 1.814 | 1.102 | 7.953 | 1.059 |
| 1.953 | 1.102 | 8.093 | 1.061 |
| 2.093 | 1.101 | 8.233 | 1.063 |
| 2.233 | 1.100 | 8.372 | 1.064 |
| 2.372 | 1.099 | 8.512 | 1.066 |
| 2.512 | 1.098 | 8.651 | 1.068 |
| 2.651 | 1.097 | 8.791 | 1.069 |
| 2.791 | 1.096 | 8.930 | 1.071 |
| 2.930 | 1.094 | 9.070 | 1.073 |
| 3.070 | 1.093 | 9.209 | 1.074 |
| 3.209 | 1.091 | 9.349 | 1.075 |
| 3.349 | 1.089 | 9.488 | 1.077 |
| 3.488 | 1.087 | 9.628 | 1.078 |
| 3.628 | 1.085 | 9.767 | 1.079 |
| 3.767 | 1.083 | 9.907 | 1.081 |
| 3.907 | 1.082 | 10.046 | 1.082 |
| 4.046 | 1.080 | 10.186 | 1.083 |
| 4.186 | 1.079 | 10.326 | 1.084 |
| 4.326 | 1.078 | 10.465 | 1.085 |
| 4.465 | 1.076 | 10.605 | 1.086 |
| 4.605 | 1.075 | 10.744 | 1.088 |
| 4.744 | 1.073 | 10.884 | 1.089 |
| 4.884 | 1.072 | 11.023 | 1.089 |
| 5.023 | 1.070 | 11.163 | 1.090 |
| 5.163 | 1.068 | 11.302 | 1.091 |
| 5.302 | 1.066 | 11.442 | 1.092 |
| 5.442 | 1.064 | 11.581 | 1.092 |
| 5.581 | 1.063 | 11.721 | 1.091 |
| 5.721 | 1.061 | 11.860 | 1.092 |
| 5.860 | 1.060 | 12.000 | 1.092 |
| 6.000 | 1.059 | | |

**Table 12. BASELOAD W(z) at 8000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|-------------------------|-------------|-------------------------|-------------|
| 0.000 | 1.103 | 6.140 | 1.059 |
| 0.140 | 1.104 | 6.279 | 1.057 |
| 0.279 | 1.105 | 6.419 | 1.055 |
| 0.419 | 1.107 | 6.558 | 1.053 |
| 0.558 | 1.108 | 6.698 | 1.051 |
| 0.698 | 1.109 | 6.837 | 1.051 |
| 0.837 | 1.110 | 6.977 | 1.051 |
| 0.977 | 1.110 | 7.116 | 1.052 |
| 1.116 | 1.110 | 7.256 | 1.054 |
| 1.256 | 1.110 | 7.395 | 1.057 |
| 1.395 | 1.110 | 7.535 | 1.058 |
| 1.535 | 1.109 | 7.674 | 1.060 |
| 1.674 | 1.109 | 7.814 | 1.062 |
| 1.814 | 1.108 | 7.953 | 1.064 |
| 1.953 | 1.107 | 8.093 | 1.065 |
| 2.093 | 1.106 | 8.233 | 1.067 |
| 2.233 | 1.105 | 8.372 | 1.068 |
| 2.372 | 1.103 | 8.512 | 1.070 |
| 2.512 | 1.102 | 8.651 | 1.071 |
| 2.651 | 1.100 | 8.791 | 1.072 |
| 2.791 | 1.098 | 8.930 | 1.074 |
| 2.930 | 1.096 | 9.070 | 1.075 |
| 3.070 | 1.093 | 9.209 | 1.076 |
| 3.209 | 1.091 | 9.349 | 1.077 |
| 3.349 | 1.088 | 9.488 | 1.078 |
| 3.488 | 1.086 | 9.628 | 1.079 |
| 3.628 | 1.084 | 9.767 | 1.080 |
| 3.767 | 1.082 | 9.907 | 1.081 |
| 3.907 | 1.080 | 10.046 | 1.082 |
| 4.046 | 1.079 | 10.186 | 1.083 |
| 4.186 | 1.077 | 10.326 | 1.084 |
| 4.326 | 1.075 | 10.465 | 1.085 |
| 4.465 | 1.074 | 10.605 | 1.086 |
| 4.605 | 1.073 | 10.744 | 1.087 |
| 4.744 | 1.072 | 10.884 | 1.088 |
| 4.884 | 1.071 | 11.023 | 1.089 |
| 5.023 | 1.070 | 11.163 | 1.089 |
| 5.163 | 1.069 | 11.302 | 1.090 |
| 5.302 | 1.068 | 11.442 | 1.090 |
| 5.442 | 1.067 | 11.581 | 1.090 |
| 5.581 | 1.065 | 11.721 | 1.090 |
| 5.721 | 1.064 | 11.860 | 1.090 |
| 5.860 | 1.062 | 12.000 | 1.091 |
| 6.000 | 1.061 | | |

**Table 13. BASELOAD W(z) at 10000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|------------------|-------|------------------|-------|
| 0.000 | 1.110 | 6.140 | 1.059 |
| 0.140 | 1.111 | 6.279 | 1.056 |
| 0.279 | 1.112 | 6.419 | 1.053 |
| 0.419 | 1.113 | 6.558 | 1.051 |
| 0.558 | 1.115 | 6.698 | 1.051 |
| 0.698 | 1.116 | 6.837 | 1.053 |
| 0.837 | 1.116 | 6.977 | 1.055 |
| 0.977 | 1.116 | 7.116 | 1.057 |
| 1.116 | 1.116 | 7.256 | 1.059 |
| 1.256 | 1.116 | 7.395 | 1.061 |
| 1.395 | 1.115 | 7.535 | 1.062 |
| 1.535 | 1.115 | 7.674 | 1.064 |
| 1.674 | 1.114 | 7.814 | 1.066 |
| 1.814 | 1.113 | 7.953 | 1.067 |
| 1.953 | 1.111 | 8.093 | 1.068 |
| 2.093 | 1.110 | 8.233 | 1.070 |
| 2.233 | 1.108 | 8.372 | 1.071 |
| 2.372 | 1.106 | 8.512 | 1.072 |
| 2.512 | 1.104 | 8.651 | 1.073 |
| 2.651 | 1.102 | 8.791 | 1.074 |
| 2.791 | 1.099 | 8.930 | 1.075 |
| 2.930 | 1.096 | 9.070 | 1.076 |
| 3.070 | 1.094 | 9.209 | 1.077 |
| 3.209 | 1.091 | 9.349 | 1.078 |
| 3.349 | 1.087 | 9.488 | 1.079 |
| 3.488 | 1.085 | 9.628 | 1.080 |
| 3.628 | 1.082 | 9.767 | 1.080 |
| 3.767 | 1.081 | 9.907 | 1.081 |
| 3.907 | 1.080 | 10.046 | 1.082 |
| 4.046 | 1.079 | 10.186 | 1.083 |
| 4.186 | 1.078 | 10.326 | 1.084 |
| 4.326 | 1.077 | 10.465 | 1.084 |
| 4.465 | 1.076 | 10.605 | 1.085 |
| 4.605 | 1.075 | 10.744 | 1.086 |
| 4.744 | 1.074 | 10.884 | 1.086 |
| 4.884 | 1.073 | 11.023 | 1.087 |
| 5.023 | 1.072 | 11.163 | 1.088 |
| 5.163 | 1.071 | 11.302 | 1.088 |
| 5.302 | 1.069 | 11.442 | 1.089 |
| 5.442 | 1.068 | 11.581 | 1.089 |
| 5.581 | 1.066 | 11.721 | 1.089 |
| 5.721 | 1.064 | 11.860 | 1.089 |
| 5.860 | 1.062 | 12.000 | 1.089 |
| 6.000 | 1.061 | | |

**Table 14. BASELOAD W(z) at 14000 MWD/MTU
V. C. Summer – Cycle 22**

| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|------------------|-------|------------------|-------|
| 0.000 | 1.123 | 6.140 | 1.059 |
| 0.140 | 1.124 | 6.279 | 1.058 |
| 0.279 | 1.125 | 6.419 | 1.059 |
| 0.419 | 1.126 | 6.558 | 1.059 |
| 0.558 | 1.127 | 6.698 | 1.060 |
| 0.698 | 1.128 | 6.837 | 1.063 |
| 0.837 | 1.128 | 6.977 | 1.065 |
| 0.977 | 1.128 | 7.116 | 1.066 |
| 1.116 | 1.128 | 7.256 | 1.068 |
| 1.256 | 1.127 | 7.395 | 1.069 |
| 1.395 | 1.126 | 7.535 | 1.071 |
| 1.535 | 1.125 | 7.674 | 1.072 |
| 1.674 | 1.123 | 7.814 | 1.073 |
| 1.814 | 1.121 | 7.953 | 1.074 |
| 1.953 | 1.119 | 8.093 | 1.075 |
| 2.093 | 1.117 | 8.233 | 1.076 |
| 2.233 | 1.114 | 8.372 | 1.077 |
| 2.372 | 1.111 | 8.512 | 1.077 |
| 2.512 | 1.108 | 8.651 | 1.077 |
| 2.651 | 1.105 | 8.791 | 1.078 |
| 2.791 | 1.101 | 8.930 | 1.079 |
| 2.930 | 1.097 | 9.070 | 1.082 |
| 3.070 | 1.093 | 9.209 | 1.085 |
| 3.209 | 1.089 | 9.349 | 1.088 |
| 3.349 | 1.086 | 9.488 | 1.090 |
| 3.488 | 1.083 | 9.628 | 1.092 |
| 3.628 | 1.080 | 9.767 | 1.095 |
| 3.767 | 1.079 | 9.907 | 1.097 |
| 3.907 | 1.077 | 10.046 | 1.098 |
| 4.046 | 1.076 | 10.186 | 1.100 |
| 4.186 | 1.076 | 10.326 | 1.101 |
| 4.326 | 1.075 | 10.465 | 1.103 |
| 4.465 | 1.074 | 10.605 | 1.104 |
| 4.605 | 1.073 | 10.744 | 1.104 |
| 4.744 | 1.072 | 10.884 | 1.105 |
| 4.884 | 1.071 | 11.023 | 1.105 |
| 5.023 | 1.070 | 11.163 | 1.106 |
| 5.163 | 1.069 | 11.302 | 1.106 |
| 5.302 | 1.068 | 11.442 | 1.105 |
| 5.442 | 1.067 | 11.581 | 1.104 |
| 5.581 | 1.066 | 11.721 | 1.103 |
| 5.721 | 1.064 | 11.860 | 1.102 |
| 5.860 | 1.063 | 12.000 | 1.102 |
| 6.000 | 1.061 | | |

**Table 15. BASELOAD W(z) at 20000 MWD/MTU
V. C. Summer – Cycle 22**


| Core Height (ft) | W(z) | Core Height (ft) | W(z) |
|------------------|-------|------------------|-------|
| 0.000 | 1.151 | 6.140 | 1.068 |
| 0.140 | 1.151 | 6.279 | 1.071 |
| 0.279 | 1.152 | 6.419 | 1.073 |
| 0.419 | 1.153 | 6.558 | 1.074 |
| 0.558 | 1.154 | 6.698 | 1.076 |
| 0.698 | 1.154 | 6.837 | 1.077 |
| 0.837 | 1.154 | 6.977 | 1.078 |
| 0.977 | 1.153 | 7.116 | 1.079 |
| 1.116 | 1.151 | 7.256 | 1.080 |
| 1.256 | 1.149 | 7.395 | 1.081 |
| 1.395 | 1.147 | 7.535 | 1.081 |
| 1.535 | 1.144 | 7.674 | 1.081 |
| 1.674 | 1.141 | 7.814 | 1.081 |
| 1.814 | 1.138 | 7.953 | 1.082 |
| 1.953 | 1.134 | 8.093 | 1.081 |
| 2.093 | 1.129 | 8.233 | 1.081 |
| 2.233 | 1.125 | 8.372 | 1.081 |
| 2.372 | 1.120 | 8.512 | 1.080 |
| 2.512 | 1.114 | 8.651 | 1.082 |
| 2.651 | 1.109 | 8.791 | 1.084 |
| 2.791 | 1.103 | 8.930 | 1.087 |
| 2.930 | 1.097 | 9.070 | 1.091 |
| 3.070 | 1.091 | 9.209 | 1.095 |
| 3.209 | 1.085 | 9.349 | 1.098 |
| 3.349 | 1.082 | 9.488 | 1.102 |
| 3.488 | 1.081 | 9.628 | 1.105 |
| 3.628 | 1.080 | 9.767 | 1.108 |
| 3.767 | 1.078 | 9.907 | 1.110 |
| 3.907 | 1.077 | 10.046 | 1.113 |
| 4.046 | 1.075 | 10.186 | 1.115 |
| 4.186 | 1.074 | 10.326 | 1.116 |
| 4.326 | 1.072 | 10.465 | 1.118 |
| 4.465 | 1.072 | 10.605 | 1.119 |
| 4.605 | 1.071 | 10.744 | 1.120 |
| 4.744 | 1.071 | 10.884 | 1.121 |
| 4.884 | 1.070 | 11.023 | 1.121 |
| 5.023 | 1.069 | 11.163 | 1.121 |
| 5.163 | 1.069 | 11.302 | 1.121 |
| 5.302 | 1.068 | 11.442 | 1.121 |
| 5.442 | 1.066 | 11.581 | 1.119 |
| 5.581 | 1.065 | 11.721 | 1.118 |
| 5.721 | 1.063 | 11.860 | 1.117 |
| 5.860 | 1.063 | 12.000 | 1.116 |
| 6.000 | 1.065 | | |

Table 16. BASE LOAD FQ Margin Decreases in Excess of 2% Per 31 EFPD – Cycle 22

| Cycle Burnup (MWD/MTU) | Maximum Decrease in FQ Margin |
|-----------------------------------|--|
| 1352 | 1.0200 |
| 1523 | 1.0200 |
| 1695 | 1.0243 |
| 1867 | 1.0286 |
| 2038 | 1.0321 |
| 2210 | 1.0347 |
| 2382 | 1.0333 |
| 2553 | 1.0317 |
| 2725 | 1.0301 |
| 2896 | 1.0286 |
| 3068 | 1.0273 |
| 3240 | 1.0262 |
| 3411 | 1.0255 |
| 3583 | 1.0250 |
| 3755 | 1.0248 |
| 3926 | 1.0249 |
| 4098 | 1.0253 |
| 4270 | 1.0254 |
| 4441 | 1.0254 |
| 4613 | 1.0252 |
| 4785 | 1.0245 |
| 4956 | 1.0234 |
| 5128 | 1.022 |
| 5300 | 1.0205 |
| 5471 | 1.0200 |

Note: All cycle burnups outside the range of this table shall use a 1.020 decrease in margin for compliance with Specification 4.2.2.4e. Linear interpolation is adequate for intermediate cycle burnups.

**Figure 5. RCS Total Flowrate vs. R for Three Loop Operation
V. C. Summer – Cycle 22**



Measurement Uncertainty of 2.1% for Flow (includes 0.1% for feedwater venturi fouling) is included in this figure.