

T.S. 6.9.1.12

LG-15-067

May 15, 2015

Designated Original per R. Ennis

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

> Limerick Generating Station, Unit 2 Renewed Facility Operating License No NPF-85 NRC Docket Nos. 50-353

Subject: Issuance of the Core Operating Limits Report (COLR) for Reload 13, Cycle 14

Enclosed is a copy of the Core Operating Limits Report (COLR) for Limerick Generating Station (LGS) Unit 2 Reload 13 Cycle 14 which incorporates the revised cycle specific parameters resulting from the new configuration implemented for LGS, Unit 2.

The COLR is being submitted to the NRC in accordance LGS, Unit 2 Technical Specification 6.9.1.12.

If you have any questions or require additional information, please contact Giuseppe Rubinaccio at 610-718-3560.

Sincerely,

Thomas J. Dougherty Site Vice President-Limerick Generating Station Exelon Generation Company, LLC

Attachment: Core Operating Limits Report for Limerick Generating Station Reload 13, Cycle 14

cc: D. Dorman, Administrator, Region I, USNRC S. Rutenkroger, USNRC Sr. Resident Inspector, LGS R. Ennis, USNRC Project Manager for LGS R. R. Janati, PADEP-BRP (w/attachments) (w/attachments) (w/attachments) (w/attachments)

A001

COLR Limerick 2 Rev. 9

CORE OPERATING LIMITS REPORT

FOR

LIMERICK GENERATING STATION UNIT 2

RELOAD 13, CYCLE 14

(This is a complete re-write; no annotations are used.)

1		
Prepared By:Molmes	Date:	5/1/15
Reviewed By:	Date:	5.1.15
Reviewed By: Ar <u>thur Stefancyzk per Telecon</u> A. Stefanczyk	Date:	5/1/2015
Reviewed By:	Date:	5/1/15
Approved By:	Date:	5/1/15
Station Qualified Reviewed By: L. Korbeil Station Qualified Reviewer	Date:	05/02/15

~

0

Table of Contents

		Page
1.0	Terms and Definitions	4
2.0	General Information	6
3.0	MAPLHGR Limits	7
4.0	MCPR Limits	8
5.0	LHGR Limits	11
6.0	Control Rod Block Setpoints	14
7.0	Turbine Bypass Valve Parameters	15
8.0	Stability Protection Setpoints	16
9.0	Modes of Operation	17
10.0	Methodology	18
11.0	References	18

List of Tables

	P	age
TABLE 3-1	MAPLHGR versus Average Planar Exposure – All Fuel Types	7
TABLE 3-2	MAPLHGR Single Loop Operation (SLO) Multiplier – All Fuel Types	7
TABLE 4-1	Operating Limit Minimum Critical Power Ratio (OLMCPR) – All Fuel Types	9
TABLE 4-2	Power Dependent MCPR Limits and Multipliers MCPR(P) and Kp - All Fuel Types	10
TABLE 4-3	Flow Dependent MCPR Limits MCPR(F) – All Fuel Types	10
TABLE 5-1	Linear Heat Generation Rate Limits – UO ₂ Rods	11
TABLE 5-2	Linear Heat Generation Rate Limits – Gad Rods	i
TABLE 5-3	LHGR Single Loop Operation (SLO) Multiplier – All Fuel Types	12
TABLE 5-4	Power Dependent LHGR Multiplier LHGRFAC(P) - All Fuel Types	12
TABLE 5-5	Flow Dependent LHGR Multiplier LHGRFAC(F) - All Fuel Types	13
TABLE 6-1	Rod Block Monitor Setpoints	14
TABLE 6-2	Reactor Coolant System Recirculation Flow Upscale Trip	14
TABLE 7-1	Turbine Bypass System Response Time	15
TABLE 7-2.	Minimum Required Bypass Valves To Maintain System Operability	15
TABLE 8-1	OPRM PBDA Trip Setpoints	16
TABLE 8-2	SLO OPRM PBDA Trip Setpoints	16
TABLE 9-1	Modes of Operation	17

٠.

.

.

1.0 Terms and Definitions

.

ARTS	APRM, RBM, and Technical Specification Improvement Program
BASE	A case analyzed with Turbine Bypass System in service and Recirculation Pump Trip in service and Feedwater Temperature Reduction allowed (FFWTR includes FWHOOS or final feedwater temperature reduction) and PLUOOS allowed at any point during the cycle in Dual Loop mode.
DLO	Dual Loop Operation
DTSP	Rod Block Monitor Downscale Trip Setpoint
EOOS	Equipment Out of Service
EOR	End of Rated, the cycle exposure at which reactor power is equal to rated thermal power with recirculation system flow equal to 100%, all control rods fully withdrawn, all feedwater heating in service and equilibrium Xenon.
FFWTR	Final Feedwater Temperature Reduction
FWHOOS	Feedwater Heaters Out of Service
HTSP	Rod Block Monitor High Trip Setpoint
ICF	Increased Core Flow
ITSP	Rod Block Monitor Intermediate Trip Setpoint
Кр	Off-rated power dependent OLMCPR multiplier
LHGR	Linear Heat Generation Rate
LHGRFAC(F)	ARTS LHGR thermal limit flow dependent multipliers
LHGRFAC(P)	ARTS LHGR thermal limit power dependent multipliers
LTSP	Rod Block Monitor Low Trip Setpoint
MAPFAC(F)	Off-rated flow dependent MAPLHGR multiplier
MAPFAC(P)	Off-rated power dependent MAPLHGR multiplier
MAPLHGR	Maximum Average Planar Linear Heat Generation Rate
MCPR	Minimum Critical Power Ratio
MCPR(F)	Off-rated flow dependent OLMCPR multiplier
MCPR(P)	Off-rated power dependent OLMCPR multiplier

COLR Limerick 2 Rev. 9

MELLLA	Maximum Extended Load Line Limit Analysis
MSIVOOS	Main Steam Isolation Valve Out of Service
OLMCPR	Operating Limit Minimum Critical Power Ratio
OPRM	Oscillation Power Range Monitor
OOS	Out of Service
PBDA	Period Based Detection Algorithm
PLUOOS	Power Load Unbalance Out of Service
PROOS	Pressure Regulator Out of Service
RBM	Rod Block Monitor
RPTOOS	Recirculation Pump Trip Out of Service
RWE	Rod Withdrawal Error
SLO	Single Loop Operation
TBSOOS	Turbine Bypass System Out of Service
тси	Turbine Control Valve
TIPOOS	Traversing In core Probe Out of Service
TSV	Turbine Stop Valve

2.0 General Information

This report provides the following cycle-specific parameter limits for Limerick Generating Station Unit 2 Cycle 14:

- Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)
- Minimum Critical Power Ratio (MCPR)
- Single Loop Operation (SLO) OLMCPR adjustment
- Off-rated OLMCPR adjustments (MCPR(P) or MCPR(F))
- Off-rated OLMCPR multipliers (Kp)
- Off-rated LHGR multipliers (LHGRFAC(P) or LHGRFAC(F))
- Rod Block Monitor (RBM) setpoints
- MAPLHGR single loop operation multiplier
- LHGR single loop operation multiplier
- Linear Heat Generation Rate (LHGR)
- Turbine Bypass Valve parameters
- Reactor Coolant System Recirculation Flow Upscale Trips
- Oscillation Power Range Monitor Period Based Detection Algorithm (OPRM PBDA) Trip Setpoints

This report is prepared in accordance with Technical Specification 6.9.1.9 of Reference 1. Preparation of this report was performed in accordance with Exelon Nuclear, Nuclear Fuels T&RM NF-AB-120-3600.

The data presented in this report is valid for all licensed operating domains on the operating map, including:

- Maximum Extended Load Line Limit down to 82.9% of rated core flow during full power operation
- Increased Core Flow (ICF) up to 110% of rated core flow
- Final Feedwater Temperature Reduction (FFWTR) up to 105°F during cycle extension operation
- Feedwater Heater Out of Service (FWHOOS) up to 60°F feedwater temperature reduction at any time during the cycle prior to cycle extension.

Further information on the cycle specific analyses for Limerick 2 Cycle 14 and the associated operating domains discussed above is available in Reference 2.

3.0 MAPLHGR Limits

3.1 Technical Specification

Section 3.2.1

3.2 Description

The limiting MAPLHGR value for the most limiting lattice (excluding natural uranium) of each fuel type as a function of average planar exposure is given in Table 3-1. For single loop operation, a multiplier is used, which is shown in Table 3-2. The power and flow dependent multipliers for MAPLHGR have been removed and replaced with LHGRFAC(P) and LHGRFAC(F); therefore, MAPFAC(P) and MAPFAC(F) are equal to 1.0 for all power and flow conditions (Reference 2). LHGRFAC(P) and LHGRFAC(F) are addressed in Section 5.0.

TABLE 3-1MAPLHGR versus Average Planar Exposure – All Fuel Types
(Reference 2)

Average Planar Exposure (GWD/ST)	MAPLHGR Limit (kW/ft)
0.0	13.78
17.52	13.78
60.78	7.50
63.50	6.69

TABLE 3-2 MAPLHGR Single Loop Operation (SLO) Multiplier – All Fuel Types (Reference 2)

SLO Multiplier	0.80

4.0 MCPR Limits

4.1 Technical Specification

Section 3.2.3

4.2 Description

Table 4-1 is derived from Reference 2 and is valid for all fuel types and all operating domains. Table 4-1 includes treatment of these MCPR limits for all conditions listed in Section 9.0, Modes of Operation.

ARTS provides for power and flow dependent thermal limit adjustments and multipliers, which allow for a more reliable administration of the MCPR thermal limit. The flow dependent adjustment MCPR(F) is sufficiently generic to apply to all fuel types and operating domains. The power dependent adjustment MCPR(P) is independent of recirculation pump trip operability. MCPR(P) and MCPR(F) are independent of Scram Time Option. In addition, there are ten sets of power dependent MCPR multipliers (Kp) for use with BASE, TBSOOS, RPTOOS, PROOS, DLO and SLO conditions, and PROOS+TBSOOS, PROOS+RPTOOS, DLO only. The PLUOOS condition is included in the BASE MCPR(P) and MCPR(F) limits and Kp multipliers and is bounded by the TBSOOS limits and multipliers; therefore, no additional adjustments are required for PLUOOS in those operating conditions. The PLUOOS condition has not been analyzed concurrent with the RPTOOS operating condition. Operation in the PLUOOS condition concurrent with the RPTOOS condition requires core thermal power < 55% of rated (Reference 3). Section 7.0 contains the conditions for Turbine Bypass Valve Operability. MCPR(P) and MCPR(F) adjustments are provided in Tables 4-2 and 4-3. The OLMCPR is determined for a given power and flow condition by evaluating the power dependent MCPR and the flow dependent MCPR and selecting the greater of the two.

COLR Limerick 2 Rev. 9

Exelon Nuclear – Nuclear Fuels Core Operating Limits Report

	SCRAM	Cycle Exposure		
EOOS Combination	Time Option ⁽¹⁾	< EOR - 2542 MWd/ST	\geq EOR - 2542 MWd/ST	
DASE	В	1.36 ⁽²⁾	1.36	
DASE	Α	1.41	1.44	
DASE SLO ⁽³⁾	В	1.58	1.58	
BASE SLO	Α	1.58	1.58	
TRECOR	B	1.37	1.39	
163003	Α	1.46	1.48	
	В	1.58	1.58	
103003 SLU	Α	1.58	1.58	
D.D.T.OOS	В	1.37	1.39	
RPTOUS	Α	1.54	1,56	
	В	1.58	1.58	
RPTOUS SLU	A	1.58	1.59	
PROOS	В	1.36 ⁽²⁾	1.36	
PROUS	A	1.41	1.47	
	В	1.58	1.58	
PROUS SLU	A	1.58	1.58	
PROOS+TBSOOS	В	1.37	1.39	
PROOS+RPTOOS	В	1.37	1.39	

TABLE 4-1 Operating Limit Minimum Critical Power Ratio (OLMCPR) – All Fuel Types (References 2 and 8)

¹ When Tau does not equal 0 or 1, determine OLMCPR via linear interpolation. For PROOS+TBSOOS and PROOS+RPTOOS, only Option B is allowed.

² Value is adjusted to obtain an OPRM amplitude setpoint of 1.12.

³ For single-loop operation, the MCPR operating limit is 0.03 greater than the analyzed two loop value. However, a minimum value of 1.58 is required to obtain an OLMCPR limit set by the Single Loop Operation Recirculation Pump Seizure Event.

	Core	Core Thermal Power (% of rated)						
EOOS	Flow	0	25	< 30	≥ 30	65	85	_100_
Combination	(% of rated)		MCPR(P)		Operating Limit MCPR Multiplier, Kp			
Pace	≤60	2.50	2.50	2.40	1.340	1 121	1.067	1.000
Dase	> 60	2.75	2.75	2.55	1.340	1.131	1.007	1.000
Base St O	≤60	2.53	2.53	2.43	1 240	1 121	1.067	1.000
	> 60	2.78	2.78	2.58	1.340	1.131		
TRECOS	≤60	3.25	3.25	2.75	1.240	1 121	1.067	1.000
153003	> 60	3.75	3.75	3.25	1.540	1.151		
	≤60	3.28	3.28	2.78	1 240	0 1 1 2 1	1.067	1.000
	> 60	3.78	3.78	3.28	1.340	1.151		
PPTOOS	≤60	2.50	2.50	2.40	1 340	1.131	1.067	1.000
N 1003	> 60	2.75	2.75	2.55	1.340			
RPTOOS SLO	<u>≤60</u>	2.53	2.53	2.43	1 340	1.131	1.067	1.000
	> 60	2.78	2.78	2.58	1.540			
PROOS	<u>≤60</u>	2.50	2.50	2.40	1 367	1 236	1 160	1 000
	> 60	2.75	2.75	2.55	1.507	1.250	1.100	1.000
PROOS SLO	<u>≤60</u>	2.53	2.53	2.43	1 267 1 226	1 236	1.160	1.000
	> 60	_2.78_	2.78	2.58	1.507	1.307 1.230		
PROOS+TRSOOS	≤60	3.25	3.25	2.75	1367 1236	1 160	1 000	
	> 60	3.75	3.75	3.25	1.507		1.100	1.000
PROOS+RPTOOS	≤60	2.50	2.50	2.40	1 367	1 226	1.160	1.000
PROUS+RPIOUS -	> 60	_2.75	2.75	2.55	1.307	1.230		

 TABLE 4-2

 Power Dependent MCPR Limits and Multipliers MCPR(P) and Kp – All Fuel Types (References 2 and 8)

TABLE 4-3
Flow Dependent MCPR Limits MCPR(F) – All Fuel Types
(Reference 2)

Flow (% rated)	MCPR(F) Limit
0.0	1.70
30.0	1.53
79.0	1.25
110.0	1.25

5.0 LHGR Limits

5.1 Technical Specification

Section 3.2.4

5.2 Description

The LHGR limit is the product of the exposure dependent LHGR limit (from Table 5-1 for UO₂ fuel rods and Table 5-2 for Gadolinia fuel rods) and the minimum of: the power dependent LHGR Factor, LHGRFAC(P), and the flow dependent LHGR Factor, LHGRFAC(F). For single loop operation, a multiplier is used, which is shown in Table 5-3 and applied in Table 5-5. No further Single Loop Operating multipliers need to be applied to the values in Tables 5-4 and 5-5.

ARTS provides for power and flow dependent thermal limit multipliers, which allow for a more reliable administration of the LHGR thermal limits. There are two sets of flow dependent LHGR multipliers for dual-loop and single-loop operation. In addition, there are ten sets of power dependent LHGR multipliers for use with the BASE, TBSOOS, RPTOOS, PROOS, DLO and SLO conditions, and PROOS+TBSOOS and PROOS+RPTOOS, DLO only. The PLUOOS condition is included in the BASE LHGRFAC(P) and LHGRFAC(F) multipliers and is bounded by the TBSOOS multipliers; therefore, no additional adjustments are required for PLUOOS in those operating condition. Operation in the PLUOOS condition concurrent with the RPTOOS operating condition. Operation in the PLUOOS condition concurrent with the RPTOOS condition requires core thermal power < 55% of rated (Reference 3). Section 7.0 contains the conditions for Turbine Bypass Valve Operability. The ARTS LHGR multipliers are shown in Tables 5-4 and 5-5. Linear interpolation should be used for points not listed in Reference 7.

Thermal limit monitoring must be performed with the more limiting LHGR limit resulting from the power and flow biased calculation. The LHGRFAC(P) curves are independent of recirculation pump trip operability.

TABLE 5-1
Linear Heat Generation Rate Limits – UO ₂ Rods
(References 5 and 7)

Fuel Type	LHGR
GNF2	See Table B-1 of Reference 7

TABLE 5-2 Linear Heat Generation Rate Limits – Gad Rods (References 5 and 7)

Fuel Type	LHGR
GNF2	See Table B-2 of Reference 7

COLR Limerick 2 Rev. 9

Exelon Nuclear – Nuclear Fuels Core Operating Limits Report

TABLE 5-3 LHGR Single Loop Operation (SLO) Multiplier – All Fuel Types (Reference 2)

SLO Multiplier ¹	0.80

TABLE 5-4 Power Dependent LHGR Multiplier LHGRFAC(P) – All Fuel Types (References 2 and 8)

	Core	_	Cor	e Therma	al Power	(% of ra	ited)	
EOOS Combination	riow (% of	0	25	< 30	≥ 30	65	85	100
	rated)			LHGRI	FAC(P)	Aultiplie	r	
PASE	≤ 60	0.485	0.485	0.490	0 750	0.917	0.022	1.000
BASE	> 60	0.434	0.434	0.473	0.750	0.017	0.922	1.000
	≤ 60	0.485	0.485	0.490	0.750	0.017	0.022	1.000
BASE SLO	> 60	0.434	0.434	0.473	0.750	0.017	0.922	1.000
TRSOOS	≤ 60	0.463	0.463	0.490	0 750	0.017	0.000	1 000
153003	> 60	0.352	0.352	0.386	0.750	0.017	0.922	1.000
TRECOR SI O	≤ 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000
103003 310	> 60	0.352	0.352	0.386	0.750			
PPTOOS	≤ 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000
1003	> 60	0.434	0.434	0.473				
D IS SOUTER	≤ 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000
	> 60	0.434	0.434	0.473	0.750			
PPOOS	≤ 60	0.485	0.485	0.490	0.750	0.917	0.022	1 000
PROUS	> 60	0.434	0.434	0.473	0.750	0.017	0.922	1.000
	≤ 60	0.485	0.485	0.490	0.750	0.817 0.92	0.000	1 000
PROUS SLU	> 60	0.434	0.434	0.473	0.750		0.922	1.000
	≤ 60	0.463	0.463	0.490	0.750	50 0.817	0.922 1	1.000
PR003+185005	> 60	0.352	0.352	0.386				
	≤ 60	0.485	0.485	0.490	0.750	0.750 0.817 0.9		1 000
rkoustkp1005	> 60	0.434	0.434	0.473			0.922	1.000

¹ Applied through Table 5-5

	Core Flow (% of rated)					
EOOS Combination	0	30	44.1	70	80	110
	LHGRFAC(F) Multiplier					
Dual Loop	0.506	0.706	- Last Hereit	0.973	1.000	1.000
Single Loop	0.506	0.706	0.800			0.800

TABLE 5-5 Flow Dependent LHGR Multiplier LHGRFAC(F) – All Fuel Types (Reference 2)

6.0 Control Rod Block Setpoints

6.1 Technical Specification

Sections 3.1.4.3 and 3.3.6

6.2 Description

The ARTS Rod Block Monitor provides for power-dependent RBM trips. Technical Specification 3.3.6 states control rod block instrumentation channels shall be OPERABLE with their trip setpoints consistent with the values shown in the Trip Setpoint column of Technical Specification Table 3.3.6-2. The trip setpoints/allowable values and applicable RBM signal filter time constant data are shown in Table 6-1. The Reactor Coolant System Recirculation Flow Upscale Trip is shown in Table 6-2. These setpoints are set high enough to allow full utilization of the enhanced ICF domain up to 110% of rated core flow.

TABLE 6-1 Rod Block Monitor Setpoints¹ (References 2 and 4)

Power Level	Analytical Limit	Allowable Value	Nominal Trip Setpoint
LTSP	123.0%	121.5%	121.5%
ITSP	118.0%	116.5%	116.5%
HTSP	113.2%	111.7%	111.0%
DTSP	No Limitation	2.0%	5.0%

TABLE 6-2 Reactor Coolant System Recirculation Flow Upscale Trip (Reference 4)

Analytical Limit	N/A
Allowable Value	115.6%
Nominal Trip Setpoint	113.4%

¹ These setpoints (with Rod Block Monitor filter time constant between 0.1 seconds and 0.55 seconds) are based on a cycle-specific rated RWE MCPR limit of 1.32, which is less than the minimum cycle OLMCPR.

COLR Limerick 2 Rev. 9

7.0 Turbine Bypass Valve Parameters

7.1 Technical Specification

Section 3.7.8 and 4.7.8.c

7.2 Description

The operability requirements for the steam bypass system are found in Tables 7-1 and 7-2. If these requirements cannot be met, the MCPR, MCPR(P) and LHGRFAC(P) limits for inoperable Steam Bypass System, known as Turbine Bypass System Out Of Service (TBSOOS), must be used. Additional information on the operability of the turbine bypass system can be found in Reference 6.

TABLE 7-1 Turbine Bypass System Response Time (Reference 3)

Maximum delay time before start of bypass valve opening following initial turbine inlet valve movement ¹	0.11 sec
Maximum time after initial turbine inlet valve movement ¹ for bypass valve position to reach 80% of full flow (includes the above delay time)	0.31 sec

¹ First movement of any TSV or any TCV or generation of the turbine bypass valve flow signal (whichever occurs first)

TABLE 7-2

Minimum Required Bypass Valves To Maintain System Operability (References 1 and 3)

Reactor Power	No. of Valves in Service
P≥25%	7

8.0 Stability Protection Setpoints

8.1 Technical Specification

Section 2.2.1

8.2 Description

The Limerick 2 Cycle 14 OPRM PBDA Trip Setpoints for the OPRM System are found in Table 8-1. These values are based on the cycle specific analysis documented in Reference 2. The setpoints provided in Table 8-1 are bounding for all modes of operation shown in Table 9-1. The setpoints provided in Table 8-2 are acceptable for use in Single Loop Operation. The standard two loop operation OPRM Setpoints specified in Table 8-1 must be implemented prior to restarting the idle pump when exiting the SLO condition.

TABLE 8-1 OPRM PBDA Trip Setpoints (Reference 2)

PBDA Trip Amplitude	Corresponding Maximum Confirmation Count Trip Setting
≤ 1.12	≤ 1 4

TABLE 8-2 SLO OPRM PBDA Trip Setpoints (Reference 2)

PBDA Trip Amplitude	Corresponding Maximum Confirmation Count Trip Setting
≤ 1.15	≤ 16

9.0 Modes of Operation

9.1 Description

The allowable modes of operation are found in Table 9-1. Operation with 1 MSIVOOS, or 1 TCV/TSV OOS is supported in all modes of operation, provided the restrictions identified in the applicable station procedures are met. All EOOS options also support the allowance of 1 TIPOOS.

TABLE 9-1Modes of Operation(References 2 and 8)

EOOS Options	Operating Region ¹
BASE, Option A or B	Yes ²
BASE SLO, Option A or B	Yes ²
TBSOOS, Option A or B	Yes ²
TBSOOS SLO, Option A or B	Yes ²
RPTOOS, Option A or B	Yes ³
RPTOOS SLO, Option A or B	Yes ³
TBSOOS and RPTOOS, Option A or B	No
TBSOOS and RPTOOS SLO, Option A or B	No
PROOS, Option A or B	Yes ²
PROOS SLO, Option A or B	Yes ²
PROOS+TBSOOS, Option A	No
PROOS+TBSOOS, Option B	Yes ²
PROOS+TBSOOS SLO, Option A or B	No
PROOS+RPTOOS, Option A	No
PROOS+RPTOOS, Option B	Yes ³
PROOS+RPTOOS SLO, Option A or B	No

¹ Operating Region refers to operation on the Power to Flow map with or without FFWTR/FWHOOS.

² The PLUOOS condition is supported in this mode of operation with no power reduction required.

³ The PLUOOS condition requires core thermal power level < 55% of rated (Reference 3).

10.0 Methodology

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following document:

- 1. "General Electric Standard Application for Reactor Fuel", Global Nuclear Fuel Document, NEDE-24011-P-A-21, May 2015 and the U.S. Supplement NEDE-24011-P-A-21-US, May 2015.
- 2. "Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications", GENE Document, NEDO-32465-A, August 1996.

11.0 References

- 1. "Technical Specifications and Bases for Limerick Generating Station Unit 2", Docket No. 50-353, License No. NPF-85, Exelon Document.
- 2. "Supplemental Reload Licensing Report for Limerick Unit 2 Reload 13 Cycle 14", Global Nuclear Fuel Document No. 000N9396-SRLR, Rev. 0, February 2015.
- 3. "Final Resolved OPL-3 Parameters for Limerick Unit 2 Cycle 14", Exelon TODI ES1400022 Rev. 0, October 30, 2014.
- 4. "GE NUMAC PRNM Setpoint Study", Exelon Design Analysis LE-0107, Rev. 2, February 23, 2012.
- 5. "Fuel Bundle Information Report for Limerick 2 Reload 13 Cycle 14", Global Nuclear Fuel Document No. 000N9397-FBIR, Rev. 0, February 2015.
- 6. "Tech Eval Stop Valve Load Limit Documentation", Exelon Document IR 917231 Assignment 7, November 11, 2009.
- 7. "GNF2 Advantage Generic Compliance with NEDE-24011-PA (GESTAR II)", Global Nuclear Fuel Document No. NEDC-33270P, Rev. 5, May 2013.
- 8. "Limerick Generating Station (LGS) Units 1 and 2 TRACG Cycle-Independent PROOS Analysis Report", GE Hitachi Nuclear Energy Document No. 002N4397, Rev. 0, February 24, 2015.