NYS000518 Submitted: June 9, 2015

ML14163A52



Protecting People and the Environment

Assessment of BTP 5-3 Protocols to Estimate RT_{NDT(u)} and USE

Mark Kirk Senior Materials Engineer RES/DE/CIB <u>mark.kirk@nrc.gov</u> **Simon Sheng**

Senior Materials Engineer NRR/DE/EVIB simon.sheng@nrc.gov

NRC/EPRI Annual Materials Issue Program Information Exchange Meeting 4th June 2014 Rockville, Maryland, USA

Outline of Presentation



- Un-Irradiated RT_{NDT} (RT_{NDT(u)}) & Un-Irradiated
 Upper Shelf Energy (USE) definitions & estimates
- Background of questions concerning BTP 5-3
- Staff Assessment Part I Technical evaluation of BTP 5-3 estimation of RT_{NDT(u)} & USE
- Staff Assessment Part I Potentially Affected Plants
- Next steps



RT_{NDT(u)} & USE Estimated by NUREG-0800 BTP 5-3





Background of Questions Concerning BTP 5-3



United States Nuclear Regulatory Commission

Protecting People and the Environment

- AREVA Letter (30 Jan 2014, AREVA Ref. NRC:14:004) & PVP Paper (PVP2014-28897) claim Position 1.1(4) of BTP 5.3 is sometimes non-conservative for A508-2 forgings
- Literature search reveals 1983
 EG&G report & 1985 IJPVP
 paper
 - Evaluation of BTP 5-3 (then MTEB 5-2) for NRC
 - Conclusions
 - Always conservative
 - Position 1.1(1): estimates T_{NDT}
 - Position 1.1(2): estimates T_{NDT}
 - Sometime non-conservative
 - Position 1.1(3): estimates T_{CVE(50/35)}
 - Position 1.1(4): estimates RT_{NDT}
 - Position 1.2: estimates USE

January 30, 2014 NRC:14:004

U.S. Nuclear Regulatory Commission Document Control Desk 11555 Rockville Pike Rockville, MD 20852

Potential Non-Conservatism in NRC Branch Technical Position 5-3



Proceedings of the ASME 2014 Pressure Vessels & Piping Conference PVP2014 July 20-24, 2014, Anaheim, California, USA

PVP2014-28897

AREVA

AN ASSESSMENT OF BRANCH TECHNICAL POSITION 5-3 TO DETERMINE UNIRRADIATED RT_{NDT} FOR SA-508 CL. 2 FORGINGS

Greg Troyer AREVA Inc. Lynchburg, Virginia, USA Matthew DeVan AREVA Inc. Lynchburg, Virginia, USA

Background of Questions Concerning BTP 5-3

- AREVA Letter (30 Jan 2014, AREVA Ref. NRC:14:004) & PVP Paper (PVP2014-28897) claim Position 1.1(4) of BTP 5.3 is sometimes non-conservative for A508-2 forgings
- Literature search reveals 1983 EG&G report & 1985 IJPVP paper
 - Evaluation of BTP 5-3 (then MTEB 5-2) for NRC
 - Conclusions
 - Always conservative
 - Position 1.1(1): estimates T_{NDT}
 - Position 1.1(2): estimates T_{NDT}
 - Sometime non-conservative
 - Position 1.1(3): estimates T_{CVE(50/35)}
 - Position 1.1(4): estimates RT_{NDT}
 - Position 1.2: estimates USE



Int. J. Pres. Ves. & Piping 19 (1985) 299-315

Adequacy of Estimates and Variability of Fracture-related Properties for Reactor Pressure Vessel Materials*

A. K. Richardson, W. L. Server & W. G. Reuter

E.G. & G. Idaho, Inc., PO Box 1625, Idaho Falls, Idaho 83415, USA

(Received: 3 October, 1984)



United States Nuclear Regulatory Commission

Protecting People and the Environment

NRC Staff Assessment Process



Part I: Technical evaluation of BTP 5-3 estimation of RT_{NDT(u)} and USE

- Data sources
 - Processed data (T₅₀, USE, ...) from 1983 EG&G report
 - Raw data (CVE, MLE, temp) in both specimen orientations from surveillance reports (stored in REAP)
 - Raw data (NDTT) from RVID refs.
- Focus on
 - Plates & forgings only
 - No plants have used BTP 5-3 for welds
 - Positions identified as sometimes non-conservative in 1983 by EG&G report
 - Position 1.1(3): estimates T_{CVE(50/35)}
 - Position 1.1(4): estimates RT_{NDT}
 - Position 1.2: estimates USE

Part II: Assessment of applicability to plants

- Query RVID
 - RT_{NDT(u)}: establishes BTP 5-3 use, but not which position was used
 - USE: establishes BTP 5-3 use
- Search for documents referenced by RVID in ADAMS legacy
 - Focus on plants closest to PTS (50.61) limit, these being most prone to influence by potential non-conservatisms
 - References establish which position of BTP 5-3 was used for RT_{NDT(u)}

Part I: Technical Evaluation



United States Nuclear Regulatory Commission

Protecting People and the Environment

- Data sources
 - Processed data (T₅₀, USE, ...) from 1983 EG&G report
 - Raw data (CVE, MLE, temp) from surveillance reports (stored in REAP)
 - Raw data (NDTT) from RVID refs.
- Focus on
 - Plates & forgings only
 - No plants have used BTP 5-3 for welds
 - Positions identified as sometimes non-conservative by 1983 EG&G report
 - Position 1.1(3): estimates T_{CVE(50/35)}
 - Position 1.1(4): estimates RT_{NDT}
 - Position 1.2: estimates USE

- While similar answers are expected from both sources ...
- Given the potential impact of this evaluation, going back to the raw data was seen to be important.



Position 1.1(3)



United States Nuclear Regulatory Commission

Protecting People and the Environment

Quotation

If transversely-oriented Charpy V-notch specimens were not tested, the temperature at which 68 J (50 ft-lbs) and 0.89 mm (35 mils) LE would have been obtained on transverse specimens may be estimated by one of the following criteria:

- Test results from longitudinally-oriented specimens reduced to 65% of their value to provide conservative estimates of values expected from transversely oriented specimens.
- Temperatures at which 68 J (50 ft-lbs) and 0.89 mm (35 mils) LE were obtained on longitudinally-oriented specimens increased 11 °C (20 °F) to provide a conservative estimate of the temperature that would have been necessary to obtain the same values on transversely-oriented specimens.

Tests Required

Longitudinally oriented CVN specimens

Clear Interpretation

Note that this position applies only to conversion between longitudinal and transverse Charpy values.

There are two approximations. They may not produce the same results. They are as follows

- (a) $E_{TRANS} = 0.65 \times E_{LONG}$, then calc $T_{C(TRANS)}$ MLE_{TRANS} = 0.65×MLE_{LONG}, then calc $T_{C(TRANS-MLE)}$
- (b) $T_{C(TRANS)} = T_{C(LONG)} + 20 \text{ °F}$ $T_{C(TRANS-MLE} = T_{C(LONG-MLE)} + 20 \text{ °F}$

where

| E _{LONG} | is CVN energy measured by a longitudinally oriented specimen |
|--------------------|--|
| E _{TRANS} | is the estimated CVN for a transversely oriented specimen |
| $T_{C(LONG)}$ | is the temperature at which the minimum of three longitudinal CVN tests exhibits >35 mils AND >50 ft-lbs |
| $T_{C(TRANS)}$ | is the estimated temperature at which the minimum of three transverse CVN tests exhibits >35 mils AND >50 ft-lbs |

Position 1.1(3)

Assessing(a): Trans = 0.65×Long

- Per the BTP, reduce
 longitudinal measurements to
 65% of the measured values
- 2. Fit Charpy curves
 - Energy vs. temperature
 - Lateral expansion vs.
 temperature
- 3. Determine MAX(T_{50ft-lb}, T_{35mills})
- Value from Step 3 estimates the transition temperature of transverse data





Position 1.1(3) Assessing(a): Trans = 0.65×Long



Protecting People and the Environment



Position is non-conservative about 36% of the time

EG&G Data

Position 1.1(3) Assessing(a): Trans = 0.65×Long



Protecting People and the Environment



T_{50ft-lbs} determines the value of T_{50ft-lbs&35mills}

- 81% of the time for longitudinal specimens
- 92% of the time for transverse specimens

Raw Data

Position is non-conservative about 30% of the time

Position 1.1(3)



United States Nuclear Regulatory Commission

Protecting People and the Environment





Trans. T₅₀ from Longx0.65[°F]

Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse T₅₀ values in a manner that is always conservative.

EG&G Data

Position 1.1(3)



United States Nuclear Regulatory Commission

Protecting People and the Environment





Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse T₅₀ values in a manner that is always conservative.

Raw Data

Position 1.1(3) Assessing(b): T_{C(TRANS)} = T_{C(LONG)} + 20 °F



Protecting People and the Environment



Position is non-conservative about two-thirds of the time

EG&G Data

Position 1.1(3) Assessing(b): T_{C(TRANS)} = T_{C(LONG)} + 20 °F



Protecting People and the Environment



T_{50ft-lbs} determines the value of T_{50ft-lbs&35mills}

- 81% of the time for longitudinal specimens
- 92% of the time for transverse specimens

Raw Data

Position is non-conservative about two-thirds of the time

Position 1.1(3)



United States Nuclear Regulatory Commission

Protecting People and the Environment





Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse T₅₀ values in a manner that is always conservative.

EG&G Data

Position 1.1(3)



United States Nuclear Regulatory Commission

Protecting People and the Environment





Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse T₅₀ values in a manner that is always conservative.

Raw Data

Position 1.1(4)

Quotation

If limited Charpy V-notch tests were performed at a single temperature to confirm that at least 41 J (30 ft-lbs) was obtained, that temperature may be used as an estimate of the RT_{NDT} provided that at least 61J (45 ft-lbs) was obtained if the specimens were longitudinally oriented. If the minimum value obtained was less than 61 J (45 ft-lbs), the RT_{NDT} may be estimated as 11 °C (20 °F) above the test temperature.



Protecting People and the Environment

| Tests Requir | red |
|-----------------------------|--|
| Limited long temperature | gitudinally oriented CVN tests at a single |
| Interpretatio | n |
| Define: | T_{TEST} = the temperature at which limited longitudinally oriented CVN tests were conducted C_V = absorbed energy observed at T_{TEST} |
| IF ELSE | $C_V \ge 45$ ft-lbs then $RT_{NDT} = T_{TEST}$ $RT_{NDT} = T_{TEST} + 20$ °F |

When assessed using data sets for which full Charpy energy curves are available, EG&G interpreted Position 1.1(4) as having 2 possible meanings:

- $RT_{NDT} = T_{45(LONG)}$, and
- $RT_{NDT} = T_{30(LONG)} + 20$ °F

These might not produce the same result. Therefore, both were assessed.

Position 1.1(4)

Assessed for Forgings



Protecting People and the Environment



Position 1.1(4)

Assessed for Plates



United States Nuclear Regulatory Commission

Protecting People and the Environment



Position 1.2



United States Nuclear Regulatory Commission

Protecting People and the Environment

Quotation

For the beltline region of reactor vessels, the upper shelf toughness must account for the effects of neutron radiation. Reactor vessel beltline materials must have Charpy upper shelf energy, in the transverse direction for base material and along the weld for weld material according to the ASME Code, of no less than 102 J (75 ft-lbs) initially and must maintain Charpy upper shelf energy throughout the life of the vessel of no less than 68 J (50 ft-lbs).

If Charpy upper shelf energy values were not obtained, conservative estimates should be made using results of tests on specimens from the first surveillance capsule removed.

If tests were only made on longitudinal specimens, the values should be reduced to 65% of the longitudinal values to estimate the transverse properties.

| Tests Required | |
|------------------------------|--|
| ongitudinally orien helf. | ted CVN specimens tested on the upper |
| Clear Interpretatio | n |
| USE _{TRANS} = | 0.65 × USE _{LONG} |
| where | |
| USE _{LONG} | is CVN energy measured by longitudinally oriented specimens on the upper shelf |
| USE _{TRANS} | is the estimated CVN energy for transversely oriented specimens on the upper shelf |

Position 1.2 Assessing: $USE_{TRANS} = 0.65 \times USE_{LONG}$



United States Nuclear Regulatory Commission

Protecting People and the Environment



Position is non-conservative about 18% of the time

EG&G Data



Position is non-conservative about 21% of the time

Raw Data

Position 1.2



United States Nuclear Regulatory Commission

Protecting People and the Environment

Assessing: Alternative USE_{TRANS} Estimates



Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse USE values in a manner that is always conservative.

EG&G Data

Position 1.2



United States Nuclear Regulatory Commission

Protecting People and the Environment

Assessing: Alternative USE_{TRANS} Estimates



Preliminary analysis suggests that alternative formulae could be developed to convert longitudinal to transverse USE values in a manner that is always conservative.

Raw Data

Summary on Part I – Technical Evaluation



United States Nuclear Regulatory Commission

Protecting People and the Environment

- Positions 1.1(3) and 1.2
 - Results of the two studies are similar
 - Staff analysis confirms non-conservatism
- Position 1.1(4)
 - EG&G report demonstrates position is non-conservative
 - Awaiting NDTT data from Archives to complete staff assessment

| Position of BPT 5-3 | | Forging Non- Predicti | Conservative on Rate | Plate Non-Conservative Prediction Rate | | |
|---------------------|--|--------------------------|-------------------------|---|----------|--|
| | | EG&G Data | Raw Data | EG&G Data | Raw Data | |
| 1.1(3) | (a) TRANS = 0.65×LONG | 43% | 48% | 33% | 19% | |
| | (b) $T_{C(TRANS)} = T_{C(LONG)} + 20 $ °F | 50% | 57% | 70% | 63% | |
| 1 1 (1) | $RT_{NDT} = T_{45(LONG)}$ | 93% | TBD | 38% | TBD | |
| 1.1(4) | $RT_{NDT} = T_{30(LONG)} + 20 $ °F | 93% | TBD | 38% | TBD | |
| 1.2 | $\text{USE}_{\text{TRANS}} = 0.65 \times \text{USE}_{\text{LONG}}$ | 14% | 33% | 20% | 13% | |

Part II: Assess Potentially Affected Plants - Position 1.1(3)



Protecting People and the Environment

Plant Identification

- Search RVID for plants using BTP 5-3 to determine plate (forging) RT_{NDT(u)}:
 20 operating plants
- Rank plates (forging) according to the difference between RT_{PTS} at 32 EFPY and 270 °F:

Eight plants have their limiting plates or forgings using BTP5-3 with difference less than 100 °F.

Plant-specific evaluation results



- The majority of the plants did not specify which BTP 5-3 B1.1 position was used in determining their RT_{NDT(u)} values
- Details of calculation of RT_{NDT(u)} values are not available.
- One plant has full transverse Charpy data and the staff confirmed that BTP 5-3 was not used , so it will be dropped from the list
- A few plants have full longitudinal Charpy data
 - The staff's RT_{NDT(u)} values using lower bound Charpy data and linear interpolation between two temperatures are lower than the licensee's value by 10 °F
- A few plants may have PTS concern because the RT_{PTS} values are below 270 °F by less than 75 °F
 - In one case, the longitudinal Charpy data for one plate are significantly higher than other plates, indicating potential mislabeling

Why do we use the Selecting criterion of 75 °F?



Protecting People and the Environment

- Identify raw data with the greatest conservatism and non-conservatism

Watts's Bar 1 – greatest non-conservatism Millstone 2 – greatest conservatism



Closer Look at the Charpy Data with the Greatest Non-Conservatism





Determine the RT_{NDT} for the Raw Data with the Greatest Non-Conservatism



Protecting People and the Environment

- Nil-ductility transition temperature (NDTT): -22 °F
- Official RT_{NDT(u)} value: = <u>54.5 °F</u> (114.5 °F - 60 °F)
- RT_{NDT(u)} based on BTP 5-3B1.1(3)a: -22 °F
 (At 31 °F, the equivalent Charpy energy (.65 x longitudinal data) is 50 ft-lb; RT_{NDT} = NDTT)
- RT_{NDT(u)} based on BTP 5-3B1.1(3)b: <u>-22 °F</u> (At -15.5 °F, the Charpy energy is 50 ft-lb; since the adjusted temp is (-15.5 °F + 20 °F), less than (-22°F + 60 °F), RT_{NDT} = NDTT)



Protecting People and the Environment

Summary on the Study Focusing on the Raw Data with the Highest Non-Conservatism

- The highest non-conservative raw data is about 75 °F
- RT_{NDT} determination is not sensitive to whether B1.1(3)a or B1.1(3)b is used for this case
- RT_{NDT} determination is affected by whether curve fitting of the entire Charpy data or hand calculations based on Charpy data at two temperatures are used

Part II: Assess Potentially Affected Plants - Position 1.2



- Plant Identification
 - 45 operating plants identified in RVID as using Position 1.2
 - RVID clearly identifies Position 1.2 as UNIRR_USE_METHOD=65%
 - Spot-checking of RVID references to confirm accuracy still TBD

Non-conservatism

 Data analysis shows the Position 1.2 estimate to be non-conservative between 13% and 33% of the time

Next Steps



<u>NRC</u>

- Complete technical analysis
 - Need NDTT data from Archives to complete assessment of Position 1.1(4)
 - Investigate GE RT_{NDT(u)} procedure
 - Document findings

Complete plant assessment

- Need to assess the impact to Pressure-temperature limits
- Recommend to NRC management regarding use of interim conservatism in defining RT_{NDT(u)} for the plants which may need to update their PTS evaluations
- Communicate findings to affected plants
 - Precise means TBD
- May need to revise BTP 5-3 in Standard Review Plan

<u>Industry</u>

 Assess the impact of reported potential non-conservatism including the need to redefine the RT_{NDT(u)} on pressure-temperature limits and PTS evaluations

BACKUP SLIDES

Comparison of Charpy Fit Methods

| Method | NDTT | Meas. T ₅₀ | Trans. T ₅₀ | RT_{NDT} | Non Conservatism | | | | |
|---|------|-----------------------|------------------------|-------------------------|------------------|--|--|--|--|
| wethou | [°F] | [°F] | [°F] | [°F] | [°F] | | | | |
| Charpy Fit Method: tanh (mean) | | | | | | | | | |
| NB-2331 | -22 | 114.5 | 114.5 | 54.5 | | | | | |
| 1.1(3)a: Energy*0.65 | -22 | 31 | 31 | -22 | 76.5 | | | | |
| 1.1(3)b: T _{50(LONG)} +20 °F | -22 | -15.5 | 4.5 | -22 | 76.5 | | | | |
| Charpy Fit Method: Interpolate lower bound data | | | | | | | | | |
| NB-2331 | -22 | 109.5 | 109.5 | 49.5 | | | | | |
| 1.1(3)a: Energy*0.65 | -22 | 41 | 41 | -19 | 68.5 | | | | |
| 1.1(3)b: T _{50(LONG)} +20 °F | -22 | 0 | 20 | -22 | 71.5 | | | | |

Main Points

- There is some effect of *tanh* fitting versus lower-bound interpolation
 - Interpolation can produce higher or lower transition temperature values than *tanh* fitting
- Using either Charpy fitting method, BTP 5-3 Position 1.1(3) is nonconservative

