

June 9, 2015
NND-15-0369
10 CFR 50.90
10 CFR 52.63

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Virgil C. Summer Nuclear Station (VCSNS) Units 2 and 3
Combined License Nos. NPF-93 and NPF-94
Docket Nos. 52-027 & 52-028

Subject: PAR 15-09-02 Preliminary Amendment Request: Use of AWS D1.1-2000 Criteria for Structural Welds

- Reference:
1. ND-15-0903, Southern Nuclear Operating Company, Vogtle Electric Generating Plant Units 3 and 4, Request for License Amendment: Use of AWS D1.1-2000 Criteria for Structural Welds (LAR-15-009), dated May 26, 2015.
 2. NND-15-0339, South Carolina Electric & Gas Company, Virgil C. Summer Nuclear Station Units 2 and 3, Request for License Amendment: Use of AWS D1.1-2000 Criteria for Structural Welds (LAR 15-09), dated May 26, 2015.
 3. ND-15-0968, Southern Nuclear Operating Company, Vogtle Electric Generating Plant Units 3 and 4, Request for License Amendment: Use of AWS D1.1-2000 Criteria for Structural Welds (LAR-15-009S), dated May 28, 2015.
 4. NND-15-0344, South Carolina Electric & Gas Company, Virgil C. Summer Nuclear Station Units 2 and 3, Request for License Amendment: Use of AWS D1.1-2000 Criteria for Structural Welds (LAR 15-09 S1), dated May 28, 2015.
 5. NND-15-0357, South Carolina Electric & Gas Company, Virgil C. Summer Nuclear Station Units 2 and 3, Preliminary Amendment Request: Use of AWS D1.1-2000 Criteria for Structural Welds (PAR 15-09), dated June 4, 2015.

In accordance with the provisions of 10 CFR 50.90, South Carolina Electric & Gas Company (SCE&G) submitted a request for license amendment to the Virgil C. Summer Nuclear Station (VCSNS) Units 2 and 3 combined licenses (COLs) numbers NPF-93 and NPF-94, respectively. By letter dated May 26, 2015, SCE&G submitted a request for a license amendment via LAR 15-09, SCE&G correspondence NND-15-0339 (Reference 2) to revise VCSNS Units 2 and 3 Updated Final Safety Analysis Report (UFSAR) to provide for use of American Welding Society (AWS) D1.1-2000, *Structural Welding Code-Steel*, in lieu of the AWS D1.1-1992 edition identified in AISC N690-1994. This request was supplemented on May 28, 2015 via LAR 15-09 S1,

SCE&G correspondence NND-15-0344 (Reference 4), to revise the Tier 2* designations of some of the proposed changes to the UFSAR.

SCE&G is submitting this additional Preliminary Amendment Request (PAR), to minimize further construction delays for Unit 2 and 3 during the NRC's evaluation of the related license amendment request (LAR). The determination of whether the NRC has any objection to SCE&G proceeding with construction based on the proposed plant licensing basis changes identified in the LAR is requested on or before June 23, 2015. Welding dependent on AWS D1.1-2000 provisions is currently on hold and delayed determination regarding this PAR will result in continued delay in the construction completion of VCSNS Unit 2 and 3 activities described in this PAR.

A description of the proposed change and the reason for the change are contained in Enclosure 1 to this letter. This PAR has been developed in accordance with guidance provided in Revision 0 – Corrected of NEI 96-07, Appendix C Guideline for Implementation of Change Processes for New NPPs Licensed Under 10 CFR Part 52. This PAR has also been developed in accordance with guidance provided in the most recent revision to the Interim Staff Guidance on Changes during Construction Under 10 CFR Part 52, COL-ISG-25 [ML13045A125], and corresponds accurately and technically with the above-mentioned LAR 15-09 and its supplement LAR 15-09 S1. The technical scope of this PAR is consistent with the technical scope of the submitted LAR. Section 7 of Enclosure 1 identifies the scope of the “no objection” sought in this PAR.

This letter contains no regulatory commitments.

Should you have any questions, please contact Mr. Justin Bouknight, Supervisor, Nuclear Licensing, at (803) 941-9828.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on this 9th day of June, 2015.

Sincerely,



April Rice
Manager
Nuclear Licensing

MMD/RAJ/mmd

Enclosures: 1) Preliminary Amendment Request Regarding the Use of AWS D1.1-2000
Criteria for Structural Welds (PAR-15-09 -02)

cc: Denise McGovern
Chandu Patel
Ruth Reyes
Timothy Chandler
Nicholas Karlovich
Jose Vasquez
Patrick Donnelly
Thomas R. Fredette
Victor McCree
Jim Reece
Stephen A. Byrne
Jeffrey B. Archie
Ronald A. Jones
Alvis J. Bynum
Kathryn M. Sutton
April R. Rice
Justin R. Bouknight
Bryan Barwick
Dean Kersey
Matthew Presson
Matthew Kunkle
Mohamed Mory Diané
Margaret Felkel
Cynthia Lanier
Kristin Seibert
Neil Haggerty
Wes Sparkman
Pat Young
Carl D. Churchman
Michael Frankle
Sean Burk
Joel Hjelseth
Brian Bedford
Brian McIntyre
Joseph Cole
Zach Harper
Jim Mermigos
Chuck Baucom
Lisa Alberghini
Curt Castell
Ken Hollenbach
Susan E. Jenkins
William M. Cherry
Rhonda O'Banion
DCRM-EDMS@SCANA.COM
VCSummer2&3ProjectMail@cbi.com
VCSummer2&3Project@westinghouse.com

South Carolina Electric and Gas Company

NND-15-0369

Enclosure 1

Virgil C. Summer Nuclear Station (VCSNS) Unit 2 and 3

Preliminary Amendment Request

Regarding the

Use of AWS D1.1-2000 Criteria for Structural Welds

(PAR 15-09-02)

(This Enclosure consists of 5 pages, including this cover page)

Pursuant to 10 CFR 50.90, South Carolina Electric and Gas Company (SCE&G) submitted a license amendment request (LAR) to change the Virgil C. Summer Nuclear Station (VCSNS) Unit 2 and 3, licensing basis documents associated with Combined License Nos. NPF-93 and NPF-94, respectively. Accordingly, SCE&G requests the determination of whether the NRC has any objection to proceeding with construction of VCSNS Unit 2 and 3 activities listed in Section 7, utilizing the criteria of American Welding Society (AWS) D1.1-2000, *Structural Welding Code-Steel*, in lieu of the AWS D1.1-1992 edition identified in AISC N690-1994, as identified in the Preliminary Amendment Request (PAR) provided below to be provided by the date shown below.

PAR Number PAR 15-09-02	Station Name VCSNS	Unit Number <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 3	PAR Date June 9, 2015
1. NRC PAR Notification Requested Date (see Block 7 for basis) <u>June 25, 2015</u>			
2. License Amendment Request References (as applicable) <input checked="" type="checkbox"/> LAR submittal date and SCE&G Correspondence Number: May 26, 2015 / NND-15-0339 as supplemented by May 28, 2015 / NND-15-0344. <input type="checkbox"/> Expected LAR submittal date: _____			
3. Brief Description of Proposed Change <p>This proposed change would revise the licensing basis, particularly the Combined Licenses' Updated Final Safety Analysis Report (UFSAR), description of the design of welding for structures in the nuclear island and in the seismic Category II portions of the turbine building and annex building.</p> <p>The design change incorporates criteria of American Welding Society (AWS) D1.1-2000, <i>Structural Welding Code-Steel</i>, into the design of structures designed to the requirements of American Institute of Steel Construction (AISC) N690-1994, <i>Specification for the Design, Fabrication, and Erection of Steel Safety-Related Structures for Nuclear Facilities</i>, so that it may be used in lieu of the AWS D1.1-1992 version identified in AISC N690-1994. This use of AWS D1.1-2000 is necessary both for future welding and for installed welding to resolve an item noted by a Nuclear Regulatory Commission (NRC) inspector.</p> <p>The proposed change simplifies the application of requirements from different codes and standards to the structural design through allowing the consistent use of the criteria for weld design in AWS D1.1-2000. The UFSAR cites AISC N690 and ACI 349 as applicable codes for these structural designs. Reference to AWS D1.1-2000 is added to these citations in the UFSAR as part of the proposed change so that it may be used in lieu of the AWS D1.1-1992 version identified in AISC N690-1994.</p> <p>Reference to AWS D1.1-2000 is added where AISC N690 is identified as the applicable code for seismic Category I structures and components in UFSAR Subsections 3.6.2.3.4.2 (pipe whip restraints), 3A.1 (heating, ventilation and air conditioning (HVAC) ducts and their supports), 3F.1 (cable trays and their supports), and 3H.3.1 (auxiliary and shield buildings). AWS D1.1-2000 may also be used to replace and supplement specific provisions in AISC N690-1994 related to welding as identified in the proposed changes to UFSAR Subsections 3.8.3.2 and 3.8.4.2. AWS D1.1 includes provisions for welding to ASTM A992 steel. The need for this addition is driven by industry changes in structural steel shape availability, as ASTM</p>			




PAR Number PAR 15-09-02	Station Name VCSNS	Unit Number <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 3	PAR Date June 9, 2015
<p>A992 has generally replaced ASTM A36 for structural steel shapes.</p> <p>The technical changes included in the AWS D1.1-2000 edition include criteria that consider load directionality on fillet welds and include an increase factor on structural fillet weld strength. The information on allowable stress for weld strength is included in AISC N690-1994 Section Q1.5.3 and Table Q1.5.3. This provision in AWS D1.1-2000 provides a supplemental set of requirements that are not included in AISC N690-1994 and AWS D1.1-1992. In addition to the changes to address load directionality, the technical changes incorporated into AWS D1.1-2000 either add more restrictive requirements or provide specific requirements for weld details not previously defined as follows: 1) The requirements on the range of weld angles in AWS D1.1-2000, Figure 3.11 – Detail C, over which requirements for skewed T joints apply is a more restrictive requirement than was included in AWS D1.1-1992; 2) The sizing criteria for complete joint penetration groove welds for welding of tubular members in AWS D1.1-2000, Section 2.3.4.1 provide specific requirements for weld details not previously defined; and 3) The weld metal to use for ASTM A992 structural shapes, identified in AWS D1.1-2000, Section 3.3 and Table 3.1 provide information not available in AISC N690-1994, Section Q1.4.4.</p> <p>The portions of the turbine building and annex building adjacent to the auxiliary building are designed as seismic Category II structures to provide for structural integrity during seismic events. The seismic Category II portions of the turbine building and annex building are designed to the criteria of AISC N690 and ACI 349. Reference to AWS D1.1-2000 is also added to the list of codes for the design, qualification, fabrication, and inspection of the welding of seismic Category II structures in the UFSAR as part of the proposed change in UFSAR Subsections 3.3.2.3, 3.7.2, and 3.7.2.8.3. As part of this change, the application of the design requirements is changed to specifically include the seismic Category II portions of the turbine building by adding reference to the turbine building to the paragraph describing requirements for seismic Category II structures.</p>			
<p>4. Reason for License Amendment Request</p> <p>These changes are driven primarily by a need to consider load directionality on fillet welds and include a corresponding increase factor on structural fillet weld strength. The information on allowable stress for weld strength is included in AISC N690-1994 Section Q1.5.3 and Table Q1.5.3. The provisions in AWS D1.1-2000 provide a supplemental set of requirements that are not included in AISC N690-1994 and AWS D1.1-1992.</p> <p>The use of AWS D1.1-2000 was previously approved in the certified Design Control Document (Revision 19) Subsections 3.8.3.2 and 3.8.4.2. However, the identification of the code was not clear as to its intended application. The proposed revision clarifies the intended application and provides for consistent code usage for structural related welding activities.</p>			
<p>5. Is an Exemption Request Required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If Yes, Briefly Describe Reason for Exemption</p> <p>Not applicable</p>			

PAR Number PAR 15-09-02	Station Name VCSNS	Unit Number <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 3	PAR Date June 9, 2015
6. (Optional) Identify Applicable Precedents <p>The use of the provisions of AWS D1.1-2000 is included in the licensing basis for the structural welding provisions associated with construction in conformance with American Concrete Institute (ACI) 349-01, <i>Code Requirements for Nuclear Safety Related Structures</i>, since it is referenced in that code. See SCE&G VCSNS Units 2 & 3 UFSAR Subsections 3.8.3.2 and 3.8.4.2.</p>			
7. (As needed) Impact of Change on Installation and Testing Schedules <p>SCE&G's requested date for approval of this license amendment as identified in the referenced LAR is July 15, 2015. This date is based primarily upon the time periods required for processing a requested license amendment. Structural welding activities dependent on the amendment are currently placed in a "construction hold" status.</p> <p>As such, this PAR requests a "no objections" finding related to this license amendment by the date identified in item 1 above (or sooner if reasonably achievable) to allow for appropriate notifications and release of related welding activities currently under the "construction hold" status to allow construction to continue.</p> <p>Specifically, SCE&G requests a "no objection" finding for the activities addressed in the revised UFSAR descriptions, which include the following welding activities:</p> <ol style="list-style-type: none"> 1. Welding associated with structural steel in the Unit 2 nuclear islands in preparation for setting of module CA01. <i>This activity is currently scheduled for mid-June.</i> 2. Welding associated with preparation and subsequent setting and connecting of Unit 2 module CA01. <i>This activity is currently scheduled to begin mid to late June.</i> 3. Welding associated with completion of Unit 2 module CA20. <i>This activity is currently scheduled for mid-June.</i> 4. Welding associated with structural steel in the Unit 3 nuclear islands in preparation for setting of module CA04. <i>This activity is currently scheduled to begin mid to late June.</i> 5. Welding associated with preparation and subsequent setting and connecting of Unit 3 module CA04. <i>This activity is currently scheduled to begin late June.</i> 6. Welding associated with preparation for setting of Unit 2 floors at elevation 82'-6" in the auxiliary building. <i>This activity is currently scheduled for mid-June.</i> 7. Welding associated with preparation and subsequent setting and connecting of Unit 2 modules CB11 and CB12. <i>This activity is currently scheduled to begin mid-June.</i> 8. Welding associated with preparation and subsequent setting and connecting of Unit 3 modules CB65 and CB66. <i>This activity is currently scheduled to begin mid-June.</i> 9. Welding associated with setting and connecting of Unit 2 modules KB16 and R104. <i>This activity is currently scheduled to begin mid-June (KB16) through mid-July (R104).</i> 10. Welding associated with Unit 2 turbine building first bay structural steel, including embed plates. <i>This activity is currently scheduled to begin mid to late July.</i> 11. Welding associated with Unit 2 annex building structural steel, including embed plates. <i>This activity is currently scheduled to begin mid to late July.</i> 			

NND-15-0369

Enclosure 1

PAR 15-09-02: Use of AWS D1.1-2000 Criteria for Structural Welds

PAR Number PAR 15-09-02	Station Name VCSNS	Unit Number <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 3	PAR Date June 9, 2015
A "no objection" finding for the above welding activities would release the associated Unit 2 and Unit 3 construction holds related to activities currently scheduled prior to the requested LAR approval date.			
8. Impact of Change on ITAAC None			
9. Additional Information None			
10. Preparer Name (Print) MOHAMED MORY DIANE	11. Preparer Signature 	12. Date 6-9-15	
13. Reviewer Name (Print) Justin Bouknight	14. Reviewer Signature 	15. Date 6/9/15	
16. Approver Name (Print) April Rice	17. Approver Signature 	18. Date 6-9-15	