



PSEG Early Site Permit Advisory Committee on Reactor Safeguards

June 10, 2015



PSEG – Overview

Christopher Schwarz
Vice President
Operations Support

PSEG Corporate Overview



Traditional T&D

Electric Customers: 2.2M
Gas Customers: 1.8M

~6,300 – Employees



Regional Wholesale Energy

Nuclear Capacity: 3,661 MW
Total Capacity: 13,446 MW

Nuclear – ~1,500

Fossil – ~1,000

ER&T and Power Support – ~90

Power Ventures / Solar Source – ~10

Total – ~2,600

Services Company – ~1,000 Employees

Total – ~12,000



Traditional T&D

Electric Customers: 1.1M


~2,100 – Employees



PSEG Power Portfolio – 2013


Fuel Diversity

Total MW: 13,466



Energy Produced

Total GWh: 54,264



Coal** - includes NJ units that fuel switch to gas

Solar <1%

- 4th largest generator in PJM
- Generating assets in four states – New Jersey / New York / Connecticut / Pennsylvania

Second largest site in country

- Approximately 3,575 MWe
- Enough electricity for ~3 million homes

Each unit licensed for 60 years (license renewal completed)

- Salem Unit 1 (PWR, 1180* MW) – August 2036
- Salem Unit 2 (PWR, 1175* MW) – April 2040
- Hope Creek (BWR, 1219* MW) – April 2046

Factors Influencing Our Future Fuel Diversity

Polar Vortex

- First concerns related to 'winter' peak vs 'summer' peak
- Challenges gas supply and availability

New Jersey High Electric Demand Day (HEDD)

- Peaking capacity required to shut down in 2015

Nuclear retirements

- In the next 20 years, a significant number of nuclear units reach their end of life (60 yrs)
- Fukushima changes could accelerate nuclear retirements as plants are no longer economic

Early Site Permit – Overview

Jamie Mallon
ESP Manager

Early Site Permit Application

PSEG Power LLC and PSEG Nuclear LLC are applicants

Reactor technology has not been selected

Application includes:

- Site Safety Analysis Report to address impacts of the environment on the plant, including hurricanes and earthquakes
- Emergency Plan – consistent with existing plants
- Environmental Report

ESPA based on a “plant parameter envelope” (PPE)

- Assumes single large unit or two smaller units
- Impacts address footprints and other parameters such as water use
- Up to 2200 MWe for the two unit plant [Westinghouse AP-1000]

Early Site Permit Application Contents

Part 1 – Administrative Information

Part 2 - Site Safety Analysis Report

- Chapter 1 – Introduction and General Description
- Chapter 2 – Site Characteristics and Site Parameters
- Chapter 3 – Aircraft Hazards
- Chapter 11 – Radioactive Waste Management
- Chapter 13 – Emergency Planning
- Chapter 15 – Transient and Accident Analysis
- Chapter 17 – Quality Assurance


Part 3 – Environmental Report

Part 4 – LWA – Not Used

Part 5 – Emergency Plan

Part 6 – SUNSI Information – Not Used

PSEG Early Site Permit Organization



Site Location

Existing 734 acre PSEG property located on southern part of Artificial Island

- 15 miles south of Delaware Memorial Bridge
- 18 miles south of Wilmington, Delaware
- 30 miles southwest of Philadelphia, Pennsylvania
- 7-1/2 miles southwest of Salem, New Jersey

Currently three operating nuclear reactors on Artificial Island


- Salem Units 1 and 2 - Westinghouse PWRs - 3459 MWt each
- Hope Creek Unit 1 – GE BWR - 3840 MWt

PSEG is in negotiation with U.S. Army Corps of Engineers (USACE) to acquire an additional 85 acres immediately north of Hope Creek Generating Station (HCGS)

PSEG ESP Site and Regional Vicinity (NJ, DE, PA AND MD)



Current PSEG Site And Local Vicinity



PSEG NUCLEAR SITE



PSEG Site



Regulatory guidance to prepare the application

- 10 CFR Part 52 – Subpart A
- RG 1.206 - Combined License Applications for Nuclear Power Plants (LWR Edition)
- NUREG – 0800 - Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition
- RS-002 – Processing Applications for Early Site Permits

Studies and processes

- Site Studies and Investigation Programs
- Conceptual Design and Analysis
- Plant Parameter Envelope

Plant Parameter Envelope Development

Follow the Part 52 process as designed

Reactor technology designs not yet mature


- Regulatory risk exists until Design Certification reviews are complete
- Technology and commercial risks exist until detailed designs are more complete

Bounding values for parameters that define facility's interaction with the environment

Reactor technology designs considered:

- Single Unit ABWR
- Single Unit U.S. EPR
- Single Unit US-APWR
- Dual Unit AP1000

Plant Parameter Development Approach



Plant Parameter Development Approach (Cont.)

PPE Table (SSAR Section 1.3)

- Reactor Parameters
 - Radiological Effluents
 - Chemical Emissions
- Owner Engineered Parameters
 - Site Layout Acreages
 - Normal Plant Heat Sink

Sample Format

PPE Item		Design Parameter	Definition
1	Structure		
1.1	Building Characteristics		
1.1.1	Height	234 ft.	The height from finished grade to the top of the tallest power block structure, excluding cooling towers.
1.1.2	Foundation Embedment	39 ft. to 84.3 ft.	The depth from finished grade to the bottom of the basemat for the most deeply embedded power block structure.

Plant Parameter Development Approach (Cont.)

Parameter Categories

- Structure
- Normal Plant and Ultimate Heat Sink
- Potable/Sanitary/Demineralized/Fire Protection Water System
- Miscellaneous Drain (Discharge)
- Unit Vent/Airborne Effluent Release Point
- Solid and Liquid Radwaste System
- Auxiliary Boiler System
- Onsite/Offsite Electrical Power System
- Standby Power System
- Plant Characteristics
- Construction
- Miscellaneous Parameters

Early Site Permit Application – Submitted May 25th 2010

	Q3 2008	Q4 2008	Q1 2009	Q2 2009	Q3 2009	Q4 2009	Q1 2010	Q2 2010
Project Planning and Kickoff								
Geotechnical Field Activities								
Geotechnical Data Review								
Hydrological Field Activities								
Hydrology Data Review								
Ecological Activities								
Ecological Data Review								
Meteorological Data Collection								
Meteorological Data Review								
Prepare Plant Parameter Envelope								
Prepare Site Safety Analysis Report								
Prepare Environmental Report								
Prepare Emergency Plan								
ESP Reviews								
Submit Early Site Permit Application								

NRC Site Safety Visits

- Pre-application Subsurface Investigation January 2009
- PPE Development March 2009
- Hazards Analysis December 2009
- Post-application ESPA Overview June 2010
- Hydrology Audit February 2011
- Quality Assurance June 2011
- Geotechnical Audit September 2011
- Seismic Analysis Sept./Dec. 2012
- Flood Re-analysis July/Sept. 2013
- Hydrology Audit February 2014

Application Timeline

ESP Application Timeline

- **Application Submitted** May 25, 2010
- **Application Docketed** August 4, 2010
- **Review Schedule Issued** November 29, 2010
- **Hydrology Audit** February 15 - 16, 2011
- **Fukushima EQ and Tsunami** March 11, 2011
 - **Flooding**
 - RAI #67 Issued – PMSS September 27, 2012
 - Flood re-analysis July - September 2013
 - Initial Response to RAI #67 September 27, 2013
 - Hydrology Audit February 4 - 6, 2014
 - Revised Response to RAI #67 April 15, 2015
 - ASER – SSAR 2.4 Issued April 22, 2015

Application Timeline (Cont.)

ESP Application Timeline

- Seismic
 - Mineral VA M5.8 EQ August 23, 2011
 - Geotechnical Audit September 29 - 30, 2011
 - NUREG-2115, CEUS-SSC Issued January 2012
 - RAI # 61 Issued – Vib. Ground Motion June 7, 2012
 - Seismic Re-analysis July - December 2012
 - ASER – SSAR 2.5 Issued July 14, 2014

ESP Application, Revision 4, submitted June 5, 2015

- Addresses all Confirmatory Items
- Closes all open licensing commitments

ASER/ACRS Committee Timeline

ASER/ACRS Committee Timeline

- Initial ASERs Issued October 31, 2013
- 2nd Set ASERs Issued January 8, 2014
- 3rd Set ASERs Issued January 15, 2014
- ACRS Subcommittee Meeting March 19, 2014
 - SSAR Sections 3.5.1.6, 11.2/11.3 13.3, 15.0.3, 17.5
- ASER – SSAR 2.5 Issued July 14, 2014
- ACRS Subcommittee Meeting September 29-30, 2014
 - SSAR Sections 2.1/2.2, 2.3, 2.5
- ASER – SSAR 2.4 Issued April 22, 2015
- ACRS Subcommittee Meeting June 9, 2015
 - SSAR Section 4
- ACRS Full Committee Meeting June 10, 2015

ESP Project Update - Licensing Process

	2010	2011	2012	2013	2014	2015	2016
Submit Early Site Permit Application							
NRC Acceptance Review							
Public Comment Period – Opportunity to Intervene							
NRC C-4 Public Meeting							
NRC & Applicant Respond to Contentions							
NRC Environmental Scoping Public Meeting							
ALSB Review of Petitions							
NRC Review of Early Site Permit Application							
NRC Issue Requests for Additional Information							
PSEG Respond to RAIs							
NRC Issue Draft EIS							
NRC Issue Final EIS							
NRC Issue Advanced Safety Evaluation Report							
ACRS Meetings – Advanced SER							
NRC Issue Final SER							
Mandatory ALSB Hearing on Early Site Permit							
NRC Issue Early Site Permit							

Chapter 2 – Section 2.4.5 Probable Maximum Surge And Seiche Flooding

2.4.5 Probable Maximum Surge and Seiche Flooding


Probable Maximum Hurricane (PMH) Storm Meteorological Parameters based on NWS 23



Probable Maximum Surge and Seiche Flooding (Cont.)

PSEG developed a high resolution 2-D storm surge model (ADCIRC+SWAN) to support development of the response to RAI No. 67

- 2-D models are recognized as a more accurate storm surge modeling tool
- FEMA Region III coastal flood study



2.4.5 Probable Maximum Surge and Seiche Flooding (Cont.)

Use high resolution
ADCIRC+SWAN
Model to determine
total design basis
WSEL for the
selected PMH storm

Finite element
mesh refined at
project site



2.4.5 Probable Maximum Surge and Seiche Flooding (Cont.)

PMH Maximum Total Water Surface Elevation

- **2-D ADCIRC+SWAN Model Results:**
 - Antecedent Water Level 1.35 ft.
 - Maximum Still Water Level 20.2 ft. NAVD
 - Wave Runup 7.4 ft.
 - 10% Exceedance High Tide 4.5 ft.
 - Maximum Total Water Surface Elevation 32.1 ft. NAVD

Design Basis Flood Total WSEL is 32.1 ft. NAVD

Chapter 2 – Section 2.5.2 Vibratory Ground Motion

Vibratory Ground Motion

Objectives

- Characterize potential earthquake hazard in the site region (200 m radius)
- Characterize seismic hazard at the site
- Characterize the seismic response of the site to develop the Ground Motion Response Spectrum (GMRS)

Vibratory Ground Motion (Cont.)

Methodology

- Used CEUS SSC as defined in NUREG-2115 in its entirety including all background sources and RLMEs
- Updated earthquake catalog (1/1/2009 to 12/31/2011) to characterize potential earthquake hazard in the site region (200 m radius)
- EQ recurrence rates for two RLMEs updated:
 - New Madrid Fault System (in-cluster branch)
 - Charleston (narrow source geometry branch)
- Used EPRI (2004, 2006) Ground Motion Prediction Equations
- Followed guidance in RG 1.208 to develop the horizontal and vertical GMRS

Vibratory Ground Motion (Cont.)

Soil Hazard Results

