

Comanche Peak 2015-06 OPERATING TEST COMMENTS

Scenario 1 (event 1)

- Add examiner note that B/U htrs may be placed in manual control during power reduction (overall - add procedure step numbers for EOP's in all scenarios)

Event 8 - Expectation for CHV-1 and SIP 1 on sequencer problem. (add procedural requirement)

Event 4 - Add examiner note that FK-121 may be placed in manual.

Scenario 2 - Event 3 - Add note that DNBR TS (3.4.1) may be entered when PORV opens (but does not apply)
Verify TS 3.3.3 NOT applicable. Event 4 - TS Action should be B.1 (not A.1)

Terminate scenario when Att. 2 complete & transition out of E-2.

JPM S-1 - 2nd handout needs to be different color. Corrected Boron concentration in JPM should (R,I) match what is on the control board. NOW ALT PATH - MOVE UPGRADES HERE

JPM S-3 - Page 4: STEP 5 should be STEP 4 (R,I)

JPM S-8 - CCW pump discharge press increase to 145 psig (or) make step 3 non-critical. (R,I)

Scenario 3 - Page 11 - Add examiner note that some actions may or may not occur.

JPM S-2 - Increase validation time to 10 minutes (everybody)

JPM S-4 - 20 MIN. STEP 15 - delete last bullet. STEP 20 IS KEY 1 STEP 21 KEY 2 (everybody) - ? - Remove upgrades? - move to S3 (now R,I)

Scenario 4 - CHANGE FROM 100% to 75% initial condition. Event 5 - Add note to turn off RCP 1-02.

JPM S-6 - no comment (I&R) | JPM S-7 - Have Att. 10.7 filled out | JPM S-5 | Change validation time to 10 min. RO only | make step 23 critical - revise task STD. | ? step 20 NOT CRITICAL

P1 - Parking? → logistics - (val. 5 min.) P2 - open cabinet? (Picture?) - step 6 "from should be "to" (on line)

P3 - OK to leave on V2? step 3 → bypass source supplying load light → is it lit at beginning of JPM? (is this step really critical?)

step 7 - does bypass supplying light extinguish when inverter to load pushbutton pressed?
Change val. time to 10 MIN. STEP 4 - switch in bypass source at beginning.

S1 - get rid of lines for TS determination. S2 - need status sheet added. A - Delete last bullet on Page 5

S3 - make step 2 critical, step 9 non-critical. step 5 - "V" should be a "P" A step 6 - MD should be AF Step 4 critical, step 10 non-critical.

S4 - list of volunteers w/ information. SA5 - task std add "in accordance with approved answer key"