



CB&I  
 128 South Tryon Street  
 Charlotte, NC 28202  
 Tel: +1 704 343 7500  
 www.CBI.com

10 CFR 21.21

June 9, 2015

U.S. Nuclear Regulatory Commission  
 Attn: Document Control Desk  
 Washington, DC 20555-0001

SUBJECT: CLOSURE OF INTERIM 10 CFR PART 21 REPORTS

This letter is being provided to update the status of nine recent interim reports submitted by CB&I in accordance with 10 CFR 21.21. These interim reports were provided by letters as identified in the following list:

Report Date	NRC Log No.	Subject
11/05/2014	2014-28-05	Updated Interim Part 21 Report Regarding Deviations of Modules and Sub-Modules Supplied for AP1000 Projects
11/13/2014	2014-85-00	Interim Report Regarding Submodules CA20-03 and CA20-07A Nonconformances for V. C. Summer Unit 2 (AP1000)
03/20/2015	2014-86-01	Updated Interim Report Regarding Threaded Rebar Terminator Deviations for V.C. Summer Units 2 & 3 (AP1000)
01/08/2015	2015-02-00	Interim Report Regarding Trends in Welding and Documentation Issues for Vogtle Units 3 and 4 AP1000 Project.
01/09/2015	2015-03-00	Interim Report Regarding Submodule CA01-15 Nonconformances for V.C. Summer Unit 2 AP1000 Project
01/22/2015	2015-11-00	Interim Report Regarding Submodule CA01-13 Nonconformances for V.C. Summer Unit 2 AP1000 Project
03/27/2015	2015-22-00	Interim 10 CFR Part 21 Report Regarding Rebar Deviations For Vogtle Unit 3 AP1000 Project
03/27/2015	2015-21-00	Interim Part 21 Report Regarding CA01 Submodule Deviations For Vogtle Unit 3 AP1000 Project
03/30/2015	2015-12-01	Updated Interim Report Regarding Nonconformances on CA01 Submodules for V.C. Summer Unit 2 AP1000 Project

Evaluations of the conditions identified in these interim reports have been completed. The conditions have been determined to be not reportable in accordance with 10 CFR Part 21. Note that the conditions associated with the November 5, 2014, interim report were found to be reportable under 10 CFR 50.55(e) and were subsequently reported by the affected combined license holders.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-321-8314.

Sincerely,

Don DePierro  
 Senior Vice President

cc: Regional Administrator, USNRC, Region II

IE19  
 NIRO