



# Recent Issues Identified During NRC EQ Inspections

**Jeffrey Jacobson**

Electrical Vendor Inspection Branch  
Division of Construction Inspection  
& Operational Programs  
Office of New Reactors



# Presentation Overview

- NRC Vendor Inspection Program Overview
- Summary of Inspection Findings
- Operating Reactor EQ Trends
- EMI/RFI Testing Overview
- Other EQ Related Issues

# NRC Vendor Inspection Program

- Covers manufacturers, test facilities, suppliers, and other service suppliers for both new and operating reactors
- About 30-40 inspections conducted per year
- Provides oversight of NUPIC effectiveness
- <http://www.nrc.gov/reactors/new-reactors/oversight/quality-assurance/vendor-insp/insp-reports/2014/>

# Vendor Inspection Scope

- Inspections have become more technically focused
- Focused on documentation that demonstrates that the components or services meet technical requirements
  - Physical environment
  - Interface requirements (Input and output assumptions)
  - Assumed lifetime and failure rates

# NRC Vendor Inspection Selection Factors

- Prior NRC Inspection Experience
- NUPIC Results
- Scope of Supply
- Complexity of Product or Service
- Susceptibility to CFSI
- Operating Experience
- New or Advanced Technology
- Oversight by Other Entities
- Significance to Pending Regulatory Actions

# Summary of Inspection Findings

- Claiming similarity so that previous qualification testing can be credited when similarity has not been adequately established
  - OEM not performing reviews and/or maintaining records of design change reviews and impact on qualification
  - Claiming similarity based upon limited visual/dimensional/electrical checks as part of dedication process
    - Not verifying whether any material changes were made that could impact EQ components
    - Not verifying design changes to internal parts have not invalidated previous qualification testing

# Summary of Inspection Findings – (cont.)

- Improper lot formation when performing sample testing
  - Basis for assuming lot homogeneity not established
  - May not be applicable when purchasing components from unaudited distributors

# Summary of Inspection Findings – (continued)

- Not understanding the test requirements
  - Invoking standards without really understanding what is required
  - Not addressing deviations from guidance contained in standards
  - Using different revisions of standards that may not be equivalent to what was specified
  - Not ensuring all aspects of the standards are met (e.g. justification for biaxial vs triaxial seismic testing).



# Summary of Inspection Findings – (cont.)

- Not fully explaining (in the test report) test anomalies, deviations from test requirements, or apparent test failures
- Improperly or uncalibrated test equipment

# Operating Reactor EQ Experience Trend

- A few recent findings/events concerning the transmission of a harsh environment to areas previously classified as a mild environment
  - Steam transmission from turbine area to switchgear rooms through ventilation systems (Diablo Canyon)
  - Gaps in HELB barriers –wall to ceiling interface (Millstone 2)

# EMI/RFI Testing Overview

---

- Applicable NRC regulations:
  - Sections: 50.55a(h) and 50.49 of 10 CFR Part 50
  - Criterion III, “Design Control,” Criterion XI, “Test Control,” of Appendix B to 10 CFR Part 50

# EMI/RFI Guidance Documents

- NRC Regulatory Guide 1.180, “Guidelines for Evaluating Electromagnetic and Radio-frequency Interference in Safety-related Instrumentation and Control Systems”
- Covers
  - Design and installation practices
  - Emissions testing
  - Susceptibility testing
  - Surge withstand capability
- References to Military and IEC Standards

## EMI/RFI Guidance Documents (cont.)

- EPRI Utility Working Group Topical Report TR-102323, "Guidelines for Electromagnetic Interference Testing in Power Plants."
  - Original 1994 revision was accepted by NRC in Safety Evaluation Report
  - Revision 2 was not accepted

# EMI/RFI EQ Testing

- Purchase orders should specify the specific standards and revisions for performance of EMI/RFI testing.
- Licensees/vendors need to ensure test facilities perform an adequate evaluation if using different revisions of Military or IEC Standards

# EMI/RFI EQ Testing

- When dedicating commercial EMI/RFI testing services, vendors/licensees need to ensure that adequate critical characteristics are evaluated (e.g. that the service provider really has the technical capability to perform and control the testing as specified)

# Other EQ Related Issues

- Petition for rulemaking to expand 50.49 to include all safety-related cables and associated electrical equipment that could be submerged or subjected to moisture intrusion
  - Petition received from member of the public in June of 2012
  - Currently being evaluated by the NRC



# Questions