

NRR-PMDAPEm Resource

From: Beltz, Terry
Sent: Friday, June 26, 2015 7:57 AM
To: Michael K Scarpello
Cc: hkish@aep.com; Danielle M Burgoyne (dmburgoyne@aep.com); Dietrich, Allison; Johnson, Andrew; Pelton, David
Subject: Donald C. Cook Nuclear Plant, Unit 1 - Requests for Additional Information re: Fall 2014 Steam Generator Inspections (TAC No. MF6090)

Dear Mr. Scarpello,

By letter dated April 13, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15105A074), Indiana Michigan Power Company (the licensee) submitted information summarizing the results of the fall 2014 steam generator (SG) inspections performed at Unit 1 of the Donald C. Cook Nuclear Plant. In a letter dated November 14, 2014 (ADAMS Accession No. ML14311A318), the U.S. Nuclear Regulatory Commission (NRC) staff summarized discussions concerning the inspections that took place during the outage.

In order to complete its review, the NRC staff in the Steam Generator Tube Integrity and Chemical Engineering Branch of the Division of Engineering requests the following additional information:

1. In the April 13, 2015, letter, the licensee states that "No abnormal conditions were identified" for the plug, channel head, and steam drum and upper internals examinations during the inspection outage.

Please indicate if there was any degradation observed.

2. During the fall 2014 outage phone call between the licensee and NRC staff, the licensee indicated that a polymer object was found in a SG. The object was approximately 1.5 to 2 inches in length and 0.5 inches in diameter. The object was classified as "poly" based on its white color, and the licensee indicated that it would assess the chemical composition of the polymer object to determine if it was acceptable to leave in service.

Please discuss the results of the assessment.

Please provide a response to the above requests for additional information by July 31, 2015.

Contact either Allison Dietrich at (301) 415-2846 or me if you require a clarification call with the NRC staff and/or you determine that additional time is needed to provide a response.

Sincerely,

TERRY A. BELTZ, SENIOR PROJECT MANAGER
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738
Mail Stop: O-8D15
Phone: (301) 415-3049
Terry.Beltz@nrc.gov

Confidentiality Notice: This email message, including any attachments, contains or may contain confidential information intended only for the addressee. If you are not an intended recipient of this message, be advised that any reading, dissemination, forwarding, printing, copying or other

use of this message or its attachments is strictly prohibited. If you have received this message in error, please notify the sender immediately by reply message and delete this email message and any attachments from your system.

Hearing Identifier: NRR_PMDA
Email Number: 2197

Mail Envelope Properties (fa2103cd1adb428cbd7d77c80609d9d3)

Subject: Donald C. Cook Nuclear Plant, Unit 1 - Requests for Additional Information re:
Fall 2014 Steam Generator Inspections (TAC No. MF6090)
Sent Date: 6/26/2015 7:57:21 AM
Received Date: 6/26/2015 7:57:00 AM
From: Beltz, Terry

Created By: Terry.Beltz@nrc.gov

Recipients:

"hkish@aep.com" <hkish@aep.com>
Tracking Status: None
"Danielle M Burgoyne (dmburgoyne@aep.com)" <dmburgoyne@aep.com>
Tracking Status: None
"Dietrich, Allison" <Allison.Dietrich@nrc.gov>
Tracking Status: None
"Johnson, Andrew" <Andrew.Johnson@nrc.gov>
Tracking Status: None
"Pelton, David" <David.Pelton@nrc.gov>
Tracking Status: None
"Michael K Scarpello" <mkscarpello@aep.com>
Tracking Status: None

Post Office: HQPWMSMRS05.nrc.gov

Files	Size	Date & Time
MESSAGE	2586	6/26/2015 7:57:00 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: