

Attachment B

**to Relief Request
15-ON-002**

UT Detail Data sheets from
2EOC-26
Limited Exam Coverage



Duke Energy / Oconee Unit 2EOC26 10 Year ISI Final Report

OCONEE - UNIT 2 EXAMINATION COVERAGE FOR WELD: W02 UPPER NOZZLE BELT TO UPPER SHELL WELD Summary Number: O2.B1.11.0003 Component ID: 2-RPV-WR18 Scan Plan Drawing Number: 8082450 Sheets 7 & 10 WELD VOLUME COVERAGE OBTAINED: 79%										
Zone Coverage Obtained										
Inner 15%T:	83.2%	Outer 85%T:	77.8%	Aggregate:	78.6%					
Examination Volume Definition										
Weld Length:	252.17 in.									
Area Measurement (axial plane)				Volume Calculation						
Inner 15%T	27.83 sq. in.	Outer 85%T	157.30 sq. in.	Inner 15%T	6967.32 cu. in.	Outer 85%T	39665.58 cu. in.			
Limitations		Limits scan by:					Compensation(s)			
Outlet nozzle boss		Slight reduction in axial and circ scan direction adjacent to outlet nozzles due to nozzle boss interference with tooling configuration.					None			
Examination Coverage Calculations										
INNER 15%T										
Axial Beam Direction Coverages										
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment	
1	70L/45L	Up/Down	27.83	222.84	6157.17	6157.17	100.0%	No	None	
2	70L/45L	Up/Down	6.35	29.32	186.34	810.15	23.0%	Yes	Outlet Nozzle Boss limits scan	
Total Axial Coverage			252.17	252.17	6343.61	6967.32	91.0%			
Circumferential Beam Direction Coverages										
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment		
3	70L/45L	CW/CCW	188.00	88.6%	100.0%	88.6%	Yes	Coverage between Inlet/Outlet Nozzles		
4	70L/45L	CW/CCW	148.20	88.6%	100.0%	88.6%	Yes	Coverage between Inlet Nozzles		
Total Circ. Beam Direction Coverage:							76.3%			
Inner 15% coverage:							83.2%			
OUTER 85%T										
Axial Beam Direction Coverages										
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment	
1	45L/45S	Up/Dn	157.30	222.84	35052.73	35052.73	100.0%	No	None	
2	45L/45S	Up/Dn	36.18	29.32	1090.77	4612.04	23.0%	Yes	Outlet Nozzle Boss limits scan	
Total Axial Coverage			252.18	252.18	36113.50	39864.77	91.0%			
Circumferential Beam Direction Coverages										
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment		
3	45L/45S	CW/CCW	1054.80	60.2%	100.0%	60.2%	Yes	Coverage between Inlet/Outlet Nozzles		
4	45L/45S	CW/CCW	744.60	71.7%	100.0%	71.7%	Yes	Coverage between Inlet Nozzles		
Total Circ. Beam Direction Coverage:							64.5%			
Outer 85% coverage:							77.8%			

ATTACHMENT B
Pg 1 of 80

RPV Weld UT Data Sheet

Utility: Duke Energy Plant: Oconee Unit: 2 Outage: 02EOC26

TWS Weld Number: **W02** Component ID: **2-RPV-WR18** Summary No.: **02.B1.11.0003**

Description: **UPPER NOZZLE BELT TO UPPER SHELL WELD**

Examination Procedure: **54-ISI-801-02, Automated UT of PWR Vessel Shell Welds. (with SDCNs #30-9188581-000 & 30-9211408-000)**

Essential Equipment Description

Manufacturer	Model	V#	Serial Number	Cal. Due Date
Zetec	µTomscan	8167	53591	8/25/2014
Zetec	16-Ch P/R	7796	0371	n/a
UT Cable Type / Length:		Montrose CBL-9847 / 25'	RG-174 / 125'	No. of Connectors: 4
UT Calibration/Acquisition Software Version:		Accusonex 6.6.1	UT Data Analyst / Version:	Accusonex 3.18.1

Calibration Information

Cal. Sheet: **CDS-4** Cal Block ID: **Vessel: RPV-95001**

Equipment Settings

See the above listed Calibration Data Sheet (CDS) and applicable channel for a listing of the equipment settings used for examination.

Scan Speed: <18 IPS Sync. Interval: 0.08" Index Value: 0.5" Couplant: Water Vessel Temp: 76 F

Transducers

Transducer Manufacturer: Sigma/GEIT						UT Head: RED Head #3 Shell Scans RED TWS			
Channel	Angle	Mode	Beam Direction	Freq.	Serial Number	Model	Focal Depth	Size	Exit Point
1/7	45°	S	Axial / Circ.	1.0 MHz	8011	Sigma: 5508	Flat	1.2"x.75" (x2)	1.15"
2	46°	S	Axial / Circ.	1.0 MHz	08012	Sigma: 5508	Flat	1.2"x.75" (x2)	1.20"
3	73°	L	Axial / Circ.	1.3 MHz	0251MK	GEIT: 389-042-010	5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.00"
4	73°	L	Axial / Circ.	1.3 MHz	0251ML	GEIT: 389-042-010	5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.05"
5	47°	L	Axial / Circ.	2.7 MHz	01T3FL	GEIT: 389-038-010	4"	1.1"x.75" (x2)	1.00"
6	47°	L	Axial / Circ.	2.7 MHz	0252DK	GEIT: 389-038-010	4"	1.1"x.75" (x2)	0.90"
-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-

Examination Coverage

Ref. Scan Plan 8068245D Examination Surface: ID

Examination Coverage: **79 %**

Examination Limitation: **Clad Patch Weld Beads**

Examination Results

No Recordable Indications Recordable Indications

Evaluation Acceptable Evaluation Unacceptable

See Attached Flaw Evaluation Summary Sheet(s)



Examination Date(s): **From 11/8/2013 to 11/8/2013** Names of data analysts for this weld are included on the attached sheets:

Remarks: **See attached "Weld Acquisition Data" and "TWS Scan plan by Frame" pages for additional information.**

Reviewed by: **Mike Hacker** Level: **III** Date: **12/13/2013**

Reviewed by: _____

Reviewed by: _____



2x3 UT HEAD CONFIGURATION #3
 FOR SHELL SCANNING
 (AS VIEWED FROM BACK OF ROBOHAND COUPLING)

CHANNEL	STATUS	TRANSDUCER
1	ACTIVE	45FS
2	ACTIVE	45FS
3	ACTIVE	72FL
4	ACTIVE	70FL
5	ACTIVE	45FL
6	ACTIVE	45FL

DETECTION SCAN PARAMETERS			
SCAN	INDEX	INTERNAL	SPEED
STP	0.50' (.34)	0.08"	18 IPS MAX
SZP	0.50' (.34)	0.08"	18 IPS MAX
SZN	0.50' (.34)	0.08"	18 IPS MAX

SIZING SCAN PARAMETERS			
SCAN	INDEX	INTERNAL	SPEED
STP	0.20' (.14)	0.08"	12 IPS MAX
SZP	0.20' (.14)	0.08"	12 IPS MAX
SZN	0.20' (.14)	0.08"	12 IPS MAX

TOTAL SCAN COVERAGE OF WELD W02 IS LIMITED DUE TO INLET AND OUTLET NOZZLE OBSTRUCTIONS

TWS ID: W02
 COMPONENT ID: 2-RP4-W018
 SUMMARY NO.: 02-21.11.0003
 ASME ITEM NO.: BL11
 ASME CATEGORY: B-A
 FIGURE: MW-2500-1

CORRECTION 2 (1/10/2003)			
NO.	DESCRIPTION	DATE	BY
1	ADD WELD W02 TO UPPER SHELL	02-21.11.0003	002

10 YEAR REACTION VESSEL, SR - 2013
 WELD 02 - UPPER NOZZLE BELLY TO UPPER SHELL



REFERENCE DRAWINGS: SEE SHEET 1

pg 3 of 80
Weld B

07-ZZ-846645 D



REVISIONS SHALL BE MADE IN THE MARGIN



- STC SCAN
- SDP SCAN
- STP SCAN
- SDH SCAN
- STDH SCAN

SCAN AREA - WELDS W01, W02, W03, AND W04

51-213066-000

REVISIONS			
NO.	DATE	BY	DESCRIPTION
1	10/13/2013
10 YEAR REACTION 103201, 08 - 2013			
SCAN AREA - WELDS W01, W02, W03, AND W04			
REV	DATE	BY	DESCRIPTION
01	10/13/2013
02	10/13/2013

pg 4 of 80
check B



Duke Energy / Oconee Unit 2EOC26 10 Year ISI Final Report

OCONEE - UNIT 2 EXAMINATION COVERAGE FOR WELD: W05 LOWER SHELL TO LOWER HEAD WELD Summary Number: 02.B1.11.0004 Component ID: 2-RPV-WR34 Scan Plan Drawing Number: 80662460 Sheets 11, 12, & 14 WELD VOLUME COVERAGE OBTAINED: 43%									
Zone Coverage Obtained									
Inner 15%T:	35.0%	Outer 85%T:	44.0%	Aggregate:	42.7%				
Examination Volume Definition									
Weld Length:		538.408 in.							
Area Measurement (axial plane)					Volume Calculation				
Inner 15%T	10.54 sq. in.			Inner 15%T	5674.60 cu. in.				
Outer 85%T	44.48 sq. in.			Outer 85%T	23937.54 cu. in.				
Limitations		Limits scan by:					Compensation(s)		
Core Guide Lugs		Guide Lugs and Flow Stabilizers restrict UT head movement					None		
Flow Stabilizers		Guide Lugs and Flow Stabilizers restrict UT head movement					None		
Examination Coverage Calculations									
INNER 15%T									
Axial Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment
1	70U45L	Up/Dn	10.54	64.30	677.72	677.72	100.0%	No	Coverage between lugs and stabilizers
2	70U45L	Up/Dn	6.95	193.40	1344.13	2038.44	65.9%	Yes	Coverage above stabilizers
3	70U45L	Up/Dn	0.00	280.71	0.00	2958.64	0.0%	Yes	Obstructed
Total Axial Coverage				538.41	2021.85	6674.80	35.6%		
Circumferential Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment	
4	70U45L	CW/CCW	88.44	20.1%	43.0%	8.6%	Yes	Coverage between lugs and stabilizers	
5	70U45L	CW/CCW	345.72	44.5%	57.0%	25.4%	Yes	Coverage above stabilizers	
Total Circ. Beam Direction Coverage:							34.0%		
Inner 15% coverage:							35.0%		
OUTER 85%T									
Axial Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment
1	45U45S	Up/Dn	44.48	64.30	2858.78	2858.78	100.0%	No	Coverage between lugs and stabilizers
2	45U45S	Up/Dn	28.28	193.40	5469.35	8598.56	63.6%	Yes	Coverage above stabilizers
3	45U45S	Up/Dn	0.00	280.71	0.00	12480.20	0.0%	Yes	Obstructed
Total Axial Coverage				538.41	8328.13	23937.54	34.8%		
Circumferential Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment	
4	45U45S	CW/CCW	1482.80	31.3%	43.0%	13.5%	Yes	Coverage between lugs and stabilizers	
5	45U45S	CW/CCW	3250.44	69.5%	57.0%	39.6%	Yes	Coverage above stabilizers	
Total Circ. Beam Direction Coverage:							53.1%		
Outer 85% coverage:							44.0%		

attach B
pg 5 of 50




Figure 1-2: TWS Weld W05 – Lower shell to Lower Head Weld

View of TWS robot in vessel lower head region showing scan limitations caused by the Core Guide Lugs and Flow Stabilizers. The weld is partially covered by the Core Guide Lugs. Flow Stabilizers welded to the head below the weld and the Core Guide Lugs restrict the UT head from scanning the entire weld. These limitations occur between each lug set. Single sided scan parameters are used near obstructions to improve examination coverage. Coverage obtained on this weld is 43%.

RPV Weld UT Data Sheet

Utility: Duke Energy Plant: Oconee Unit: 2 Outage: 02EOC28

TWS Weld Number: W05 Component ID: 2-RPV-WR34 Summary No.: 02.B1.11.0004

Description: LOWER SHELL TO LOWER HEAD TORUS WELD

Examination Procedure: 54-ISI-801-02, Automated UT of PWR Vessel Shell Welds. (with SDCNs #30-9168581-000 & 30-9211408-000)

Essential Equipment Description

Manufacturer	Model	VH#	Serial Number	Cal. Due Date
Zetec	µTomoscan	8167	63591	9/25/2014
Zetec	16-Ch P/R	7798	0371	n/a
UT Cable Type / Length:		Montrose CBL-9847 / 28'	RG-174 / 125'	No. of Connectors: 4
UT Calibration/Acquisition Software Version:		Accusonax 8.6.1	UT Data Analyze / Version:	Accusonax 3.18.1

Calibration Information

Cal. Sheet: CDS-4 Cal Block ID: Vessel: RPV-95001

Equipment Settings

See the above listed Calibration Data Sheet (CDS) and applicable channel for a listing of the equipment settings used for examination.

Scan Speed: <12 IPS Sync. Interval: 0.08" Index Value: 0.2" Couplant: Water Vessel Temp: 76 F

Transducers

Transducer Manufacturer: Sigma/GEIT				UT Head: RED Head #3		Shell Scans RED TWS			
Channel	Angle	Mode	Beam Direction	Freq.	Serial Number	Model	Focal Depth	Size	Exit Point
1/7	45°	S	Axial / Circ.	1.0 MHz	8011	Sigma: 5508	Flat	1.2"x.75" (x2)	1.15"
2	48°	S	Axial / Circ.	1.0 MHz	09012	Sigma: 5508	Flat	1.2"x.75" (x2)	1.20"
3	73°	L	Axial / Circ.	1.3 MHz	0251MK	GEIT: 389-042-010	.5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.00"
4	73°	L	Axial / Circ.	1.3 MHz	0251ML	GEIT: 389-042-010	.5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.05"
5	47°	L	Axial / Circ.	2.7 MHz	01T3FL	GEIT: 389-038-010	4"	1.1"x.75" (x2)	1.00"
6	47°	L	Axial / Circ.	2.7 MHz	0252DK	GEIT: 389-038-010	4"	1.1"x.75" (x2)	0.90"
-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-

Examination Coverage

Ref. Scan Plan 8068245D Examination Surface: ID

Examination Coverage: 43 %

Examination Limitation: Core Guide Lugs and Flow Stabilizers

Examination Date(s): From 11/7/2013 to 11/8/2013

Examination Results

No Recordable Indications Recordable Indications
 Evaluation Acceptable Evaluation Unacceptable

See Attached Flaw Evaluation Summary Sheet(s)

Names of data analysts for this weld are included on the attached sheets.

Remarks: See attached "Weld Acquisition Data" and "TWS Scan plan by Frame" pages for additional information.

Reviewed by: Mike Hacker Level: III Date: 12/13/2013

Reviewed by:


Reviewed by:

51-213066-000



REVISIONS SHEETS SAME REV LEVELS
 SHEET NO. 41 OF 45

*** ALL "I" VALUES TAKEN FROM MATING SURFACE ***




TOTAL SCAN COVERAGE OF WELD WGS IS LIMITED DUE TO CORE LUG OBSTRUCTIONS AND FLOW STABILIZER REMNANTS

THIS IS: WGS
 COMPONENT ID: 2-RPV-WK34
 SUMMARY No.: 02.01.11.0004
 ASME ITEM NO.: 01.11
 ASME CATEGORY: S-A
 FIGURE: BRG-2500-1


DETECTION SCAN PARAMETERS				
SCAN	INDEX	INTERVAL	SPEED	
MTP	0.2" (0.13")	0.08"	12 IPS MAX	
MAP	0.2" (0.13")	0.08"	12 IPS MAX	
MAH	0.2" (0.13")	0.08"	12 IPS MAX	

SIZING SCAN PARAMETERS				
SCAN	INDEX	INTERVAL	SPEED	
MAP	0.2" (0.13")	0.08"	12 IPS MAX	
MAH	0.2" (0.13")	0.08"	12 IPS MAX	

SHELL WELD CHANNEL FIRING 2x3 HEAD #3		
CHANNEL	STATUS	THRESHOLDER
1	ACTIVE	49% 49%
2	ACTIVE	48% 48%
3	ACTIVE	70% 70%
4	ACTIVE	70% 70%
5	ACTIVE	48% 48%
6	ACTIVE	49% 49%



2x3 UT HEAD CONFIGURATION #3 FOR SHELL SCANNING (AS VIEWED FROM BACK OF ROBORWAD COUPLING)



SCANNING BETWEEN CORE LUGS FLOW STABILIZER REMNANT OBSTRUCTION

NOTE:
 1) DUE TO THE NUMBER OF SCANS PATCHES REQUIRED TO SCAN AROUND THE OBSTRUCTIONS FOR WELD WGS AND A MAXIMUM OF 90 PATCHES PER WELD AVAILABLE FOR USE IN THE DATABASE, THE WELD NAME PORTION OF THE SCAN IDENTIFICATION NUMBER (SN) WILL BE AS FOLLOWS:
 WGS - FOR ALL SHELL RELATED SCANS
 WSA - FOR ALL MERIDIONAL RELATED SCANS


CORRECTION SHEET				
10 YEAR REVISION NUMBER IS - 3013				
WELD WGS - LOWER SHELL TO LOWER HEAD TORUS				
(1) (2) (3) (4) (5) (6) (7) (8) (9) (10) (11) (12) (13) (14) (15) (16) (17) (18) (19) (20)				
NO.	BY	DATE	DESCRIPTION	APPROVED
1	BY SHELL	11/11/04	11 OF 18	102-80682450
2	BY SHELL	11/11/04	12 OF 18	102-80682450

REFERENCE DRAWINGS: SEE SHEET 1


08/08/80




*** ALL "Z" VALUES TAKEN FROM MATING SURFACE ***



CHANNEL	STATUS	TRANSducer
1	ACTIVE	49FS
2	ACTIVE	49FS
3	ACTIVE	70FL
4	ACTIVE	70FL
5	ACTIVE	49FL
6	ACTIVE	49FL



2x3 UT HEAD CONFIGURATION #3
 FOR SHELL SCANNING
 (AS VIEWED FROM BACK OF ROSSIGNOL COUPLING)



SCANNING BETWEEN CORE LUGS

THIS IS: WDS
 COMPONENT ID: 3-894-48134
 SUMMARY No.: 02.01.11.0004
 ASME REF. NO.: 81.11
 ASME CATEGORY: B-A
 FIGURE: WDS-2900-1

DETECTION SCAN PARAMETERS			
SCAN	INDEX	INTERVAL	SPEED
STP	0.2" (0.13")	0.08"	12 IPS MAX
STN	0.2" (0.13")	0.08"	12 IPS MAX
SZP	0.2"	0.08"	12 IPS MAX
SZN	0.2"	0.08"	12 IPS MAX


NOTE:
 1) DUE TO THE NUMBER OF SCANS PATCHES REQUIRED TO SCAN AROUND THE OBSTRUCTIONS FOR WELD WDS AND A MAXIMUM OF 60 PATCHES PER WELD AVAILABLE FOR USE IN THE DATABASE, THE WELD NAME PORTION OF THE SCAN IDENTIFICATION NUMBER (SN) WILL BE AS FOLLOWS:
 WSL - FOR ALL SHELL RELATED SCANS
 WSL - FOR ALL INTERNAL RELATED SCANS

REFERENCE DRAWINGS: SEE SHEET 1

DATE: 07/15/2013	BY: H. BULLIE	CHECKED BY: H. BULLIE	APPROVED BY: H. BULLIE
WELD WDS - LOWER SHELL TO LOWER HEAD TORUS	11 WELD PATCHES	02-8086245D	002

pg 9 of 80
 Attach B




02-806245 D



CONTAINMENT LAYOUT

NONCIRCULAR LEGEND
(USED THROUGHOUT SCAM PLANS)

W - SITE VESSEL AXIS (W, X, Y, OF Z)
OF - TWS ANGULAR LAYOUT - RIGHT HAND RULE (CCW DIRECTION)




TWS WELD WORK SCOPE

WELD ID	DESCRIPTION	REV. NUMBER	REV. DESCRIPTION
001	FLANGE TO UPPER INSIDE SHEET WELD	0001.000001	1-001-0011
002	UPPER INSIDE SHEET TO UPPER SHELL WELD	0001.010001	1-001-0012
003	UPPER SHELL TO INTERMEDIATE SHELL WELD	0001.010001	1-001-0013
004	INTERMEDIATE SHELL TO LOWER SHELL WELD	0001.010001	1-001-0014
005	LOWER SHELL TO LOWER HEAD TORUS WELD	0001.010001	1-001-0015
006	LOWER HEAD TORUS TO LOWER HEAD BOWL WELD	0001.010001	1-001-0016
007	CORE FLOOD NEEDLES TO SHELL WELD AT 180° (2 ANG)	0001.010001	1-001-0017
008	CORE FLOOD NEEDLES TO SHELL WELD AT 0° (2 ANG)	0001.010001	1-001-0018
009	SHEET NEEDLES TO SHELL WELD AT 120° (SHEET W, X)	0001.010001	1-001-0019
010	SHEET NEEDLES TO SHELL WELD AT 300° (SHEET W, X)	0001.010001	1-001-0020
011	SHEET NEEDLES TO SHELL WELD AT 30° (2 ANG)	0001.010001	1-001-0021
012	SHEET NEEDLES TO SHELL WELD AT 150° (2 ANG)	0001.010001	1-001-0022
013	SHEET NEEDLES TO SHELL WELD AT 210° (SHEET W, X)	0001.010001	1-001-0023
014	CORE FLOOD NEEDLES TO SHELL WELD AT 180° (2 ANG)	0001.010001	1-001-0024
015	CORE FLOOD NEEDLES TO SHELL WELD AT 0° (2 ANG)	0001.010001	1-001-0025
016	SHEET NEEDLES TO SHELL WELD AT 120° (SHEET W, X)	0001.010001	1-001-0026
017	SHEET NEEDLES TO SHELL WELD AT 300° (SHEET W, X)	0001.010001	1-001-0027
018	SHEET NEEDLES TO SHELL WELD AT 30° (2 ANG)	0001.010001	1-001-0028
019	SHEET NEEDLES TO SHELL WELD AT 150° (2 ANG)	0001.010001	1-001-0029
020	SHEET NEEDLES TO SHELL WELD AT 210° (SHEET W, X)	0001.010001	1-001-0030

08/09/80
attach B

APPLIES TO:
W05
AND



- | | | | |
|--|----------|--|----------|
| | SZP SCAN | | STP SCAN |
| | SZH SCAN | | STH SCAN |
| | WAP SCAN | | WEP SCAN |
| | WAV SCAN | | WTH SCAN |

INCORE 37
INCORE 36
INCORE 35
INCORE 34
INCORE 33
INCORE 32
INCORE 31
INCORE 30
INCORE 29
INCORE 28
INCORE 52
INCORE 51
INCORE 23
INCORE 22
INCORE 21
INCORE 50
INCORE 49
INCORE 48
INCORE 47
INCORE 46
INCORE 45
INCORE 44
INCORE 43
INCORE 42
INCORE 41
INCORE 40
INCORE 38
INCORE 37

SCAN AREA - WELDS W05 & W06

PS 11/1/80
Welds B

*APPLIES TO
W05 AND
W06*



Duke Energy / Oconee Unit 2 EOC26 10 Year ISI Final Report

OCONEE - UNIT 2									
EXAMINATION COVERAGE FOR WELD: W06									
LOWER HEAD TORUS TO LOWER HEAD DOME WELD									
Summary Number: 02.B1.21.0001									
Component ID: 2-RPV-WR35									
Scan Plan Drawing Number: 8088245D Sheets 13 & 14									
WELD VOLUME COVERAGE OBTAINED: 36%									
Zone Coverage Obtained									
Inner 15%T:	32.7%	Outer 85%T:	37.1%	Aggregate:	36.4%				
Examination Volume Definition									
Weld Length: 449.248 in.									
Area Measurement (axial plane)									
Inner 15%T	5.77 sq. in.			Volume Calculation			2592.16 cu. in.		
Outer 85%T	33.04 sq. in.			Inner 15%T			14843.15 cu. in.		
Outer 85%T				Outer 85%T					
Limitations			Limits scan by:				Compensation(s)		
Incore instrumentation Nozzles			Incore Nozzles restrict UT head movement				None		
Flow Stabilizers			Flow Stabilizers restrict UT head movement				None		
Examination Coverage Calculations									
INNER 15%T									
Axial Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment
1	70U45L	Up/Dn	5.77	160.61	926.70	926.70	100.0%	No	Coverage between nozzles and stabilizers
2	70U45L	Up/Dn	3.28	34.44	112.97	198.73	56.8%	Yes	Coverage above nozzles 45 and 52
3	70U45L	Up/Dn	1.07	11.23	12.02	64.80	18.5%	Yes	Coverage above nozzle 48
4	70U45L	Up/Dn	0.00	242.97	0.00	1401.93	0.0%	Yes	Obstructed
Total Axial Coverage				449.25	1051.69	2592.16	40.6%		
Circumferential Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment	
5	70U45L	CW/CCW	90.72	20.3%	100.0%	20.3%	Yes	Coverage between nozzles and stabilizers	
6	70U45L	CW/CCW	20.18	4.5%	80.0%	3.6%	Yes	Coverage above nozzles 45 and 52	
7	70U45L	CW/CCW	10.08	2.3%	42.0%	0.9%	Yes	Coverage above nozzle 48	
Total Circ. Beam Direction Coverage:						24.9%			
Inner 15% coverage:							32.7%		
OUTER 85%T									
Axial Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Length Examined (in.)	Volume Examined (cu. in.)	Volume Required (cu. in.)	Percent Examined	Limited	Comment
1	45U45S	Up/Dn	33.04	160.61	5306.42	5306.42	100.0%	No	Coverage between nozzles and stabilizers
2	45U46S	Up/Dn	28.98	34.44	997.45	1137.97	87.7%	Yes	Coverage above nozzles 45 and 52
3	45U45S	Up/Dn	17.91	11.23	201.15	371.08	54.2%	Yes	Coverage above nozzle 48
4	45U45S	Up/Dn	0.00	242.97	0.00	8027.87	0.0%	Yes	Obstructed
Total Axial Coverage				449.25	6505.03	14843.15	43.8%		
Circumferential Beam Direction Coverages									
Entry #	Exam. Angle (deg.)	Beam Direction	Area Examined (sq. in.)	Circ Extent Examined (%)	Axial Extent Examined (%)	Percent Examined	Limited	Comment	
5	45U45S	CW/CCW	638.28	24.8%	100.0%	24.8%	Yes	Coverage between nozzles and stabilizers	
6	45U45S	CW/CCW	141.84	5.5%	81.0%	4.5%	Yes	Coverage above nozzles 45 and 52	
7	45U45S	CW/CCW	70.82	2.8%	39.0%	1.1%	Yes	Coverage above nozzle 48	
Total Circ. Beam Direction Coverage:						30.3%			
Outer 85% coverage:							37.1%		

attach B
pg 12 of 80




Figure 1-3: TWS Weld W06 – Lower Shell to Lower Head Weld

View of TWS robot in vessel lower head region showing scan limitations caused by the Incore Nozzles and Flow Stabilizers. The weld is partially covered by the Flow Stabilizers. Flow Stabilizers welded to the head above the weld and the Incore Nozzles restrict the UT head from scanning the entire weld. The Core Guide Lugs also provide some interference with robot movement. These limitations occur between each Flow Stabilizer/Core Guide Lug set. Single-sided scan parameters are used near obstructions to improve examination coverage. Coverage obtained on this weld is 36%.

RPV Weld UT Data Sheet

Utility: Duke Energy Plant: Oconee Unit: 2 Outage: 02EOC26

TWS Weld Number: W06 Component ID: 2-RPV-WR35 Summary No.: 02.B1.21.0001

Description: LOWER HEAD TORUS TO LOWER HEAD DOME WELD

Examination Procedure: 54-ISI-801-02, Automated UT of PWR Vessel Shell Welds. (with SDCNs #30-9188581-500 & 30-9211408-000)

Essential Equipment Description

Manufacturer	Model	VH#	Serial Number	Cal. Due Date
Zetec	µTomoscan	8187	83591	9/25/2014
Zetec	16-Ch P/R	7796	0371	n/a
UT Cable Type / Length:	Montrose CBL-9847 / 28'	RG-174 / 128'	No. of Connectors: 4	
UT Calibration/Acquisition Software Version:	Accusonax 8.8.1	UT Data Analysis / Version:	Accusonax	3.18.1

Calibration Information

Cal. Sheet: CDS-4 Cal Block ID: Vessel: RPV-95001

Equipment Settings

See the above listed Calibration Data Sheet (CDS) and applicable channel for a listing of the equipment settings used for examination.

Scan Speed: <12 IPS (MTP/ MTN) Sync. Interval: 0.08" Index Value: 0.2" Couplant: Water Vessel Temp: 76 F

Scan Speed: <18 IPS (MAP/ MAN) Sync. Interval: 0.08" Index Value: 0.5"

Transducers

Transducer Manufacturer:		Sigma/GEIT		UT Head:		RED Head #3	Shell Scars RED TWS		
Channel	Angle	Mode	Beam Direction	Freq.	Serial Number	Model	Focal Depth	Size	Exit Point
1/7	45°	S	Axial / Circ.	1.0 MHz	8011	Sigma: 5508	Flat	1.2"x.75" (x2)	1.15"
2	48°	S	Axial / Circ.	1.0 MHz	08012	Sigma: 5508	Flat	1.2"x.75" (x2)	1.20"
3	73°	L	Axial / Circ.	1.3 MHz	0251MK	GEIT: 389-042-010	.5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.00"
4	73°	L	Axial / Circ.	1.3 MHz	0251ML	GEIT: 389-042-010	.5"	1.5"x.375" (x2), 1.5"x.75" (x1)	1.05"
5	47°	L	Axial / Circ.	2.7 MHz	01T3FL	GEIT: 389-038-010	4"	1.1"x.75" (x2)	1.00"
6	47°	L	Axial / Circ.	2.7 MHz	0252DK	GEIT: 389-038-010	4"	1.1"x.75" (x2)	0.90"
-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-

Examination Coverage

Ref. Scan Plan 8068245D Examination Surface: ID

Examination Coverage: 36 %

Examination Limitation: Incore Nozzles and Flow Stabilizers

Examination Date(s): 11/6/2013

Examination Results

No Recordable Indications Recordable Indications

Evaluation Acceptable Evaluation Unacceptable

See Attached Flaw Evaluation Summary Sheet(s)

Names of data analysis for this weld are included on the attached sheets.

Remarks: See attached "Weld Acquisition Data" and "TWS Scan plan by Frame" pages for additional information.

Reviewed by: Mike Hacker Level: III Date: 12/13/2013


Reviewed by:

Reviewed by:

D 59Z9908-20


REVISIONS ALL SHEETS ARE REV LEVEL

--- ALL "Z" VALUES GIVEN FROM MATING SURFACE ---



SHELL WELD CHANNEL FIRING
2x3 HEAD #3

CHANNEL	STATUS	TRANSDUCER
1	ACTIVE	45S
2	ACTIVE	45S
3	ACTIVE	70L
4	ACTIVE	72S
5	ACTIVE	45L
6	ACTIVE	45L



2x3 UT HEAD CONFIGURATION #3
FOR SHELL SCANNING
(AS VIEWED FROM BACK OF ROSBANG COUPLING)

TOTAL SCAN COVERAGE OF WELD WOB IS LIMITED DUE TO INCORE INSTRUMENTATION NOZZLES AND FLOW STABILIZER REMNANTS

MTH USED ON INCORE OBSTRUCTED SCANS WHERE APPLICABLE

DETECTION SCAN PARAMETERS

SCAN	INDEX	INTERVAL	SPEED
MTP	0.2" (0.13")	0.08"	12 IPS MAX
MTH	0.2" (0.13")	0.08"	12 IPS MAX
MAP	0.5" (0.33")	0.08"	18 IPS MAX
MAN	0.5" (0.33")	0.08"	18 IPS MAX
*MAP	0.2" (0.13")	0.08"	12 IPS MAX
*MAN	0.2" (0.13")	0.08"	12 IPS MAX

TWS ID: W06
COMPONENT ID: 2-09V-0035
SUMMARY No.: 02.01.21.0001
ASME ITEM NO.: 01.21
ASME CATEGORY: 3-A
FIGURE: MW-2500-3

SIZING SCAN PARAMETERS

SCAN	INDEX	INTERVAL	SPEED
MAP	0.2" (0.13")	0.08"	12 IPS MAX
MAN	0.2" (0.13")	0.08"	12 IPS MAX

* MAP & MAN SCANS AT 0.2" INDEX USED OVER INCORE NOZZLES 45, 46, AND 52 ONLY

pg 15 of 80
Stack B

51-8213066-000

REFERENCE DRAWINGS: SEE SHEET 1

SCHEMATIC 1 (2000283)
10 YEAR REACTOR VESSEL (R) - 2013
WELD WOB - LOWER HEAD TOWERS TO LOWER HEAD DOME
LIMITED COVERAGE

DESIGNED BY	DESIGNED BY	DESIGNED BY	DESIGNED BY
CHECKED BY	CHECKED BY	CHECKED BY	CHECKED BY

02-0068245D 002



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: O2.B3.110.0009
 Workscope: ISI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 2025416

Outage No.: O2-26
 Report No.: UT-13-1169
 Page: 1 of 1

Code: 1998/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN2-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 2-PZR-WP26-1 Size/Length: N/A Thickness/Diameter: CS / 6.187 / N/A
 Limitations: Yes - See attached sheet Start Time: 1006 Finish Time: 1134

Instrument Settings
 Serial No.: 13G00172
 Manufacturer: GE
 Model: USN 60 SW
 Delay: 1.2778 Range: 10"
 M/I Cal/Vel: .2319 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 9.5 Circ. Gain (dB): N/A
1 Screen Div. = 1.0 in. of Depth
 Linearity Report No.: L-13-271

Search Unit
 Serial No.: 00607N
 Manufacturer: KBA
 Size: .75" Shape: Round
 Freq.: 2.25 MHz Style: Gamma
 Exam Angle: 0 # of Elements: Single
 Mode: Long
 Measured Angle: N/A
 Wedge Style: N/A
Search Unit Cable
 Type: RG - 174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1057	10/24/2013
Inter. Cal.		
Inter. Cal.	1128	10/24/2013
Inter. Cal.		
Final Cal.	1215	10/24/2013

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
1/4T SDH	80	1.5	1.51"
1/2T SDH	45	3.3	3.29"
3/4T SDH	22	5.0	5.04"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
1.3	1" Side	80	1.0	1.00"

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: Flat
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40198
 Comp. Temp. 90 Temp. Tool: MCNDE40198
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Reference Block
 Serial No.: 97-5588
 Type: ROMPAS

Comments: Reference Report # UT-13-1170 for additional information.

Examiner	Level	II-N	Signature	Date	Reviewer	Signature	Date
Tucker, David K.			<i>David K. Tucker</i>	10/24/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	10-30-13
Examiner	Level	II-N	Signature	Date	Site Review	Signature	Date
Bull, W. Keith			<i>W. Keith Bull</i>	10/24/2013			
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/5/13

ATTACHMENT B
16 of 80

DUKE ENERGY COMPANY

ISI LIMITATION REPORT

Summary #: <u>2-PZR-WP26-1</u> Component ID <u>O2.B3.110.0009</u>			remarks: Due to nozzle configuration
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>Toe</u> to <u>Beyond</u> ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70</u> FROM <u>0</u> DEG to <u>360</u> DEG			
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG			UT-13-1170 Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Steven Dean</u> Level: <u>II</u> Date: <u>10/24/13</u>		Sheet <u>5</u>	
Reviewed By: <u>Rod Sheffield</u> Date: <u>10.30.13</u>		Authorized Inspector: <u>MARK E. ZURBUCH</u> Date: <u>11/5/13</u>	

ATTACHMENT 13
 14 of 80

PZR Sampling Nozzle to Shell % of Coverage

Item No. : 02.B3.110.0009

Weld No. : WP26-1

Weld Coverage

<u>Scan</u>	<u>Angle</u>	<u>% Coverage Obtained</u>	
S1	45° & 60°	39.52	+
S1	60° & 70°	9.48	=
S1	Aggregate	49	
S2	45° & 60°	0	
CW	45° & 60°	0	
CCW	45° & 60°	0	
	Total	49	
	49	÷ 4 =	<u>12.3</u> % Coverage

Base Material Coverage

S1	45° & 60°	43.21%	
S1	60° & 70°	18.87	
CW & CCW	on taper	9.23	
CW & CCW	on flat	<u>27.26</u>	
	Total	<u>98.6%</u>	
	98.60%	÷ 2 =	<u>49.3</u> % Coverage

<u>0° Scan Coverage</u>		21.73 + 7.39	
	=	<u>29.1</u>	% Coverage

Aggregate Coverage = Weld + Base Material + 0° ÷ 3			
	=	<u>30.2</u>	<u>% Coverage</u>

Inspector / Date : Rod Sheffield / 10-30-13

Page 6 of 16


ATTACHMENT B

18 of 80


Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-1

 Total Weld Metal Examined with at least 2 angles from one direction.
A combination of 45° and 60° angles were used to obtain coverage.

% Examined from Surface 1 = $7.015 / 11.413 \times 100 = 61.46\%$
64.3% of length x 61.46% of volume = 39.52% of total S1 weld coverage
% Examined from Surface 2, CW, and CCW = 0%
Untapered surface was present for 18" of 28" of total weld circumference
 $18 / 28 \times 100 = 64.3\%$



ATTACHMENT B
19 A80

Inspector: *[Signature]* 10/29/13

Rod Sheffield
10-30-13

7.015 sq. in.

7 of 16

Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-1



Base Metal Examined with 60° and 45° angles.

% Examined 60° and 45° = $19.03 / 44.87 \times 100 = 42.4\%$

64.3% of length x 42.4% of volume = 27.26% of total CW/CCW coverage

Untapered surface was present for 18" of 28" of total weld circumference

$18 / 28 \times 100 = 64.3\%$

60°, NS and 45° Circ. scan

Nozzle Surface 2

19.03 sq. in.

Shell Surface 1

21 of 80

ATTACHMENT B

Inspector: *[Signature]* 10/29/13

Rod Sheffield 10-30-13

Item No. : 02.B3.110.009

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-1

 Base Metal Examined with 60° and 45° angles.

% Examined with 0° = $19.03 / 56.283 \times 100 = 33.8\%$

64.3% of length x 33.8% of volume = 21.73% of total 0° coverage

Untapered surface was present for 18" of 28" of total weld circumference

$18 / 28 \times 100 = 64.3\%$

Nozzle
Surface 2

0° scan

19.03 sq. in.

Shell
Surface 1

ATTACHMENT B
22 of 80


Inspector:  10/29/13

Rod Sheffield 10-30-13

Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-1


 A combination of 60° & 70° angles were used to obtain a maximum amount of coverage on tapered surface.

% Examined 60° and 70° = $3.03 / 11.413 \times 100 = 26.55\%$

35.7% of length x 26.55% of volume = 9.48% of total S1 weld coverage.

Tapered surface was present for 10" of 28" of total weld circumference


$10 / 28 \times 100 = 35.7\%$



Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-1


 A combination of 60° & 70° angles were used to obtain a maximum amount of coverage on tapered surface.

% Examined 60° and 70° = $24.22 / 45.83 \times 100 = 52.85\%$

35.7% of length x 52.85% of volume = 18.87% of total S1 coverage.

Tapered surface was present for 10" of 28" of total weld circumference

$10 / 28 \times 100 = 35.7\%$




ATTACHMENT B
79.9780

Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-1

 % Examined 45° and 60° = $11.85 / 45.83 \times 100 = 25.86\%$
35.7% of length x 25.86% of volume = 9.23% of total CW/ CCW coverage

Tapered surface was present for 10" of 28" of total weld circumference
 $10 / 28 \times 100 = 35.7\%$

Nozzle
Surface 2

60°, NS, and 45° Circ. scan

Shell
Surface 1


11.85 sq. in.

25 of 80
ATTACHMENT B

Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-1

 % Examined with 0° = $11.85 / 57.24 \times 100 = 20.7\%$
35.7% of length x 20.7% of volume = 7.39 % of total 0° coverage
Tapered surface was present for 10" of 28" of total weld circumference
 $10 / 28 \times 100 = 35.7\%$

Nozzle
Surface 2


0° scan

Shell
Surface 1

11.85 sq. in.

26 of 80
ATTACHMENT 3

Page 4 of 16

Inspector:  10/24/13

Rob Sheffield 10-30-13

14 of 16

Item No. : 02.B3.110.0009

Pressurizer Sampling Nozzle to Shell


Weld No. : 2-PZR-WP26-1

*Scan 45°, 60° & 60°NS axially toward nozzle (ref. surface distance below for exam volume coverage)

*Scan 45° CW & CCW

*See NDE-820 Fig. 7 Category B-D for exam volume.

Nozzle
Surface 2



Item No. : 02.B3.110.0009


Pressurizer Sampling Nozzle to Shell Htr. Shell (Heater Bundle Section)

Weld No. : 2-PZR-WP26-1

*Scan 60°, 70° & 60°NS axially toward nozzle (ref. surface distance below for exam volume coverage)

*Scan 45°, 60°, 60°NS CW & CCW

*See NDE-820 Fig. 7 Category B-D for exam volume.



28780
ATTACHMENT B

Level III Reviewer / Date : Rod Sheffield / 10-16-13

Page 16 of 16



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: O2.B3.110.0010
 Workscope: ISI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 2025416

Outage No.: O2-26
 Report No.: UT-13-1171
 Page: 1 of 1

Code: 1998/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN2-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 2-PZR-WP26-2 Size/Length: N/A Thickness/Diameter: CS / 6.187 / NA
 Limitations: Yes - See attached sheet Start Time: 1050 Finish Time: 1200

Instrument Settings
 Serial No.: 13G00172
 Manufacturer: GE
 Model: USN 60 SW
 Delay: 1.2778 Range: 10"
 M'tl Cal/Vel: .2319 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 9.5 Circ. Gain (dB): N/A
1 Screen Div. = 1.0 in. of Depth
 Linearity Report No.: L-13-271

Search Unit
 Serial No.: 00607N
 Manufacturer: KBA
 Size: .75" Shape: Round
 Freq.: 2.25 MHz Style: Gamma
 Exam Angle: 0 # of Elements: Single
 Mode: Long
 Measured Angle: N/A
 Wedge Style: N/A
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1057	10/24/2013
Inter. Cal.		
Inter. Cal.	1138	10/24/2013
Inter. Cal.		
Final Cal.	1215	10/24/2013

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
1/4T SDH	80	1.5	1.51"
1/2T SDH	45	3.3	3.29"
3/4T SDH	22	5.0	5.04"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
1.3	1" Side	80	1.0	1.00"

Calibration Block
 Cal. Block No.: 40338
 Thickness 7 Dia.: Flat
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40198
 Comp. Temp. 90 Temp. Tool: MCNDE40198
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Reference Block
 Serial No.: 97-5588
 Type: ROMPAS

Comments: Reference Report # UT-13-1172 for additional information.

ATTACHMENT 29 of 80

Examiner	Level	II-N	Signature	Date	10/24/2013	Reviewer	Signature	Date	10-31-13
Tucker, David K.			<i>[Signature]</i>			ROD STEFFIELD	<i>[Signature]</i>		
Examiner	Level	II-N	Signature	Date	10/24/2013	Site Review	Signature	Date	
Bull, W. Keith			<i>[Signature]</i>				<i>[Signature]</i>		
Other	Level	N/A	Signature	Date		ANII Review	Signature	Date	
N/A						MARK E. ZURBUCH	<i>[Signature]</i>		11/5/13

PZR Sampling Nozzle to Shell % of Coverage

Item No. : 02.B3.110.0010

Weld No. : WP26-2

Weld Coverage

<u>Scan</u>	<u>Angle</u>	<u>% Coverage Obtained</u>
S1	45° & 60°	39.52 +
S1	60° & 70°	9.48 =
S1	Aggregate	49
S2	45° & 60°	0
CW	45° & 60°	0
CCW	45° & 60°	<u>0</u>
	Total	49

49 + 4 = 12.3 % Coverage

Base Material Coverage

S1	45° & 60°	43.21%
S1	60° & 70°	18.87
CW & CCW	on taper	9.23
CW & CCW	on flat	<u>27.26</u>
	Total	<u>98.6%</u>

98.60% ÷ 2 = 49.3 % Coverage

0° Scan Coverage = 21.73 + 7.39
= 29.1 % Coverage

Aggregate Coverage = Weld + Base Material + 0° ÷ 3

= 30.2 % Coverage

Inspector / Date : Rad Sheffield / 10-31-13

Page 6 of 16

ATTACHMENT B

31 of 80

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-2



Total Base Metal Examined with at least 2 angles from one direction.

A combination of 45° and 60° angles were used to obtain coverage.

$$\% \text{ Examined} = (24.45 + 5.705) / 44.87 \times 100 = 67.2\%$$

$$64.3\% \text{ of length} \times 67.2\% \text{ of volume} = 43.21\% \text{ of total S1 base metal coverage.}$$

Untapered surface was present for 18" of 28" of total weld circumference

$$18 / 28 \times 100 = 64.3\%$$

Nozzle
Surface 2

60°, NS

45°

24.45 sq. in.

Shell
Surface 1

5.705 sq. in.

Inspector: *[Signature]* 10/29/13

Rod Sheffield 10-31-13

529/80
ATTACHMENT B

8 of 11

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-2



Base Metal Examined with 60° and 45° angles.

% Examined 60° and 45° = $19.03 / 44.87 \times 100 = 42.4\%$

64.3% of length x 42.4% of volume = 27.26% of total CW/CCW coverage

Untapered surface was present for 18" of 28" of total weld circumference

$18 / 28 \times 100 = 64.3\%$

Nozzle
Surface 2

60°, NS and 45° Circ. scan

19.03 sq. in.

Shell
Surface 1

Inspector: *[Signature]* 10/29/13

Rod Sheffield 10-31-13

33.98
B
10/29/13

a c 11

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-2



Base Metal Examined with 60° and 45° angles.

% Examined with 0° = $19.03 / 56.283 \times 100 = 33.8\%$

64.3% of length x 33.8% of volume = 21.73% of total 0° coverage

Untapered surface was present for 18" of 28" of total weld circumference

$18 / 28 \times 100 = 64.3\%$

Nozzle
Surface 2

0° scan

19.03 sq. in.

Shell
Surface 1

ATTACHMENT B
34 of 80

Inspector: *[Signature]* 10/29/13


Rod Sheffield 10-31-13

10 of 16

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-2

 A combination of 60° & 70° angles were used to obtain a maximum amount of coverage on tapered surface.

% Examined 60° and 70° = $3.03 / 11.413 \times 100 = 26.55\%$.

35.7% of length x 26.55% of volume = 9.48% of total S1 weld coverage.

Tapered surface was present for 10" of 28" of total weld circumference

$10 / 28 \times 100 = 35.7\%$

60°, NS

70°

Nozzle
Surface 2

70°

60°,
NS

Shell
Surface 1


3.03 sq. in.

35 of 80
ATTACHMENT
B

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-2

 A combination of 60° & 70° angles were used to obtain a maximum amount of coverage on tapered surface.

% Examined 60° and 70° = $24.22 / 45.83 \times 100 = 52.85\%$

35.7% of length x 52.85% of volume = 18.87% of total SI coverage.

Tapered surface was present for 10" of 28" of total weld circumference

$10 / 28 \times 100 = 35.7\%$

Nozzle Surface 2

60°, NS

70°

70°

60°, NS

Shell Surface 1

22.62 sq. in.

1.60 sq. in.


3/2 of 80
ATTACHMENT

ATTACHMENT

Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-2

 % Examined 45° and 60° = $11.85 / 45.83 \times 100 = 25.86\%$
35.7% of length x 25.86% of volume = 9.23% of total CW/ CCW coverage

Tapered surface was present for 10" of 28" of total weld circumference
 $10 / 28 \times 100 = 35.7\%$


Nozzle
Surface 2

60°, NS, and 45° Circ. scan

Shell
Surface 1

02.10.13
ATTACHMENT B

11.85 sq. in.


Page 3 of 16 Inspector:  10/29/13

Rod Sheffield 10-31-13

Item No. : 02.B3.110.0010


Pressurizer Sampling Nozzle to Shell Htr. Shell

Weld No. : WP26-2

 % Examined with 0° = $11.85 / 57.24 \times 100 = 20.7\%$
35.7% of length x 20.7% of volume = 7.39 % of total 0° coverage.

Tapered surface was present for 10" of 28" of total weld circumference
 $10 / 28 \times 100 = 35.7\%$

Nozzle
Surface 2



Item No. : 02.B3.110.0010

Pressurizer Sampling Nozzle to Shell


Weld No. : 2-PZR-WP26-2

*Scan 45°, 60° & 60°NS axially toward nozzle (ref. surface distance below for exam volume coverage)

*Scan 45° CW & CCW

*See NDE-820 Fig. 7 Category B-D for exam volume.

Nozzle
Surface 2



Level III Reviewer / Date : Red Sheffield / 10-16-13

Inspector: [Signature] 10/29/13

Item No. : 02.B3.110.0010


Pressurizer Sampling Nozzle to Shell Htr. Shell (Heater Bundle Section)

Weld No. : 2-PZR-WP26-2

*Scan 60°, 70° & 60°NS axially toward nozzle (ref. surface distance below for exam volume coverage)

*Scan 45°, 60°, 60°NS CW & CCW

*See NDE-820 Fig. 7 Category B-D for exam volume.



ATTACHMENT B
4 of 80

Level III Reviewer / Date : Rob Sheffield / 10-16-13

Page 16 of 16



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: 02.B3.110.0011
 Workscope: ISI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 2025416

Outage No.: 02-26
 Report No.: UT-13-1174
 Page: 1 of 1

Code: 1998/2000A Cal./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN2-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 2-PZR-WP26-3 Size/Length: N/A Thickness/Diameter: CS / 6.187 / NA
 Limitations: Yes - See attached sheet Start Time: 0920 Finish Time: 1033

Instrument Settings
 Serial No.: 13G00172 Manufacturer: GE Model: USN 60 SW
 Delay: 1.2778 Range: 10" M'l Cal/Vel: .2319 Pulser: Square Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz Filter: Fixed Mode: PE Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 9.5 Circ. Gain (dB): N/A 1 Screen Div. = 1.0 In. of Depth
 Linearity Report No.: L-13-271

Search Unit
 Serial No.: 00607N Manufacturer: KBA Size: .75" Shape: Round
 Freq.: 2.25 MHz Style: Gamma Exam Angle: 0 # of Elements: Single
 Mode: Long Measured Angle: N/A Wedge Style: N/A

Search Unit Cable
 Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0920	10/23/2013
Inter. Cal.		
Inter. Cal.	1012	10/23/2013
Inter. Cal.		
Final Cal.	1045	10/23/2013

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
1/4T SDH	80	1.5	1.51"
1/2T SDH	45	3.3	3.29"
3/4T SDH	22	5.0	5.04"

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A			

Calibration Block
 Cal. Block No. 40338 Thickness 7 Dia.: Flat CW CCW Scan dB: N/A
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40198 Exam Surface: O.D.
 Comp. Temp. 90 Temp. Tool: MCNDE40198 Surface Condition: Machined

Scan Coverage
 Upstream Downstream Scan dB: 23.5
 Surface Condition: Machined

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Reference Block
 Serial No.: 97-5588
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
1.3	1" Side	80	1.0	1.00"

Comments: Reference Report # UT-13-1175 for additional information.

Examiner	Level	II-N	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	Level	II-N	<i>[Signature]</i>	10/23/2013	ROD SHEFFIELD	<i>[Signature]</i>	10-30-13
Bull, W. Keith	Level	II-N	<i>[Signature]</i>	10/23/2013	Site Review	<i>[Signature]</i>	
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					MARK E. ZURBUCH	<i>[Signature]</i>	11/5/13

ATTACHMENT 41 of 80

PZR Sampling Nozzle to Shell % of Coverage

Item No. : 02.B3.110.0011

Weld No. : WP26-3

Weld Coverage

<u>Scan</u>	<u>Angle</u>	<u>% Coverage Obtained</u>	
S1	45° & 60°	61.46	
S2	45° & 60°	0	
CW	45° & 60°	0	
CCW	45° & 60°	0	
	Total	61.46	
	61.46 ÷ 4 =	<u>15.4</u>	% Coverage

Base Material Coverage

S1	45° & 60°	67.2	
CW & CCW	45° & 60°	<u>42.4</u>	
	Total	109.6	
	109.6 ÷ 2 =	<u>54.8</u>	% Coverage
<u>0° Scan Coverage</u>	=	<u>33.8</u>	% Coverage

Aggregate Coverage = Weld + Base Material + 0° ÷ 3

= 34.7 % Coverage

Inspector / Date : Bob Sheffield / 10-30-13

Page 5 of 10


ATTACHMENT B

43.780

Item No. : 03.B3.110.0011

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-3

 Total Weld Metal Examined with at least 2 angles from one direction.

A combination of 45° and 60° angles were used to obtain coverage.

% Examined from Surface 1 = $7.015 / 11.413 \times 100 = 61.46\%$

% Examined from Surface 2, CW, and CCW = 0%

Nozzle
Surface 2

60°, NS

45°


Shell
Surface 1

7.015 sq. in.

Inspector:  10/29/13

Red Sheffield
10-30-13

44 of 80
ATTACHMENT B



Item No. : 02.B3.110.0011


Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-3



Total Base Metal Examined with at least 2 angles from one direction.
A combination of 45° and 60° angles were used to obtain coverage.

$$\% \text{ Examined} = (24.45 + 5.705) / 44.87 \times 100 = 67.2\%$$



Inspector: *[Signature]* 10/29/13


Rod Sheffield 10-30-13

5.705 sq. in.

Item No. : 03.B3.110.0011

Weld No. : WP26-3

Pressurizer Sampling Nozzle to Shell

 Base Metal Examined with 60° and 45° angles.

% Examined 60° and 45° = $19.03 / 44.87 \times 100 = 42.4\%$

Nozzle
Surface 2

60°, NS, and 45° Circ. scan


19.03 sq. in.

Shell
Surface 1

46 of 288
ATTACHMENT B

Inspector:  10/29/17

Rod Sheffield 10-30-13



Item No. : 03.B3.110.0011


Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-3



Base and Weld Metal Examined with 0° angle.

$$\% \text{ Examined } 0^\circ = 19.03 / 56.283 \times 100 = 33.8\%$$



Inspector: *[Signature]* 10/29/17

Rod Sifford 10-30-13

Item No. : 02.B3.110.0011

Pressurizer Sampling Nozzle to Shell

Weld No. : 2-PZR-WP26-3

*Scan 45°, 60° & 60°NS axially toward nozzle (ref. surface distance below for exam volume coverage)

*Scan 45° CW & CCW

*See NDE-820 Fig. 7 Category B-D for exam volume.

Nozzle
Surface 2

Sur. Distance from Nozzle= 16.88"

Sur. Distance from Nozzle= 12.41"

60°, 60° NS and 45° Circ.

Sur. Distance= 10.71"

Sur. Distance= 6.187"

Sur. Distance from Nozzle= 8.9"

60°

45°

60° NS

60° & 60°NS

45°

ATTACHMENT
45 of 80

Shell
Surface 1

Level III Reviewer / Date: Bob Sheffield / 10-16-13

Inspector: [Signature] 10/29/13

Page 10 of 40