



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: 02.B3.150.0003
 Workscope: ISI

Procedure: NDE-3630
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: 02-26
 Report No.: UT-13-1186
 Page: 1 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____
 Drawing No.: O-ISIS4-101A-2.1 Description: Nozzle to Channel Body
 System ID: 51A
 Component ID: 2-LDCB-IN-WJ33V Size/Length: N/A Thickness/Diameter: SS / .875 / NA
 Limitations: Yes - See attached sheets Start Time: 1140 Finish Time: 1207

Instrument Settings		Search Unit		Cal. Checks			Axial Orientated Search Unit				
Serial No.:	<u>023DP0</u>	Serial No.:	<u>SB0492</u>	Initial Cal.	<u>1009</u>	<u>11/3/2013</u>	Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
Manufacturer:	<u>GE</u>	Manufacturer:	<u>GE</u>	Inter. Cal.			ID Notch #2	<u>80</u>	<u>4.9</u>	<u>1.225"</u>	
Model:	<u>USN 60 SW</u>	Size:	<u>.25</u> Shape: <u>Round</u>	Inter. Cal.	<u>1100</u>	<u>11/3/2013</u>					
Delay:	<u>4.4078</u> Range: <u>2.5"</u>	Freq.:	<u>2.25 MHz</u> Style: <u>Comp - G</u>	Inter. Cal.							
M'U Cal/Vel:	<u>.1236</u> Pulsar: <u>Square</u>	Exam Angle:	<u>45</u> # of Elements: <u>Single</u>	Final Cal.	<u>1217</u>	<u>11/3/2013</u>					
Damping:	<u>500</u> Reject: <u>0%</u>	Mode:	<u>Shear</u>								
Rep. Rate:	<u>Autohigh</u> Freq.: <u>2.25 MHz</u>	Measured Angle:	<u>44</u>	Couplant			Circumferential Orientated Search Unit				
Filter:	<u>Fixed</u> Mode: <u>PE</u>	Wedge Style:	<u>MSWQC</u>	Cal. Batch:	<u>12125</u>		Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
Voltage:	<u>450</u> Other: <u>Fullwave</u>			Type:	<u>ULTRAGEL II</u>		ID Notch #3	<u>80</u>	<u>5.4</u>	<u>1.352"</u>	
Ax. Gain (dB):	<u>31.5</u> Circ. Gain (dB): <u>38.1</u>	Search Unit Cable		Mfg.:	<u>MAGNAFLUX</u>						
<u>1</u> Screen Div. = <u>0.25</u> in. of <u>Sound Path</u>	Type:	<u>RG - 174</u>		Exam Batch:	<u>12125</u>						
Linearity Report No.:	<u>L-13-266</u>	Length:	<u>6'</u> No. Conn.: <u>0</u>	Type:	<u>ULTRAGEL II</u>						
		Scan Coverage		Mfg.:	<u>MAGNAFLUX</u>						
Cal. Block No.	<u>40411</u>	Upstream <input type="checkbox"/> Downstream <input checked="" type="checkbox"/>	Scan dB: <u>45.5</u>	Reference Block			Reference/Simulator Block				
Thickness	<u>0.875</u> Dia.: <u>8.75</u>	CW <input checked="" type="checkbox"/> CCW <input checked="" type="checkbox"/>	Scan dB: <u>52.1</u>	Serial No.:	<u>04-8743</u>		Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
Cal. Blk. Temp.	<u>68</u> Temp. Tool: <u>MCNDE40131</u>	Exam Surface:	<u>O.D.</u>	Type:	<u>ROMPAS</u>		<u>19.9</u>	<u>1" Radius</u>	<u>80</u>	<u>4.0</u>	<u>1.00"</u>
Comp. Temp.	<u>73</u> Temp. Tool: <u>MCNDE40131</u>	Surface Condition:	<u>As Ground</u>								
Recordable Indication(s):	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	(If Yes, Ref. Attached Ultrasonic Indication Report.)									
Results:	Accept <input checked="" type="checkbox"/> Reject <input type="checkbox"/> Info <input type="checkbox"/>			Comments: <u>FC 11-16</u>							
Percent Of Coverage Obtained > 90%:	No <input type="checkbox"/> Reviewed Previous Data: Yes <input type="checkbox"/>										

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David K. Tucker</i>	11/3/2013	Red SHEFFIELD	<i>Red Sheffield</i>	11-4-13
N/A	N/A			Site Review		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/8/13

ATTACHMENT 1
 49 of 53



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: O2.B3.150.0003
 Workscope: ISI

Procedure: NDE-3830
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: O2-26
 Report No.: UT-13-1186
 Page: 2 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____
 Drawing No.: O-ISIN4-101A-2.1 Description: Nozzle to Channel Body
 System ID: 51A
 Component ID: 2-LDCB-IN-WJ33V Size/Length: N/A Thickness/Diameter: SS / .875 / N/A
 Limitations: Yes - See attached sheets Start Time: 1140 Finish Time: 1207

Instrument Settings
 Serial No.: 023DP0 Manufacturer: GE Model: USN 60 SW
 Delay: 6.8406 Range: 3.0" M'tl Cal/Vel: .2298 Pulsar: Square
 Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 53.0 Circ. Gain (dB): N/A
1 Screen Div. = 0.3 in. of Sound Path
 Linearity Report No.: L-13-268

Search Unit
 Serial No.: 03-767 Manufacturer: RTD Size: 2(7x10) Shape: Rect.
 Freq.: 2.0 MHZ Style: TRLA Exam Angle: 60 # of Elements: Dual
 Mode: Long. Measured Angle: 59 Wedge Style: Integral
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1023	11/3/2013
Inter. Cal.		
Inter. Cal.	1157	11/3/2013
Inter. Cal.		
Final Cal.	1216	11/3/2013

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch #2	80	5.1	1.537"

Couplant
 Cal. Batch: 12125 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No. 40411 Thickness 0.875 Dia.: 8.75
 Cal. Btk. Temp. 68 Temp. Tool: MCNDE40131 Exam Surface: O.D.
 Comp. Temp. 73 Temp. Tool: MCNDE40131 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 67.0
 CW CCW Scan dB: N/A

Reference Block
 Serial No.: 04-8743 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
26.7	1" Radius	80	3.3	1.00"

Comments: FC 11-16

50 9-8-03 ATTACHMENT

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David K. Tucker</i>	11/3/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	11-4-13
N/A	N/A			Site Review		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/8/13



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: 02.B3.150.0003
 Workscope: ISI

Procedure: NDE-3630
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: 02-26
 Report No.: UT-13-1186
 Page: 3 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____
 Drawing No.: O-ISIS4-101A-2.1 Description: Nozzle to Channel Body
 System ID: S1A
 Component ID: 2-LDCB-IN-WJ33V Size/Length: N/A Thickness/Diameter: SS / .875 / NA
 Limitations: Yes - See attached sheets Start Time: 1140 Finish Time: 1207

Instrument Settings
 Serial No.: 023DP0 Manufacturer: GE Model: USN 60 SW
 Delay: 7.3884 Range: 4.0" M/I Cal/Vel: .2306 Pulsar: Square
 Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 43.7 Circ. Gain (dB): N/A
1 Screen Div. = 0.4 in. of Sound Path
 Linearity Report No.: L-13-266

Search Unit
 Serial No.: 03-769 Manufacturer: RTD
 Size: 2(7x10) Shape: Rect. Freq.: 2.0 MHZ Style: TRLA
 Exam Angle: 70 # of Elements: Dual Mode: Long.
 Measured Angle: 68 Wedge Style: Integral
 Search Unit Cable Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1030	11/3/2013
Inter. Cal.		
Inter. Cal.	1204	11/3/2013
Inter. Cal.		
Final Cal.	1215	11/3/2013

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch #2	80	5.3	2.135"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
32.0	1" Radius	80	2.5	1.00"

Calibration Block
 Cal. Block No. 40411 Thickness 0.875 Dia.: 8.75
 Cal. Blk. Temp. 68 Temp. Tool: MCNDE40131
 Comp. Temp. 73 Temp. Tool: MCNDE40131
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 57.7
 CW CCW Scan dB: N/A
 Exam Surface: O.D. Surface Condition: As Ground

Reference Block
 Serial No.: 04-8743 Type: ROMPAS

Comments: FC 11-16

51880 ATTACHMENT B

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David K. Tucker</i>	11/3/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	11-4-13
N/A	N/A			Site Review		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/8/13

Let Down Cooler - Nozzle to Channel Body

% Coverage Calculations

Weld No. : 2-LDCB-IN-WJ33V

Dia. = 3.5"

"t" = 0.875"

Weld Length = 27.1"

Axial Scans

Along Axis of Pipe = 100% of the Length x 34.6% of the Volume = 34.6%

Along Radius of Pipe = 100% of the Length x 47.4% of the Volume = 47.4%

Average = $34.6\% + 47.4\% / 2 = 41.0\%$

Circ. Scans

Along Axis of Pipe = 100% of the Length x 55.5% of the Volume = 55.5%

Along Radius of Pipe = 100% of the Length x 81.7% of the Volume = 81.7%

Average = $55.5\% + 81.7\% / 2 = 68.6\%$

Total = $(41.0 + 68.6) / 2 = 54.8\%$ Aggregate Coverage

Inspector / Date: Rod Sheffield / 11-7-13 Page 4 of 10

ATTACHMENT B


52 of 80

Letdown Cooler Nozzle to Channel Body

Weld No. : 2-LDCB-IN-WJ33V

Item No. : O2.B3.150.0003

Total Exam Area = 2.72 sq. in.



Scale: 1" = 1"

53 of 80

ATTACHMENT B

Rod Sheffield 11-4-13


5 of 10

Letdown Cooler Nozzle to Channel Body Area Examined - Axial Scans

Weld No. : 2-LDCB-IN-WJ33V

Item No. : 02.B3.150.0003

- Area not Examined = 1.78 sq. in.
- Area Examined = $2.72 - 1.78 / 2.72 \times 100 = 34.6\%$




54 of 80
ATTACHMENT B

Rod Sheffield 11-7-13


Letdown Cooler Nozzle to Channel Body Area Examined - Circ. Scans

Weld No. : 2-LDCB-IN-WJ33V

Item No. : O2.B3.150.0003

 Area not Examined = $0.81 + 0.40 = 1.21$ sq. in.

 Area Examined = $2.72 - 1.21 / 2.72 \times 100 = 55.5\%$



ATTACHMENT B
55 of 80

Road Sheffield 11-4-13


7 of 10

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : 2-LDCB-IN-WJ33V

Item No. : O2.B3.150.0003

Total Exam Area = 2.30 sq. in.



Scale: 1" = 1"

56488
ATTACHMENT B



Rod Khehulal 11-4-13


8 of 10

Letdown Cooler Nozzle to Channel Body (Radius View) Area Examined - Axial Scans

Weld No. : 2-LDCB-IN-WJ33V

Item No. : O2.B3.150.0003

-  Area not Examined = 1.21 sq. in.
-  Area Examined = $2.30 - 1.21 / 2.30 \times 100 = 47.4\%$



ATTACHMENT B
59 of 80

Rod Sheffield 11-7-13

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : 2-LDCB-IN-WJ33V


Item No. : O2.B3.150.0003



Area not Examined = .42 sq. in.



Area Examined = $2.30 - .42 / 2.30 \times 100 = 81.7\%$



58 of 80
ATTACHMENT B

Rod Sheffield 11-4-13

10 of 10



UT Calibration Examination



Site/Unit: Oconee / 2
 Summary No.: 02.B3.150.0004
 Workscope: ISI

Procedure: NDE-3630
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: 02-26
 Report No.: UT-13-1187
 Page: 1 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____
 Drawing No.: O-4SIN4-101A-2.1 Description: Nozzle to Channel Body
 System ID: 51A
 Component ID: 2-LDCB-OUT-WJ36V Size/Length: N/A Thickness/Diameter: SS / .875 / NA
 Limitations: Yes - See attached sheets Start Time: 1148 Finish Time: 1210

Instrument Settings
 Serial No.: 023DP0 Manufacturer: GE Model: USN 60 SW
 Delay: 4.4078 Range: 2.5" M'tl Cal/Vel: .1236 Pulsar: Square
 Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 31.5 Circ. Gain (dB): 38.1
1 Screen Div. = 0.25 in. of Sound Path
 Linearity Report No.: L-13-268

Search Unit
 Serial No.: SB0492 Manufacturer: GE Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G Exam Angle: 45 # of Elements: Single
 Mode: Shear Measured Angle: 44 Wedge Style: MSWQC
Search Unit Cable
 Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1009	11/3/2013
Inter. Cal.		
Inter. Cal.	1100	11/3/2013
Inter. Cal.		
Final Cal.	1217	11/3/2013

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch #2	80	4.9	1.225"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch #3	80	5.4	1.352"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
19.9	1" Radius	80	4.0	1.00"

Calibration Block
 Cal. Block No. 40411 Thickness 0.875 Dia.: 8.75
 Cal. Blk. Temp. 88 Temp. Tool: MCNDE40131
 Comp. Temp. 73 Temp. Tool: MCNDE40131
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 45.5
 CW CCW Scan dB: 52.1
 Exam Surface: O.D. Surface Condition: As Ground

Reference Block
 Serial No.: 04-8743
 Type: ROMPAS

Comments: FC 11-16

ATTACHMENT 1
08.10.65

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David K. Tucker</i>	11/3/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	11-4-13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A					
Other	Level	Signature	Date	ANI Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/8/13



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: O2.B3.150.0004
 Workscope: ISI

Procedure: NDE-3830
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: O2-26
 Report No.: UT-13-1187
 Page: 2 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____

Drawing No.: O-ISIN4-101A-2.1 Description: Nozzle to Channel Body

System ID: 51A

Component ID: 2-LDCB-OUT-WJ36V Size/Length: N/A Thickness/Diameter: SS / .875 / NA

Limitations: Yes - See attached sheets Start Time: 1148 Finish Time: 1210

Instrument Settings				Search Unit				Cal. Checks			Axial Orientated Search Unit			
Serial No.:	<u>0230P0</u>			Serial No.:	<u>03-767</u>			Initial Cal.	<u>1023</u>	<u>11/3/2013</u>	Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Manufacturer:	<u>GE</u>			Manufacturer:	<u>RTD</u>			Inter. Cal.			ID Notch #2	<u>80</u>	<u>5.1</u>	<u>1.537"</u>
Model:	<u>USN 80 SW</u>			Size:	<u>2(7x10)</u>	Shape:	<u>Rect.</u>	Inter. Cal.	<u>1157</u>	<u>11/3/2013</u>				
Delay:	<u>6.8408</u>	Range:	<u>3.0"</u>	Freq.:	<u>2.0 MHz</u>	Style:	<u>TRLA</u>	Inter. Cal.						
M/U Cal/Vel:	<u>.2298</u>	Pulser:	<u>Square</u>	Exam Angle:	<u>60</u>	# of Elements:	<u>Dual</u>	Final Cal.	<u>1216</u>	<u>11/3/2013</u>				
Damping:	<u>500</u>	Reject:	<u>0%</u>	Mode:	<u>Long.</u>									
Rep. Rate:	<u>Autohigh</u>	Freq.:	<u>2 MHz</u>	Measured Angle:	<u>59</u>		Couplant							
Filter:	<u>Fixed</u>	Mode:	<u>Dual</u>	Wedge Style:	<u>Integral</u>		Cal. Batch:	<u>12125</u>						
Voltage:	<u>450</u>	Other:	<u>Fullwave</u>				Type:	<u>ULTRAGEL II</u>						
Ax. Gain (dB):	<u>53.0</u>	Circ. Gain (dB):	<u>N/A</u>	Search Unit Cable				Mfg.:	<u>MAGNAFLUX</u>					
<u>1</u> Screen Div. = <u>0.3</u> in. of <u>Sound Path</u>				Type:	<u>RG - 174</u>		Exam Batch:	<u>12125</u>						
Linearity Report No.:	<u>L-13-266</u>			Length:	<u>6'</u>	No. Conn.:	<u>0</u>	Type:	<u>ULTRAGEL II</u>					
				Scan Coverage				Mfg.:	<u>MAGNAFLUX</u>					
				Upstream <input type="checkbox"/>	Downstream <input checked="" type="checkbox"/>	Scan dB:	<u>67.0</u>	Reference Block						
				CW <input type="checkbox"/>	CCW <input type="checkbox"/>	Scan dB:	<u>N/A</u>	Serial No.:	<u>04-8743</u>					
				Cal. Block No.:	<u>40411</u>			Type:	<u>ROMPAS</u>					
				Thickness <u>0.875</u>	Dia.:	<u>8.75</u>	Exam Surface:	<u>O.D.</u>						
				Cal. Blk. Temp. <u>68</u>	Temp. Tool:	<u>MCNDE40131</u>	Surface Condition:	<u>As Ground</u>						
				Comp. Temp. <u>73</u>	Temp. Tool:	<u>MCNDE40131</u>	Recordable Indication(s): Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> (If Yes, Ref. Attached Ultrasonic Indication Report.)							
				Results: Accept <input checked="" type="checkbox"/> Reject <input type="checkbox"/> Info <input type="checkbox"/>							Comments: <u>FC 11-16</u>			
				Percent Of Coverage Obtained > 90%: <u>No</u>							Reviewed Previous Data: <u>Yes</u>			

60 of 80 ATTACHMENT B

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David K. Tucker</i>	11/3/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	11-4-13
N/A	N/A			Site Review		
Other	Level	Signature	Date	ANN Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark E. Zurbuch</i>	11/4/13



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: 02.B3.150.0004
 Workscope: ISI

Procedure: NDE-3630
 Procedure Rev.: 2
 Work Order No.: 2025408

Outage No.: 02-25
 Report No.: UT-13-1187
 Page: 3 of 10

Code: 1998/2000A Cat./Item: B-D /B3.150 Location: _____
 Drawing No.: Q-ISIN4-101A-2.1 Description: Nozzle to Channel Body
 System ID: 51A
 Component ID: 2-LDCB-OUT-WJ36V Size/Length: N/A Thickness/Diameter: SS / .875 / NA
 Limitations: Yes - See attached sheets Start Time: 1148 Finish Time: 1210

Instrument Settings
 Serial No.: 023DP0 Manufacturer: GE Model: USN 60 SW
 Delay: 7.3684 Range: 4.0" M'tl Cal/Vel: .2306 Pulsar: Square Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2 MHz Filter: Fixed Mode: Dual Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 43.7 Circ. Gain (dB): N/A
1 Screen Div. = 0.4 in. of Sound Path
 Linearity Report No.: L-13-266

Search Unit
 Serial No.: 03-769 Manufacturer: RTD Size: 2(7x10) Shape: Rect.
 Freq.: 2.0 MHZ Style: TRLA Exam Angle: 70 # of Elements: Dual Mode: Long.
 Measured Angle: 88 Wedge Style: Integral
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1030	11/3/2013
Inter. Cal.		
Inter. Cal.	1204	11/3/2013
Inter. Cal.		
Final Cal.	1215	11/3/2013

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch #2	80	5.3	2.135"

Couplant
 Cal. Batch: 12125 Type: ULTRAGEL II Mfg.: MAGNAFLUX
 Exam Batch: 12125 Type: ULTRAGEL II Mfg.: MAGNAFLUX

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No. 40411 Thickness 0.875 Dia.: 8.75 CW CCW Scan dB: N/A
 Cal. Blk. Temp. 68 Temp. Tool: MCNDE40131 Exam Surface: O.D.
 Comp. Temp. 73 Temp. Tool: MCNDE40131 Surface Condition: As Ground

Scan Coverage
 Upstream Downstream Scan dB: 57.7
 (If Yes, Ref. Attached Ultrasonic Indication Report.)

Reference Block
 Serial No.: 04-8743 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
32.0	1" Radius	80	2.5	1.00"

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: FC 11-16

ATTACHMENT 61780

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Tucker, David K.	II-N	<i>David Tucker</i>	11/3/2013	ROD SHEFFIELD	<i>Rod Sheffield</i>	11-4-13
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A					
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			MARK E. ZURBUCH	<i>Mark Zurbuch</i>	11/8/13

Let Down Cooler - Nozzle to Channel Body

% Coverage Calculations

Weld No. : 2-LDCB-OUT-WJ36V

Dia. = 3.5"

"t" = 0.875"

Weld Length = 27.1"

Axial Scans

Along Axis of Pipe = 100% of the Length x 34.6% of the Volume = 34.6%

Along Radius of Pipe = 100% of the Length x 47.4% of the Volume = 47.4%

Average = $34.6\% + 47.4\% / 2 = 41.0\%$

Circ. Scans

Along Axis of Pipe = 100% of the Length x 55.5% of the Volume = 55.5%

Along Radius of Pipe = 100% of the Length x 81.7% of the Volume = 81.7%

Average = $55.5\% + 81.7\% / 2 = 68.6\%$

Total = $(41.0 + 68.6) / 2 = 54.8\%$ Aggregate Coverage

Inspector / Date: Boyd Sheffield / 11-7-13 Page 4 of 60


ATTACHMENT B
62/80

Letdown Cooler Nozzle to Channel Body

Weld No. : 2-LDCB-OUT-WJ36V

Item No. : O2.B3.150.0004

Total Exam Area = 2.72 sq. in.



Scale: 1" = 1"

63780
ATTACHMENT B

Rad Sheffield 11-4-13

5 of 10


Letdown Cooler Nozzle to Channel Body Area Examined - Axial Scans

Weld No. : 2-LDCB-OUT-WJ36V

Item No. : O2.B3.150.0004

Area not Examined = 1.78 sq. in.

Area Examined = $2.72 - 1.78 / 2.72 \times 100 = 34.6\%$



64 of 80
ATTACHMENT B

Rod Sheffall 11-7-13

Letdown Cooler Nozzle to Channel Body Area Examined - Circ. Scans

Weld No. : 2-LDCB-OUT-WJ36V


Item No. : O2.B3.150.0004



Area not Examined = $0.81 + 0.40 = 1.21$ sq. in.



Area Examined = $2.72 - 1.21 / 2.72 \times 100 = 55.5\%$



65 of 80
ATTACHMENT B

Red Sheffield 11-4-13


7 of 10

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : 2-LDCB-OUT-WJ36V

Item No. : O2.B3.150.0004

Total Exam Area = 2.30 sq. in.



Scale: 1" = 1"

66 of 80
ATTACHMENT B



Rod Sheffield 11-4-13


8 of 10

Letdown Cooler Nozzle to Channel Body (Radius View) Area Examined - Axial Scans

Weld No. : 2-LDCB-OUT-WJ36V

Item No. : O2.B3.150.0004

-  Area not Examined = 0.92 sq. in.
-  Area Examined = $2.30 - 1.21 / 2.30 \times 100 = 47.4\%$





ATTACHMENT B
6797-80


Rod Sheffield 11-7-13

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : 2-LDCB-OUT-WJ36V

Item No. : O2.B3.150.0004

-  Area not Examined = .42 sq. in.
-  Area Examined = $2.30 - .42 / 2.30 \times 100 = 81.7\%$



*ATTACHMENT B
68 of 80*

Rod Sheffield 11-4-13



UT Calibration Examination

Site/Unit: Oconee / 2
 Summary No.: O2.C1.30.0001
 Workscope: ISI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 2025907

Outage No.: O2-26
 Report No.: UT-13-1176
 Page: 1 of 1

Code: 1998/2000A Cat./Item: C-A /C1.30 Location: _____
 Drawing No.: OM-201.S-0001 Description: Tubesheet to Shell
 System ID: 03
 Component ID: 2-SGB-W69 Size/Length: N/A Thickness/Diameter: CS / 5.125 / 132.0
 Limitations: Yes - See attached sheet Start Time: 0910 Finish Time: 1115

Instrument Settings
 Serial No.: 0263P4 Manufacturer: GE Model: USN 60 SW
 Delay: 1.0672 Range: 8.0" M'U Cal/Vel: .2319 Pulsar: Square
 Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 16.0 Circ. Gain (dB): 16.0
1 Screen Div. = .8 in. of Depth
 Linearity Report No.: L-13-260

Search Unit
 Serial No.: C12004SP Manufacturer: KBA Size: 1.0 Shape: Round
 Freq.: 2.25 MHz Style: Gamma Exam Angle: 0 # of Elements: Single
 Mode: Long Measured Angle: N/A Wedge Style: Integral
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0700	10/23/2013
Inter. Cal.		
Inter. Cal.	0910	10/23/2013
Inter. Cal.		
Final Cal.	1310	10/23/2013

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
1/4T SDH	80	1.3	1.06"
1/2T SDH	75	3.0	2.40"
3/4T SDH	70	4.6	3.67"
BW	+100	6.2	5.0"

Couplant
 Cal. Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX
 Exam Batch: 12125
 Type: ULTRAGEL II
 Mfg.: MAGNAFLUX

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A			

Calibration Block
 Cal. Block No. 20T-240 Thickness 5.0 Dia.: Flat
 Cal. Blk. Temp. 73 Temp. Tool: MCNDE40197
 Comp. Temp. 76 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 30.0
 CW CCW Scan dB: 30.0
 Exam Surface: O.D. Surface Condition: Flush

Reference Block
 Serial No.: 91-5938
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
6.0	1" Side	80	1.25"	1.0"

Comments: Reference Report # UT-13-1179 for additional information. Backwall lost at 2.5" from weld toe, due to tubesheet.

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Koster, Rickey	II-N	<i>[Signature]</i>	10/23/2013	ROD STEFFIELD	<i>[Signature]</i>	11-2-13
Hassel, Matt	II-N	<i>[Signature]</i>	10/23/2013	Site Review	<i>[Signature]</i>	
Other	N/A	Signature	Date	ANIL	<i>[Signature]</i>	11/5/13

ATTACHMENT 69 of 80

DUKE ENERGY COMPANY

ISI LIMITATION REPORT

Summary #: <u>2-SGB-W69</u> Component ID <u>O2.C1.30.0001</u>			remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			Lateral restraint #1
FROM L <u>2-12.5"</u> to L <u>2+12.5"</u> INCHES FROM W0 <u>CL-3.0</u> to <u>Beyond</u>			
ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u> FROM <u>N/A</u> DEG to <u>N/A</u> DEG			
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw			Lateral restraint #1
FROM L <u>2-12.5"</u> to L <u>2+12.5"</u> INCHES FROM W0 <u>CL+2.0</u> to <u>CL-2.0</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u> FROM <u>N/A</u> DEG to <u>N/A</u> DEG			
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			Lateral restraint #2
FROM L <u>9-12.5"</u> to L <u>9+12.5"</u> INCHES FROM W0 <u>CL+3.0</u> to <u>Beyond</u>			
ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u> FROM <u>N/A</u> <u>N/A</u> DEG			
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw			Lateral restraint #2
FROM L <u>9-12.5"</u> to L <u>9+12.5"</u> INCHES FROM W0 <u>CL+2.0</u> to <u>CL-2.0</u>			Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u> FROM <u>N/A</u> DEG to <u>N/A</u> DEG			<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Dave Griebel</u> Level: <u>II</u> Date: <u>10/23/13</u>	Sheet <u>5</u> of <u>15</u>		
Reviewed By: <u>Rod Sheffield</u> Date: <u>11-2-13</u>	Authorized Inspector: <u>MARK E. ZURBUCH</u> Date: <u>11/5/13</u>		

ATTACHMENT B
10/28/13

DUKE ENERGY COMPANY

ISI LIMITATION REPORT

Summary #: 2-SGB-W69 Component ID O2.C1.30.0001

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 16+12.5" to L 16+12.5" INCHES FROM W0 CL+3.0 to Beyond
 ANGLE: 0 45 60 other 60NS FROM N/A DEG to N/A DEG

Lateral restraint #3

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 16-12.5 to L 16+12.5" INCHES FROM W0 CL+2.0 to CL-2.0
 ANGLE: 0 45 60 other 60NS FROM N/A DEG to N/A DEG

Lateral restraint #3

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 24-12.5" to L 24+12.5" INCHES FROM W0 CL+3.0 to Beyond
 ANGLE: 0 45 60 other _____ FROM N/A DEG to N/A DEG

Lateral restraint #4

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 24-12.5" to L 24+12.5" INCHES FROM W0 CL+2.0 to CL-2.0
 ANGLE: 0 45 60 other _____ FROM N/A DEG to N/A DEG

Lateral restraint #4

Sketch(s) attached
 yes No

Prepared By: Dave Griebel Level: II Date: 10/23/13 Sheet 5 of 15

Reviewed By: Rod Sheffield Date: 11-2-13 Authorized Inspector: MARK E. ZURBACH Date: 11/5/13

ATTACHMENT B
9180

DUKE ENERGY COMPANY

ISI LIMITATION REPORT

Summary #: <u>2-SGB-W69</u>	Component ID: <u>O2.C1.30.0001</u>	remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L <u>31-12.5"</u> to L <u>31+12.5"</u>	INCHES FROM W0 <u>CL+3.0</u> to <u>Beyond</u>	Lateral restraint #5
ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u>	FROM <u>N/A</u> DEG to <u>N/A</u> DEG	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>31-12.5"</u> to L <u>31+12.5"</u>	INCHES FROM W0 <u>CL+2.0</u> to <u>CL-2.0</u>	Lateral restraint #5
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u>	FROM <u>N/A</u> DEG to <u>N/A</u> DEG	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L <u>1-9"</u> to L <u>1+9"</u>	INCHES FROM W0 <u>CL+7.0</u> to <u>Beyond</u>	Lifting trunnion
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>60NS</u>	FROM <u>N/A</u> DEG to <u>N/A</u> DEG	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L <u>18-9"</u> to L <u>18+9"</u>	INCHES FROM W0 <u>CL+7.0</u> to <u>Beyond</u>	Lifting trunnion
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____	FROM <u>N/A</u> DEG to <u>N/A</u> DEG	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Dave Griebel</u>	Level: <u>II</u> Date: <u>10/23/13</u>	Sheet <u>7</u> of <u>15</u>
Reviewed By: <u>Rod Sheffield</u>	Date: <u>11-2-13</u>	Authorized Inspector: <u>MARK E. ZURBUCH</u> Date: <u>11/5/13</u>

ATTACHMENT B
72980

DUKE ENERGY COMPANY

ISI LIMITATION REPORT

Summary #: 2-SGB-W69 Component ID O2C1.30.0001

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 7-10" to L 7+10" INCHES FROM W0 CL+7" to Beyond
 ANGLE: 0 45 60 other _____ FROM N/A DEG to N/A DEG

Manway

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes No


Prepared By: Dave Griebel Level: II Date: 10/23/13 Sheet 8 of 13
 Reviewed By: Rod Sheffield Date: 11-2-13 Authorized Inspector: MARK E. ZURBUCH Date: 11/5/13

ATTACHMENT B
93/80

Steam Generator Upper Tubesheet to Shell

This scan limitation exists for 125" of weld length
Total Scan Coverage for 0° CW & CCW

Weld No. : 2-SGB-W69
Item No. : O2.C1.30.0001
Scale 1" = 2"



Base Metal Area=9.34 sq. in.
Weld Metal Area=6.36 sq. in.
Total Exam Area=15.7 sq. in.

CW, CCW, 0° Coverage

100 % missed coverage

Limitation exists for 125"
 $125" / 465" = 26.9\%$

ATTACHMENT B
11/4/88

Inspector / Date : [Signature] 10-23-13


Page 9 of 15

Red Sheffield 11-2-13

Steam Generator Upper Tubesheet to Shell

This scan limitation exists for 125" of weld length
Total Scan Coverage for Base Metal

Weld No. : 2-SGB-W69
Item No. : O2.C1.30.0001
Scale 1" = 2"



Base Metal Area = 9.34 sq. in.
Weld Metal Area = 6.36 sq. in.
Total Exam Area = 15.7 sq. in.

Base Metal Coverage

5.85 sq. in. / 9.34 sq. in. =
62.6% of missed coverage

Limitation exits for 125"
 $125" / 465" = 26.9\%$

75 of 83
ATTACHMENT B

Inspector / Date : *[Signature]* 10-23-13


Page 10 of 15

Rod Sheffield 11-2-13

Steam Generator Upper Tubesheet to Shell

This scan limitation exists for 125" of weld length
Total Scan Coverage for Weld Metal

Weld No. : 2-SGB-W69
Item No. : O2.C1.30.0001
Scale 1" = 2"



Base Metal Area = 9.34 sq. in.
Weld Metal Area = 6.36 sq. in.
Total Exam Area = 15.7 sq. in.

5.67 sq. in. of missed coverage

Weld Metal Coverage

$5.67 \text{ sq. in.} / 6.36 \text{ sq. in.} = 89.2\%$ of missed coverage

Limitation exits for 125"
 $125" / 465" = 26.9\%$

Surface 2 - Shell

764987
ATTACHMENT B

Inspector / Date : LDH/R 10-23-13

Page 11 of 15

Rod Shekhal 11-2-13

Steam Generator Upper Tubesheet to Shell

This scan limitation exists for 36" of weld length

Weld No. : 2-SGB-W69

Item No. : O2.C1.30.0001

Scale 1" = 2"

Lifting Trunion

35°, 45°

Base Metal Area=9.34 sq. in.
Weld Metal Area=6.36 sq. in.
Total Exam Area=15.7 sq. in.

Base Metal Coverage
.84 sq. in. / 9.34 sq. in. =
9 % of missed coverage

Limitation exits for 36"
36" / 465" = 7.7 %

.84 sq. in. of missed coverage

Surface 2 - Shell

799 of 801
ATTACHMENT B

Inspector / Date : D. H. P. 10-23-13

Page 12 of 15

Rod Shellfield 11-2-13


Steam Generator Upper Tubesheet to Shell

This scan limitation exists for 20" of weld length

Weld No. : 2-SGB-W69

Item No. : O2.C1.30.0001

Scale 1" = 2"



175 of 80
ATTACHMENT B

Inspector / Date : [Signature] 10-23-13

Page 13 of 15

Road Sheffield 11-2-13

**ONS Steam Generator 2B
02.C1.30.0001
2-SGB-W69**

Scan Direction	% Coverage	% Length	Total %
<u>Weld Coverage</u>			
S1	10.8	125 / 465.1 = 26.9 %	
	100	340 / 465.1 = 73.1 %	76.0%
S2	100	340 / 465.1 = 73.1 %	73.1%
CW	100	340 / 465.1 = 73.1 %	73.1%
CCW	100	340 / 465.1 = 73.1 %	73.1%
Total Weld Aggregate			73.8%
<u>Base Metal Coverage</u>			
S1	100	340 / 465.1 = 73.1 %	
	91	56 / 465.1 = 12.0 %	84.0%
S2	37.4	125 / 465.1 = 26.9 %	
	100	340 / 465.1 = 73.1 %	83.2%
CW	100	340 / 465.1 = 73.1 %	73.1%
CCW	100	340 / 465.1 = 73.1 %	73.1%
Total Base Metal Aggregate			78.4%
<u>0° Coverage</u>			
	100	340 / 465.1 = 73.1 %	73.1%
Total 0° Aggregate			73.1%

Total Exam Coverage = 73.8 + 78.4 + 73.1 = 225.3 / 3 = 75.1 %

Inspector: *[Signature]*

Review: *Red Sheffield 11-2-13*

19 of 15

ATTACHMENT B
799.80

Steam Generator Upper Tubesheet to Sec. Shell

*45° Scanned in four directions.
 *60° & 60°NS Scanned in four directions.


Weld No. : 2-SGB-W69
 Item No. : O2.C1.30.0001

***All axial scans will scan the entire examine volume to be conservative.
 60 Near Surface Required
 Cal. 35° due to possible Limitation

⊕

Surface 1 - Tubesheet

Surface 2 - Shell



Exam volume .5" outside of toe, full volume. See Figure 8 NDE-820

Level III Reviewer / Date : Jerry D 9-5-13

Scale 1" = 2"

Page 15 of 15

ATTACHMENT B
80 of 88