

ocket Nos. 50-269
50-270
50-287

6/27/78

ocket Files

NRC

PDR

PDR

From: B. Grimes, AD for Engineering and Projects, DOR/NRC
To: Mr. William O. Parker, Jr., Duke Power Co.

By letter dated June 22, 1978, you advised us of a
sust fault associated with Rod 6 of Safety Group 4 of
the control rod system at Oconee-2 and requested
extension of the surveillance interval for this rod for
seven days (through July 4, 1978).

This is to advise you that your specific request
is denied because we conclude that the subject

rod is inoperable per Specification 3.5.2.2 b.
except as noted below,

Accordingly, you should perform the various actions
set forth in the Facility Technical Specifications

relative to the existence of one inoperable rod.

This does not include surveillance testing of the inoperable rod, however.

The exception deals with conformance with Specification

i
3.S.2.2. In the present case of inoperability of
Rod 6 of Group 4 of Oconee-2, the requirements of
Specification 3.S.2.2.i are waived effective immediately
and continuing through July 1, 1978 at which time
this waiver will expire. The basis for this waiver is
that power reduction called for by Specification 3.S.2.2.i
is based on the possible effects of rod misalignment.

In the present instance, since the rod is properly aligned, there is no undue hazard to health and safety of the public by operating at full power so long as the rod ~~retains~~ maintains its alignment. We understand that you will shut down prepared by GB Justy ORPM to repair the unjacketed rod no later than July 3, 1972.

Brian Thomas 6:50 pm
6/27/78

If this requirement does not apply as the case of, 1, 1978.
~~if~~ Rod & Safety Group 4 until July 1, 1978. The panel reduction will not be required due to the unoperability of this rod for the limited period through July 1, 1978 or until the licensee obtains information indicating that the rod may not be capable of performing its assigned safety function, whichever occurs first.

Footnote to Oconee-2 TS 3.5.2.2.i