

SEP 28 1976

Docket Nos. 50-269
50-270
and 50-287

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President
Steam Production
Post Office Box 2176
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

RE: OCONEE NUCLEAR STATION

In our letter dated May 11, 1976, we requested that you conduct an examination of your facility to compare its existing fire protection provisions with the guidelines in the Standard Review Plan 9.5.1, "Fire Protection," dated May 1, 1976, which included Branch Technical Position APCS 9.5-1. We are enclosing a copy of Appendix A to Branch Technical Position APCS 9.5-1, "Guidelines for Fire Protection For Nuclear Power Plants Docketed Prior to July 1, 1976" (Enclosure 1). This document presents certain acceptable alternatives for operating plants to the positions given in APCS 9.5-1. We are sending this to you for your information because we will be using Appendix A in our evaluation of your plant.

After reviewing the licensee submittals made to date in response to our letter, we believe your initial response may not adequately present the results of your fire hazards analysis. We stress that in order to begin a re-evaluation of the fire protection program of your facility, you must perform a fire hazards analysis with the assistance and technical direction of a qualified fire protection engineer. In order for us to evaluate your fire hazards analysis we require that you submit the results in sufficient detail. To provide further guidance, we are enclosing a copy of "Supplementary Guidance on Information Needed For Fire Protection Program Evaluation" (Enclosure 2). This document indicates the type of information that will enable us to evaluate the total fire hazards analysis for your facility. This type of information may or may not be included in the detailed point-by-point comparison with Standard Review Plan 9.5.1 depending upon how you present that information.

OFFICE ➤					
SURNAME ➤					
DATE ➤					

SEP 28 1976

In addition, we request at this time that you propose Technical Specifications for your present fire protection systems and inform us of the date you intend to meet Section B of Appendix A "Administrative Procedures, Controls and Fire Brigade". Your presently scheduled submittal should include the information indicated by Enclosure 2 and proposed Technical Specifications for the fire protection systems of your facility.

Sincerely,

Original Signed By
Karl R. Goller
Karl R. Goller, Assistant Director
for Operating Reactors
Division of Operating Reactors

Enclosures:

1. Appendix A to Branch Technical
Position APCSB 9.5-1
2. Supplementary Guidance

cc w/enc1:

Mr. William L. Porter
Duke Power Company
P. O. Box 2170
422 South Church Street
Charlotte, North Carolina 28242

Mr. Troy B. Conner
Conner & Knotts
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691

DISTRIBUTION

Docket(3)
NRC-PDR(3)
Local PDR
ORB#1 Reading
VStello
TJCarter
ASchwencer
SMSheppard
DNeighbors
TWambach
OELD
OI&E(3)
WButler
DEisenhut
VBenaroya
TBAbernathy
JRBuchanan
ACRS(16)

OFFICE ➤	ORB#1	ORB#1	ORB#1	AD:OR		
x27433:tsb SURNAME ➤	Twambach	DNeighbors	ASchwencer	KRGoller		
DATE ➤	9/28/76	9/ /76	9/ /76	9/ /76		