

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

Central File
50-269
278
287

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

August 11, 1978

TELEPHONE: AREA 704
373-4083


Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

RE: RII:JPO
50-269
50-270
50-287

Dear Mr. O'Reilly:

With regard to your letter of June 12, 1978 which transmitted IE Bulletin 78-08 a review of the design of Oconee Nuclear Station has been conducted. Surveys have been previously performed around the fuel transfer tube areas in the Unit 1 Penetration Rooms which have indicated that there is no problem with the shielding design of the transfer tubes. Additional areas within the Unit 1 Reactor Building will be investigated during the forthcoming refueling outage. In as much as the design of Unit 1 is representative of all three Oconee units, there does not appear to be any excessive radiation levels present at the fuel element transfer tubes at Oconee.

Very truly yours,


William O. Parker, Jr.

RLG:scs

A112
R