

Duke Power Company
Oconee Nuclear Station

**Oconee Unit 1, Cycle 10
Reload Report**

DPC-RD-2006

November 1985

8512060290 851119
PDR ADDCK 05000269
P PDR

OCONEE UNIT 1, CYCLE 10

- Reload Report -

DPC - RD - 2006

November 1985

Duke Power Company
Design Engineering Department
P. O. Box 33189
Charlotte, North Carolina 28242

CONTENTS

	Page
1. INTRODUCTION AND SUMMARY	1-1
2. OPERATING HISTORY	2-1
3. GENERAL DESCRIPTION	3-1
4. FUEL SYSTEM DESIGN	4-1
4.1. Fuel Assembly Mechanical Design	4-1
4.2. Fuel Rod Design	4-1
4.2.1. Cladding Collapse	4-1
4.2.2. Cladding Stress	4-2
4.2.3. Cladding Strain	4-2
4.3. Thermal Design	4-2
4.4. Material Design	4-3
5. NUCLEAR DESIGN	5-1
5.1. Physics Characteristics	5-1
5.2. Analytical Input	5-2
5.3. Changes in Nuclear Design	5-2
6. THERMAL-HYDRAULIC DESIGN	6-1
7. ACCIDENT AND TRANSIENT ANALYSIS	7-1
7.1 General Safety Analysis	7-1
7.2 Accident Evaluation	7-1
8. PROPOSED MODIFICATIONS TO TECHNICAL SPECIFICATIONS	8-1
REFERENCES	A-1

List of Tables

Table	Page
4-1. Fuel Design Parameters and Dimensions	4-4
4-2. Linear Heat Rate to Melt Analysis	4-5
5-1. Oconee 1 Physics Parameters	5-3
5-2. Shutdown Margin Calculation for Oconee 1, Cycle 10 . .	5-5
6-1. Thermal-Hydraulic Design Conditions	6-3
7-1. Comparison of Key Parameters for Accident Analysis	7-3
7-2. LOCA Limits, Oconee 1, Cycle 10, After 2600 MWd/mtU . .	7-4
7-3. LOCA Limits, Oconee 1, Cycle 10, 0-2600 MWd/mtU	7-4

List of Figures

Figure	
3-1. Core Loading Diagram for Oconee 1, Cycle 10	3-2
3-2. Enrichment and Burnup Distribution for Oconee 1, Cycle 10	3-3
3-3. Control Rod Locations for Oconee 1, Cycle 10	3-4
3-4. BPRA Enrichment and Distribution for Oconee 1, Cycle 10	3-5
5-1. BOC Cycle 10 Two-Dimensional Relative Power Distribution - Full Power, Equilibrium Xenon, Nominal Rod Positions. . .	5-6
8-1. Core Protection Safety Power-Imbalance Limits.	8-2
8-2. Maximum Allowable Power-Imbalance Setpoints.	8-3

1. INTRODUCTION AND SUMMARY

This report justifies the operation of the tenth cycle of Oconee Nuclear Station, Unit 1, at the rated core power of 2568 MWt. Included are the required analyses as outlined in the USNRC document "Guidance for Proposed License Amendments Relating to Refueling," June 1975.

To support Cycle 10 operation of Oconee Unit 1, this report employs analytical techniques and design bases established in reports that were previously submitted and accepted by the USNRC and its predecessor (see references).

A brief summary of Cycle 9 and 10 reactor parameters related to power capability is included in Section 5 of this report. All of the accidents analyzed in the FSAR¹ have been reviewed for Cycle 10 operation. In those cases where Cycle 10 characteristics were conservative compared to those analyzed for previous cycles, no new accident analyses were performed.

Four of the Batch 10 assemblies are gadolinia lead test assemblies (LTAs). These assemblies are part of a joint Duke Power/Babcock & Wilcox/Department of Energy program to develop and demonstrate an advanced fuel assembly design incorporating $UO_2 - Gd_2O_3$ for extended burnup in pressurized water reactors. Reference 2 describes the LTAs and their presence will not adversely affect Cycle 10 operation.

The Technical Specifications have been reviewed, and the modifications required for Cycle 10 operation are justified in this report.

Based on the analyses performed, which take into account the postulated effects of fuel densification and the Final Acceptance Criteria for Emergency Core Cooling Systems, it has been concluded that Oconee Unit 1 can be operated safely for Cycle 10 at the rated power level of 2568 MWt.

2. OPERATING HISTORY

The referenced fuel cycle for the nuclear and thermal-hydraulic analyses of Oconee Unit 1, Cycle 10, is the currently operating Cycle 9. Cycle 9 achieved initial criticality on November 28, 1984 and power escalation commenced on November 29, 1984. The fuel cycle design length for Cycle 10 - 400 EFPD - is based on Cycle 9 length of 410 EFPD. No operating anomalies occurred during previous cycle operations that would adversely affect fuel performance in Cycle 10.

Cycle 10 will operate in a feed-and-bleed mode for its entire design length, as did Cycle 9.

3. GENERAL DESCRIPTION

The Oconee Unit 1 reactor core and fuel design basis are described in detail in Chapter 3, of the FSAR.¹ The Cycle 10 core consists of 177 fuel assemblies, each of which is a 15 by 15 array containing 208 fuel rods, 16 control rod guide tubes, and one incore instrument guide tube. The fuel consists of dished-end, cylindrical pellets of uranium dioxide clad in cold-worked Zircaloy-4. The fuel assemblies in all batches except the batch containing the gadolinia LTAs have an average nominal fuel loading of 463.6 kg uranium. The gadolinia LTAs have an average fuel loading of 426.9 kg uranium. The undensified nominal active fuel lengths, theoretical densities, fuel and fuel rod dimensions, and other related fuel parameters are given in Table 4-1.

Figure 3-1 is the core loading diagram for Oconee 1, Cycle 10. Eleven of the Batch 10C assemblies will be discharged at the end of Cycle 9 along with Batch 9B. The remaining 49 Batch 10C assemblies, designated "10D," and the fresh Batch 12 FAs - with initial enrichments of 3.41 and 3.24 wt % ^{235}U , respectively - will be loaded into the central portion of the core. The four Batch 10B gadolinia LTAs,² with an initial enrichment of 4.00 wt % ^{235}U , are in locations symmetric to H12. Batch 11, with an initial enrichment of 3.31 wt % ^{235}U , will occupy primarily the core periphery. Figure 3-2 is a quarter-core map showing the assembly burnup and enrichment distribution at the beginning of Cycle 10.

Cycle 10 will operate in a rods-out, feed-and-bleed mode. Core reactivity control is supplied mainly by soluble boron and supplemented by 61 full-length Ag-In-Cd control rods and 52 burnable poison rod assemblies (BPRAs). In addition to the full-length control rods, eight Inconel gray axial power shaping rods (APSRs) are provided for additional control of axial power distribution. Since gray APSRs are being utilized, there are eight control rods in group seven and twelve in group five to reduce the negative offset response to the group seven rod movement. The Cycle 10 locations of the 69 control rods and the group designations are indicated in Figure 3-3. The Cycle 10 locations and enrichments of the BPRAs are shown in Figure 3-4.

FIGURE 3.1. CORE LOADING DIAGRAM FOR OCONEE 1, CYCLE 10

X															
A						M04 11	K06 11	P08 10D	K10 11	M12 11					
B					L03 11	12	N03 11	12	M08 11	12	N13 11	12	L13 11		
C				D09 11	P09 11	L05 11	12	P10 10D	12	P06 10D	12	L11 11	P07 11	K12 11	
D	C10 11	K14 11	G12 11	12	K01 10D	12	C08 10B	12	K15 10D	12	N09 11	K02 11	C06 11		
E	12	E10 11	12	C03 10D	12	A06 10D	R08 11	A10 10D	12	C13 10D	12	E06 11	12		
F	D11 11	C12 11	12	A09 10D	12	B05 10D	12	P05 10D	12	E14 10D	12	A07 10D	12	C04 11	D05 11
G	F09 11	12	L14 10D	12	F01 10D	12	B04 10D	P04 10D	D14 10D	12	F15 10D	12	L02 10D	12	F07 11
HW	H14 10D	H11 11	12	H03 10B	H15 11	M14 10D	N14 10D	H09 10D	D02 10D	E02 10D	H01 11	H13 10B	12	H05 11	H02 10D
K	L09 11	12	F14 10D	12	L01 10D	12	N02 10D	B12 10D	P12 10D	12	L15 10D	12	F02 10D	12	L07 11
L	N11 11	O12 11	12	R09 10D	12	M02 10D	12	B11 10D	12	P11 10D	12	R07 10D	12	O04 11	N05 11
M	12	M10 11	12	O03 10D	12	R06 10D	A08 11	R10 10D	12	O13 10D	12	M06 11	12		
N	O10 11	G14 11	D07 11	12	G01 10D	12	O08 10B	12	G15 10D	12	K04 11	G02 11	O06 11		
O	12	G04 11	B09 11	F05 11	12	B10 10D	12	B06 10D	12	F11 11	B07 11	N07 11			
P					F03 11	12	D03 11	12	E08 11	12	D13 11	12	F13 11		
R						E04 11	G06 11	B08 10D	G10 11	E12 11					
Z															
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15															

XX	PREVIOUS CYCLE LOCATION
X	BATCH NO.

FIGURE 3.2 ENRICHMENT & BURNUP FOR OCONEE 1, CYCLE 10

	8	9	10	11	12	13	14	15
H	3.41 30417	3.41 21965	3.41 23053	3.31 10003	4.00 32397	3.24 0	3.31 16924	3.41 30588
K	3.41 21965	3.41 21977	3.24 0	3.41 22427	3.24 0	3.41 25113	3.24 0	3.31 16540
L	3.41 23053	3.24 0	3.41 23062	3.24 0	3.41 24148	3.24 0	3.31 12712	3.31 16114
M	3.31 10004	3.41 22456	3.24 0	3.41 23596	3.24 0	3.31 16632	3.24 0	
N	4.00 32405	3.24 0	3.41 24155	3.24 0	3.31 16408	3.31 14538	3.31 16072	
O	3.24 0	3.41 25122	3.24 0	3.31 16657	3.31 14540	3.31 16395		
P	3.31 16938	3.24 0	3.31 12720	3.24 0	3.31 16085			
R	3.41 30579	3.31 16565	3.31 16144					

X.XX INITIAL ENRICHMENT, wt% ^{235}U

XXXXX BOC BURNUP, MWd/mtU

FIGURE 3.4 BPRA ENRICHMENT & DISTRIBUTION FOR OCONEE 1, CYCLE 10

	8	9	10	11	12	13	14	15
H						0.8		
K			1.4		1.4		0.2	
L		1.4		1.4		0.8		
M			1.4		1.4		NONE	
N		1.4		1.4				
O	0.8		0.8					
P		0.2		NONE				
R								

X.X

BPRA CONCENTRATION, wt % B_4C IN Al_2O_3

4. FUEL SYSTEM DESIGN

4.1 Fuel Assembly Mechanical Design

The types of fuel assemblies and pertinent fuel design parameters for Oconee 1 Cycle 10, are listed in Table 4-1. All fuel assemblies are mechanically interchangeable. Four regenerative neutron sources will be used in the Mark B5Z fuel assemblies.

The Batch 12 Mark B5Z fuel assemblies are a Mark B5 design with zircaloy intermediate spacer grids. Both the B5 design and the zircaloy grid concept have been previously demonstrated separately (References 19 and 5, respectively), and there are no new features not previously demonstrated. Additionally, the Batch 12 fuel rods have a slightly reduced prepressurization level to provide a small increase in fuel rod burnup. This level of prepressurization has also been previously implemented.¹⁶ The four fuel assemblies in Batch 10B are gadolinia LTAs. The mechanical design of the LTAs is described in Reference 2. All 52 BPRAs will be inserted into Batch 12 fuel assemblies.

Other results presented in the FSAR¹ fuel assembly mechanical discussions and in previous reload reports, are applicable to the reload fuel assemblies. Duke has performed generic mechanical analyses, as described below, which envelope the Cycle 10 design. All methods are consistent with the approved methodologies of Reference 10 except where specifically stated. B&W has reviewed the operating conditions for the gadolinia LTAs in Oconee 1 Cycle 10. Mechanical analyses similar to those described below were performed by B&W for the LTAs (References 17 and 18).

4.2 Fuel Rod Design

The mechanical evaluation of the fuel rod is discussed below.

4.2.1 Cladding Collapse

The fuel of Batches 10B and 10D is more limiting than the other batches due to its longer previous incore exposure time. The Batch 10D assembly power histories were assessed against Duke's generic creep collapse analysis which is based on the CROV computer code and procedures described in topical report

BAW-10084, Rev. 2¹³. The TACO2⁶ code was used to calculate internal pin pressures and clad temperatures used as input to CROV. The collapse time for the most limiting assembly was conservatively determined to be 31,400 EFPH, which is greater than the maximum projected residence time of Cycle 10 fuel (Table 4-1).

A detailed creep analysis was performed on the gadolinia-bearing fuel rods in the LTAs. The collapse time for these rods was greater than the maximum projected residence time.

4.2.2 Cladding Stress

As described in Reference 10, Duke has performed a generic and conservative fuel rod cladding stress analysis in accordance with the guidelines set forth in Section III, Division 1 - Subsection NB, of the ASME Boiler and Pressure Vessel Code. All methods are consistent with Reference 10. Compliance with ASME Code criteria verify the structural integrity of the cladding throughout the most limiting design conditions.

The following conservatisms exist in the generic cladding stress calculation:

- high external cladding pressure (110% of design system pressure)
- low internal pressure (HZP - min. specified pre-pressure)
- maximum possible radial temperature gradient through clad (fuel melt conditions)
- conservative cladding dimensions with regard to stress

4.2.3 Cladding Strain

Duke has performed a cladding strain calculation using TACO2⁶ in accordance with the approved methodology ¹⁰. This analysis demonstrated that the uniform, circumferential strain of the cladding was within 1.0%.

4.3 Thermal Design

All fuel in the Cycle 10 core is thermally similar, except for the urania-gadolinia fuel in the four LTAs. The fresh Batch 12 fuel inserted for Cycle 10 operation introduces no significant differences in fuel thermal performance relative to the other fuel remaining in the core. The linear heat rate to melt capability based on centerline fuel melt was assessed separately for each batch of fuel against Duke's generic linear heat rate to melt analysis, which is based on the TACO2⁶ computer code. The fuel parameters used to determine the fuel melt limits are shown in Table 4-2.

The analysis includes the following bounding, generic conservatisms:

1. A maximum gap based on as-fabricated pellet and cladding data.
2. Maximum incore densification based on resinter test results.

The burnup dependent linear heat rate (LHR) capability and the average fuel temperature for each batch are shown in Table 4-2.

The maximum assembly average burnup is predicted to be 40,347 MWd/MtU for the pure UO_2 fuel and 46,796 MWd/MtU for the Batch 10B $UO_2-Gd_2O_3$ fuel. The maximum fuel rod burnup is predicted to be 42,434 MWd/MtU for the pure UO_2 fuel and 48,882 MWd/MtU for the Batch 10B UO_2-GdO_3 fuel. Fuel rod internal pressure has been evaluated using TACO2⁶ with a conservative pin power history, and the maximum pressure is less than the nominal reactor coolant (RC) system pressure of 2200 psia.

4.4 Material Design

The Batch 12 fuel assemblies are not unique in concept, nor do they utilize different component materials. Therefore, the chemical compatibility of all possible fuel-cladding-coolant-assembly interactions for the Batch 12 fuel assemblies is identical to those of the present fuel.

Table 4-1.

Fuel Design Parameters and Dimensions

	Batch No.		
	<u>10B/10D</u>	<u>11</u>	<u>12</u>
FA type	Mark GdB4/ Mark B4	Mark B4Z	Mark B5Z
No. of FAs	4/49	64	60
Fuel rod OD, in.	0.430	0.430	0.430
Fuel rod ID, in.	0.377	0.377	0.377
Flex spacers, type	Spring	Spring	Spring
Rigid spacers, type	Zr-4	Zr-4	Zr-4
Undensified active fuel length, in.	143.5/ 141.8	141.8	141.8
Fuel pellet OD (mean spec), in.	0.3686	0.3686	0.3686
Fuel pellet initial density (mean spec), %TD	95.0	95.0	95.0
Initial fuel enrich- ment, wt % ²³⁵ U	4.00/ 3.41	3.31	3.24
Est. residence time, EOC 10, EFPH	29,668	19,920	9,840
Cladding collapse time, EFPH	>31,400	>31,400	>20,000

Table 4-2. Linear Heat Rate to Melt Analysis

	Batch No.			
	10B(c)	10D	11	12
Nominal initial density, % TD	95.0	95.0	95.0	95.0
Nominal initial pellet diameter, in.	0.3686	0.3686	0.3686	0.3686
Nominal initial clad ID, in.	0.377	0.377	0.377	0.377
Nominal initial clad OD, in.	0.430	0.430	0.430	0.430
Average linear heat rate @ 100% of 2568 MW, kW/ft	5.68	5.74	5.74	5.74
Linear heat rate capability ^(b) from 0-1000 MWD/MTU, kW/ft	17.6	20.15	20.15	20.15
Linear heat rate capability ^(b) >1000 MWD/MTU, kW/ft	17.6	21.20	21.20	21.20
Average fuel temp. @ nominal linear heat rate, °F	1240 ^(a)	1240 ^(a)	1240 ^(a)	1240 ^(a)

(a) Basis: TACO₂, 96.5% TD @ 4000 MWD/MTU, nominal pellet and cladding dimensions.

(b) These values are utilized as fuel design limits for Cycle 10.

(c) Gadolinia LTAs.

5. NUCLEAR DESIGN

5.1 Physics Characteristics

Table 5-1 compares the core physics parameters of design Cycle 10 with those of the reference Cycle 9. The values for Cycle 9 were generated by Babcock and Wilcox and are obtained from Reference 5. Cycle 10 values were generated by Duke Power Company using the CASMO-2 based reload design methods described in Reference 10. Since the core has not yet reached an equilibrium cycle, differences in core physics parameters are to be expected between the cycles. Figure 5-1 illustrates a representative relative power distribution for the beginning of Cycle 10 at full power with equilibrium xenon and normal rod positions.

The primary reasons for the differences in the physics parameters between Cycles 9 and 10 are the decreased number of fresh fuel assemblies, different BPRA loadings, and different shuffle patterns. Critical boron concentrations for Cycle 10 are lower because the design cycle length is shorter and there is more excess reactivity at the end of Cycle 9. Differences in rod worths between cycles are due to changes in the radial flux and burnup distributions. Calculated ejected rod worths and their adherence to criteria are considered at all times in life and at all power levels in the development of the rod position limits presented in the Core Operational Limits Report for Oconee 1 Cycle 10. All safety criteria associated with these rod worths are met. The adequacy of the shutdown margin with Cycle 10 stuck rod worths is demonstrated in Table 5-2. The following conservatisms were applied for the shutdown calculations:

1. Poison material depletion allowance.
2. 10% uncertainty on net rod worth.

Flux redistribution was explicitly accounted for since the shutdown analysis was calculated using a three-dimensional model. The reference fuel cycle shutdown margin is presented in the Oconee 1, Cycle 9 Reload Report.⁵

5.2 Analytical Input

The Cycle 10 incore measurement calculation constants to be used to compute core power distributions were obtained in a similar manner for Cycle 10 as for the reference cycle.

5.3 Changes in Nuclear Design

Core design changes for Cycle 10 include a reduction in the design cycle length to 400 EFPD, and a reduction in the number of fresh Mark BZ assemblies introduced to 60. The reference cycle contained 64 fresh assemblies. The number of BPRAs is also reduced from 60 to 52 for Cycle 10. Another difference is that Duke Power calculational methods are used to obtain the important nuclear design parameters for this cycle.

Table 5-1. Oconee 1 Physics Parameters^(a)

	Cycle 9 ^(b)	Cycle 10 ^(c)
Cycle length, EFPD	410	400
Cycle burnup, MWd/mtU	12,858	12,553
Average core burnup, EOC, MWd/mtU	24,724	25,496
Initial core loading, mtU	82.1	81.9
Critical boron - BOC (no xenon), ppm		
HZP, groups 7 and 8 at nominal positions ^(d)	1682	1558
HFP, groups 7 and 8 at nominal positions	1454	1319
Critical boron - EOC (equilibrium xenon), ppm		
HZP, groups 7 and 8 at nominal positions	457	422
HFP, groups 7 and 8 at nominal positions	121	38
Control rod worths - HFP, BOC, % $\Delta k/k$		
Group 7	0.93	0.89
Group 8 (e)	0.10	0.15
Control rod worths - HFP, EOC, % $\Delta k/k$		
Group 7	1.00	1.01
Group 8 (e)	0.10	0.19
Max ejected rod worth - HZP, % $\Delta k/k$		
BOC, (N12) groups 5-8 inserted	0.35	0.30
EOC, (N12) groups 5-8 inserted	0.36	0.35
Max stuck rod worth - HZP, % $\Delta k/k$		
BOC (N12)	1.31	0.86
EOC (N12)	1.35	1.35
Power deficit, HFP to HZP, % $\Delta k/k$		
BOC	1.51	1.73
EOC	2.29	2.93
Doppler coeff - HFP, 10^{-5} ($\Delta k/k-^{\circ}F$)		
BOC (equilibrium xenon)	-1.53	-1.22
EOC (equilibrium xenon)	-1.77	-1.54

Table 5-1. (Cont'd)

	<u>Cycle 9</u> ^(b)	<u>Cycle 10</u> ^(c)
Moderator coeff - HFP, 10^{-4} ($\Delta k/k$ -°F)		
BOC (equilibrium xenon)	-0.47	-0.66
EOC (equilibrium xenon)	-2.75	-2.93
Boron worth - HFP, ppm/% $\Delta k/k$		
BOC	130	126
EOC	111	116
Xenon worth - HFP, % $\Delta k/k$		
BOC (4 days)	2.53	2.55
EOC (equilibrium)	2.66	2.77
Effective delayed neutron fraction - HFP		
BOC	0.00621	0.00610
EOC	0.00526	0.00519

- (a) Cycle 10 data are for the conditions stated in this report. The Cycle 9 core conditions are identified in Reference 5.
- (b) Based on a 410-EFPD Cycle 8. (Actual Cycle 8 length 406.17 EFPD).
- (c) Based on a Cycle 9 length of 410-EFPD.
- (d) Nominal positions are as follows:

	<u>Cycle 9</u>	<u>Cycle 10</u>
HZP (BOC)	group 7 at 100% WD, 8 at 25.0% WD	group 7 at 100% WD, 8 at 25.0% WD
HFP (BOC)	group 7 at 93.5% WD, 8 at 32% WD	group 7 at 92% WD, 8 at 35% WD
HZP (EOC)	group 7 at 100% WD, 8 at 25.0% WD	group 7 at 100% WD, 8 at 25.0% WD
HFP (EOC)	group 7 at 100% WD, 8 at 32% WD	group 7 at 100% WD, 8 at 35% WD

- (e) Worth is calculated from 32% to 100% WD for Cycle 9, 35% to 100% WD for Cycle 10

Table 5-2. Shutdown Margin Calculation for
Oconee 1, Cycle 10

	BOC, <u>% $\Delta k/k$</u>	EOC, <u>% $\Delta k/k$</u>
<u>Available Rod Worth</u>		
Total rod worth, HZP	8.24	8.87
Worth reduction due to poison burnup	-0.42	-0.42
Maximum stuck rod, HZP	<u>-0.86</u>	<u>-1.35</u>
Net worth	6.96	7.10
Less 10% uncertainty	<u>-0.70</u>	<u>-0.71</u>
Total available worth	6.26	6.39
<u>Required Rod Worth</u>		
Power deficit, HFP to HZP	1.73	2.93
Max inserted rod worth, HFP	<u>0.30</u>	<u>0.44</u>
Total required worth	2.03	3.37
<u>Shutdown Margin</u>		
Total available worth minus total required worth	4.23	3.02

Note: Required shutdown margin is 1.00% $\Delta k/k$.

FIGURE 5-1
 OCONEE 1, CYCLE 10
 TWO DIMENSIONAL
 RELATIVE POWER DISTRIBUTION

HFP, 004 EFPD, EQXE
 NOMINAL ROD POSITIONS

	8	9	10	11	12	13	14	15
H	0.832	0.985	1.117	1.308	1.010	1.331	1.057	0.450
K	0.985	1.071	1.274	1.190	1.254	1.107	1.199	0.539
L	1.117	1.274	1.175	1.285	1.075	1.297	1.022	0.425
M	1.308	1.190	1.285	1.135	1.195	1.037	0.887	
N	1.010	1.254	1.075	1.195	1.000	0.781	0.421	
O	1.331	1.107	1.297	1.037	0.781	0.429		
P	1.057	1.199	1.022	0.887	0.421			
R	0.450	0.539	0.425					

SL

6. THERMAL-HYDRAULIC DESIGN

The generic Mark-B and Mark-BZ thermal-hydraulic design analyses supporting Cycle 10 operation were performed by Duke Power Company using the methods described in References 1, 3, 8, and 10. The Cycle 9 and Cycle 10 maximum design conditions are summarized in Table 6-1.

The Cycle 10 transition core will include 60 fresh Mark-BZ Batch 12 fuel assemblies, 52 of which will contain BPRAs, leaving 56 fuel assemblies with open guide tubes. This results in a core bypass flow of 8.2% of the total system flow, which is the bypass flow assumed in the generic thermal-hydraulic analyses. The core will also contain four gadolinia LTAs which are geometrically and hydraulically identical to the Mark-BZ assemblies.

The Mark-BZ fuel assembly has a slightly higher pressure drop than the Mark-B assembly as a result of the increased flow resistance of the Zircaloy spacer grids. The presence of Mark-BZ and Mark-B assemblies in a core results in less coolant flow in the Mark-BZ fuel than would occur in an all Mark-BZ core. The generic Mark-BZ analyses conservatively account for this transition core effect.

In a Mark-BZ transition core the limiting Mark-B hot channel will receive more coolant and yield better DNB performance than would be predicted for a full Mark-B core. Thus, the generic Mark-B analyses, based on the B&W-2 CHF correlation, are bounding and are applicable to the Cycle 10 transition core.

No fuel rod bow penalty was included in the DNBR limit used in the generic Mark-BZ analyses, as justified in Reference 9. The rod bow topical report concludes that a DNBR penalty is no longer required for thermal-hydraulic analyses. Nevertheless, to account for fuel rod bow, the generic Mark-B analyses used for determining plant operating limits (except the flux to flow setpoint analysis) were based on a DNBR criteria including 10.2% margin from

the 1.30 design limit. Primarily due to this conservatism, the current pressure-temperature envelope and design radial x local peaking have been shown to be conservative for a full and transition Mark-BZ core.

A flux to flow setpoint of 1.07 will be used for Cycle 10 operation. A conservative transition core pump coastdown analysis was performed based on a 1.07 flux to flow setpoint and the reference design radial-local peaking factor, $F_{\Delta H} = 1.714$. The minimum DNBR determined in the Mark-BZ transition core flux to flow analysis is greater than the BWC CHF correlation limit of 1.18, Reference 11. The minimum DNBR determined in the generic Mark-B flux to flow analysis, also based on a 1.07 flux to flow setpoint, is greater than the BAW-2 CHF correlation limit of 1.30.

Table 6-1. Thermal Hydraulic Design Conditions

	<u>Cycle 9</u>	<u>Cycle 10</u>
Design power level, MWt	2568	2568
System pressure, psia	2200	2200
Reactor coolant flow, % design flow	106.5	106.5
Core bypass flow, % total flow ^(a)	7.9	8.2
Vessel inlet/outlet coolant temp at 100% power, °F	555.6/602.4	555.6/602.4
Ref design radial-local power peaking factor	1.71	1.71
Ref design axial flux shape	1.5 cosine	1.5 cosine
Active fuel length, in.	141.8	141.8
Avg heat flux at 100% power, 10 ³ Btu/h-ft ²	176 ^(b)	176 ^(b)
CHF correlation	BAW-2/BWC	BAW-2/BWC
Min DNBR with densification penalty	>2.05/>1.74	>2.05/>1.74
Hot channel factors:		
Enthalpy rise	1.011/1.011	1.011/1.011
Heat flux	1.014/1.014	1.014/1.014
Flow area	0.98/0.97	0.98/0.97

(a) Generic analyses based on 8.2% core bypass flow.

(b) Heat flux based on a conservative minimum densified length of 140.3 in.

7. ACCIDENT AND TRANSIENT ANALYSIS

7.1 General Safety Analysis

Each FSAR¹ accident analysis has been examined with respect to changes in Cycle 9 parameters to determine the effect of the Cycle 10 reload and to ensure that thermal performance during hypothetical transients is not degraded. The effects of fuel densification on the FSAR accident results have been evaluated and are reported in Reference 8. Since Batch 12 reload fuel assemblies contain fuel rods with a theoretical density higher than those considered in Reference 8, the conclusions in that reference are still valid.

No new dose calculations were performed for the reload report. The dose considerations in Reference 5 are characteristic for Oconee 1 Cycle 10 based upon comparisons of key parameters which determine radionuclide inventories.

7.2 Accident Evaluations

The key parameters that have the greatest effect on determining the outcome of a transient can typically be classified in three major areas: core thermal parameters, thermal-hydraulic parameters, and kinetics parameters, including the reactivity feedback coefficients and control rod worths.

Fuel thermal analysis parameters for each batch in Cycle 10 are given in Table 4-2. Table 6-1 compares the Cycle 9 and 10 thermal-hydraulic maximum design conditions. Table 7-1 compares the key kinetics parameters from the FSAR and Cycle 10.

A generic LOCA analysis for the B&W 177-FA, lowered-loop NSSS has been performed using the Final Acceptance Criteria ECCS Evaluation Model given in BAW-10103, Rev. 3.¹² The analysis in BAW-10103 is generic since the limiting values of key parameters for all plants in this category were used. Furthermore, the combination of average fuel temperature as a function of LHR

and the lifetime pin pressure data used in the BAW-10103 LOCA limits analysis^{7,12} is conservative compared to those calculated for this reload. In addition, it has been determined that the slightly lower prepressurization of the Batch 12 fuel rods has a negligible impact on the LOCA analyses¹⁴. Thus, the analysis and the LOCA limits reported in BAW-10103 provide conservative results for the operation of Oconee 1, Cycle 10 fuel. The Oconee 1 Cycle 10 core contains four gadolinia LTAs. Analysis has shown that the gadolinia assemblies are non-limiting with respect to LOCA kw/ft limits.

The LOCA kw/ft limits have been reduced for the first 65 EFPDs. This reduction will ensure conservative limits based upon an interim bounding analytical assessment of NUREG 0630 on LOCA and operating kw/ft limits performed by Babcock and Wilcox^{4,15}. The LOCA kw/ft limits for the first 65 EFPD are shown in Table 7-2. Table 7-3 shows the bounding values for allowable LOCA peak LHRs for Oconee 1 Cycle 10 fuel after 65 EFPD.

From the examination of Cycle 10 core thermal properties and kinetics properties with respect to acceptable previous cycle values, it is concluded that this core reload will not adversely affect the safe operation of Oconee 1 during Cycle 10. Considering the previously accepted design basis used in the FSAR and subsequent cycles, the transient evaluation of Cycle 10 is considered to be bounded by previously accepted analyses. The initial conditions of the transients in Cycle 10 are bounded by the FSAR and/or the fuel densification report.⁸

Table 7.1. Comparison of Key Parameters for Accident Analysis

<u>Parameter</u>	<u>FSAR¹ value</u>	<u>Predicted Cycle 10 value</u>
BOC Doppler coeff, 10^{-5} , $\Delta k/k/^\circ F$	-1.17	-1.22
EOC Doppler coeff, 10^{-5} $\Delta k/k/^\circ F$	-1.33 ^(a)	-1.54
BOC moderator coeff, 10^{-4} , $\Delta k/k/^\circ F$	+0.5 ^(b)	-0.66
EOC moderator coeff, 10^{-4} , $\Delta k/k/^\circ F$	-3.0	-2.93
All rod bank worth, HZP, % $\Delta k/k$	10.0	8.87
Boron reactivity worth, 70°F ppm/1% $\Delta k/k$	75	88
Max. ejected rod worth, HFP, % $\Delta k/k$	0.65	0.15
Dropped rod worth, HFP, % $\Delta k/k$	0.46	0.12
Initial boron conc, HFP, ppm	1400	1319

(a) $-1.2 \times 10^{-5} \Delta k/k/F$ was used for steam line break analysis.

$-1.3 \times 10^{-5} \Delta k/k/F$ was used for cold water accident (pump start-up).

(b) $+0.94 \times 10^{-4} \Delta k/k/F$ was used for the moderator dilution accident.

Table 7-2. LOCA Limits, Oconee 1, Cycle 10

<u>Elevation,</u> <u>ft</u>	<u>LHR Limits, kW/ft</u>	
	<u>0-1000 MWd/mtU^(a)</u>	<u>1000-2600 MWd/mtU^(b)</u>
2	13.5	15.0
4	16.1	16.6
6	16.5	18.0
8	17.0	17.0
10	16.0	16.0

Table 7-3. LOCA Limits, Oconee 1, Cycle 10,
After 2600 MWD/mtU(b)

<u>Elevation,</u> <u>ft</u>	<u>LHR limits,</u> <u>kW/ft</u>
2	15.5
4	16.6
6	18.0
8	17.0
10	16.0

(a) 1000 MWd/mtU corresponds to approximately 25 EFPD for the most limiting assembly

(b) 2600 MWd/mtU corresponds to approximately 65 EFPD for the most limiting assembly

8. PROPOSED MODIFICATIONS TO TECHNICAL SPECIFICATIONS

The Technical Specifications have been revised for Cycle 10 operation in accordance with the methods of Reference 10 to account for minor changes in power peaking and control rod worths. Section 2 of the Technical Specifications has been edited to reflect the fact that the safety limits and limiting safety system settings are identical for all three Oconee units.

The figures for the operating limits on rod index and axial power imbalance have been removed from Section 3 of the Technical Specifications and will be included in the cycle specific Core Operational Limits Report.

In addition:

1. The operating limits on rod index and axial power imbalance were developed in accordance with the LOCA linear heat rate limits discussed in Chapter 7. These operational limits are provided in the Oconee 1 Cycle 10 Core Operational Limits Report.
2. Due to the lower worth of the gray APSRs, operational limits for the Group 8 control rods are not required for Cycle 10. Administrative position and maneuvering limits for the APSRs, however, will be utilized to ensure adequate fuel performance during Cycle 10 operation.

Based on the Technical Specifications derived from the analyses presented in this report, The Final Acceptance Criteria ECCS limits will not be exceeded, nor will the thermal design criteria be violated. Figures 8-1 and 8-2 are revisions to previous Technical Specification limits.

Figure 8-1

Core Protection Safety Power-Imbalance Limits





Figure 8-2.

Maximum Allowable Power-Imbalance Setpoints



REFERENCES

1. Oconee Nuclear Station, Units 1, 2, and 3 Final Safety Analysis Report, Docket Nos. 50-269, 50-270, and 50-287.
2. Gadolinia - Bearing Lead Test Assemblies Design Report, BAW-1772-P, Babcock & Wilcox, Lynchburg, Virginia, June 1983.
3. Oconee Unit 3, Cycle 9 - Reload Report, DPC-RD-2005, Duke Power Company, May, 1985.
4. Bounding Analytical Assessment of NUREG 0630 on LOCA and Operating kw/ft Limits, B&W Document No. 77-1141256-00, Babcock & Wilcox.
5. Oconee Unit 1, Cycle 9 - Reload Report, BAW-1841, Babcock & Wilcox, August 1984.
6. TACO2 - Fuel Performance Analysis, BAW-10141P-A, Rev. 1, Babcock & Wilcox, June 1983.
7. J. H. Taylor (B&W) to S. A. Varga (NRC), Letter, July 18, 1978.
8. Oconee 1 Fuel Densification Report, BAW-1388, Rev. 1, Babcock & Wilcox, July 1973.
9. Fuel Rod Bowing in Babcock & Wilcox Fuel Designs, BAW-10147P-A, Rev. 1, Babcock & Wilcox, May 1983.
10. Oconee Nuclear Station Reload Design Methodology II, DPC-NE-1002, Duke Power Company, Charlotte, North Carolina, March 1985.
11. Correlation of 15x15 Geometry Zircaloy Grid Rod Bundle CHF Data with the BWC Correlation, BAW-10143, Part 2, Babcock & Wilcox, Lynchburg, Virginia, March 1980.
12. ECCS Analysis of B&W's 177-FA Lowered-Loop NSS, BAW-10103, Rev. 3, Babcock & Wilcox, July 1977.
13. Program to Determine In-Reactor Performance of B&W Fuels - Cladding Creep Collapse, BAW-10084A, Rev. 2, Babcock & Wilcox Co., Lynchburg, Virginia, October 1978.
14. R. J. Walker (B&W) to K. S. Canady (Duke Power Company), Letter, February 18, 1985.

REFERENCES (Cont'd)

15. BOL LOCA Limits, B & W Document No. 86-1153360-00, Babcock & Wilcox, April 1985.
16. Oconee Unit 2, Cycle 8 - Reload Report, DPC-RD-2004, Duke Power Company, December 1984.
17. Mark-B Gadolinia LTA Mechanical Evaluation Oconee 1 Cycle 10, B&W Document No. 51-1157033-00, June 1985.
18. Oconee 1 Cycle 10 LTA Evaluation, B&W Document No. 51-1158394-00, June 1985.
19. Oconee Unit 3, Cycle 7 - Reload Report, DPC-RD-2001, Rev. 1, Duke Power Company, July 1982.

