

ACCESSION NBR: 7908100270 DC DATE: 79/08/06 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation

SUBJECT: Forwards proposed changes to Tech Specs required to support operation at full rated power during Cycle 6, Class IV amend & Cycle 6 Reload Rept encl.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 40 SIZE: 3+71
 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC

NOTES: W/CHECK \$13,100.00 Rpt Given to Subj Files on 8-17-79
for Microfiching

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	05 BC ORB 4	7	7			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	16 AD SYS/PROJ	1	1
	17 ENGR BR	1	1	18 REAC SFTY BR	1	1
	19 PLANT SYS BR	1	1	20 EEB	1	1
	21 EFLT TRT SYS	1	1	22 BRINKMAN	1	1
	OELD	1	0			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

M CUNNINGHAM - All AMOIS TO FSAR + CHANGES TO TECH SPECS.

Rpt: "Oconee Unit 1, Cycle 6, Reload Rpt." AUG 13 1979
 BAW-1552
 JULY 1979
 MNO: 7908100287

MPP2
 CCP

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

August 6, 1979

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

REGULATORY DOCKET FILE COPY

Attention: Mr. R. W. Reid, Chief
Operating Reactors Branch #4

Re: Oconee Nuclear Station, Unit 1
Docket No. 50-269

Dear Sir:

Pursuant to 10CFR50, §50.90, please find attached proposed changes to the Oconee Nuclear Station Technical Specifications which are required to support the operation of Oconee Unit 1 at full rated power during Cycle 6.

This proposal contains changes to the Core Protection Safety Limits, Protective System Maximum Allowable Setpoints, and Rod Position Limits of Specifications 2.1, 2.3 and 3.5.2, respectively. Also attached is a Babcock and Wilcox Report BAW-1552, "Oconee Unit 1, Cycle 6, Reload Report." This report includes a summary of Cycle 6 operating parameters and contains the safety analyses supporting the operation of the Oconee 1, Cycle 6 core at rated power in accordance with the Technical Specifications provided.

Also included in this proposal are changes to Specification 3.3, Emergency Core Cooling, Reactor Building Cooling, Reactor Building Spray, and Low Pressure Service Water Systems. These changes have been proposed to simplify the presentation of the existing specification and to incorporate the appropriate Limiting Condition for Operation for Unit 3 with the HPI cross-connect installed.

The Bases of Specification 4.1 has been revised to reflect the current practice of instrument calibration following transient conditions of operation.

The Unit 1, Cycle 6 physics test will be conducted consistent with the testing program previously described for Cycle 5.

790810020


A001
S 3/40

W/Check
#13,100

Mr. Harold R. Denton, Director
Page Two
August 6, 1979

This proposed revision to the Oconee Nuclear Station Technical Specifications is considered to be a Class IV amendment for Unit 1 with two Class I amendments for essentially identical Units 2 and 3. Accordingly, a check in the amount of \$13,100 is attached.

Very truly yours,




William O. Parker, Jr.

RLG:scs
Attachment


Mr. Harold R. Denton
Page 3
August 6, 1979

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



William O. Parker, Jr., Vice President

Subscribed and sworn to before me this 6th day of August, 1979.



Vivian B. Robbins
Notary Public

My Commission Expires:

February 15, 1982