

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

9/15/79

ACCESSION NBR: 7909130239 DOC. DATE: 79/09/11 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION  
 PARKER, W.O. Duke Power Co.  
 RECID. NAME RECIPIENT AFFILIATION  
 REID, R.W. Operating Reactors Branch 4  
 DENTON, H.R. Office of Nuclear Reactor Regulation

SUBJECT: Forwards proposed amend to Licenses DPR-38, DPR-47 & DPR-55 to incorporate secondary water-chemistry monitoring program.

DISTRIBUTION CODE: A0015 COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 3  
 TITLE: General Distribution for After Issuance of Operating Lic

NOTES: M. CUNNINGHAM ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
	05 BC ORB #4	7	7			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	17 ENGR BR	1	1
	18 REAC SFTY BR	1	1	19 PLANT SYS BR	1	1
	20 EEB	1	1	21 EFLT TRT SYS	1	1
	22 BRINKMAN	1	1	OELD	1	0
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

SEP 14 1979

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 37

K.B.  
 Appl 2

DUKE POWER COMPANY  
POWER BUILDING  
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

September 11, 1979

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

**REGULATORY DOCKET FILE COPY**


Attention: Mr. Robert W. Reid, Chief  
Operating Reactor Branch No. 4

Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

In your letter of July 23, 1979 you requested that Duke Power Company propose an amendment to the Facility Operating Licenses for the Oconee Nuclear Station to incorporate a secondary water-chemistry monitoring program. Please find attached the requested proposed amendment. As noted in your letter, this supplements an earlier proposal dated September 22, 1976, and, as such, no licensing fees are required.

Very truly yours,



William O. Parker, Jr.


WOP:scs  
Attachment

Acc  
5/3

7909130 239 p

Mr. Harold R. Denton, Director  
September 11, 1979  
Page Two

WILLIAM O PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Facility Operating Licenses DPR-38, DPR-47 and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

  
\_\_\_\_\_  
William O. Parker, Jr., Vice President

Subscribed and sworn to before me this 11th day of September, 1979.

\_\_\_\_\_  
Notary Public

My Commission Expires:

February 15, 1982

DUKE POWER COMPANY  
OCONEE NUCLEAR STATION

Proposed Amendment to Operating Licenses  
DPR-38, -47, -55

- 3G. The licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include:
1. Identification of a sampling schedule for the critical parameters and control points for these parameters;
  2. Identification of the procedures used to quantify parameters that are critical to control points;
  3. Identification of process sampling points;
  4. Procedure for the recording and management of data;
  5. Procedures defining corrective actions for off control point chemistry conditions; and
  6. A procedure identifying the authority responsible for the interpretation of the data, and the sequence and timing of administrative events required to initiate corrective action.