

3

LIMITING CONDITIONS FOR OPERATION

3.0

LIMITING CONDITION FOR OPERATION

Specification

In the event a Limiting Condition for Operation and/or associated Action requirements cannot be satisfied because of circumstances in excess of those addressed in the specification, the affected unit shall be placed in at least Hot Shutdown within the next 12 hours, and in at least Cold Shutdown within the following 24 hours unless corrective measures are completed that permit operation under the permissible Action statements for the specified time interval as measured from initial discovery or until the reactor is placed in a mode in which the specification is not applicable. Exceptions to these requirements shall be stated in the individual specifications.

Base

This specification delineates the ACTION to be taken for circumstances not directly provided for in the ACTION statements and whose occurrence would violate the intent of the specification. For example, Specification 3.3.1 requires that two independent trains of the High Pressure Injection (HPI) System be operable and provides explicit Action requirements if one train of the HPI System is inoperable. Under the terms of Specification 3.0, if more than one train of the HPI System is inoperable, the affected unit is required to be in at least Hot Shutdown within the following 12 hours and in at least Cold Shutdown within the following 24 hours. It is assumed that the unit is brought to the required mode within the required times by promptly initiating and carrying out the appropriate Action statement.

### 3.1 REACTOR COOLANT SYSTEM

#### Applicability

Applies to the operating status of the reactor coolant system.

#### Objective

To specify those limiting conditions for operation of the reactor coolant system components which must be met to ensure safe reactor operation.

#### Specification

##### 3.1.1 Operational Components

###### a. Reactor Coolant Pumps

1. Whenever the reactor is critical, single pump operation shall be prohibited, single-loop operation shall be restricted to testing, and other pump combinations permissible for given power levels shall be as shown in Table 2.3-1.
2. Except for test purposes and limited by Specification 2.3, power operation with one idle reactor coolant pump in each loop shall be restricted to 24 hours. If the reactor is not returned to an acceptable RC pump operating combination at the end of the 24-hour period, the reactor shall be in a hot shutdown condition within the next 12 hours.
3. The boron concentration in the reactor coolant system shall not be reduced unless at least one reactor coolant pump or one low pressure injection pump is circulating reactor coolant.

###### b. Steam Generator

1. One steam generator shall be operable whenever the reactor coolant average temperature is above 250°F.

###### c. Pressurizer Safety Valves

1. All pressurizer code safety valves shall be operable whenever the reactor is critical.
2. At least one pressurizer code safety valve shall be operable whenever all reactor coolant system openings are closed, except for hydrostatic tests in accordance with the ASME Section III Boiler and Pressure Vessel Code.