

UNITED STATES
NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

Submitted: August 10, 2015

ENERGY NUCLEAR INDIAN POINT 3, LLCAND ENERGY NUCLEAR OPERATIONS, INC.DOCKET NO. 50-286INDIAN POINT NUCLEAR GENERATING UNIT NO. 3AMENDED FACILITY OPERATING LICENSE

Amendment No. 203
 License No. DPR-64

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Power Authority of the State of New York (PASNY) and Entergy Nuclear Indian Point 3, LLC (ENIP3) and Entergy Nuclear Operations, Inc. (ENO), submitted under cover letters dated May 11 and May 12, 2000, as supplemented on June 13, June 16, July 14, September 21, October 26, and November 3, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I; Amdt. 203
11/27/00
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. ENIP3 and ENO are financially and technically qualified to engage in the activities authorized by this amendment; Amdt. 203
11/27/00
 - E. ENIP3 and ENO have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements" of the Commission's regulations; Amdt. 203
11/27/00
 - F. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public;

Amendment No. 225

- G. The receipt, possession and use of source, byproduct and special nuclear material as authorized by this amendment will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70 including 10 CFR Sections 30.33, 40.32, 70.23, and 70.31; and
 - H. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. DPR-64 (previously issued to Consolidated Edison Company of New York, Inc., and the Power Authority of the State of New York) is hereby amended in its entirety and transferred to ENIP3 and ENO on November 21, 2000, to read as follows:
- A. This amended license applies to the Indian Point Nuclear Generating Unit No. 3, a pressurized water nuclear reactor and associated equipment (the facility), owned by ENIP3 and operated by ENO. The facility is located in Westchester County, New York, on the east bank of the Hudson River in the Village of Buchanan, and is described in the "Final Facility Description and Safety Analysis Report" as supplemented and amended, and the Environmental Report, as amended. Amdt. 203
11/27/00
 - B. Subject to the conditions and requirements incorporated herein, the Commission licenses:
 - (1) Pursuant to Section 104b of the Act and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," (a) ENIP3 to possess and use, and (b) ENO to possess, use and operate, the facility at the designated location in Westchester County, New York, in accordance with the procedures and limitations set forth in this amended license; Amdt. 203
11/27/00
 - (2) ENO pursuant to the Act and 10 CFR Part 70, to receive, possess, and use, at any time, special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Facility Description and Safety Analysis Report, as supplemented and amended; Amdt. 203
11/27/00
 - (3) ENO pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use, at any time, any byproduct source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required; Amdt. 203
11/27/00

3.1 REACTIVITY CONTROL SYSTEMS

3.1.4 Rod Group Alignment Limits

- LCO 3.1.4 All shutdown and control rods shall be OPERABLE, with rod group alignment limits as follows:
- a. When THERMAL POWER is $> 85\%$ RTP, the difference between each individual indicated rod position and its group step counter demand position shall be within the limits specified in Table 3.1.4-1 for the group step counter demand position; and
 - b. When THERMAL POWER is $\leq 85\%$ RTP, the difference between each individual indicated rod position and its group step counter demand position shall be within 24 steps.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more rod(s) untrippable.	A.1.1 Verify SDM is within the limits specified in the COLR.	1 hour
	<u>OR</u>	
	A.1.2 Initiate boration to restore SDM to within limit.	1 hour
	<u>AND</u>	
	A.2 Be in MODE 3.	6 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. One rod not within alignment limits.</p>	<p>B.1 Restore rod to within alignment limits.</p>	<p>1 hour</p>
	<p>OR</p>	
	<p>B.2.1.1 Verify SDM is within the limits specified in the COLR.</p>	<p>1 hour</p>
	<p>OR</p>	
	<p>B.2.1.2 Initiate boration to restore SDM to within limit.</p>	<p>1 hour</p>
	<p>AND</p>	
	<p>B.2.2 Reduce THERMAL POWER to < 75% RTP.</p>	<p>2 hours</p>
	<p>AND</p>	
	<p>B.2.3 Verify SDM is within the limits specified in the COLR.</p>	<p>Once per 12 hours</p>
	<p>AND</p>	
<p>B.2.4 Perform SR 3.2.1.1.</p>	<p>72 hours</p>	
<p>AND</p>		
<p>B.2.5 Perform SR 3.2.2.1.</p>	<p>72 hours</p>	
<p>AND</p>		

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B (continued)	B.2.6 Re-evaluate safety analyses and confirm results remain valid for duration of operation under these conditions.	5 days
C. Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 3.	6 hours
D. More than one rod not within alignment limit.	D.1.1 Verify SDM is within the limits specified in the COLR. <u>OR</u> D.1.2 Initiate boration to restore required SDM to within limit. <u>AND</u> D.2 Be in MODE 3.	1 hour 1 hour 6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.1.4.1 NOTE..... Not required to be met for individual control rods until 1 hour after completion of control rod movement. Verify individual rod positions within alignment limit.</p>	<p>12 hours</p>
<p>SR 3.1.4.2 Verify rod freedom of movement (trippability) by moving each rod not fully inserted in the core > 10 steps in one direction.</p>	<p>92 days</p>
<p>SR 3.1.4.3 Verify rod drop time of each rod, from the fully withdrawn position, is \leq 1.8 seconds from the loss of stationary gripper coil voltage to dashpot entry, with:</p> <p>a. $T_{avg} \geq 500^{\circ}F$; and</p> <p>b. All reactor coolant pumps operating.</p>	<p>Prior to reactor criticality after each removal of the reactor head</p>

Table 3.1.4-1

Maximum Permissible Rod Misalignment
(Indicated Rod Position minus Group Step Counter Demand Position)
When > 85 % RTP

Step Counter Demand Position (steps)	Maximum Permissible Deviations (IRPI Position minus Step Counter Demand Position) (steps)
≤ 212	≥ -12 and ≤ +12
213 to 225	≥ -12 and ≤ +17
226	≥ -13 and ≤ +17
227	≥ -14 and ≤ +17
228	≥ -15 and ≤ +17
229	≥ -16 and ≤ +17
≥ 230	≥ -17 and ≤ +17

3.1 REACTIVITY CONTROL SYSTEMS

3.1.5 Shutdown Bank Insertion Limits

LCO 3.1.5 Each shutdown bank shall be within insertion limits specified in the COLR.

APPLICABILITY: MODE 1,
 MODE 2 with any control bank not fully inserted.

.....NOTE.....
This LCO is not applicable while performing SR 3.1.4.2.
.....

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more shutdown banks not within limits.	A.1.1 Verify SDM is within the limits specified in the COLR.	1 hour
	OR	
	A.1.2 Initiate boration to restore SDM to within limit.	1 hour
	AND	
	A.2 Restore shutdown banks to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours