

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8302160236 DOC. DATE: 83/02/10 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director
 STOLZ, J.F. Operating Reactors Branch 4

SUBJECT: Application for amend to Licenses DPR-38, DPR-47 & DPR-55, allowing use of RCS inservice leak & hydrostatic test heatup & cooldown limitations during performance of leak tests of connected sys.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+10
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy. 05000269
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR ORB4 BC 01	7	7			
INTERNAL:	ELD/HDS4	1	0	NRR/DE/MTEB	1	1
	NRR/DL DIR	1	1	NRR/DL/ORAB	1	0
	NRR/DSI/MTEB	1	1	NRR/DSI/RAB	1	1
	<u>REG FILE</u> 04	1	1	RGN2	1	1
EXTERNAL:	ACRS 09	6	6	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			
NOTES:		1	1			

w/check: \$4800.00

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

February 10, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

Pursuant to 10 CFR 50, §50.90, please find attached a proposed amendment to the Oconee Facility Operating License and revision to the Oconee Technical Specifications. This proposal consists of several changes of minimal safety impact.


Specification 3.1.2 has been revised to allow the use of the Reactor Coolant System (RCS) inservice leak and hydrostatic test heatup and cooldown limitations during the performance of leak tests of connected systems when the RCS pressure-temperature limits are controlling. Additional justification is provided in the bases of the Specification.

Table 4.4-1 of Specification 4.4 has been revised to reflect that Penetrations 24, 42 are now in use as part of the Reactor Building Hydrogen Analyzer installed pursuant to NUREG-0737.

Specifications 4.5.1.2.1, 4.5.2.2.1, 4.9.1, 4.9.2 have been revised to make the surveillance frequencies consistent with the requirements of Section XI of the ASME Boiler and Pressure Vessel Code and applicable addenda as required by 10 CFR 50.55a(g)(4).

This proposed revision to the Oconee Technical Specifications is considered to consist of one Class III and two Class I license amendments. Accordingly, please find enclosed a check in the amount of \$4800 for the applicable licensing fees.

Very truly yours,



Hal B. Tucker

RLG/php
Attachment

*A001
w/check:
\$4800.00*

8302160236 830210
PDR ADOCK 05000269
P PDR

Mr. Harold R. Denton, Director
February 10, 1983
Page 2


cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. E. L. Conner, Jr.
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Mr. Harold R. Denton, Director
February 10, 1983
Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 10th day of February, 1983


Notary Public

My Commission Expires:

September 20, 1984