

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8305270259 DOC. DATE: 83/05/19 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH. NAME: TUCKER, H.B. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director
 STOLZ, J.F. Operating Reactors Branch 4

SUBJECT: Application to amend License DPR-38 changing core protection
 safely limits, protective sys max allowable setpoints & rod
 position limits. *SEE SUBT FILE for BAN 1774*

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 4+85
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy.

05000269

We check: \$12,876.00

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR ORB4 BC 01	7	7			
INTERNAL:	ELD/HDS4	1	0	NRR/DE/MTEB	1	1
	NRR/DL DIR	1	1	NRR/DL/ORAB	1	0
	NRR/DSI/METB	1	1	NRR/DSI/RAB	1	1
	<u>REG FILE</u> 04	1	1	RGN2	1	1
EXTERNAL:	ACRS 09	6	6	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

NOTES:

All Extras to NRR ORB#4BC

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

May 19, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station, Unit 1
Docket No. 50-269

Dear Sir:

Pursuant to 10 CFR 50, §50.90, please find attached proposed changes to the Oconee Nuclear Station (ONS) Technical Specifications which are required to support the operation of Oconee Unit 1 at full rated power during Cycle 8.

This proposal contains changes which concern the following:

1. Core Protection Safety Limits of Specification 2.1;
2. Protective System Maximum Allowable Setpoints of Specification 2.3;
3. Rod Position Limits of Specification 3.5.2.

Also attached, as Attachment 4, is Babcock and Wilcox Report BAW-1774, "Oconee Unit 1, Cycle 8 Reload Report". This report includes a summary of Cycle 8 operating parameters and contains the safety analyses supporting the operation of Oconee 1, Cycle 8 core at rated power in accordance with the Technical Specifications provided.

This reload report employs a LOCA analysis which does not incorporate the NUREG-0630 data. My letter of March 7, 1983 stated the bounding analytical assessment of NUREG-0630 on LOCA and operating kw/ft limits, when implemented, would result in a 0.5 kw/ft penalty at the 2, 4 and 6 foot elevations. Further, it was stated that these penalties would be factored into the upcoming reload analysis and submittals for this year (Oconee 1 Cycle 8 and Oconee 2 Cycle 7). This analysis utilizing the heat transfer correlation based on the FLECHT-SEASET tests is currently in progress in an attempt to obtain optimum operating limits. The reanalysis and a supplement containing the required changes will be submitted by June 20, 1983.

Startup testing of Oconee Unit 1 Cycle 8 will be performed in accordance with a modified version of the report entitled "Oconee Nuclear Station Generic Startup Physics Test Program" which was initially approved by the Staff by a March 23, 1981 letter and as modified by a May 29, 1981 Duke letter. The modification to the report involves the following:

8305270259 830519
PDR ADOCK 05000269
P PDR

ADD
5
1/40
w/d lect
#12, 876.00

Mr. Harold R. Denton, Director
May 19, 1983
Page 2

1. Establishing a criterion for possible elimination of the 75% Full Power (FP) Distribution Test
2. Changing the names of the 40% FP, 75% FP and the 100% FP Distribution Tests to low power core mapping, intermediate power core mapping and full power core mapping, respectively
3. The core symmetry test and the core mapping tests are to be performed within the following power ranges:

Core Symmetry - 5 to 20% FP
Low Power Core Mapping - 30 to 60% FP
Intermediate Power Core Mapping - 70 to 85% FP
Full Power Core Mapping - 90 to 100% FP

4. Changes to the Core Symmetry and the Critical Boron Concentration Tests


Please find attached the modified version of the "Oconee Nuclear Station Generic Startup Physics Test Program" and a discussion justifying the change (Attachment 2). This modified version will be used for the Oconee 1 Cycle 8 reload and all subsequent reloads thereafter.

Duke has determined that the activities associated with the proposed amendment do not constitute a significant hazard to the public health and safety of the environment. Analysis of the proposed amendment was performed in accordance with the standards contained in §50.92 regarding the issue of no significant hazards consideration. Please find attached (Attachment 3) the No Significant Hazards Consideration evaluation. Further, Duke is forwarding a copy of this application to the South Carolina Department of Health & Environmental Control for review and, as appropriate, subsequent consultation with the Staff.

Oconee 1 is expected to be shut down June 3, 1983 to commence the Cycle 8 refueling outage. The present expected duration is 63 days; however this length may change as a result of activities planned during the outage. The NRC will be kept apprised of the schedule for restart through the Project Manager.

This proposed revision to the Oconee Technical Specifications is a Class IV licensing action. Therefore, pursuant to 10 CFR 170, §170.12, please find enclosed a check in the amount of \$12,300 as set forth in §170.22.

Very truly yours,



Hal B. Tucker

PFG/php
Attachment

Mr. Harold R. Denton, Director

May 19, 1983

Page 3

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Mr. John F. Suermann
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. Hayward Shealey, Chief
Bureau of Radiological Health
South Carolina Department of Health and
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. Harold R. Denton, Director
May 19, 1983
Page 4

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 19th day of May, 1983


Sue C. Merrill
Notary Public

My Commission Expires:

September 20, 1984