



August 11, 2015

NRC 2015-0045
10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
Renewed License Nos. DPR-24 and DPR-27

Technical Requirements Manual Change Summary

In accordance with 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra), is submitting changes made to the Point Beach Nuclear Plant Technical Requirements Manual (TRM).

The enclosure contains the TRM change summary for the period January 1, 2014, through December 31, 2014. NextEra previously submitted the TRM change summary for January 1, 2013, through December 31, 2013, on August 21, 2014 (ML14233A426).

This letter contains no new commitments and no revisions to existing commitments.

If you have questions or require additional information, please contact me at (920) 755-7599.

Very truly yours,

NextEra Energy Point Beach, LLC

A handwritten signature in black ink, appearing to read "Bryan Woyak".

Bryan Woyak
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC

ENCLOSURE

NEXTERA ENERGY POINT BEACH, LLC POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

TECHNICAL REQUIREMENT MANUAL CHANGE SUMMARY FOR 2014

<u>Affected Section</u>	<u>Date of Change</u>	<u>Affected Pages(s)</u>	<u>Summary</u>
2.1 (U1)	10/15/14	All	New Core Operating Limits for Unit 1 Cycle 36.
2.1 (U2)	3/26/14	All	New Core Operating Limits for Unit 2 Cycle 34.
2.2	11/20/14	All	Revised Reactor Coolant System Pressure and Temperature Limits Report to reflect issuance of Amendments 250 and 254.
3.4.5	9/18/14	3.4.5-1, 3	Corrected the Technical Requirements Manual (TRM) Limiting Condition for Operation (TLCO) Applicability verbiage for chloride, fluoride and oxygen concentration limits.
3.7.7	6/26/14	3.7.7-1, 7, 9	Removed reference to Auxiliary Feedwater Pump 2P-29. This pump is no longer impacted by Service Water limitations due to a station modification that resulted in no longer using Service Water for pump bearing cooling.