

*Central File*

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

April 21, 1981

TELEPHONE: AREA 704  
373-4083

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, GA 30303



Re: Oconee Nuclear Station  
IE Bulletin 80-11  
Docket Nos. 50-269, -270, -287

Dear Sir:

Your letter of March 13, 1981 requested interim progress reports during the analysis and evaluation phase of IE Bulletin 80-11 work.

Attachment I details the present status of analysis. As pointed out in my letter of February 9, 1981, the walls included in Priority II and III have configurations requiring more sophisticated analysis techniques and therefore require significantly more analysis time. In many cases, it has become necessary to perform a separate computer analysis for each wall.

To date, no walls that have been analyzed have required upgrading to meet the criteria outlined in Section 6.0 of the Oconee Criteria for Evaluation of Masonry Walls.

Very truly yours,

*William O. Parker, Jr.*  
William O. Parker, Jr.

FTP/mwk  
Attachment

cc: Director  
Division of Reactor Operations  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Q 105060245

ATTACHMENT 1

OCONEE NUCLEAR STATION  
UNITS 1-3  
ANALYSIS AND EVALUATION STATUS  
APRIL 15, 1981

	<u>Number of Walls</u>	<u>Qualified By Analysis</u>	<u>Percent of Engineering Effort Complete</u>
Priority I	175	174	98%
Priority II	266	163	40%
Priority III	42	-	-
TOTAL	483	337	