

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9007170195 DOC. DATE: 90/07/11 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 50-369 William B. McGuire Nuclear Station, Unit 1, Duke Powe 05000369
 50-370 William B. McGuire Nuclear Station, Unit 2, Duke Powe 05000370
 50-413 Catawba Nuclear Station, Unit 1, Duke Power Co. 05000413
 50-414 Catawba Nuclear Station, Unit 2, Duke Power Co. 05000414

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC Bulletin 90-001, "Loss of Fill-Oil in Transmitters Mfg by Rosemount."

DISTRIBUTION CODE: IE39D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: NRC Bulletin 90-001, Loss of Fill Oil in Transmitters Mfg by Rosemount

NOTES: LPDR 2cys AMDTS to FSAR. ASLB 1cy. 05000413
 LPDR 2cys AMDTS to FSAR. ASLB 1cy. 05000414

		RECIPIENT	COPIES		RECIPIENT	COPIES	
		ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
		PD2-3 LA	1	0	PD2-3 PD	1	1
		WIENS, L	1	1	HOOD, D	1	1
		JABBOUR, K	1	1			
INTERNAL:		NRR LE, N	1	1	NRR PERCH, R	1	1
		NRR RAMSEY, J	2	2	NRR/DRIS/RVIB	1	1
		REG FILE 02	1	1	RES FARMER, W	1	1
		RGN2 FILE 01	1	1			
EXTERNAL:		LPDR	3	3	NRC PDR	1	1
		NSIC	1	1			
NOTES:			3	3			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 20

Handwritten initials/signature

Duke Power Company
P.O. Box 33198
Charlotte, N.C. 28242

HAL B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

July 11, 1990

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, -270, -287
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369, -370
Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413, 414
Loss of Fill-Oil in Transmitters Manufactured by Rosemount
Response to NRC Bulletin No. 90-01

Gentlemen:

The subject NRC Bulletin 90-01 dated March 9, 1990 requested that addresses promptly identify and take appropriate corrective actions for Model 1153 Series B, Model 1153 Series D, and Model 1154 transmitters manufactured by Rosemount that may be leaking fill-oil. The bulletin identified five action items to be taken for operating reactors and requested responses within 120 days after the receipt of this bulletin.

The purpose of this letter is to inform the NRC that we have completed our review of the subject Rosemount transmitters for Oconee, McGuire, and Catawba Nuclear Stations. We are currently in the process of developing a final response which will summarize our findings and describe corrective actions taken for our nuclear stations. However, additional response time will be required for an internal review of our final response to assure consistency and appropriateness of responses for all three nuclear stations. Accordingly, my response to the NRC Bulletin 90-01 will be submitted by no later than August 10, 1990.

Very truly yours,

Hal B. Tucker
Hal B. Tucker

MAH/110

9007170195 900711
PDR ADOCK 05000269
Q PDC

IE39
40

Document Control Desk
July 11, 1990
Page 2

xc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. L. A. Wiens
Office of NRR
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Darl S. Hood
Office of NRR
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. K. N. Jabbour
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 14H25
Washington, D.C. 20555

Mr. P. H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

Mr. P. K. VanDoorn
NRC Resident Inspector
McGuire Nuclear Station

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station