

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9304210001 DOC. DATE: 93/04/15 NOTARIZED: NO DOCKET #

FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269

50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270

50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION

HAMPTON, J.W. Duke Power Co.

RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards draft PT/0/A/0610/21, "Degraded Grid & Switchyard Isolation Functional Test."

DISTRIBUTION CODE: A045D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1422

TITLE: OR Submittal: Emergency Preparedness Plans, Implement'g Procedures, C

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
	LTR	ENCL	LTR	ENCL	LTR	ENCL	LTR	ENCL
		PD2-3 PD	1	1	WIENS, L		1	1
INTERNAL:	AEOD/DOA/IRB		1	1	NRR/DRSS/PEPB		1	1
	NUDOCS-ABSTRACT		1	1	<u>REG FILE</u> 01		1	1
EXTERNAL:	NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 8 ENCL 8

MA-4

R
I
D
S
/
A
D
S
/
A
D
S
/
A
D
S

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

April 15, 1993

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Overhead Emergency Power Path Testing

Attached for your information is the latest draft copy of the degraded grid and switchyard isolation functional test procedure. Also included with this procedure is a restricted change for pages 6, 10, 11, 12 and 13 which restarts a reactor coolant pump on the overhead power path from Keowee. It is anticipated that this test will be performed on May 1, 1993 during the Oconee Unit 2 refueling outage. In the event of significant changes to this procedure when finalized, the NRC Resident Inspectors will be notified of the changes prior to the test.

Very Truly Yours,

Joe M Davis for
J. W. Hampton

xc: P. E. Harmon, Senior Resident Inspector
Oconee Nuclear Station

L. A. Wiens, Project Manager
ONRR

S. D. Ebnetter, Regional Administrator
Region II

9304210001 930415
PDR ADDCK 05000269
P 190000 PDR

AO45